

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 21-Mar-11 TO 27-Mar-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Cent_Sect	Tarapur 2	80	4-Mar-11	01.25		Continued.	Refueling Work.
Dabhol	1B	230	15-Mar-11	02.37		Continued.	Upgradation Work.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Nasik	Unit 2	120	18-Mar-11	21.07	22-Mar-11	01.35	BLR T/L.
Dabhol	2B	230	18-Mar-11	23.23	22-Mar-11	16.07	For inlet air filter replacement.
Nasik	Unit 1	120	19-Mar-11	19.50	22-Mar-11	03.25	BLR T/L.
Cent_Sect	NTPC(V) 9	500	20-Mar-11	21.19	21-Mar-11	07.24	Tripped.
CPP	WPCL U-1	135	20-Mar-11	14.49	22-Mar-11	16.42	Boiler Tube Leakage.
Parli	Unit 6	250	21-Mar-11	04:33	24-Mar-11	16.38	Furnace Pressure high.
Koradi	Unit 6	210	21-Mar-11	18.16	23-Mar-11	21.24	BLR T/L.
Koyna	Unit 9	80	21-Mar-11	06.50	21-Mar-11	18.30	Bus Section-I Outage.
Koyna	Unit 10	80	21-Mar-11	06.50	21-Mar-11	18.30	Bus Section-I Outage.
Nasik	Unit 1	120	22-Mar-11	11.00	23-Mar-11	04.10	Water Valve Problem.
Nasik	Unit 2	120	22-Mar-11	14.30	22-Mar-11	14.50	Drum Level High.
Bhusawal	Unit 3	210	22-Mar-11	15.48	22-Mar-11	18.33	Boiler Feed Pump.
Bhusawal	Unit 3	210	22-Mar-11	18.44	22-Mar-11	19.23	Drum Level Low.
Parli	Unit 7	250	22-Mar-11	18.58	22-Mar-11	22.30	Loss of Fuel.
Dabhol	2A	230	22-Mar-11	21.43	26-Mar-11	06.37	Capacity Demonstration for 3 days.
Cent_Sect	NTPC(V-7)	500	22-Mar-11	08.09	23-Mar-11	02.49	To Attend Unit 1 G B Ph 400KV Side Bushing Oil Leakage.
Cent_Sect	Tarapur 1	80	22-Mar-11	22.18		Continued.	7 Days Maint.Work.
Parli	Unit 7	250	23-Mar-11	00.35	25-Mar-11	22.42	Boiler Tube Leakage.
Nasik	Unit 1	120	23-Mar-11	08.10	23-Mar-11	15.55	Governer Problem.
Nasik	Unit 1	120	23-Mar-11	16.35	24-Mar-11	22.35	Governer Problem.
Paras	Unit 3	250	23-Mar-11	11.51	25-Mar-11	04.38	BLR T/L.
Koyna	ST-IV 1	250	23-Mar-11	22.30	24-Mar-11	05.15	Preventive maintenance work.
CPP	WPCL U-3	135	23-Mar-11	01.53	25-Mar-11	03.00	Tripped.
Paras	Unit 4	250	24-Mar-11	11.52	24-Mar-11	14.48	Air heater tripped.
CPP	JSW (J) U2	300	24-Mar-11	10.30	27-Mar-11	21.04	ESP problem.
Koyna	Unit 2	75	24-Mar-11	07.15	25-Mar-11	18.30	Needle maintenance work.
Nasik	Unit 1	120	24-Mar-11	23.40	26-Mar-11	18.20	Governer problem.
Hydro	GHATGHAR	250	24-Mar-11	14.45	24-Mar-11	20.50	Installation of energy meter.
Koyna	Unit 5	80	26-Mar-11	07.10	26-Mar-11	16.20	Governer oil pump motor replacement.
Bhusawal	Unit 3	210	26-Mar-11	12.20	26-Mar-11	13.55	Flashover on boiler Board.
Parli	Unit 5	210	26-Mar-11	11.32	27-Mar-11	05.07	Unit auxiliary T/F.
Cent_Sect	NTPC (V-1)	210	26-Mar-11	19.31	27-Mar-11	15:24	Boiler tube leakage.
Cent_Sect	NTPC(K-7)	500	27-Mar-11	18:31		Continued.	Tripped.
Koyna	ST-IV 2	250	27-Mar-11	22.30	28-Mar-11	04.30	Preventive maint.work
CPP	JSW (J) U1	300	28-Mar-11	04.13		Continued.	Due to tripping of N.Koyna-Jaigad lines
CPP	JSW (J) U2	300	28-Mar-11	04.13		Continued.	Due to tripping of N.Koyna-Jaigad lines