

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 25-Apr-11 TO 1-May-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1B	230	15-Mar-11	02.37		Continued.	Upgradation Work.
Khaparkheda	Unit 3	210	25-Apr-11	02.51		Continued.	Annual overhaul.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
CPP	WPCL U-3	135	25-Apr-11	01.22	27-Apr-11	05.00	Filter replacement work.
Koyna	Unit 10	80	25-Apr-11	07.30	25-Apr-11	18.00	R.M.Work
Nasik	Unit 5	210	25-Apr-11	12.15	25-Apr-11	13.45	Bus Bar Protection Operated
Uran	Unit 8	108	25-Apr-11	08.30	25-Apr-11	18.00	Filter replacement
Dabhol	3A	230	25-Apr-11	08.16	25-Apr-11	21.27	Air Cooler Leakage
CPP	WPCL U-1	135	25-Apr-11	16.50	25-Apr-11	18.32	Tripped
Parli	Unit 5	210	25-Apr-11	22.21	1-May-11	09.50	Non availability of coal mill
Parli	Unit 6	250	25-Apr-11	09.28	25-Apr-11	12.11	High Furnace Pressure
Parli	Unit 3	210	26-Apr-11	10.41	26-Apr-11	15.07	Bus Fault at Parli GCR
Cent_Sect	Tarapur 2	80	26-Apr-11	17.50	2-May-11	00.45	Water Heater outlet Valve problem
Cent_Sect	NTPC(V) 9	500	27-Apr-11	03.40	27-Apr-11	09.12	Drum Level Protection
Parli	Unit 7	250	27-Apr-11	13.00	27-Apr-11	15.50	Attending Hot Spot on B Ph GT H V Bushing.
Bhusawal	Unit 3	210	27-Apr-11	10.40	27-Apr-11	12.22	Air Heater Trip.
Nasik	Unit 1	120	27-Apr-11	11.40	1-May-11	21.30	Boiler Tube Leakage.
Cent_Sect	Kawas GT2A	106	27-Apr-11	12.43		Continued.	Preventive maint.work
Cent_Sect	Kawas ST2C	116	27-Apr-11	13.10	27-Apr-11	13.55	Withdrawn.
CPP	WPCL U-3	135	27-Apr-11	06.30	27-Apr-11	07.18	Tripped.
Nasik	Unit 2	120	28-Apr-11	07.55	28-Apr-11	15:30	Tripped on low drum level.
Cent_Sect	NTPC(K-4)	500	28-Apr-11	14.53	30-Apr-11	07.27	Boiler Tube Leakage.
Parli	Unit 4	210	29-Apr-11	16.58		Continued.	I.D.Fan problem.
Koyna	Unit 4	75	29-Apr-11	14.28	29-Apr-11	17.26	Safety valve problem.
Cent_Sect	NTPC(K-5)	500	29-Apr-11	12.15	29-Apr-11	23.45	Cooling pump problem.
Cent_Sect	NTPC(K-6)	500	29-Apr-11	12.15	30-Apr-11	00.56	Cooling pump problem.
Cent_Sect	NTPC(K-5)	500	30-Apr-11	02.55	1-May-11	05.40	Boiler Tube Leakage.
Bhusawal	Unit 3	210	30-Apr-11	09.02		Continued.	Boiler Tube Leakage.
Parli	Unit 6	250	30-Apr-11	14.35	30-Apr-11	17.50	Furnance pressure high.
Parli	Unit 6	250	30-Apr-11	20.37		Continued.	Boiler Tube Leakage.
Paras	Unit 3	250	2-May-11	03.48		Continued.	Flame Failure
Uran	Unit 6	108	30-Apr-11	22.05	1-May-11	01.51	Replacement of relay.
Koyna	Unit 11	80	1-May-11	07.00		Continued.	Rotor E/F
Nasik	Unit 2	120	1-May-11	18.40	1-May-11	23.45	FST and Condensor Level Problem
Bhusawal	Unit 2	210	1-May-11	16.58		Continued.	Boiler Tube Leakage
Nasik	Unit 1	120	1-May-11	22.15	2-May-11	01.25	Vaccume Level Low
Koyna	ST-IV 1	250	30-Apr-11	22.00	1-May-11	05.00	R.M.Work