

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 23-May-11 TO 29-May-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Khaparkheda	Unit 3	210	25-Apr-11	02.51	24-May-11	07.01	Annual overhaul.
Cent_Sect	NTPC (V-1)	210	7-May-11	00.46		Continued.	A/OH
Cent_Sect	NTPC(K-5)	500	10-May-11	00.00		Continued.	Annual Overhaul
Koyna	Unit 10	80	13-May-11	00.00	26-May-11	11.30	Annual Overhaul
Dabhol	1A	230	20-May-11	13.22		Continued.	Rotor replacement.
Koyna	Unit 11	80	24-May-11	23.00	25-May-11	00.05	U-10 Drafter Gate opened
Koyna	Unit 12	80	24-May-11	23.25	25-May-11	00.10	U-10 Drafter Gate opened
Koyna	Unit 1	75	27-May-11	05.30	27-May-11	17.55	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel.
Koyna	Unit 2	75	27-May-11	05.30	27-May-11	17.40	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel
Koyna	Unit 3	75	27-May-11	05.30	27-May-11	18.30	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel
Koyna	Unit 4	75	27-May-11	05.30	27-May-11	19.05	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel
Koyna	Unit 5	80	27-May-11	05.30	27-May-11	19.00	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel
Koyna	Unit 6	75	27-May-11	05.30	28-May-11	02.45	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel
Koyna	Unit 7	80	27-May-11	05.30	27-May-11	19.40	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel
Koyna	Unit 8	80	27-May-11	05.30	27-May-11	19.35	Urgent Removal of Raft Entargled @ Entrance of Tail race Canel.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	NTPC(K-7)	500	11-May-11	01.15	28-May-11	04.40	Fire in GT
CPP	JSW (J) U1	300	12-May-11	00.24	30-May-11	01.25	Annual Overhaul.
Paras	Unit 4	250	17-May-11	04.50	29-May-11	05.25	Performance guarantee test for 10 days .
Dabhol	1X	290	20-May-11	13.22		Continued.	Unit 1A and 1B out
Dabhol	1B	230	21-May-11	02.17		Continued.	High speed.
Parli	Unit 3	210	21-May-11	22.21	24-May-11	07.20	Turbine first up.
Cent_Sect	NTPC(V) 9	500	22-May-11	10.00	24-May-11	06.57	Boiler tube leakage.
Koyna	ST - IV 3	250	22-May-11	14.23	24-May-11	03.09	T/F D/C fault.
Uran	Unit 6	108	23-May-11	10.06	23-May-11	10.26	Turbine bearing vibration .
Paras	Unit 3	250	23-May-11	10.24	25-May-11	16.52	Boiler tube leakage.
CPP	WPCL U-4	135	23-May-11	11.24	23-May-11	15.09	Furnace pressure high.
CPP	WPCL U-4	135	23-May-11	15.28	28-May-11	08.50	TRIPPED.
Koyna	ST - IV 4	250	23-May-11	19.56	23-May-11	21.44	Turbine guide bearing temp.high
Nasik	Unit 2	120	23-May-11	22.25	27-May-11	13.35	Boiler tube leakage.
Koyna	ST - IV 4	250	24-May-11	02.20	24-May-11	03.09	Replacement of card from Unit-4 to Unit-3
Parli	Unit 3	210	24-May-11	07.30	24-May-11	10.21	Low Vaccume
Cent_Sect	sipat-5	500	25-May-11	02.55	25-May-11	05.26	Low Vaccume
Nasik	Unit 3	210	25-May-11	06.30	25-May-11	14.00	Flame Failure.
Bhusawal	Unit 2	210	26-May-11	21.59	28-May-11	20.00	Boiler Tube Leakage.
Cent_Sect	NTPC(V-5)	210	27-May-11	04.59	28-May-11	11.08	Boiler Tube Leakage
Khaparkheda	Unit 1	210	27-May-11	17.01	29-May-11	21.09	Boiler T/L.
Cent_Sect	NTPC(V-2)	210	27-May-11	18.47		Continued.	Boiler T/L.
CPP	WPCL U-1	135	28-May-11	01.30	30-May-11	03.57	Furnace protection operated.(Suspected BTL.)
Parli	Unit 6	250	28-May-11	10.29	29-May-11	10.45	Coal Handling Problem.
CPP	WPCL U-4	135	28-May-11	16.38	28-May-11	23.47	W/Dn.
Koyna	ST - IV 4	250	29-May-11	22.30	30-May-11	04.40	R.M.Work
Chandrapur	Unit 1	210	30-May-11	00.07		Continued.	for extension of boiler steaming validity.