

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 21-May-12 TO 27-May-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Paras	Unit 4	250	1-May-12	03:25		Continued.	Annual Overhaul.
Cent_Sect	NTPC(V-3)	210	20-May-12	00:25		Continued.	AOH.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	1A	230	30-Mar-12	23:29		Continued.	Gas Shortage
Bhusawal	Unit 5	500	30-Mar-12	04:34		Continued.	Hand Tripped
Dabhol	1B	230	31-Mar-12	19:45		Continued.	Maintenance work.
Dabhol	1X	290	31-Mar-12	19:43		Continued.	Maintenance work.
Cent_Sect	Kawas GT2A	106	26-Apr-12	18:13	22-May-12	17:31	Less Requisition
Koyna	Unit 12	80	16-May-12	22:30	25-May-12	02:30	Rotor earth fault.
Dabhol	2B	230	17-May-12	16:37	23-May-12	13:27	W/Dn due to gas shortage.
Chandrapur	Unit 4	210	18-May-12	22:02	21-May-12	23:56	Boiler Tube Leakage.
REL	2	250	19-May-12	01:30	21-May-12	07:25	Boiler tube leakage.
Koradi	Unit 7	210	20-May-12	08:27	22-May-12	23:00	Boiler Tube Leakage.
Nasik	Unit 4	210	20-May-12	21:30	21-May-12	07:09	Control Supply Fail.
Parli	Unit 3	210	20-May-12	19:40	22-May-12	11:50	P.A. Fan Problem.
Bhusawal	Unit 4	500	20-May-12	18:41	24-May-12	18:41	Inspection by M/S BHEL.
Chandrapur	Unit 6	500	20-May-12	23:09	28-May-12	06:15	Air Heater problem
CPP	WPCL U-3	135	21-May-12	05:36	24-May-12	12:56	Bottom Ash Problem
Koyna	ST - IV 4	250	21-May-12	06:12	22-May-12	11:40	Load Variation problem
Cent_Sect	NTPC(V-10)	500	21-May-12	09:12	21-May-12	11:39	Reheater Problem
Uran	Unit 8	108	22-May-12	11:53	24-May-12	18:17	Gas Shortage.
Uran	Unit B0	120	22-May-12	12:29		Continued.	Y Phase Bushing Oil Leakage.
Khaparkheda	Unit 5	500	23-May-12	10:18	23-May-12	12:58	Reheater Protection Operated.
Bhusawal	Unit 2	210	23-May-12	15:40	24-May-12	12:53	Air Heater Problem.
Koradi	Unit 7	210	23-May-12	22:08	23-May-12	03:47	Turbine Extration Pipe Leakage.
Bhusawal	Unit 2	210	24-May-12	14:23	24-May-12	17:34	Boiler Trip.
Bhusawal	Unit 2	210	24-May-12	17:50	24-May-12	19:40	Boiler Trip.
CPP	WPCL U-2	135	24-May-12	15:10	24-May-12	16:51	Flame Failure.
Koyna	ST - IV 4	250	24-May-12	16:00		Continued.	Replacement of spherical valve servomotor seal.
Koradi	Unit 6	210	25-May-12	15:23	25-May-12	17:19	Loss of fuel.
CPP	WPCL U-3	135	25-May-12	09:30	25-May-12	10:38	Furnace pressure high.
CPP	WPCL U-1	135	25-May-12	13:18	26-May-12	23:18	ID fan problem.
Bhusawal	Unit 4	500	26-May-12	19:00	27-May-12	01:49	Drum level high.
Dabhol	3A	230	26-May-12	11:35		Continued.	Gas shortage.
Parli	Unit 6	250	26-May-12	20:53	27-May-12	01:28	Boiler problem,furnace pressure high.
Cent_Sect	NTPC(K-4)	500	26-May-12	22:56		Continued.	Economiser tube leakage.
CPP	WPCL U-3	135	27-May-12	07:00	27-May-12	08:08	High furnace pressure.
Khaparkheda	Unit 4	210	28-May-12	02:46		Continued.	Due to low coal flow.
Khaparkheda	Unit 5	500	28-May-12	05:35		Continued.	Flame failure.
Koradi	Unit 6	210	28-May-12	05:54		Continued.	Boiler tube leakage.