

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 20-Jun-11 TO 26-Jun-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1A	230	20-May-11	13.22		Continued.	Rotor replacement.
Parli	Unit 6	250	16-Jun-11	05.50		Continued.	Annual Overhaul

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	TARAPUR-4	540	30-May-11	20.00		Continued.	Survilence Test
Uran	Unit 8	108	6-Jun-11	23.12		Continued.	Bus Bar Protection operated,as Y-Ph BKR pole of Uran U-5 burst.
Uran	Unit B0	120	16-Jun-11	01.03		Continued.	R/M work
Parli	Unit 7	250	16-Jun-11	19.12	21-Jun-11	04.05	No Coal Flow(Conveyor Belt Broken)
CPP	JSW (J) U2	300	19-Jun-11	00.13	22-Jun-11	05.00	C W Line Leakage.
CPP	WPCL U-3	135	20-Jun-11	03.16		Continued.	Maintenance work.
CPP	JSW (J) U3	300	20-Jun-11	04.54	20-Jun-11	11.12	Electrial fault.
Dabhol	2A	230	20-Jun-11	20.42	21-Jun-11	08.42	Air filter replacement.
Nasik	Unit 3	210	20-Jun-11	23.15	21-Jun-11	07.05	Drum level high.
Parli	Unit 7	250	21-Jun-11	09.37	21-Jun-11	11.23	Flame failure.
Nasik	Unit 2	120	21-Jun-11	18.35	21-Jun-11	19.50	Drum level high.
Nasik	Unit 2	120	21-Jun-11	21.00	21-Jun-11	23.00	Drum level high.
Cent_Sect	NTPC(K-3)	210	21-Jun-11	11.38	22-Jun-11	17.14	Tripped.
Koradi	Unit 5	200	22-Jun-11	21.58		Continued.	Boiler Tube Leakage
Koradi	Unit 6	210	22-Jun-11	09.21	22-Jun-11	12.05	Tripped, Forward Power control Last
Nasik	Unit 1	120	23-Jun-11	03.20	23-Jun-11	19.25	Chain Exciator problem
CPP	WPCL U-4	135	23-Jun-11	04.37	23-Jun-11	14.42	Low Drum Level
CPP	JSW (J) U2	300	23-Jun-11	14.50	25-Jun-11	05.03	Electrical system problem
CPP	JSW (J) U3	300	23-Jun-11	13.27	23-Jun-11	15.40	Electrical system problem
CPP	WPCL U-1	135	23-Jun-11	14.52	24-Jun-11	01.54	Power Control Panel problem
Chandrapur	Unit 2	210	23-Jun-11	22.27	26-Jun-11	11.56	I D Fan Problem.
Cent_Sect	NTPC(K-3)	210	24-Jun-11	03.25	25-Jun-11	14.12	Generator Protection Tripped.
Koradi	Unit 4	105	24-Jun-11	14.12	24-Jun-11	16.27	Flame Failure.
Dabhol	1B	230	24-Jun-11	23.10	25-Jun-11	13.25	High Exhaust Temp.Spred Problem.
Dabhol	1X	290	24-Jun-11	23.10	25-Jun-11	16.13	High Exhaust Temp.Spred Problem.
Nasik	Unit 1	120	25-Jun-11	04.35		Continued.	Boiler Tube Leakage.
CPP	JSW (J) U3	300	25-Jun-11	10.42	25-Jun-11	17.19	D C Charge Fault.
Paras	Unit 4	250	25-Jun-11	08.28	25-Jun-11	18.41	Low Drum Level.
Uran	Unit A0	120	25-Jun-11	10.40		Continued.	Cable Damaged.
Nasik	Unit 4	210	26-Jun-11	11.55		Continued.	Bottom Ash hopper heavy.
Parli	Unit 4	210	26-Jun-11	11.40	26-Jun-11	16.34	Boiler Trip.
Parli	Unit 4	210	26-Jun-11	22.35		Continued.	CVSM Problem.