

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 25-Jun-12 TO 1-Jul-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Paras	Unit 4	250	1-May-12	03.25	25-Jun-12	20.57	Annual Overhaul.
Cent_Sect	NTPC(V-3)	210	20-May-12	00:25	27-Jun-12	19.54	AOH.
Khaparkheda	Unit 2	210	1-Jun-12	05.45		Continued.	Annual overhaul.
Cent_Sect	NTPC(K-5)	500	1-Jun-12	23.50	30-Jun-12	21.31	A/OH.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 5	500	30-Mar-12	04.34		Continued.	Hand Tripped
Bhusawal	Unit 4	500	6-Jun-12	06.27		Continued.	Vibration Problem
Paras	Unit 3	250	13-Jun-12	17.05		Continued.	Structure collapse near ESP.
Dabhol	1A	230	16-Jun-12	11.45		Continued.	Withdrawn.
Koyna	Unit 11	80	18-Jun-12	08.00		Continued.	Stator E/F.
Uran	Unit 7	108	20-Jun-12	12.30	30-Jun-12	12.44	Gas Shortage.
Koyna	ST-IV 2	250	20-Jun-12	11.00		Continued.	Attending Spherical Valve Srevomotor Oil Leakage.
Dabhol	2A	230	20-Jun-12	22.25	28-Jun-12	11.27	Gas Shortage.
Khaparkheda	Unit 5	500	23-Jun-12	11.09	2-Jul-12	01.27	Bunkering problem.
Parli	Unit 6	250	23-Jun-12	15.03		Continued.	Bunkering problem.
Cent_Sect	NTPC(V-8)	500	23-Jun-12	23.38		Continued.	Boiler tube leakage.
Cent_Sect	Sipat U-2	660	24-Jun-12	11.32	25-Jun-12	10.46	Boiler tube leakage.
Parli	Unit 3	210	25-Jun-12	00.26	28-Jun-12	13.45	MS2 volve leakage.
Dabhol	3B	230	25-Jun-12	09.41		Continued.	Gas Shortage
Paras	Unit 4	250	26-Jun-12	03.50	26-Jun-12	14.46	Generator Protection
CPP	JSW (J) U3	300	26-Jun-12	05.30	26-Jun-12	10.48	Generator Transformer CB tripped
Koradi	Unit 5	200	26-Jun-12	21.06	1-Jul-12	05.27	High Drum Level
Koyna	Unit 8	80	26-Jun-12	07.05	26-Jun-12	20.30	E/F Indication appeared
Uran	Unit 5	108	26-Jun-12	12.50		Continued.	Gas Shortage
Chandrapur	Unit 3	210	27-Jun-12	13.21	27-Jun-12	17.46	Flame Failure.
Dabhol	2B	230	28-Jun-12	14.44		Continued.	Gas Shortage.
Bhusawal	Unit 3	210	28-Jun-12	23.38	2-Jul-12	06.51	Boiler Validity Expire.
Koyna	Unit 4	75	28-Jun-12	07.10		Continued.	All Injectors Insitu Meter Filling Work.
Koradi	Unit 6	210	29-Jun-12	08.26	29-Jun-12	12.03	Flame failure.
Parli	Unit 7	250	29-Jun-12	14.45		Continued.	Furnace pressure high.
Paras	Unit 4	250	30-Jun-12	07.03		Continued.	Main oil tank leakage.
Koradi	Unit 6	210	30-Jun-12	15.56	1-Jul-12	09.31	ID fan high vibration.
Nasik	Unit 5	210	30-Jun-12	21.45	1-Jul-12	06.35	Flame failure.
Parli	Unit 4	210	1-Jul-12	01.50	1-Jul-12	08.54	Furnace pressure high.
Nasik	Unit 5	210	1-Jul-12	06.40		Continued.	Tripped on turbine problem.
Parli	Unit 3	210	1-Jul-12	08.09	2-Jul-12	02.38	Tripped on low vaccum.
Cent_Sect	sipat-5	500	2-Jul-12	04.35		Continued.	Excitor AVR fault.