

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 26-Jul-10 TO 1-Aug-10

UNIT UNDER PLANNED OUTAGE

name	date_trip	time_trip	date_sync	time_sync	reason
Cent. Sect KARPR1	01/Jul/2008	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Chandrapur Unit 3	26/May/2010	23.59		Continued.	Water Balancing Problem.
Koradi Unit 5	26/Jun/2010	02:33	28/Jul/2010	14.27	Annual Overhaul.
Cent. Sect NTPC (K-2)	30/Jun/2010	23.46	27/Jul/2010	02:19	Annual Overhaul.
Cent. Sect Kawas ST2C	01/Jul/2010	00.08		Continued.	Annual Overhaul.
Cent. Sect NTPC(V) 9	01/Jul/2010	00.04	26/Jul/2010	16.29	Annual Overhaul.
Parli Unit 4	05/Jul/2010	09.27		Continued.	Capital Overhaul
Koyna ST - IV 3	16/Jul/2010	00.00		Continued.	Preparing work for 2nd lake tapping.
Koyna ST - IV 4	16/Jul/2010	00.00		Continued.	preparing work for 2nd lake tapping.
Koyna ST-IV 2	16/Jul/2010	00.00		Continued.	preparing work for 2nd lake tapping.
Koyna ST-IV 1	16/Jul/2010	00.00		Continued.	Preparing work for 2nd lake tapping.
Tata Trombay 7A	25/Jul/2010	17.39		Continued.	Main T/F replacement
Tata Trombay 7B	25/Jul/2010	15.45		Continued.	Inspection and Maint.work
Bhusawal Unit 3	31/Jul/2010	05.26		Continued.	AOH.

UNIT UNDER FORCED OUTAGE

name	date_trip	time_trip	date_sync	time_sync	reason
Uran Unit 2	04/Oct/2008	19.00		Continued.	Gas Restriction
Uran Unit 4	01/Apr/2009	00.00		Continued.	Gas Restriction
Paras Unit 2	13/Jun/2010	17.35		Continued.	For Scrapping.
Uran Unit 3	16/Jun/2010	19.52		Continued.	R.M.Work.
Dabhol 1A	18/Jun/2010	13.09		Continued.	Unit Differential.
Dabhol 1B	18/Jun/2010	13.09		Continued.	Unit Differential.
Dabhol 1X	18/Jun/2010	13.09		Continued.	Unit Differential.
Parli Unit 1	18/Jun/2010	12:11		Continued.	For Scrapping.
Parli Unit 2	18/Jun/2010	06:26		Continued.	For Scrapping.
Koradi Unit 4	06/Jul/2010	10.03	30/Jul/2010	10.36	Boiler Tube Leakage.
Dabhol 2A	12/Jul/2010	01.55		Continued.	Tripped due to Electrical Fault
Dabhol 2B	12/Jul/2010	01.55		Continued.	Tripped due to Electrical Fault
Dabhol 2X	12/Jul/2010	01.55		Continued.	Tripped due to Electrical Fault
Cent. Sect Tarapur 1	22/Jul/2010	13.19	26/Jul/2010	03.10	Maintenance work.
Chandrapur Unit 2	24/Jul/2010	22.43	28/Jul/2010	07.47	Reheater tube leakage.
Khaparkheda Unit 4	24/Jul/2010	15.56	26/Jul/2010	20.23	Boiler tube leakage.
Bhusawal Unit 1	26/Jul/2010	01.25	28/Jul/2010	01.40	Abnormal Turbine Parameter due to Wet Coal.
Bhusawal Unit 3	26/Jul/2010	16.39	26/Jul/2010	19.16	Flame Failure.
Cent. Sect NTPC(K-3)	26/Jul/2010	20.48	28/Jul/2010	02.36	Boiler Tube Leakage.
Cent. Sect NTPC(V-10)	26/Jul/2010	21.57	27/Jul/2010	00:15	Flame Failure.
Nasik Unit 1	26/Jul/2010	10.30	30/Jul/2010	07.00	Boiler Tube Leakage.
Nasik Unit 5	26/Jul/2010	00.15	26/Jul/2010	02.10	Furnance Draft
Paras Unit 4	26/Jul/2010	16.39	26/Jul/2010	18.38	Flame Failure.
Parli Unit 7	26/Jul/2010	13.41	26/Jul/2010	22.37	Main Steam Temp.Low.
Parli Unit 7	26/Jul/2010	02.20	26/Jul/2010	05.45	Flame Failure
Bhusawal Unit 2	27/Jul/2010	12.56	30/Jul/2010	03.50	Boiler Tube Leakage.
Nasik Unit 5	27/Jul/2010	11.20	28/Jul/2010	05.00	Due to Wet Coal and Bunkers.
Parli Unit 6	27/Jul/2010	23.30	28/Jul/2010	03.17	Drum Level High.
Parli Unit 6	27/Jul/2010	18.00	27/Jul/2010	22.56	Furnace Pressure Low.
Parli Unit 7	27/Jul/2010	17.20	27/Jul/2010	19.26	Flame Failure.
Bhusawal Unit 1	28/Jul/2010	03.45	31/Jul/2010	02.38	Trip.
Koradi Unit 2	28/Jul/2010	11.31		Continued.	Bunkering Problem.
Paras Unit 3	28/Jul/2010	09.31	28/Jul/2010	12.33	Drum Level Low.
Nasik Unit 2	29/Jul/2010	03.15	29/Jul/2010	05.15	UAT Trip.
Paras Unit 3	29/Jul/2010	10.07	30/Jul/2010	17.08	Bunkering Problem.
Cent. Sect NTPC(V-6)	30/Jul/2010	06.46	31/Jul/2010	11.20	BLR T/L.
Koradi Unit 4	30/Jul/2010	16.11	30/Jul/2010	19.24	A.C.Supply Trip.
Koradi Unit 5	30/Jul/2010	08.41		Continued.	BLR T/L.
Nasik Unit 3	30/Jul/2010	08.32	31/Jul/2010	22.25	Wet coal.
Paras Unit 4	30/Jul/2010	00.00	30/Jul/2010	23.38	Bunkering problem.
Parli Unit 7	30/Jul/2010	21.34	30/Jul/2010	22.57	Flame/Failure.
Bhusawal Unit 1	31/Jul/2010	19.25		Continued.	Wet coal problem.
Parli Unit 3	31/Jul/2010	04.35	31/Jul/2010	12.40	Coal feeder chockup.
Parli Unit 6	31/Jul/2010	15.29		Continued.	Economiser Tube Leakage.
Nasik Unit 4	01/Aug/2010	01.15		Continued.	BTL.