

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 25-Jul-11 TO 31-Jul-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1A	230	20-May-11	13.22		Continued.	Rotor replacement.
Chandrapur	Unit 7	500	29-Jun-11	21:40		Continued.	COH
Chandrapur	Unit 6	500	12-Jul-11	17.24		Continued.	Stator Earth Fault(Mini overhaul)
Tata	Trombay 8	250	15-Jul-11	01:45		Continued.	AOH
Cent_Sect	NTPC(V-7)	500	18-Jul-11	00.03		Continued.	Annual overhaul.
Nasik	Unit 3	210	23-Jul-11	01.55		Continued.	Annual Overhaul.
CPP	WPCL U-4	135	24-Jul-11	06.40		Continued.	Maint.Work.
Koradi	Unit 5	200	28-Jul-11	22:25	30-Jul-11	04.07	ID Fan problem.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 5	108	15-Jul-11	10.40		Continued.	Turbine Blade Replacement.
Uran	Unit 6	108	17-Jul-11	11.52	31-Jul-11	06.32	Stator earth fault.
Uran	Unit A0	120	17-Jul-11	11.52		Continued.	Stator earth fault.
Cent_Sect	NTPC (K-2)	210	23-Jul-11	15.51	25-Jul-11	05:22	Boiler Tube Leakage.
Khaparkheda	Unit 2	210	24-Jul-11	14.27	27-Jul-11	19.55	Boiler Tube Leakage
Parli	Unit 4	210	25-Jul-11	04.15	26-Jul-11	01.00	Low Pressure Turbine Problem.
Parli	Unit 5	210	25-Jul-11	01.11	25-Jul-11	04.25	Choking of Coal Mill.
Koyna	ST-IV 2	250	25-Jul-11	09.57	25-Jul-11	12.40	Turbine head cover water level high.
Parli	Unit 3	210	25-Jul-11	23.44	26-Jul-11	09.25	Drum level low.
Parli	Unit 7	250	26-Jul-11	06.11	26-Jul-11	10.03	Furnace pressure high.
Koyna	ST - IV 4	250	26-Jul-11	09.14	26-Jul-11	21.40	Excitation Problem.
Paras	Unit 3	250	26-Jul-11	08.57	26-Jul-11	11.36	Low furnace pressure.
Khaparkheda	Unit 5	0	26-Jul-11	1940	26-Jul-11	19.41	Test charged.
Bhusawal	Unit 3	210	26-Jul-11	17.15	26-Jul-11	19.35	Loss of Excitation.
Khaparkheda	Unit 5	0	27-Jul-11	02.55	27-Jul-11	12.13	FD Fan Problem
Parli	Unit 6	250	27-Jul-11	02.55	28-Jul-11	01.24	Flame Failure.
Cent_Sect	NTPC(V-10)	500	27-Jul-11	09.24	27-Jul-11	17.55	Generator Diff.prot.operated
Koradi	Unit 6	210	27-Jul-11	19.00	27-Jul-11	22.29	High Drum Level
Parli	Unit 7	250	27-Jul-11	20.43	27-Jul-11	23.37	High Drum Level
Khaparkheda	Unit 5	0	27-Jul-11	21.50	28-Jul-11	00:44	Main Steam Temp.Low
Parli	Unit 6	250	28-Jul-11	02.48	28-Jul-11	04.46	High Drum Level
Parli	Unit 6	250	28-Jul-11	05.40	29-Jul-11	02.18	Steam Temp.Low
Nasik	Unit 4	210	28-Jul-11	06.01	28-Jul-11	08:45	Furnace pressure Low
Uran	Unit 8	108	28-Jul-11	20:20	28-Jul-11	21:32	Due to Tripping of Kharghar 220 KV Uran II on Heavy Jurk.
Uran	Unit B0	120	28-Jul-11	20:20	29-Jul-11	02:02	Due to Tripping of Kharghar 220 KV Uran II on Heavy Jurk.
Koradi	Unit 6	210	28-Jul-11	17:13	28-Jul-11	19:03	Furance Pressure high.
Bhusawal	Unit 2	210	28-Jul-11	11:00	30-Jul-11	23.25	BTL
Parli	Unit 4	210	29-Jul-11	10.11		Continued.	Wet Coal
Parli	Unit 5	210	29-Jul-11	11.43	31-Jul-11	11.55	Wet Coal
Koradi	Unit 6	210	29-Jul-11	16.30	29-Jul-11	19.42	Bus Fault.
Koradi	Unit 7	210	29-Jul-11	15.27	29-Jul-11	17.54	Trip.
Khaparkheda	Unit 5	0	29-Jul-11	13.06		Continued.	Loss of Fuel.
Parli	Unit 6	250	31-Jul-11	19.05	31-Jul-11	22.57	I D Fan Problem.
Parli	Unit 7	250	31-Jul-11	17.06		Continued.	Main Steam Temp.Low.
Koradi	Unit 6	210	31-Jul-11	23.59	1-Aug-11	02.57	Flame Failure.
Parli	Unit 6	250	1-Aug-11	02.47		Continued.	I D Fan Problem.