

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 20-Dec-10 TO 26-Dec-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Parli	Unit 5	210	19-Nov-10	01.05	23-Dec-10	02.20	Annual Overhaul
Nasik	Unit 2	120	23-Nov-10	00.40	21-Dec-10	17.20	Annual Overhaul.
Cent_Sect	NTPC(K-6)	500	2-Dec-10	7:44		Continued.	Annual Overhaul
Parli	Unit 2	30	11-Dec-10	23.51		Continued.	Annual Overhaul.
Koyna	ST-IV 1	250	17-Dec-10	00.05		Continued.	For Inspection of 4B Junction Gates and Attending Leakages if any.
Koyna	ST-IV 2	250	17-Dec-10	00.05		Continued.	For Inspection of 4B Junction Gates and Attending Leakages if any.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Dabhol	2A	230	12-Jul-10	01.55	23-Dec-10	19.04	Tripped due to Electrical Fault
Paras	Unit 2	55	16-Nov-10	23.00		Continued.	Boiler tube validity expired.
Koradi	Unit 4	105	12-Dec-10	22.20	23-Dec-10	19.15	Bearing Vibration.
Parli	Unit 1	30	15-Dec-10	04.31		Continued.	W/Dn.
Bhusawal	Unit 1	58	15-Dec-10	10.40		Continued.	Coal Mill problem.
Koradi	Unit 3	105	17-Dec-10	22.11	22-Dec-10	07.45	Heavy Hydrogen leakage.
Chandrapur	Unit 7	500	19-Dec-10	10.19	21-Dec-10	09.34	Economiser Tube Leakage.
Cent_Sect	NTPC(V-10)	500	20-Dec-10	13.49	20-Dec-10	20.34	Electrical problem.
Khaparkheda	Unit 2	210	21-Dec-10	07.06	21-Dec-10	10.52	Elect & Thyristor problem.
Dabhol	1X	290	21-Dec-10	19.53	22-Dec-10	01.07	System Turbine Tripped.
Dabhol	1A	230	21-Dec-10	19.53	21-Dec-10	23.00	Hand tripped.
Dabhol	1B	230	21-Dec-10	19.53	22-Dec-10	09.16	Hand tripped.
Nasik	Unit 2	120	22-Dec-10	05.35	24-Dec-10	18.25	Boiler Tube Leakage.
Koyna	Unit 7	80	22-Dec-10	13.10	22-Dec-10	15.25	To attend oil leakage.
Koradi	Unit 5	200	22-Dec-10	19.01	25-Dec-10	17.38	Economiser tube leakage.
Parli	Unit 5	210	23-Dec-10	12.25	23-Dec-10	22.25	Flame Failure.
Nasik	Unit 3	210	24-Dec-10	02.20		Continued.	Boiler Tube Leakage.
Dabhol	1A	230	24-Dec-10	13.09	27-Dec-10	01.21	Less Fuel Gas Availability.
Koradi	Unit 4	105	24-Dec-10	06.54	25-Dec-10	15.41	Condensar Tube Leakage.
Parli	Unit 6	250	25-Dec-10	13.02	25-Dec-10	17.37	Furnance Pressure High.
Parli	Unit 6	250	25-Dec-10	18.25	25-Dec-10	20.37	Furnance Pressure High.
Khaparkheda	Unit 1	210	25-Dec-10	21.56		Continued.	Boiler Tube Leakage.
Koradi	Unit 7	210	26-Dec-10	10.39	26-Dec-10	13.55	Flame Failure.
Dabhol	3A	230	26-Dec-10	15.39		Continued.	Stopped Due to Gas Leakage.