

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 26-Mar-12 TO 1-Apr-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Koyna	Unit 5	80	10-Mar-12	7.1	27-Mar-12	11.33	Pressure Shaft work
Koyna	UNIT 6	75	10-Mar-12	7.05		Continued.	Pressure Shaft work
Chandrapur	Unit 1	210	11-Mar-12	8.48		Continued.	Annual Overhaul
Cent_Sect	NTPC(V-2)	210	1-Apr-12	0:01		Continued.	AOH.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	3B	230	4-Feb-12	23.43	30-Mar-12	14.13	Gas Shortage
Khaparkheda	Unit 5	500	13-Feb-12	22.18	29-Mar-12	17.05	Low Vaccum.
Tata	Trombay 4	150	14-Feb-12	0.08		Continued.	Withdrawn/Cold Standby
Dabhol	3A	230	7-Mar-12	15.42	31-Mar-12	16.05	Gas shortage.
Dabhol	3X	290	7-Mar-12	15.42	30-Mar-12	21.17	Gas shortage.
Cent_Sect	TARAPUR-3	540	15-Mar-12	22.13		Continued.	Primary coolant pump fail.
CPP	WPCL U-2	135	19-Mar-12	3.21	1-Apr-12	3.34	Precepitator & Gas Filtter Replacement Work.
Koradi	Unit 5	200	19-Mar-12	6.3	28-Mar-12	11.31	I D Fan Problem.
Dabhol	2B	230	23-Mar-12	21.39	27-Mar-12	9.57	Gas shortage.
Parli	Unit 3	210	23-Mar-12	23.57		Continued.	Coal shortage.
Koradi	Unit 7	210	24-Mar-12	22.26	26-Mar-12	7.4	Boiler Tube Leakage
Cent_Sect	NTPC(V) 9	500	24-Mar-12	14.2	26-Mar-12	16.27	Boiler tube leakage.
Bhusawal	Unit 4	500	25-Mar-12	17.37		Continued.	Gen.Protection.
Khaparkheda	Unit 2	210	25-Mar-12	13.08	28-Mar-12	19.38	Boiler Tube Leakage.
Koradi	Unit 7	210	26-Mar-12	7.5	26-Mar-12	9.33	Electrical problem.
Uran	Unit 5	108	26-Mar-12	7.4	26-Mar-12	8.49	Boiler protection operated.
Uran	Unit 6	108	26-Mar-12	6.5	26-Mar-12	9.46	Bus fault.
Uran	Unit 6	108	26-Mar-12	10.54	26-Mar-12	15.39	Control system problem.
Uran	Unit 7	108	26-Mar-12	6.5	26-Mar-12	9.08	Bus fault.
Uran	Unit 8	108	26-Mar-12	6.5	26-Mar-12	9.25	Bus fault.
Uran	Unit A0	120	26-Mar-12	7.4	26-Mar-12	20.27	U-5 tripped.
Uran	Unit B0	120	26-Mar-12	6.5	27-Mar-12	3.05	Bus fault.
Dabhol	2A	230	27-Mar-12	13.45	27-Mar-12	16.32	Low drum level.
Dabhol	2X	290	27-Mar-12	13.49	27-Mar-12	15.11	Low drum level.
Koyna	Unit 10	80	29-Mar-12	8	29-Mar-12	17.5	Governer Maint.work
Parli	Unit 6	250	29-Mar-12	11.2	29-Mar-12	20.42	Conveyer Problem
Koradi	Unit 5	200	29-Mar-12	18.35	30-Mar-12	18.21	ID Fan problem
Khaparkheda	Unit 5	500	29-Mar-12	17.11	29-Mar-12	22.12	Auxiliary T/F Trip
Khaparkheda	Unit 5	500	29-Mar-12	22.48	29-Mar-12	23.22	Hand Tripped
Khaparkheda	Unit 5	500	29-Mar-12	23.4	30-Mar-12	0.1	Bus change over.
Bhusawal	Unit 5	500	29-Mar-12	14.58	29-Mar-12	16.53	Tripped on Glass "A" prot.
Bhusawal	Unit 5	500	29-Mar-12	19.05	30-Mar-12	12:00	Tripped on condensor vaccum pressure low.
Khaparkheda	Unit 5	500	30-Mar-12	13	30-Mar-12	17.29	Flame Failure
Parli	Unit 7	250	30-Mar-12	15.5	30-Mar-12	19.05	Flame Failure
Dabhol	1A	230	30-Mar-12	23.29		Continued.	Gas Shortage
Bhusawal	Unit 5	500	30-Mar-12	4.34		Continued.	Hand Tripped
Dabhol	1B	230	31-Mar-12	19.45		Continued.	Maintenance work.
Dabhol	1X	290	31-Mar-12	19.43		Continued.	Maintenance work.
Cent_Sect	NTPC(K-4)	500	31-Mar-12	23:18	1-Apr-12	18:38	CWP Problem.
CPP	WPCL U-1	135	1-Apr-12	11:49	30-Apr-12	13:26	P T Problem.
Khaparkheda	Unit 3	210	2-Apr-12	4:03		Continued.	Boiler Tube Leakage.