

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 28-May-12 TO 3-Jun-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Paras	Unit 4	250	1-May-12	03.25		Continued.	Annual Overhaul.
Cent_Sect	NTPC(V-3)	210	20-May-12	00:25		Continued.	AOH.
Khaparkheda	Unit 2	210	1-Jun-12	05.45		Continued.	Annual overhaul.
Cent_Sect	NTPC(K-5)	500	1-Jun-12	23.50		Continued.	A/OH.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	1A	230	30-Mar-12	23.29		Continued.	Gas Shortage
Bhusawal	Unit 5	500	30-Mar-12	04.34		Continued.	Hand Tripped
Dabhol	1B	230	31-Mar-12	19:45		Continued.	Maintenance work.
Dabhol	1X	290	31-Mar-12	19:43		Continued.	Maintenance work.
Chandrapur	Unit 6	500	20-May-12	23.09	28-May-12	06.15	Air Heater problem
Uran	Unit B0	120	22-May-12	12.29	31-May-12	22.36	Y Phase Bushing Oil Leakage.
Koyna	ST - IV 4	250	24-May-12	16.00	3-Jun-12	19.06	Replacement of spherical valve servomotor seal.
Dabhol	3A	230	26-May-12	11.35	29-May-12	15.34	Gas shortage.
Cent_Sect	NTPC(K-4)	500	26-May-12	22.56	30-May-12	18.46	Economiser tube leakage.
Khaparkheda	Unit 4	210	28-May-12	02.46	28-May-12	13.45	Due to low coal flow.
Khaparkheda	Unit 5	500	28-May-12	05.35	28-May-12	08.49	Flame failure.
Koradi	Unit 6	210	28-May-12	05.54	30-May-12	00:17	Boiler tube leakage.
Khaparkheda	Unit 5	500	28-May-12	08.53	28-May-12	10.44	Tripped.
Uran	Unit 7	108	29-May-12	09.00	1-Jun-12	07.27	Gas Shortage.
Khaparkheda	Unit 5	500	29-May-12	07.31	1-Jun-12	17.02	Flame Failure.
CPP	JSW (J) U3	300	29-May-12	07.20	30-May-12	5:35	Condenser Vaccum Cleaning Work.
Cent_Sect	Sipat U-1	660	29-May-12	14.14	31-May-12	10.11	Clinker Problem.
CPP	JSW (J) U2	300	31-May-12	05.20	1-Jun-12	09.43	Tripped.
Dabhol	3A	230	31-May-12	10.51		Continued.	Gas shortage.
Parli	Unit 3	210	31-May-12	15.28	1-Jun-12	13.50	Flame failure.
CPP	WPCL U-2	135	1-Jun-12	02.57	2-Jun-12	08.08	Excitation problem.
Parli	Unit 4	210	2-Jun-12	00.30		Continued.	ID Fan problem.
Bhusawal	Unit 4	500	2-Jun-12	06.15	2-Jun-12	10.21	Class A prot.operated.
Uran	Unit 6	108	2-Jun-12	19.13	2-Jun-12	23.44	Tripped on CTO high.
Chandrapur	Unit 2	210	2-Jun-12	22.48		Continued.	Economiser T/L.
Khaparkheda	Unit 1	210	3-Jun-12	21.05		Continued.	Flame failure.
Paras	Unit 3	250	3-Jun-12	09.04	4-Jun-12	05.35	Replacement of 29D isolator at GCR end.
Chandrapur	Unit 3	210	4-Jun-12	03.35		Continued.	Aux.supply fail.