

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 28-Jun-10 TO 4-Jul-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Chandrapur	Unit 6	500	1-Apr-10	01.15	1-Jul-10	02.49	Annual Overhaul
Chandrapur	Unit 5	500	16-Apr-10	15.49		Continued.	Water Balancing Problem.
Chandrapur	Unit 7	500	25-Apr-10	00.23		Continued.	Water Balancing Problem.
Chandrapur	Unit 3	210	26-May-10	23.59		Continued.	Water Balancing Problem.
Koradi	Unit 5	200	26-Jun-10	02:33		Continued.	Annual overhaul
Cent_Sect	NTPC (K-2)	210	30-Jun-10	23.46		Continued.	AOH
Cent_Sect	NTPC(V) 9	500	1-Jul-10	00.04		Continued.	AOH
Cent_Sect	Kawas ST2C	116	1-Jul-10	00.08		Continued.	AOH

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Paras	Unit 2	55	13-Jun-10	17.35		Continued.	For Scrapping.
Paras	Unit 4	250	15-Jun-10	20.55	30-Jun-10	03.13	Clinker Formation.
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Tata	Trombay 4	150	18-Jun-10	01.40		Continued.	Low demand.
Dabhol	1B	230	18-Jun-10	13.09		Continued.	Unit Differential.
Dabhol	1A	230	18-Jun-10	13.09		Continued.	Unit Differential.
Dabhol	1X	290	18-Jun-10	13.09		Continued.	Unit differential.
Bhusawal	Unit 1	58	18-Jun-10	05.10		Continued.	For Scrapping.
Parli	Unit 2	30	18-Jun-10	06:26		Continued.	For Scrapping.
Parli	Unit 1	30	18-Jun-10	12:11		Continued.	For Scrapping.
Koyna	ST - IV 4	250	23-Jun-10	07.50	1-Jul-10	18.14	Servomotor seal replacement.
Parli	Unit 4	210	24-Jun-10	23.18		Continued.	HPCV problem.
REL	2	250	26-Jun-10	02.19	28-Jun-10	15.56	Condensor Tube Leakage
Dabhol	3A	230	27-Jun-10	00.20	29-Jun-10	00.40	Heavy Leakages in Boiler
Koradi	Unit 6	210	27-Jun-10	13.53	28-Jun-10	19.13	Furnace Pressure High.
Cent_Sect	NTPC(K-4)	500	27-Jun-10	18:57	29-Jun-10	06.58	Boiler Tube Leakage.
Paras	Unit 3	250	28-Jun-10	00:17	28-Jun-10	03.36	Drum level low.
Dabhol	2A	230	28-Jun-10	02.39	28-Jun-10	06.40	U.A.Tr.Tripped.
Koradi	Unit 1	105	28-Jun-10	05.53		Continued.	Low Bunkering.
Cent_Sect	TARAPUR-4	540	28-Jun-10	05.54		Continued.	System deficiency.
Bhusawal	Unit 2	210	29-Jun-10	13.31	29-Jun-10	15.25	Drum Level Low.
Parli	Unit 7	250	29-Jun-10	09.00	29-Jun-10	13.56	Low Drem Level.
Parli	Unit 7	250	29-Jun-10	19.50	30-Jun-10	00.28	Flame Failure.
Koradi	Unit 4	105	29-Jun-10	16.44	1-Jul-10	02.10	Bunkering Problem.
Chandrapur	Unit 2	210	30-Jun-10	11.48	30-Jun-10	13.46	Tripped during changing over of UAT supply.
Koradi	Unit 2	105	30-Jun-10	20.16	4-Jul-10	15.17	Boiler Tube Leakage.
Parli	Unit 7	250	30-Jun-10	19.09	1-Jul-10	02.04	Tripped on Main Steam Temp. Low.
Cent_Sect	sipat-5	500	1-Jul-10	04.41	1-Jul-10	09.20	Low vacum problem.
Koyna	Unit 11	80	1-Jul-10	08.15	1-Jul-10	18.14	Q.M.Work
Bhusawal	Unit 2	210	1-Jul-10	12.40	2-Jul-10	14.07	Clinker Formation.
Dabhol	3A	230	1-Jul-10	17.52	1-Jul-10	22.01	Exhaust Temp High.
Parli	Unit 7	250	2-Jul-10	02.58	2-Jul-10	10.04	FD Fan problem
Dabhol	3A	230	2-Jul-10	04.54	2-Jul-10	12.42	Exhaust Temp High.
Chandrapur	Unit 6	500	2-Jul-10	13:32	4-Jul-10	23.07	Water shortage problem
Parli	Unit 5	210	2-Jul-10	06:58	2-Jul-10	10.35	Drum level low.
Parli	Unit 7	250	2-Jul-10	10.13	2-Jul-10	11.53	Flame Failure
Parli	Unit 3	210	3-Jul-10	05.06	4-Jul-10	12.10	Coal Mill Problem
Parli	Unit 7	250	3-Jul-10	08.55	5-Jul-10	01.31	Fire in Coal Mill side
Chandrapur	Unit 1	210	3-Jul-10	15.17	3-Jul-10	19.05	Turbine Trip Ckt faulty
Cent_Sect	NTPC(K-6)	500	3-Jul-10	04.43	4-Jul-10	7:22	Boiler Tube Leaakge
Dabhol	2B	230	3-Jul-10	18.18	4-Jul-10	00.21	Water ingress in Bus Accessory compartment
Dabhol	3A	230	3-Jul-10	19.46	3-Jul-10	22.29	Combustion trouble
Koradi	Unit 4	105	4-Jul-10	03.13		Continued.	Condensor Tube Leakage
Parli	Unit 3	210	4-Jul-10	15.15		Continued.	Coal Mill Chockup
Dabhol	2A	230	4-Jul-10	16.08	4-Jul-10	21.51	Filter replacement
Dabhol	3A	230	5-Jul-10	00.35		Continued.	Exhaust Temp.High
Parli	Unit 7	250	5-Jul-10	02.00	5-Jul-10	03.39	Loss of Fuel
Dabhol	3X	290	5-Jul-10	02.50		Continued.	Tripped
Dabhol	3B	230	5-Jul-10	02.50		Continued.	Hand tripped