

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 27-Jun-11 TO 3-Jul-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1A	230	20-May-11	13.22		Continued.	Rotor replacement.
Parli	Unit 6	250	16-Jun-11	05.50		Continued.	Annual Overhaul
Chandrapur	Unit 7	500	29-Jun-11	21:40		Continued.	COH
Cent_Sect	NTPC(V-10)	500	15-Jun-11	01.24		Continued.	C/OH
Nasik	Unit 2	120	30-Jun-11	23.50		Continued.	Scrapped
Nasik	Unit 1	120	25-Jun-11	04.35		Continued.	Scrapped

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	TARAPUR-4	540	30-May-11	20.00		Continued.	Survilence Test
Uran	Unit 8	108	6-Jun-11	23.12		Continued.	Bus Bar Protection operated,as Y-Ph BKR pole of Uran U-5 burst.
Uran	Unit B0	120	16-Jun-11	01.03	1-Jul-11	13:26	R/M work
CPP	WPCL U-3	135	20-Jun-11	03.16		Continued.	Maintenance work.
Koradi	Unit 5	200	22-Jun-11	21.58	30-Jun-11	06.59	Boiler Tube Leakage
Koyna	ST-IV 1	250	30-Jun-11	19.38	1-Jul-11	00.07	Spirical valve problem
Uran	Unit A0	120	25-Jun-11	10.40	30-Jun-11	08.49	Cable Damaged.
Nasik	Unit 4	210	26-Jun-11	11.55	2-Jul-11	04:15	Bottom Ash hopper heavy.
Parli	Unit 4	210	26-Jun-11	22.35	30-Jun-11	13.36	CVSM Problem.
Parli	Unit 3	210	29-Jun-11	03.10	29-Jun-11	11:10	Furnace shaft problem.
Parli	Unit 7	250	30-Jun-11	04.14	30-Jun-11	07.00	Loss of Fuel
Bhusawal	Unit 2	210	30-Jun-11	07.07	3-Jul-11	15.56	Boiler Tube Leakage
Nasik	Unit 3	210	30-Jun-11	21.05	1-Jul-11	00.35	Drum Level High
Koradi	Unit 5	200	1-Jul-11	10:37	1-Jul-11	12:45	Turbine Protection Fail.
Parli	Unit 4	210	2-Jul-11	07.40	2-Jul-11	12.46	Low Vaccum.
Bhusawal	Unit 3	210	3-Jul-11	17.05	3-Jul-11	20.13	H P Turbine Trip.