

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 28-Nov-11 TO 4-Dec-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasons
Chandrapur	Unit 2	210	5-Nov-11	11.02	4-Dec-11	11.10	Boiler Tube Leakage,converted to AOH.
Cent_Sect	TARAPUR-4	540	6-Nov-11	01.00		Continued.	Annual Overhaul
Parli	Unit 3	210	12-Nov-11	21.25		Continued.	Annual Overhaul.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 4	500	17-Oct-11	03.55		Continued.	Hand Tripped
CPP	WPCL U-4	135	2-Nov-11	04.40		Continued.	ID Fan Problem, Preparation for P.G. Test.
Dabhol	1A	230	14-Nov-11	12:00		Continued.	Gas Shortage.
Cent_Sect	Kawas GT2A	106	21-Nov-11	18:30	1-Dec-11	18.56	W/Dn.
Dabhol	1B	230	23-Nov-11	03.45		Continued.	Gas Shortage
Dabhol	1X	290	23-Nov-11	03.45		Continued.	Gas Shortage
Koyna	Unit 7	80	24-Nov-11	07.46	28-Nov-11	17.30	Outage.
Khaparkheda	Unit 5	500	24-Nov-11	09.40	28-Nov-11	15.58	Boiler Tube Leakage.
Nasik	Unit 4	210	26-Nov-11	09.15	29-Nov-11	13.38	Boiler Tube Leakage.
Parli	Unit 6	250	26-Nov-11	07.05	28-Nov-11	14.55	By pass valve problem.
Cent_Sect	sipat-5	500	27-Nov-11	05.54	28-Nov-11	12.50	Boiler Tube Leakage.
Cent_Sect	NTPC(V) 9	500	27-Nov-11	23.21	29-Nov-11	20.00	Boiler Tube leakage.
Paras	Unit 4	250	28-Nov-11	01.29	28-Nov-11	05.12	ACW pump tripped.
Parli	Unit 5	210	28-Nov-11	04.26	1-Dec-11	19.20	P.A.fan problem.
Koradi	Unit 7	210	28-Nov-11	17.36	28-Nov-11	19.16	Furnace Pressure High
Koradi	Unit 5	200	29-Nov-11	00.39	30-Nov-11	18.18	Boiler Tube Leakage
Cent_Sect	KARPR2	220	30-Nov-11	21.01	2-Dec-11	23.04	Reactor problem.
Koradi	Unit 6	210	1-Dec-11	12.24	1-Dec-11	22.03	CHP Bunkering Problem
Cent_Sect	NTPC (K-2)	210	1-Dec-11	15.45	1-Dec-11	20.44	Drum Level High
Cent_Sect	NTPC(K-7)	500	2-Dec-11	00.44		Continued.	Boiler Bottom Ring Header Leakage
Paras	Unit 4	250	2-Dec-11	15.59	2-Dec-11	18.01	Flame Failure.
Koradi	Unit 6	210	2-Dec-11	10.58	2-Dec-11	12.13	FD Fan Problem.
Uran	Unit 5	108	3-Dec-11	01.35	3-Dec-11	02.29	Boiler Protection.
Uran	Unit 6	108	3-Dec-11	01.35	3-Dec-11	02.09	Boiler Protection.
Uran	Unit A0	120	3-Dec-11	01.35	3-Dec-11	06.26	Sealed steam protection fail.
CPP	JSW (J) U3	300	3-Dec-11	18.18	4-Dec-11	02.30	Heavy oil leakage in turbine.
CPP	WPCL U-3	135	3-Dec-11	17.47		Continued.	Bottom Ash problem.
Koradi	Unit 6	210	3-Dec-11	11.16		Continued.	BLR T/L.
CPP	JSW (J) U3	300	4-Dec-11	10.27	4-Dec-11	12.50	Gen.Prof'n Operated.
Chandrapur	Unit 6	500	5-Dec-11	01.09		Continued.	BLR T/L.