

LINE OUTAGES FOR THE WEEK

FROM 3-Jan-10 TO 9-Jan-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE - II	3-Jan-11	18.08	3-Jan-11	20.06	Converter Transformer Tripped.
400KV	Parli-Lonikand -I	20-Dec-10	10.57	3-Jan-11	11.40	Overhauling work.Line on TBC.
400KV	Akola - Wardha - II	24-Dec-10	23.44	5-Jan-11	10.53	Over Voltage.
400KV	Kolhapur - Mapusa - I	30-Dec-10	22.48	6-Jan-11	10.45	Over Voltage
400KV	Dhule-Sar'Sarovar - I	1-Jan-11	22.37	4-Jan-11	18.36	Over Voltage
400KV	Karad - Kolhapur - I	2-Jan-11	22.19	3-Jan-11	06.57	Over Voltage.
400KV	Lonikand- Koyna Stage IV	2-Jan-11	23.45	3-Jan-11	06.36	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	2-Jan-11	23.17	3-Jan-11	10.08	Over Voltage.
400KV	Bhusawal- Aurangabad	3-Jan-11	00.58	3-Jan-11	06.12	Over Voltage.
400KV	Karad-Lamboti	3-Jan-11	01.03	3-Jan-11	05.43	Over Voltage.
400KV	Karad - Kolhapur - II	3-Jan-11	22.01	4-Jan-11	06.44	Over Voltage.
400KV	Bhusawal- Aurangabad	3-Jan-11	22.12	3-Jan-11	05.46	Over Voltage.
400KV	Koradi-Satpur	3-Jan-11	15.29	7-Jan-11	18.08	Main Bkr Trip Ckt Faulty.Ckt is on TBC.
400KV	Koradi-Akola	3-Jan-11	21.22	3-Jan-11	21.34	Line Reactor 50 MVAR Oil Filtration Work.Reactor Bypassed.
400KV	Bhusawal- Aurangabad	3-Jan-11	22.11	4-Jan-11	05.45	Over Voltage.
400KV	Lonikand- Koyna Stage IV	4-Jan-11	00.35	4-Jan-11	06.50	Over Voltage.
400KV	400/220 KV 315MVA ICT-II @ Karad	4-Jan-11	14.34	4-Jan-11	19.38	H.V.Side BKR Repl.Work.
400KV	400/220 KV 315MVA ICT-II @ Karad	4-Jan-11	19.38		Continued.	H.V.Side BKR Repl.Work,Kept on TBC.
400KV	Kalwa-Padgha II	4-Jan-11	14.46	5-Jan-11	13.23	Taken on TBC,To attend Hot Spot at Kalwa end.
400KV	400/220 KV 315 MVA ICT- I @ Parly.	4-Jan-11	07.20	4-Jan-11	08.21	Bus Fault.
400KV	400/220 KV 315 MVA ICT - II @ Parli	4-Jan-11	07.20	4-Jan-11	08.47	Bus Fault.
400KV	Dhule - S'Sarovar- II	4-Jan-11	22.55	5-Jan-11	15.37	Over Voltage.
400KV	Bhusawal- Aurangabad	4-Jan-11	22.54	5-Jan-11	05.55	Over Voltage.
400KV	Karad - Kolhapur - I	4-Jan-11	23.19	5-Jan-11	07.10	Over Voltage.
400KV	400/220 KV 315 MVA ICT- I @ Parly.	4-Jan-11	11.28	4-Jan-11	19.47	LV Side 220KV Bus Sec.outage.
400KV	Chandrapur-Bhadravati II	5-Jan-11	10.54	5-Jan-11	12.17	Bus II fault at chandrapur
400KV	Chandrapur - Bhadravati-IV	5-Jan-11	10.54	5-Jan-11	11.55	Bus II fault at chandrapur
400KV	New Koyna - Dabhol - II	5-Jan-11	14.15	5-Jan-11	17.34	To attend 'C'isolator jumpering in New Koyna.
400KV	Bus Coupler @ Chandrapur	5-Jan-11	08.57	6-Jan-11	19.03	Tan delta and Maintenance work.
400KV	Bhusawal- Aurangabad	5-Jan-11	19.48	6-Jan-11	05.56	Over Voltage.
400KV	Dhule-S'Sarovar I	5-Jan-11	15.59	6-Jan-11	10.50	Over Voltage.
400KV	Akola - Wardha - I	5-Jan-11	21.25		Continued.	Over Voltage.
400KV	Chandrapur-400KV Bus-II	5-Jan-11	10.54	5-Jan-11	11.40	Bus fault LBB GT4 operated.
400KV	Chandrapur - Parly - III	5-Jan-11	10.54	5-Jan-11	11.57	Bus fault LBB GT4 operated
400KV	400/220 KV 315 MVA ICT-II @ Chandrapur	5-Jan-11	10.54	5-Jan-11	12.08	Bus fault LBB GT4 operated
400KV	Karad - Kolhapur - II	5-Jan-11	22.17	6-Jan-11	07.50	Over Voltage.
400KV	Karad-Lamboti	5-Jan-11	23.37	6-Jan-11	05.52	Over Voltage.
400KV	400/220 KV 315 MVA ICT- I @ Parly.	5-Jan-11	19.47		Continued.	LV side on TBC.M.BKR PDR problem
400KV	400/220KV 315MVA ICT-II @ New Koyna	6-Jan-11	00.15	6-Jan-11	02.25	H/T for bus changeover bus-II to bus-I
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	6-Jan-11	10.20	6-Jan-11	22.33	Testing work.
400KV	Parli - Lamboti	6-Jan-11	10.55	6-Jan-11	13.48	Loc.No.216 'R"ph insulator replacement.
400KV	Bhusawal- Aurangabad	6-Jan-11	23.27	7-Jan-11	05.49	Over Voltage
400KV	Kolhapur - Mapusa - II	6-Jan-11	22.27	7-Jan-11	12.52	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	6-Jan-11	23.30	9-Jan-11	07.30	Over Voltage
400KV	Lonikand- Koyna Stage IV	6-Jan-11	23.57	7-Jan-11	06.42	Over Voltage.

400KV	Karad - Kolhapur - I	6-Jan-11	23.11	7-Jan-11	08.47	Over voltage.
400KV	80 MVAR Reactor @ Kharghar	6-Jan-11	09.22	6-Jan-11	17.06	Testing work.
400KV	Main Bus-II At New Koyna	6-Jan-11	00.30	6-Jan-11	14.15	Repair of B ph.bus-II broken conductor.
400KV	Dabhol - NewKoyna - II	7-Jan-11	08.09	7-Jan-11	18.31	Replacement of Insulator
400KV	Karad-Kolhapur-II	7-Jan-11	18.23	8-Jan-11	08.30	Over Voltage
400KV	Koradi - Akola	7-Jan-11	18.36	7-Jan-11	19.54	For taking reactor in service
400KV	Bhusawal- Aurangabad	7-Jan-11	20.04	8-Jan-11	05.48	Over Voltage
400KV	400 KV TBC @ Lonikand	7-Jan-11	12.30	7-Jan-11	14.30	DCRM KIT Demo
400KV	Kolhapur - Mapusa - I	7-Jan-11	23.12	8-Jan-11	10.49	Over Voltage
400KV	Lonikand- Koyna Stage IV	8-Jan-11	00.06	8-Jan-11	05.49	Over Voltage
400KV	New Koyna - Dabhol - II	8-Jan-11	07.54	8-Jan-11	18.58	Insulator Replacement.
400KV	Dhule-Sar'Sarovar - II	8-Jan-11	23.54	10-Jan-11	09.41	Over Voltage.
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	8-Jan-11	18.48	8-Jan-11	21.08	A Bus Fault,220KV Sawantwadi,220KV Bus R Ph String Faulty.
400KV	Bhusawal- Aurangabad	8-Jan-11	20.52	9-Jan-11	04.49	Over Voltage.
400KV	80 MVAR Bus Reactor @ Padgha	8-Jan-11	10.25	8-Jan-11	17.20	Tan'd Measurment of Reactor C T.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	8-Jan-11	15.03	8-Jan-11	16.34	To Attend R Ph Oil Leakage.
400KV	New Koyna - Dabhol - II	9-Jan-11	07.45	9-Jan-11	18.02	Replacement of Insulator,Cold Washing & Hot Spot Attending.
400KV	Kolhapur - Mapusa - I	9-Jan-11	00.01	9-Jan-11	09.45	Over Voltage.
400KV	Bhusawal- Aurangabad	9-Jan-11	21.06	10-Jan-11	06.00	Over Voltage.
400KV	Koyna IV - Jejuri	9-Jan-11	22.55	10-Jan-11	06.44	To Attend Sparking on B Ph Wave trap @ Stage IV End.
400KV	Kolhapur - Mapusa - I	9-Jan-11	23.34		Continued.	Over Voltage.
220KV	220 KV TBC At Warora	21-Dec-10	14.40	5-Jan-11	15.30	Bkr.Y-Ph pole mechanical problem.
220KV	220/132KV,100 MVA ICT-I At Peth	22-Dec-10	08.00	5-Jan-11	16.45	Oil replacement.
220KV	New Parly-Nanded	23-Dec-10	09.48	4-Jan-11	18.22	Shifting work of PRL-Nanded in U-8 area.
220KV	Parly - New Parly TPS - II	23-Dec-10	09.48	4-Jan-11	18.13	Shifting work of PRL-Nanded in U-8 area.
220KV	220/66KV 50 MVA ICT- II @ Warora	3-Jan-11	15.20	3-Jan-11	16.05	Diff Relay Testing Work.
220KV	Padgha-Jambhul	3-Jan-11	14.52	3-Jan-11	16.41	Testing Work.
220KV	Pedambe-Kharepatan	3-Jan-11	07.50	3-Jan-11	17.35	Red Hot @ B Ph Isolator.
220KV	Kalwa-Mulund-I	3-Jan-11	07.45	3-Jan-11	11.08	To Attend Red Hot Spot on R Ph C T Side Jumper.
220KV	Uran-Kharghar-II	3-Jan-11	21.31	3-Jan-11	22.06	Distance Protection, R Ph Z-I.
220KV	220KV Beed - 132KV Beed	3-Jan-11	17.57	3-Jan-11	18.05	Due to Overloading 560 A Load.
220KV	Karad-Oglewadi-I	4-Jan-11	10.06	4-Jan-11	14.30	Annual Maintenance work.
220KV	Jejuri-Phursungi	4-Jan-11	05.47	4-Jan-11	06.17	Coal disturbancy.
220KV	Lonand - Baramati	4-Jan-11	10.05	4-Jan-11	13.10	Q.M.Work
220KV	Parly - New Parly TPS - II	4-Jan-11	07.20	4-Jan-11	08.35	Snapping of Y-Ph Bus side jumper of 220KV PRL Ext.line.
220KV	Parli-Murud	4-Jan-11	07.20	5-Jan-11	00.30	Bus Fault.
220KV	Parli-Girwali III	4-Jan-11	09.48	4-Jan-11	17.43	220KV Bus Sec.outage at Parli.
220KV	220/132KV 100 MVA ICT- II @ Parli-II	4-Jan-11	07.20	4-Jan-11	08.27	Bus Fault.
220KV	220/132KV 100 MVA ICT- III @ Parli-II	4-Jan-11	07.20	4-Jan-11	08.52	Bus Fault.
220KV	Parly - Harangool - I	4-Jan-11	07.20	4-Jan-11	09.12	Bus Fault.
220KV	Parly - Harangool - II	4-Jan-11	07.20	4-Jan-11	09.13	Bus Fault.
220KV	Parly - New Parly -I	4-Jan-11	07.20	4-Jan-11	08.29	Bus Fault.
220KV	Parly - Girwali - II	4-Jan-11	07.20	4-Jan-11	08.31	Bus Fault.
220KV	Parly - Girwali - IV	4-Jan-11	07.20	4-Jan-11	17.44	Bus Fault.
220KV	Parly (Ext.) - Beed - II	4-Jan-11	07.20	4-Jan-11	16.38	Bus Fault.
220KV	Parli(Ext.)-Beed I	4-Jan-11	07.20	4-Jan-11	16.36	Bus Fault.
220KV	Nasik-Navsari-I	4-Jan-11	17.45	4-Jan-11	18.05	PDR
220KV	220/132KV 100 MVA ICT- I @ Parly-II	4-Jan-11	07.20	4-Jan-11	08.50	Bus Fault.
220KV	220/100 KV 200 MVA ICT II at Trombay	4-Jan-11	09.20	4-Jan-11	12.15	T/F internal fault.
220KV	Parli-Usmanabad	4-Jan-11	07.20	5-Jan-11	00.23	Bus fault.

220KV	New Parli-Nanded	4-Jan-11	09.48	4-Jan-11	18.22	220KV Bus Sec.outage.
220KV	Parli-Girwali III	4-Jan-11	11.11	4-Jan-11	17.43	220KV Bus Sec.outage.
220KV	220/132KV 100 MVA ICT- I @ Parly-II	4-Jan-11	11.13	4-Jan-11	17.40	220KV Bus Sec.outage.
220KV	Girwali - Parbhani	4-Jan-11	11.53	4-Jan-11	18.12	220KV Bus Sec.outage.
220KV	220KV Bus Section I at 400 Kv Parli	4-Jan-11	11.53	4-Jan-11	17.23	Reconnection of jumpers of 220KV Nanded ckt.
220KV	Bale - Lamboti I	5-Jan-11	00.02	5-Jan-11	17.32	R-Ph CT Burst at Bale.
220KV	Bale-Lamboti II	5-Jan-11	00.02	5-Jan-11	00.52	At Bale end.
220KV	220/132KV,200MVA ICT-I at Malegaon	5-Jan-11	07.38	5-Jan-11	12.50	OLTC Surge Relay maloperated due to moisture.
220KV	220/132 KV,100 MVA T/F- I @ Malegaon	5-Jan-11	07.38	5-Jan-11	08.12	O/L due to tripping of 200 MVA ICT.
220KV	220/132 KV 150 MVA ICT - IV @ Bale	5-Jan-11	00.02	5-Jan-11	13.17	CT of Lamboti Ckt.I 'R' ph.burst.
220KV	220/33KV 50 MVA T/F-II at Karkamb	5-Jan-11	12.01	6-Jan-11	21.15	X'mer Internal fault.
220KV	Pophali - Kandalgaon - I	5-Jan-11	11.55	6-Jan-11	08.36	Y ph.wave trap conductor snap at Pophali.
220KV	Pophali - Karad	5-Jan-11	08.30	5-Jan-11	11.42	SF-6 Gas Filling.
220KV	Ghodbandar-Varsowa	5-Jan-11	14.00	6-Jan-11	00.45	To attend oil leakage of Y ph.CT.
220KV	Wardha--Dhamangaon	5-Jan-11	10.22	5-Jan-11	19.37	Relay Testing work
220KV	Khaparkheda-Kawlewada-I	5-Jan-11	10.03	5-Jan-11	16.59	Q.M.Work.
220KV	Khaparkheda - Kanhan - II	5-Jan-11	09.09	5-Jan-11	15.58	Q.M.Work
220KV	Badnera--Rly.TSS - I	5-Jan-11	12.18	5-Jan-11	17.53	Testing work.
220KV	Kharghar-TSS-Panvel	5-Jan-11	10.06	5-Jan-11	16.28	B ph.LA replacement.
220KV	Pedambe-Newkoyna	6-Jan-11	08.25	6-Jan-11	13.57	R ph.WT replacement at Pedambe.
220KV	Babaleshwar - Alephata	6-Jan-11	08.25	6-Jan-11	17.08	Replacement of insulator.
220KV	Baramati-Kurkumb	6-Jan-11	09.50	6-Jan-11	14.25	Q.M.Work.
220KV	Uran-Kharghar-II	6-Jan-11	10.12	6-Jan-11	17.43	Insulator replacement work.
220KV	220/100 KV125 MVA ICT-III @Trombay	6-Jan-11	12.03		Continued.	Augmentation by New 200 MVA ICT up to 20.03.2011.
220KV	Mudsungi-Amona	6-Jan-11	19.07	6-Jan-11	19.58	Distance protection.
220KV	Amona-ponda- I	6-Jan-11	19.15	6-Jan-11	21.25	Distance protection.
220KV	Tilari-Amona-II	6-Jan-11	19.15	6-Jan-11	21.36	Pole discrepancy At Amona.
220KV	Abhijeet-Wardha Ckt.	6-Jan-11	14.26	6-Jan-11	17.51	Earth wire replacement.
220KV	Ambazari-Wardha	6-Jan-11	14.19	6-Jan-11	17.55	Earth wire replacement.
220KV	220/132 KV 200 MVA ICT @ Kalmeshwar	6-Jan-11	08.27	6-Jan-11	13.05	To attend low pressure of N2 gas.
220KV	220/132 KV 200 MVA ICT- II @ Kalmeshwar	6-Jan-11	14.52	6-Jan-11	16.31	Oil top up work.
220KV	Girivali - Parli - III	6-Jan-11	09.10	10-Jan-11	15.35	Replacement of Aux.and line isolator.
220KV	Wardha-RLY TSS I	6-Jan-11	03.50	6-Jan-11	05.28	Tripped low air pressure alarm.
220KV	Dhule - Dhule - I	6-Jan-11	10.05		Continued.	Line Isolator Replacement Work.
220KV	Kalwa - Ghatghar	7-Jan-11	05.30	7-Jan-11	06.11	Distance protection.
220KV	Vankuswadi - MIDC Satara- II	7-Jan-11	09.20	8-Jan-11	17.00	Reorientation work
220KV	Vankuswade-Malharpath	7-Jan-11	13.55	8-Jan-11	17.00	Reorientation work
220KV	Jambhual - Pal-I	7-Jan-11	14.52	7-Jan-11	18.45	Stringing work of 220KV Anandnagar LILO work
220KV	Jambhual - Pal-II	7-Jan-11	08.15	7-Jan-11	14.22	Stringing work of 220KV Anandnagar LILO work
220KV	Lote - Dasturi	7-Jan-11	21.01		Continued.	B phase Crossarm Bend at Loc.No.97
220KV	Nasik-Navsari-I	7-Jan-11	14.23	7-Jan-11	18.30	PDR at Nasik
220KV	Murud-Bale	7-Jan-11	16.45	7-Jan-11	20.34	Distance Protection
220KV	Karad - Vita - I	7-Jan-11	15.42	7-Jan-11	16.06	Tripped at Vita end
220KV	220/100KV 100MVA T/F @ K'gaon	7-Jan-11	09.00	7-Jan-11	11.37	PDR Trip
220KV	Wardha Power - Warora-I	7-Jan-11	16.59	7-Jan-11	17.00	New Line Charge
220KV	Nasik - Ghatghar	7-Jan-11	09.35	9-Jan-11	10.40	Bus PT replacement,taken on TBC
220KV	220/100KV 100 MVA T/F- I @ Tambati	7-Jan-11	11.30	7-Jan-11	17.45	LV Bushing Leakage work
220KV	Bus PT - II at Nasik GCR	7-Jan-11	06.56	9-Jan-11	10:30	P.T.Replacement work
220KV	Dhule-Dondaicha-II	7-Jan-11	11.06	7-Jan-11	11.44	To attend sparking on R phase line side Isolator
220KV	Aurangabad - Padegaon - I.	7-Jan-11	13.36	7-Jan-11	15.48	To attend Oil Leakage of Y PH CT

220KV	220/132KV 200 MVA ICT- III @ Padegaon	7-Jan-11	10.55	7-Jan-11	17.55	Q.M.Work
220KV	220/132 KV 200 MVA ICT - I @ Kalmeshwa	7-Jan-11	12.39	7-Jan-11	16.28	To attend Heavy Oil Leakage
220KV	Babaleshwar - Bhenda	7-Jan-11	11.59	8-Jan-11	12.46	To Control Loading.
220KV	220/33KV 100MVA T/F-II at Aarey	8-Jan-11	02.17	8-Jan-11	06.10	Work on LV side
220KV	Vankuswadi - MIDC Satara- II	8-Jan-11	17.05	8-Jan-11	18.05	R Ph L A Burst.
220KV	Apta-Uran-II	8-Jan-11	08.55	8-Jan-11	18.52	Insulator Replacement Under LE's.
220KV	Babaleshwar - Ranjangaon	8-Jan-11	12.29	8-Jan-11	15.15	Tan'D Measurment of Link.
220KV	Trombay-Mulund	8-Jan-11	15.09	8-Jan-11	19.55	Bus Section Outage of Trombay.
220KV	Trombay-Tata Tie - I	8-Jan-11	15.07	8-Jan-11	20.23	Bus Section Outage @ Trombay.
220KV	Talangde-Five star MIDC	8-Jan-11	18.48	8-Jan-11	20.45	220KV Bus Fault @ Bus Section A Due to R Ph Faulty String.
220KV	Talangade-Mudshingi	8-Jan-11	18.48	8-Jan-11	21.19	Bus Fault @ Bus Section A Due to R Ph Faulty String.
220KV	Talandge - Sawantwadi	8-Jan-11	18.48	8-Jan-11	20.58	Bus A Fault @ Talangade.
220KV	220 KV Bus Coupler @ Talangde	8-Jan-11	18.48		Continued.	Bus A Fault @ Talangade
220KV	220/132 KV 200 MVA ICT - II @ Raymand	8-Jan-11	09.45	8-Jan-11	17.00	Attending Y Ph H V Bushing Oil Leakage.
220KV	Bus Section - III @ Trombay	8-Jan-11	15.30	8-Jan-11	19.55	Hot Spot Attending.
220KV	220/100 KV 200 MVA ICT- IV @ Apta	8-Jan-11	09.32	8-Jan-11	10.40	Hydrolick Oil Replacement.
220KV	TBC @ Chalisgaon	8-Jan-11	09.05	8-Jan-11	13.00	Quarterly Maintenance Work.
220KV	Khargar-Topworth	8-Jan-11	23.07	9-Jan-11	09.00	CB Compressor Problem.
220KV	Jejuri-Phursungi	9-Jan-11	04.31	9-Jan-11	04.56	Dist.Prot.
220KV	Bhoisor - Borivali	9-Jan-11	09.20	9-Jan-11	13.28	Hot Spot Attending & Tand Measurment.
220KV	Kolhapur-Sawantwadi	9-Jan-11	11.56	10-Jan-11	15.40	Taken on TBC TO Attend Bus A R Ph Insulator Flashour.
220KV	220/33KV 50 MVA T/F @ Aurangabad	9-Jan-11	14.10	9-Jan-11	14.19	Over Current & Earth Fault Protection.
220KV	220/33 KV 100 MVA ICT IV at Jamde	9-Jan-11	12.42		Continued.	Tripped.Declared Fail.
220KV	220/33 KV 25 MVA T/F @ Aurangabad	9-Jan-11	14.10	9-Jan-11	14.22	Feeder Fault.
132KV	Dhule-Dondaicha - I	30-Dec-10	13.25	3-Jan-11	19.10	Replacement of Line Isolator,Line H/T From Dhule End.
132KV	Malegaon- Malegaon-I	5-Jan-11	07.38	5-Jan-11	08.13	220/132 kv ICTs tripped, 132 kv bus dead.
132KV	Malegaon - Malegaon - II	5-Jan-11	07.38	5-Jan-11	08.14	220/132 kv ICTs tripped, 132 kv bus dead.
132KV	Malegaon - Nampur	5-Jan-11	07.38	5-Jan-11	08.14	220/132 kv ICTs tripped, 132 kv bus dead.
132KV	Malegaon-Manmad	5-Jan-11	07.38	5-Jan-11	13.15	220/132 kv ICTs tripped, 132 kv bus dead.
132KV	Buldana-Motala	5-Jan-11	18.45		Continued.	To Control Chikhali ICT Over Loading.
132KV	Pusad-Jambazar	6-Jan-11	08.46	6-Jan-11	08.55	Distance Protection
132KV	Bhandara - Madgi - II	7-Jan-11	09.48	9-Jan-11	18.00	Earthwire Replacement Work.
132KV	Bhusawal -Yawal	8-Jan-11	08.20	8-Jan-11	08.38	Replacement of P T & Isolator.
132KV	Harangul-Chakur	8-Jan-11	15.28	8-Jan-11	15.45	Distance Protection Z-I B Ph.
132KV	Bhandara - Madgi -I	8-Jan-11	15.48	8-Jan-11	17.36	Low Pressure of SF6 Gas Main Breaker.
132KV	Giravali-Latur	9-Jan-11	09.21	9-Jan-11	13.39	Q.M.Work.
132KV	Kannad - Kagzipura	9-Jan-11	22.15	10-Jan-11	09.15	Distance Protection Operated B Ph to N.
132KV	Dhule-Dondaicha - I	9-Jan-11	11.35		Continued.	Outage on 150 MVA ICT @ Dhule.
132KV	Dhule - Dondaicha - II	9-Jan-11	11.45		Continued.	Outage on 150 MVA ICT @ Dhule.
100KV	Kalwa - Salshet - I	31-Dec-10	18.12	7-Jan-11	09.00	H/T from Kalwa end
100KV	Chinchwad - Talegaon	6-Jan-11	08.10	6-Jan-11	17.59	Errection of Tower.
100KV	Kalwa - Salsette - II	7-Jan-11	09.22		Continued.	From Kalwa End