

LINE OUTAGES FOR THE WEEK

FROM 31-Jan-11 TO 6-Feb-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Dhule - S'Sarovar- II	29-Jan-11	22.11	31-Jan-11	09.21	Over Voltage
400KV	Kolhapur - Mapusa - I	29-Jan-11	22.47	31-Jan-11	11.11	Over Voltage
400KV	Bhusawal- Aurangabad	30-Jan-11	20.18	31-Jan-11	05.30	Over Voltage.
400KV	Wardha - Akola - II	30-Jan-11	20.27	31-Jan-11	07.52	Over Voltage.
400KV	Karad - Kolhapur - II	31-Jan-11	00.08	31-Jan-11	08.02	Over Voltage.
400KV	Bhusawal- Aurangabad	31-Jan-11	21.12	1-Feb-11	05.30	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	31-Jan-11	01.15	2-Feb-11	08.23	Over Voltage.
400KV	Karad - Kolhapur - I	31-Jan-11	21.34	1-Feb-11	07.14	Over Voltage.
400KV	Kolhapur - Mapusa - I	31-Jan-11	23.03	1-Feb-11	11.47	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	31-Jan-11	23.44	1-Feb-11	08.57	Over Voltage.
400KV	Akola - Wardha - II	31-Jan-11	23.16	1-Feb-11	07.24	Over Voltage.
400KV	Bhusawal- Aurangabad	1-Feb-11	20.35	2-Feb-11	05.29	Over Voltage.
400KV	Kolhapur - Mapusa - I	1-Feb-11	22.44	2-Feb-11	09.06	Over Voltage.
400KV	Akola - Wardha - I	1-Feb-11	23.57	2-Feb-11	09.24	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	1-Feb-11	23.57	3-Feb-11	06.29	Over Voltage.
400KV	Kalwa-Kharghar	2-Feb-11	08.48	2-Feb-11	13.12	29A Isolator Sparking.
400KV	Bhusawal- Aurangabad	2-Feb-11	22.22	3-Feb-11	05.42	Over Voltage.
400KV	Karad - Kolhapur - I	2-Feb-11	22.01	3-Feb-11	07.38	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	2-Feb-11	23.34	3-Feb-11	18.03	Over Voltage
400KV	Akola - Wardha - II	2-Feb-11	23.38	3-Feb-11	06.31	Over Voltage
400KV	Kolhapur-Mapusa-II	2-Feb-11	23.05	3-Feb-11	11.39	Over Voltage
400KV	Bhusawal- Aurangabad	3-Feb-11	21.59	4-Feb-11	04.54	Over Voltage.
400KV	Karad - Kolhapur - II	3-Feb-11	22.24	4-Feb-11	07.00	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	3-Feb-11	22.44	6-Feb-11	18.26	Over Voltage.
400KV	Akola - Wardha - I	3-Feb-11	22.42	4-Feb-11	05.19	Over Voltage.
400KV	Kolhapur - Mapusa - I	3-Feb-11	23.24	4-Feb-11	10.05	Over Voltage.
400KV	400/220 KV 315 MVA ICT @ Khadka	4-Feb-11	21.46	4-Feb-11	21.59	Tripped during Testing of Bus Bar Prot.Scheme
400KV	Karad-Kolhapur-II	4-Feb-11	18.02	5-Feb-11	06.34	Over Voltage
400KV	Bhusawal- Aurangabad	4-Feb-11	21.21	5-Feb-11	04.23	Over Voltage
400KV	Kolhapur - Mapusa - II	4-Feb-11	23.11	5-Feb-11	08.40	Over Voltage
400KV	Akola - Wardha - II	4-Feb-11	23.14	5-Feb-11	06.37	Over Voltage
400KV	Chandrapur - Parli - II	4-Feb-11	08.31	4-Feb-11	13.59	Repl.of damaged Corona Ring
400KV	Padgha - Nagothane - I	5-Feb-11	09.16	5-Feb-11	17.07	Bay Maint.work
400KV	Lonikand- Koyna Stage IV	5-Feb-11	11.59	5-Feb-11	15.04	To attend Hot Spot
400KV	Karad - Kolhapur - I	5-Feb-11	22.27	6-Feb-11	07.14	Over Voltage

400KV	Karad - Solapur (PGCIL)	5-Feb-11	18.09	5-Feb-11	18.52	To take additional reactor out of service at Solapur end
400KV	Bhusawal- Aurangabad	5-Feb-11	22.30	6-Feb-11	04.50	Over Voltage
400KV	400/220 KV 105 MVA Spare ICT @ Akola.	5-Feb-11	08.36	5-Feb-11	17.37	Q.M.work
400KV	Kolhapur - Mapusa - I	5-Feb-11	23.24	6-Feb-11	08.18	Over Voltage
400KV	400/220KV 315MVA ICT-III at Karad.	6-Feb-11	09.59		Continued.	CT replacement up to 08/2/11
400KV	Dhule-S'Sarovar I	6-Feb-11	18.40		Continued.	Shunt Reactor pannel problem
400KV	Dhule - S'Sarovar- II	6-Feb-11	18.21		Continued.	For observation of CSR 1 Pannel.
400KV	Kolhapur-Mapusa-II	6-Feb-11	22.58		Continued.	Over Voltage
400KV	Bableshtar-Aurangabad	6-Feb-11	22.06	7-Feb-11	03.19	Over Voltage
400KV	Karad - Kolhapur - I	6-Feb-11	21.38		Continued.	Over Voltage
220KV	220/132 KV 100 MVA ICT- II @ Babaleshtar	25-Dec-10	12.15	6-Feb-11	17.50	Augmentation by 200MVA ICT(charged at 18.00Hrs on 4/2/11.)
220KV	220/132KV 100 MVA ICT-I @Padegaon	26-Dec-10	13.30	4-Feb-11	19.59	Main Breaker Replacement,ICT on TBC
220KV	220/132 KV 100 MVA ICT- II @ Bhusawal	2-Jan-11	08.58	5-Feb-11	17.48	Repl.of 100 MVA By 200 MVA ICT(charged at 16.36Hrs on 4/2/11.)
220KV	220/6.6KV 40MVA Stn.T/F-IV at K'Kheda	14-Jan-11	12.26	3-Feb-11	15.26	Oil Filtration work(10Days)
220KV	Chandrapur-Warora - I	23-Jan-11	18.14	31-Jan-11	19.42	To Control 220KV Warora-Hinganghat Loading.
220KV	220/132 KV, 100 MVA ICT - II @ Beed.	24-Jan-11	07.00	5-Feb-11	12.05	Repl.of 100MVA ICT by 200MVA
220KV	220/66 KV 50 MVA T/F @ Chandrapur	27-Jan-11	09.24	1-Feb-11	11.33	Repl.of 66KV Breaker(up to 1/2/11)
220KV	220/100 ICT- I @ Kolshet	31-Jan-11	11.05	31-Jan-11	21.40	To Attend Trip Ckt Faulty Indication.
220KV	Vita - Miraj	31-Jan-11	11.05	31-Jan-11	13.20	Tan d Measurment.
220KV	Miraj -Ichalkarajni	31-Jan-11	14.15	31-Jan-11	17.55	Tan d Measurment.
220KV	Warora - Wardha Power - II	31-Jan-11	19.37	2-Feb-11	19.14	Y Ph C T Burst.
220KV	220/132 200 MVA ICT II @ Jalna	31-Jan-11	11.03	31-Jan-11	15.15	Attending Hot Spot.
220KV	220/132 KV 200 MVA ICT - II @ Nanded	31-Jan-11	10.59	31-Jan-11	14.20	Quarterly Maintainance Work of ICT.
220KV	Pusad-Nanded	31-Jan-11	10.20	31-Jan-11	18.08	C T Replacement Work.
220KV	Chandrapur-Warora - I	1-Feb-11	00.39		Continued.	To Control Line Loading of 220KV Warora-Hinganghat.
220KV	Lote-Dasturi	1-Feb-11	11.56	1-Feb-11	19.44	Distance Protection.
220KV	220/100 KV 200 MVA ICT-II @ Apta	1-Feb-11	13.50	1-Feb-11	18.12	R Ph H V Bushing Oil Leakage.
220KV	Airoli-Knowledge park-Nasik	2-Feb-11	04.25	2-Feb-11	05.00	Tripped.
220KV	Bhoisor - Bhoisor PGCIL-II	2-Feb-11	14.28	2-Feb-11	15.33	Distance Protection
220KV	Lonikand -Theur - II	3-Feb-11	14.40	3-Feb-11	17.16	To attend Hot Spot.
220KV	Apta-Bombay Dyeing	3-Feb-11	15.30	3-Feb-11	18.50	For testing of relay.
220KV	Kolhapur - Amona	3-Feb-11	15.54	3-Feb-11	16.15	Distance Protection.
220KV	Talangade - Mumewadi	3-Feb-11	15.53	3-Feb-11	16.13	Distance Protection.
220KV	Pophali - Karad	3-Feb-11	11.19	3-Feb-11	11.55	Distance Protection.
220KV	Bhugaon - IIPL	3-Feb-11	20.00		Continued.	H/T.
220KV	220/110KV 100MVA T/F-III at Miraj	4-Feb-11	20.10	5-Feb-11	00.25	To attend Y phase CT leakage
220KV	220/100KV, 200MVA T/F-IV at Kalwa	4-Feb-11	20.35	6-Feb-11	11.46	H/T from LV side due to formation of gas
220KV	Babaleshtar - Nagar - I	4-Feb-11	14.24	4-Feb-11	14.31	Tripped due to Load Trimming operated at 400KV BBLSR S/stn.
220KV	Babaleshtar - Nagar - II	4-Feb-11	14.24	4-Feb-11	14.40	Tripped due to Load Trimming operated at 400KV BBLSR S/stn.
220KV	220/132KV,200 MVA T/F-I At Nagar	4-Feb-11	13.43	4-Feb-11	14.02	O/C ,E/F prot.operated

220KV	Aurangabad - Padegaon - I.	4-Feb-11	10.25	4-Feb-11	18.54	Strengthening of Jumper at Cut point locations
220KV	220/132KV 50MVA ICT-I @Peth	4-Feb-11	08.45		Continued.	Augmentation by 100MVA ICT(upto 10/02/2011).
220KV	Kalwa - Siemens	5-Feb-11	11.57	5-Feb-11	15.30	For connecting metering cable to CT/PT
220KV	Varsova - Aarey - I	5-Feb-11	13.38	5-Feb-11	20.14	Cable termination work
220KV	220/132 KV,200MVA ICT-I at Nasik GCR	5-Feb-11	10.06	5-Feb-11	14.55	To attend Hot Spot
220KV	Girawli - New Parly TPS	5-Feb-11	09.37	5-Feb-11	15.01	To attend Hot Spot
220KV	220/132KV 200 MVA ICT- II @ Jalna	5-Feb-11	10.30	5-Feb-11	11.55	To attend R phase CT oil leakage
220KV	220/132 KV100 MVA ICT-I @ Chalisgaon	5-Feb-11	10.40	5-Feb-11	15.42	Q.M.Work
220KV	Borivali-Tarapur	6-Feb-11	13.10	6-Feb-11	15.50	CT tan delta measurement
220KV	BBLSR-Waluj	6-Feb-11	09.28		Continued.	To control BBLSR ICT Loading
220KV	Varsova - Aarey - I	6-Feb-11	11.42	6-Feb-11	22.35	Line Maint.work
220KV	Borivali-Boisar	6-Feb-11	09.02	6-Feb-11	12.45	Tan delta measurment
220KV	220/100KV, 200MVA T/F-IV at Kalwa	6-Feb-11	20.32		Continued.	For Thermovision inspection
220KV	220/33KV 100MVA T/F- I at Versova	6-Feb-11	07.57	6-Feb-11	20.23	Annual Maint.work
220KV	Kalwa - Borivali	6-Feb-11	22.51		Continued.	From Kalwa end strengthing Mumbai system
220KV	Borivali-Mulund	6-Feb-11	22.17		Continued.	From Borivali end for strengthing Mumbai system
132KV	Butibori MIDC - Khapri - II	30-Jan-11	15.36	31-Jan-11	07.05	Distance Protection Opreated Zone-I.
132KV	Jalna - Ambad	31-Jan-11	11.02	31-Jan-11	15.45	Quarterly Maintainance Work.
132KV	Butibori MIDC - Khapri - II	31-Jan-11	15.36	31-Jan-11	17.05	Distance Protection Operated Zone-I.
132KV	A'nagar - Ashti	4-Feb-11	13.43	4-Feb-11	14.03	Tripped
132KV	A'nagar - Supa	4-Feb-11	13.43	4-Feb-11	14.04	Tripped
132KV	A'nagar - MIDC	4-Feb-11	13.43	4-Feb-11	14.05	Tripped
132KV	Kanhan - Bhandara	4-Feb-11	18.28	5-Feb-11	16.02	To attend Low Pressure Alarm(Ckt on TBC)
132KV	Giravali-Parli-I	4-Feb-11	11.41		Continued.	Breaker replacement
132KV	Chikhali - Dhad	6-Feb-11	18.45	6-Feb-11	19.12	Distance Protection
100KV	Kalwa - Salshet - I	12-Jan-11	13.46	4-Feb-11	17.13	H/T from Kalwa end
100KV	Kalwa - Salsette - II	4-Feb-11	17.14		Continued.	H/T From Kalwa end.