

LINE OUTAGES FOR THE WEEK

FROM 4-Apr-11 TO 10-Apr-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Lonikand-Karad	20-Mar-11	07:45	30-Mar-11	13.22	Erection of 2 Nos. of In line towers at Loc. No. 328 .
400KV	Bhusawal- Aurangabad	27-Mar-11	20:44	28-Mar-11	05.36	Over Voltage
400KV	Dhule - S'Sarovar- II	27-Mar-11	23.24	28-Mar-11	08.08	Over Voltage
400KV	Newkoyna - Jaigad - I	28-Mar-11	04.13	28-Mar-11	06.28	Distance Protection
400KV	New Koyna-Jaigad II	28-Mar-11	03.50	28-Mar-11	06.03	Distance Protection
400KV	Karad - Kolhapur - I	28-Mar-11	22.05	29-Mar-11	06.36	Over Voltage
400KV	Kolhapur - Mapusa - II	28-Mar-11	22.10	29-Mar-11	10.02	Over Voltage
400KV	Newkoyna - Jaigad - I	28-Mar-11	15.32	28-Mar-11	18.23	Insulator washing
400KV	Dhule-Sar'Sarovar - I	28-Mar-11	15.09	30-Mar-11	06.39	Over Voltage
400KV	400/220 KV 315 MVA ICT- III @ Lonikand.	28-Mar-11	11.08	31-Mar-11	10.33	Breaker O/H work,HV side on TBC
400KV	Bhusawal- Aurangabad	28-Mar-11	23.10	29-Mar-11	04.20	Over Voltage
400KV	Akola - Wardha - II	28-Mar-11	23.05	29-Mar-11	10.47	Over Voltage
400KV	Chandrapur - Parli - III	28-Mar-11	17.21	28-Mar-11	17.42	For withdrawal of Line Reactor
400KV	Akola - Aurangabad- II	28-Mar-11	12.08	28-Mar-11	20.14	R.M.work (Line on Tie Breaker)
400KV	50 MVAR Reactor of Parli-Chandrapur - III	28-Mar-11	07.21	1-Apr-11	17.51	Oil Filtration Work.
400KV	400/220KV 315MVA ICT- I @ Kharghar	29-Mar-11	07.21	29-Mar-11	20.30	Breaker Maint. & R.M.Work.
400KV	Newkoyna - Jaigad - I	29-Mar-11	05.28	29-Mar-11	06.09	Distance Protection
400KV	Lonikand - Parli - I	29-Mar-11	17.25	29-Mar-11	18.01	Distance Protection.
400KV	Bhusawal- Aurangabad	29-Mar-11	22.27	30-Mar-11	03.28	Over Voltage.
400KV	Karad - Kolhapur - II	30-Mar-11	00.08	30-Mar-11	09.03	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	30-Mar-11	01.22	30-Mar-11	12.43	Over Voltage.
400KV	Dhule-S'Sarovar I	30-Mar-11	17.44	31-Mar-11	07.24	Over Voltage.
400KV	Bhusawal- Aurangabad	30-Mar-11	21.48	31-Mar-11	05.36	Over Voltage.
400KV	Karad - Kolhapur - I	30-Mar-11	21.56	31-Mar-11	07.21	Over Voltage.
400KV	Akola - Wardha - I	31-Mar-11	00.33	31-Mar-11	07.08	Over Voltage.
400KV	Newkoyna - Jaigad - I	31-Mar-11	05.12	31-Mar-11	18.20	Distance Protection,R Ph.Z-I,Declared Faulty.
400KV	Dhule-Sar'Sarovar - II	31-Mar-11	00.04	2-Apr-11	08.29	Over Voltage.
400KV	400/220 KV 315 MVA ICT-II @ Lonikand	31-Mar-11	07.10	31-Mar-11	11.31	Replacement of O T & W T Meter
400KV	Lonikand-Kalwa	31-Mar-11	07.51	31-Mar-11	18.59	Replacement of Insulator.
400KV	New Koyna - Jaigad - II	31-Mar-11	06.37	31-Mar-11	07.20	Distance Protection.
400KV	Koradi - Bhusawal	31-Mar-11	06.55	31-Mar-11	07.42	Distance Protection.
400KV	Main Bus- I @ Jejuri	31-Mar-11	14.40	31-Mar-11	21.02	Connecting New Parvati & Phursungi Bay.
400KV	400/220 KV 315 MVA ICT - II @ Solapur P G	31-Mar-11	18.06	31-Mar-11	18.06	Kept on Humming (No Load).
400KV	Kolhapur - Mapusa - I	31-Mar-11	23.42	1-Apr-11	08.29	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	31-Mar-11	23.45	1-Apr-11	10.55	Over Voltage.
400KV	Akola - Wardha - II	1-Apr-11	00.04	1-Apr-11	08.39	Over Voltage.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	1-Apr-11	04.36	1-Apr-11	05.20	Bus Bar Protection Operated.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	1-Apr-11	04.36	1-Apr-11	05.29	Bus Bar Protection Operated.
400KV	400/220KV,500MVA ICT-III At Kalwa.	1-Apr-11	04.36	2-Apr-11	06.52	Y Ph C T Burst of ICT-III.
400KV	Newkoyna - Jaigad - I	1-Apr-11	09.41	1-Apr-11	17.42	Insulator Washing Work.
400KV	Kalwa - Lonikand	1-Apr-11	04.36	1-Apr-11	06.24	Bus fault at 400 KV Kalwa
400KV	400/220KV,315MVA ICT-I at Karad	1-Apr-11	11.59	1-Apr-11	15.16	B Ph L V Side C T Red Hot.
400KV	Dabhol-Nagothane - II	1-Apr-11	13.20	1-Apr-11	13.59	Distance Protection.
400KV	Chandrapur - Parli - III	1-Apr-11	17.09	1-Apr-11	17.51	To Take Reactor in Service.
400KV	Koradi-Bhilai	1-Apr-11	19.06	2-Apr-11	14.22	R Ph ICT Leakage.

400KV	Dhule-Sar'Sarovar - I	1-Apr-11	23.34	3-Apr-11	08.47	Over Voltage.
400KV	Kolhapur - Mapusa - II	1-Apr-11	23.31	2-Apr-11	08.48	Over Voltage.
400KV	Bhusawal- Aurangabad	1-Apr-11	21.38	2-Apr-11	07.13	Over Voltage.(Taken on TBC)
400KV	Bus Coupler @ Bhusawal	1-Apr-11	22.02	1-Apr-11	22.37	B/B Prot.For Bus-II Operated.
400KV	440/220 KV 315 MVA ICT @ Bhusawal II	1-Apr-11	22.02	1-Apr-11	22.40	B/B Prot.For Bus-II Operated.
400KV	400/132KV 200 MVA ICT- I @ Bhusawal	1-Apr-11	22.02	1-Apr-11	22.41	B/B Prot.For Bus-II Operated.
400KV	Koradi - Bhusawal	1-Apr-11	22.02	1-Apr-11	22.42	B/B Prot.For Bus-II Operated.
400KV	Own breaker of Akola-Aurangabad-II	1-Apr-11	11.49	1-Apr-11	21.34	To attend Trip Ckt Faulty Alarm(Line on Tie Breaker)
400KV	Bhusawal- Aurangabad	2-Apr-11	20.12	3-Apr-11	06.15	Over Voltage
400KV	Akola - Wardha - I	2-Apr-11	20.32	3-Apr-11	08.48	Over Voltage.
400KV	Kolhapur - Mapusa - I	2-Apr-11	20.38	3-Apr-11	08.50	Over Voltage.
400KV	Babaleshwar - Bhusawal	2-Apr-11	16.16	2-Apr-11	16.45	Distance protection.
400KV	Dhule-Sar'Sarovar - II	2-Apr-11	21.56		Continued.	Over Voltage.
400KV	Karad - Kolhapur - II	2-Apr-11	22.03	3-Apr-11	07.29	Over Voltage
400KV	New Koyna-Jaigad II	3-Apr-11	10.32	3-Apr-11	19.42	Line Insulator cleaning
400KV	Bhusawal- Aurangabad	3-Apr-11	21.48	4-Apr-11	05.45	Over Voltage
400KV	Kolhapur-Mapusa-II	3-Apr-11	22.00		Continued.	Over Voltage
400KV	Newkoyna - Jaigad - I	3-Apr-11	14.33	3-Apr-11	14.35	PLCC Communication Problem
220KV	Borivali-Mulund	6-Feb-11	22.17	31-Mar-11	14.30	From Borivali end for strengthing Mumbai system up to 30.03.11
220KV	220/100KV 125 MVA ICT-II @ Kalwa	28-Feb-11	11.10	1-Apr-11	18.32	Augmetation to 200 MVA
220KV	Chandrapur-Warora - I	11-Mar-11	21.53	30-Mar-11	14.47	To control Warora-Hinganghat loading.
220KV	220/100 KV 125MVA ICT-II @ Borivali	19-Mar-11	09.30	1-Apr-11	17.40	Augmentation by 200MVA.
220KV	220/132 KV100 MVA ICT-I @ Chalisgaon	19-Mar-11	14.26	1-Apr-11	11.12	Augmentation from 100 to 200 MVA ICT
220KV	Main Bus Section-I at Wathar	28-Mar-11	09.45	28-Mar-11	12.45	To attend Hot Spot
220KV	Wadhkal-Ispat II	28-Mar-11	10.16	28-Mar-11	12.07	Testing work
220KV	Pedambe - Karad	28-Mar-11	06.22	28-Mar-11	20.20	Bus Section-II outage at Pedambe
220KV	Pedambe-Kharepatan	28-Mar-11	06.26	28-Mar-11	15.40	Bus Section-II outage at Pedambe
220KV	Pedambe-Tambati	28-Mar-11	06.57	28-Mar-11	15.55	Bus Section-II outage at Pedambe
220KV	Pedambe - Pophali	28-Mar-11	06.57	28-Mar-11	18.00	Bus Section-II outage at Pedambe
220KV	Main Bus Section-II at Pedambe	28-Mar-11	06.57	28-Mar-11	15.12	Main Bus side Isolator O/H work .
220KV	Akola - Badnera - II	28-Mar-11	08.13	28-Mar-11	12.28	Replacement of Broken Disc
220KV	New Paras TPS - Chikhali - II	28-Mar-11	13.56	28-Mar-11	18.06	Jumpering work of New Bus
220KV	220/132KV 200 MVA ICT- II @ Chikhali	28-Mar-11	13.56	28-Mar-11	17.52	Jumpering work of New Bus
220KV	Main Bus Section-II at Chikhali	28-Mar-11	14.00	28-Mar-11	17.52	Jumpering work of New Bus
220KV	Hingoli-Pusad	28-Mar-11	06.17		Continued.	To control Load on Wardha-Yavatmal line
220KV	220/132 KV,100 MVA ICT At Hinganghat	28-Mar-11	11.45	28-Mar-11	14.32	To attend Oil Leakage
220KV	Aurangabad-Shendra	28-Mar-11	14.05	28-Mar-11	16.30	Alignment work of Isolators
220KV	Karad-Mudsingi-IV	28-Mar-11	23.18	29-Mar-11	12.05	To attend SF6 Gas Leakage
220KV	Apta-Uran-II	29-Mar-11	14.57	29-Mar-11	17.33	Relay Testing Work.
220KV	Kolhapur-Karad-IV	29-Mar-11	09.32	29-Mar-11	12.05	Line Taken on TBC @ Karad To Attend SF6 Leakage Problem.
220KV	220/110KV 100MVA T/F- I @ Miraj	29-Mar-11	10.05	29-Mar-11	12.21	Q.M.Work.
220KV	220/100KV 100 MVA T/F- I @ Tambati	29-Mar-11	10.43	29-Mar-11	18.20	Red Hot Attending Work.
220KV	Tifli-Trombay	29-Mar-11	11.36	29-Mar-11	14.36	Red Hot Attending Work.
220KV	Aarey-Versova-I	29-Mar-11	13.00	29-Mar-11	15.55	Earth Wire Stringing Work.
220KV	220 A Bus @ Nagothane	29-Mar-11	10.55	29-Mar-11	23.16	For Stringing Jack Bus,Bus Isolator Jumpering Work.
220KV	220/132 KV 200 MVA ICT - II @ Bhusawal	29-Mar-11	07.50		Continued.	Replacement of Isolators,ICT on TBC.Upto 05.04.2011.
220KV	Karad-Wathar	30-Mar-11	05.14	30-Mar-11	14.58	Distance Protection.
220KV	Kalmeshwar - Pandurna	30-Mar-11	12.15	30-Mar-11	12.43	Distance protection.
220KV	Kalmeshwar - Pandurna	30-Mar-11	12.50	30-Mar-11	17.05	Distance protection.
220KV	Warora - Wardha Power - II	30-Mar-11	13.04	30-Mar-11	13.27	Bus bar protection operatd at WPCL end.

220KV	Warora-Wardha	30-Mar-11	13.04	30-Mar-11	14.25	Bus Bar protection operated at WPCL end.
220KV	Lonikand-Khadki	31-Mar-11	09.02	31-Mar-11	19.54	To Make LILO @ VSNL S/S.
220KV	Kandalgaon - Dasturi	31-Mar-11	09.01	31-Mar-11	20.25	Replacement of L A, C C & W T.
220KV	Ghodbandar-Varsowa	31-Mar-11	06.34	31-Mar-11	16.42	LILO Work @ 220KV Wror S/S.
220KV	Karad Mudsingi-II	31-Mar-11	09.43	31-Mar-11	18.37	Fixing of C C & W T.
220KV	BombayDyeing - Sahara	31-Mar-11	11.40	31-Mar-11	19.45	Replacement of E/W.
220KV	Talangade - Mumewadi	31-Mar-11	18.18	31-Mar-11	18.39	Distance Protection.
220KV	Bhosari-Telco	31-Mar-11	13.14	31-Mar-11	14.52	Attending Comperssor Problem.
220KV	Bhosari-Telco	31-Mar-11	15.17	31-Mar-11	20.10	To Reduce Load on Lnknd Bhosari.
220KV	Phursungi - Theur	31-Mar-11	15.00	31-Mar-11	20.27	To Control Lnknd ICT Loading.
220KV	Bus Sectionlizer @ Apta	31-Mar-11	15.55	31-Mar-11	16.55	Connecting Tripping Wire of Bus Bar Protection.
220KV	Hingoli-Pusad	31-Mar-11	12.05	31-Mar-11	17.00	Replacement of Relays.Ckt is Already H/T since 28.03.2011.
220KV	Badnera - Akola - I	31-Mar-11	05.02	31-Mar-11	06.34	To Attend Main CB Air Compressor Problem Ckt was Taken on TBC.
220KV	220/7 KV 20 MVA Stn.T/F-II at Korady	31-Mar-11	10.47		Continued.	Oil Leakage.
220KV	Kalwa-Ghatghar	1-Apr-11	04.36	1-Apr-11	05.36	Bus Fault at 400KV Kalwa
220KV	Kalwa - Tifil	1-Apr-11	04.36	1-Apr-11	05.35	Bus Fault at 400KV Kalwa
220KV	Kalwa - Salshet - III	1-Apr-11	04.36	1-Apr-11	05.24	Bus fault at 400 KV Kalwa
220KV	Kalwa-Colourchem	1-Apr-11	04.36	1-Apr-11	05.35	Bus Fault at 400KV Kalwa
220KV	Kalwa - Salshet - IV	1-Apr-11	04.36	1-Apr-11	05.25	Bus fault at 400 KV Kalwa
220KV	Trombay-Kalwa	1-Apr-11	04.36	1-Apr-11	05.50	Bus Fault at 400KV Kalwa
220KV	Kalwa-Mulund II	1-Apr-11	04.36	1-Apr-11	05.27	Bus fault at 400 KV Kalwa
220KV	Kalwa-Mulund-I	1-Apr-11	04.36	1-Apr-11	05.28	Bus fault at 400 KV Kalwa
220KV	Kalwa - Borivali	1-Apr-11	04.36	1-Apr-11	05.29	Bus Fault at 400KV Kalwa
220KV	220 KV Interconnector @ Kalwa	1-Apr-11	04.36	1-Apr-11	05.33	Bus fault at 400 KV Kalwa
220KV	Kalwa-Mahape	1-Apr-11	04.36	1-Apr-11	05.30	Bus Fault at 400KV Kalwa
220KV	Phursungi - Theur	1-Apr-11	11.48	1-Apr-11	14.25	C T Tan Delta Work.
220KV	Khargar-Topworth	1-Apr-11	08.50	1-Apr-11	20.11	E/W Replacement Work.
220KV	Kandalgaon - ONGC	1-Apr-11	08.30	1-Apr-11	19.16	E/W Replacement.
220KV	220/132 KV 100 MVA T/F - I @ Jambul	1-Apr-11	11.15	1-Apr-11	15.28	C T Oil Leakage.
220KV	Khaparkheda - Kanhan - II	1-Apr-11	07.25	1-Apr-11	19.16	Replacement of E/W.
220KV	Hinjawadi-I - Hinjawadi-II	1-Apr-11	23.15	2-Apr-11	07.30	To attend hot spot.
220KV	Pawas-Kharepatan	2-Apr-11	04.40	2-Apr-11	04.59	O/C & E/F Protection
220KV	220 KV Bus Coupler @ New Koyna	2-Apr-11	04.18	2-Apr-11	04.52	O/C & E/F Protection Opearated.
220KV	New Koyna - Pawas	2-Apr-11	04.18	2-Apr-11	05.00	Distance Protection
220KV	Bus section - I @ Pawas	2-Apr-11	12.17	2-Apr-11	14.44	T attend red hot on Y ph.insulator string.
220KV	BBLSR-Waluj	2-Apr-11	08.42		23.00	To control ICT load.
220KV	BBLSR-Waluj-I	2-Apr-11	20.32	3-Apr-11	10.54	Over Voltage.
220KV	Parli Ext.-Nanded	3-Apr-11	01.50	3-Apr-11	02.16	Distance protection.
220KV	Borivali -Tarapur	3-Apr-11	09.10		Continued.	LILO work of 220KV Borivali-Boilsrer at 220KV Ghodbandar.
220KV	Khargar-Topworth	3-Apr-11	08.32	3-Apr-11	20.31	E/W replacement
220KV	Kharghar-TSS	3-Apr-11	08.57	3-Apr-11	20.10	E/W replacement
220KV	Borivali-Boisar	3-Apr-11	09.48		Continued.	LILO work of 220KV Borivali-Bhoisor at 220KV Ghodbandar
220KV	Kalwa I-Taloja	3-Apr-11	19.25	3-Apr-11	22.55	Red Hot on R phase Wave Trap
220KV	New Parli-Nanded	3-Apr-11	01.50	3-Apr-11	02.16	Distance Protection
220KV	220/100KV 200MVA ICT-III at Kalwa	3-Apr-11	16.00		Continued.	Buchholz Trip,Diff.Prot.operated,PRV tripped
132KV	Paras-Malkapur	28-Mar-11	10.00	28-Mar-11	12.08	To attend Hot Glow on Line side Isolator
132KV	Amravati - Tiwsa	28-Mar-11	11.10	28-Mar-11	13.14	Distance Protection
132KV	Jaina - GAPS	28-Mar-11	08.50	28-Mar-11	18.20	LILO arrangement for 132KV Badnapur
132KV	Main Bus at Amravati	28-Mar-11	12.20	28-Mar-11	14.05	To attend Hot Glow on Bus Side Isolator
132KV	Dhule-Dondaicha	31-Mar-11	14.40	2-Apr-11	12.35	132KV Line Side Isolator Replacement Work
132KV	Parbhani-Purna	31-Mar-11	10.30	31-Mar-11	15.52	132KV Purna Line LILO for Basmat S/S Stringing @ Loc. 76 to 79.
132KV	Peth-Sirla	1-Apr-11	06.35	1-Apr-11	07.07	Distance Protection.
132KV	Peth-Walagaon	1-Apr-11	06.35	1-Apr-11	07.44	Distance Protection.
132KV	Amravati - Akola	1-Apr-11	17.17	1-Apr-11	17.28	Distance Protection.
132KV	Chalisgaon - Kannad	3-Apr-11	16.16	3-Apr-11	16.20	FTR Protection operated
132KV	Paras - Akot	3-Apr-11	16.58	3-Apr-11	17.13	Distance Protection
132KV	Achalpur - Anjangaon	3-Apr-11	16.58	3-Apr-11	17.23	Backup Protection operated