

LINE OUTAGES FOR THE WEEK

FROM 30-Apr-12 TO 6-May-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	Chandrapur-Padaghe Pole - II	1-May-12	08.30	1-May-12	22.17	Attending Oil Leakage in R & B Ph. Convartor X'mer.
400KV	Deepnagar-Aurangabad-I	11-Apr-12	16.03	4-May-12	15:54	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	25-Apr-12	18.11	5-May-12	09.39	Over Voltage.
400KV	Bhusawal- Aurangabad	28-Apr-12	17.33	30-Apr-12	06.38	Over Voltage
400KV	Chandrapur - Bhadravati - III	29-Apr-12	18.04	5-May-12	13.07	Over Voltage
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	30-Apr-12	08.08	30-Apr-12	18.12	Q.M.Work.
400KV	Bableswhar-Aurangabad	30-Apr-12	10.11	30-Apr-12	18.53	R Ph. C V T Replacement.
400KV	Chandrapur - Parli - I	30-Apr-12	17.04	30-Apr-12	17.53	Distance Protection.
400KV	Bhusawal- Aurangabad	30-Apr-12	18.13	1-May-12	10.19	Over Voltage.
400KV	Nagothane-Dabhol-I	1-May-12	04.11	2-May-12	12.09	Distance Protection,Declared Faulty.
400KV	Bhusawal- Aurangabad	1-May-12	13.04	2-May-12	09.25	Over Voltage.
400KV	Kolhapur - Mapusa - I	1-May-12	16.13	2-May-12	09.20	Over Voltage.
400KV	New Koyna - Jaigad - II	1-May-12	09.48	1-May-12	16.16	Cold Line Insulator Washing.
400KV	400/220 KV 315 MVA ICT- I @ Nagothane	1-May-12	09.56	1-May-12	19.55	Replacement of Old WTI & OTI Meter.
400KV	400/220 KV 315MVA ICT-II @ Karad	1-May-12	11.06	1-May-12	19.22	Installation Commissioning of ER Make Relay.
400KV	Kolhapur - Mapusa - I	2-May-12	18.37	3-May-12	09.33	Over Voltage.
400KV	Dhule - Babhaleshwar - I	2-May-12	08.12	2-May-12	08.52	Due to Sparking on B Ph. Isolator.
400KV	Karad-Jaigad II	2-May-12	15.29	3-May-12	06.30	Cold Line Insulator Washing.
400KV	Dabhol - New Koyna - I	2-May-12	15.16	2-May-12	22.22	Replacement of Flashover String.
400KV	Newkoyna - Jaigad - I	2-May-12	09.24	2-May-12	14.53	Cold Line Insulator Washing.
400KV	Chandrapur - Parli - I	2-May-12	13.36	2-May-12	14.29	Distance Protection.
400KV	Chandrapur - Parli - I	2-May-12	15.48	2-May-12	16.41	Distance Protection.
400KV	Main Bus - I @ Chandrapur	2-May-12	09.57	2-May-12	21.52	Replacement of Y Ph.Bus CVT.
400KV	Lonikand - Parli - II	3-May-12	08.43	3-May-12	18.49	Line reactor isolator erection, jumpering and commissioning of reactor.
400KV	Karad - Lonikand	3-May-12	12.14	3-May-12	14.20	For taking TCSR 80 MVAR reactor in service.
400KV	Chandrapur - Parli - I	3-May-12	12.37	3-May-12	19.48	Distance protection.
400KV	Bhusawal- Aurangabad	3-May-12	17.08	4-May-12	08:10	Over Voltage.
400KV	Kolhapur-Mapusa-II	3-May-12	20.48	4-May-12	09:06	Over Voltage.
400KV	Tie Breaker at Akola	3-May-12	10.11	3-May-12	14.24	R.M.work and Testing work.
400KV	Bablswr-Padgha Ckt I	4-May-12	03.16	4-May-12	03.35	Distance protection operated at BBLSR end.
400KV	Chandrapur - Parli - I	4-May-12	14.32	4-May-12	15.23	Distance protection.
400KV	Chandrapur - Parli - I	4-May-12	16.37	5-May-12	06:46	Distance protection.
400KV	Kolhapur - Mapusa - I	4-May-12	17.08	5-May-12	09.13	Over Voltage.
400KV	Aurangabad-Deepnagar-II	4-May-12	20.39		Continued.	Over Voltage.
400KV	Main Bus- I @ Nagothane	4-May-12	12.53	4-May-12	21.00	R.M.Work
400KV	Akola - Aurangabad- II	4-May-12	10.34	4-May-12	23.04	To sort out problem of unbalance in bus bar relay.
400KV	Aus.Bus at Koradi	4-May-12	10:01	4-May-12	16:10	For erection of IPS tube for new 400 kv K'Kheda bay.
400KV	400/220KV 500MVA ICT- I at Khaperkheda	4-May-12	22:37	5-May-12	03:21	Inverse over current earth fault.
400KV	400/220 KV 500 MVA ICT - II at Khaparkhe	4-May-12	22:38	5-May-12	02:35	Inverse over current earth fault.
400KV	Bhusawal- Aurangabad	5-May-12	03:56	5-May-12	08.00	Over Voltage.
400KV	Dhule - Babaleshwar - II	5-May-12	08.25	5-May-12	17.12	Replacement of Y ph.CVT.
400KV	400/220KV, 315MVA ICT-I @ New Koyna.	5-May-12	09.16	5-May-12	12.33	Hot spot.
400KV	Chandrapur - Parli - I	5-May-12	11.08	5-May-12	13.10	Tree cutting work.
400KV	Chandrapur - Bhadravati - III	5-May-12	17.53		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	5-May-12	17.51		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - I	5-May-12	21.53	6-May-12	10.31	Over Voltage.
400KV	Bhusawal- Aurangabad	5-May-12	21.48	6-May-12	06.20	Over Voltage.
400KV	Koradi - Bhusawal	6-May-12	13.08	6-May-12	13.22	Distance Protection

400KV	Kolhapur - Mapusa - II	6-May-12	18.03		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	6-May-12	21.50		Continued.	Over Voltage
220KV	Pawas-Kharepatan	30-Apr-12	09.39	30-Apr-12	17.07	Cold Washing of Insulator.
220KV	Boisor-Versova	30-Apr-12	10.24	30-Apr-12	15.02	Hot Spot.
220KV	Nasik-Navsari-I	30-Apr-12	08.11	30-Apr-12	18.52	Maintenance Work.
220KV	Junction Breaker @ Pophali	30-Apr-12	10.20	30-Apr-12	17.55	Preventive Maintenance Work.
220KV	Chandrapur-Warora	1-May-12	04.03	1-May-12	12.26	To Control Line Loading.
220KV	Nasik-Navsari-I	1-May-12	07.55	1-May-12	18.05	Maintenance Work.
220KV	Vita-Mhaisal	1-May-12	08.51	1-May-12	19.15	Stringing of 400KV Solapur-Kolhapur Crossing Line.
220KV	Miraj - Mhaisal	1-May-12	08.40	1-May-12	19.20	Stringing of 400KV Solapur-Kolhapur Crossing Line.
220KV	Kalwa - Salshet - III	1-May-12	09.01	1-May-12	18.16	C T Replacement Work.
220KV	Dahanu-Versova	1-May-12	16.36	1-May-12	16.37	Replacement of String Insulator.
220KV	Padgha-Temghar I	2-May-12	20.34		Continued.	To Control Load on ICT @ Padgha.
220KV	Nasik-Navsari-I	2-May-12	08.50	2-May-12	17.52	R.M.Work.
220KV	Uran-Apta-II	2-May-12	10.52	2-May-12	20.08	Bus Bar Protection Work.
220KV	Pawas-Kharepatan	2-May-12	11.14	2-May-12	16.30	Insulator Replacement Work.
220KV	Koradi-Ambazari-I	2-May-12	08.02	2-May-12	12.13	Dismantling of Old Aux.Isolator.
220KV	220/132 KV,200 MVA ICT-II At Chalisgaon	2-May-12	10.21	2-May-12	11.51	CRM Measurement.
220KV	220/132 KV 200 MVA ICT- II @ Kalmeshwar	2-May-12	09.54	2-May-12	18.42	Quarterly Maintainance Work.
220KV	Main Bus Section - II @ Gadchiroli	2-May-12	07.17	2-May-12	12.27	M.B. Iso. Work.
220KV	Lonand - Baramati	3-May-12	08.28	4-May-12	19:58	Breaker replacement work.
220KV	Babaleshwar - Ranjangaon	3-May-12	07.30	4-May-12	00.32	Replacement of R and Y ph.CT.
220KV	220/132 KV 150 MVA ICT- II @ Nasik	3-May-12	09.02	3-May-12	17.00	Bay maintenance and tan delta of HV and LV CT.
220KV	Jejuri (New) - Phursungi - II	3-May-12	09.32	3-May-12	18.02	Maintenance work.
220KV	Uran-ONGC	3-May-12	09.56	3-May-12	16.55	R.M.Work
220KV	Uran - HOCL	3-May-12	10.01	3-May-12	17:41	Hot Spot.
220KV	Wadkhal-IPCL I	3-May-12	08.52	3-May-12	15.32	R.M.Work
220KV	Wadkhal-IPCL-II	3-May-12	15.44	3-May-12	17.50	R.M.Work
220KV	220/132 KV 200 MVA ICT- II @ Boiser	3-May-12	09.49	3-May-12	17.42	Differential protection.
220KV	NASIK-NAVSARI-II	3-May-12	08.37	3-May-12	18.16	Insulator washing.
220KV	Nasik-Navsari-I	3-May-12	10.39	3-May-12	10.45	Distance protection.
220KV	NASIK-NAVSARI-II	4-May-12	08.43	4-May-12	18.05	Water washing of insulator replacement.
220KV	Padgha-Jambhul-I	4-May-12	09:21	4-May-12	17:19	R. M. Work.
220KV	Uran - Nerul	4-May-12	09:37	4-May-12	18:31	For taking 2nd trip coil in service and bay main. work.
220KV	Wathar - Mudshingi	4-May-12	10.00	4-May-12	18.11	Q.M.Work
220KV	Uran - JNPT	4-May-12	11.58	4-May-12	18.02	R.M.Work
220KV	Inter Connector @ Kalwa	4-May-12	08.50	4-May-12	17.51	Replacement of 3 Nos.of C.T.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	4-May-12	10.42	4-May-12	17.34	To attend red hot spot and tan delta testing work of CT.
220KV	Chalisgaon - Malegaon	4-May-12	08:40	4-May-12	11:14	To attend red hot on Y ph line isolator.
220KV	Dhule - Malegaon	4-May-12	11:28	4-May-12	17:57	Connecting interconnector to new 220 kv switchyard.
220KV	New Paras TPS-Alola-II	4-May-12	08:24	4-May-12	12:28	Quarterly Maintainance work.
220KV	Khaparkheda - Kanhan - I	4-May-12	11:59	4-May-12	19:02	Distance Protection Operated Zone 1 R & Y ph.
220KV	Lonikand-Ranjangaon	4-May-12	22:54	5-May-12	06:51	To control 400 KV Parly - Lonikand line loading.
220KV	Kalmeshwar-Kaparkheda	4-May-12	22:04	4-May-12	23:05	Distance Protection Operated Zone 1 B ph.
220KV	220/132KV 200MVA ICT-II at BBLSR	5-May-12	08.00	5-May-12	16.20	Q.M.Work
220KV	Malegaon - Satana - I	5-May-12	10.30	5-May-12	13.29	Insulator replacement.
220KV	220/132KV 100 MVA ICT- III @ Nasik OCR	5-May-12	08.19	5-May-12	16.37	Transormer bushing maintenance.
220KV	220/132 KV,200 MVA ICT-I at Eklahare	5-May-12	08.28	5-May-12	14.15	Tan delta measurement of C.T.
220KV	Lonikand-Kathapur	5-May-12	09.10	5-May-12	19.31	Replacement of vibration damper.

220KV	Trombay Sonkhar	5-May-12	10.03	5-May-12	14.34	Bolt tightening.
220KV	220/66 KV 150 MVA ICT- I @ Gadchandur	5-May-12	10.26	5-May-12	19.12	CTR fire protection system work.
220KV	Nasik-Navsari -II	6-May-12	07.31	6-May-12	14.34	Maint.work
220KV	Padghe - Nashik - II	6-May-12	18.30	6-May-12	19.02	Distance Protection
220KV	Bus-Section - II @ Trombay	6-May-12	08.46	6-May-12	18.22	Hot Spot
220KV	Chakan-Volkaswagon	6-May-12	09.01	6-May-12	14.31	Replacement of CT
220KV	220/100KV,200 MVA ICT-II at Trombay.	6-May-12	08.41	6-May-12	15.22	Attending Hot Spot of Main Bus,T Clamp of Tifil feeder
132KV	Pench - Kanhan	3-May-12	11.18	3-May-12	15.36	R.M.Work
132KV	Malkapur-Motala	3-May-12	11.20	5-May-12	15.02	Repl. of bus side isolator.
132KV	Hingna I - Mankapur CKT.	4-May-12	22.36	4-May-12	23:14	Distance Protection operated Zone 1 R ph.
132KV	Kanhan-Uppalwadi	5-May-12	19.54	6-May-12	14.27	Attending sparking on 132 KV Ambazari-Mankapur-II line isolator.
132KV	Parbhani-Jintur	6-May-12	14.05	6-May-12	14.17	Distance Protection
100KV	Creek side Bus at Kalwa	4-May-12	05:55	4-May-12	17:42	Convorsion of old bus conductor with twin bus conductor.