

LINE OUTAGES FOR THE WEEK

FROM 7-Jun-10 TO 13-Jun-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Akola - Aurangabad - I	9-Apr-10	13.00	4-Jun-10	17.14	To control Aurangabad ICT loading.
400KV	Wardha - Akola - II	29-Apr-10	11.37	5-Jun-10	15.52	Due to line loading.
400KV	Bhusawal- Aurangabad	24-May-10	18.01	31-May-10	07.29	For BBLR-A'bad outage.
400KV	Dhule-Sar'Sarovar - II	24-May-10	23.34	2-Jun-10	09.33	For Over Voltage.
400KV	400/220 KV,315 MVA ICT-I at Parly.	29-May-10	22.22	11-Jun-10	17.20	ICT Charged with LV Side on TBC due to PDR Problem.
400KV	Bableshtar-Aurangabad	31-May-10	07.35	1-Jun-10	04.28	Replacement of disc insulator string.
400KV	C'pur-Parli II	31-May-10	07.41	1-Jun-10	04.41	Replacement of faulty disc insulator.
400KV	Bhusawal- Aurangabad	1-Jun-10	04.11	3-Jun-10	09.53	H/T for O/V.
400KV	C'pur-Parli CKT .I	1-Jun-10	07.00	1-Jun-10	18.43	Replacement of faulty disc insulator string.
400KV	Karad-Kolhapur CKT I	1-Jun-10	09.42	1-Jun-10	19.43	Replacement of faulty disc insulator string.
400KV	Kalwa-Padgha CKT I	1-Jun-10	09.50	1-Jun-10	12.22	Contact resistance and timing measurement,(line on TBC)
400KV	Main B Bus at Chakan	1-Jun-10	14.06	1-Jun-10	16.42	Isolator alignment.
400KV	Karad-Kolhapur CKT I	2-Jun-10	09.08	2-Jun-10	19.17	Replacement of faulty disc insulator.
400KV	400/220 KV,600 MVA ICT-II at Kalwa	2-Jun-10	01.04	2-Jun-10	01.59	Tripped on NDR.
400KV	Chandrapur-Bhadravti - I	2-Jun-10	00.19	2-Jun-10	12.40	H/T For O/V.
400KV	Kolhapur-Mapusa Ckt I	2-Jun-10	01.34	2-Jun-10	09.01	H/T for O/V.
400KV	Dhule-S'Sarovar I	2-Jun-10	01.31	3-Jun-10	14.08	H/T for O/V.
400KV	C'pur-Parli CKT .I	2-Jun-10	08.23	2-Jun-10	18.42	Repl of faulty disc insulator,
400KV	400/220KV, 500MVA ICT at Lamboti	2-Jun-10	10.22	2-Jun-10	18.28	ICT-II,jumpering work.
400KV	Chandrapur-Khaparkheda	3-Jun-10	01.08	3-Jun-10	18.03	Tripped
400KV	Babaleshtar-Bhusawal	3-Jun-10	07.44	3-Jun-10	20.05	Replacement of 400KV CT
400KV	Padgha - Chakan	3-Jun-10	08.21	3-Jun-10	18.32	Replacement of Insulator work
400KV	Karad-Kolhapur CKT I	3-Jun-10	09.05	3-Jun-10	18.33	Replacement of Faulty Disc Insulator
400KV	Koradi-Akola	3-Jun-10	17.07	3-Jun-10	22.11	Tripped
400KV	Dhule-Bblswr-II	3-Jun-10	17.40	3-Jun-10	18.14	Distance protection
400KV	400/220 KV, 500 MVA ICT - II at Jejuri	3-Jun-10	00.53	3-Jun-10	06.09	404-29 T Isolator Alignment work
400KV	Padgha-Tarapur CKT I	3-Jun-10	14.33	3-Jun-10	15.03	Breaker problem , taken on TBC
400KV	Bhusawal- Aurangabad	3-Jun-10	20.06	4-Jun-10	04.40	Over Voltage
400KV	Dhule-Sar'Sarovar - I	3-Jun-10	18.08	8-Jun-10	12.15	Over Voltage
400KV	Main Bus-I at Jejuri	3-Jun-10	12.11	3-Jun-10	17.03	Maintenance work
400KV	Bableshtar-Aurangabad	3-Jun-10	23.07	4-Jun-10	00.10	Ckt on TBC for attending Red Hot Spot on Main Breaker Clamp.
400KV	Chandrapur-Khaparkheda	4-Jun-10	00.19	4-Jun-10	10.52	Over Voltage
400KV	Bableshtar-Aurangabad	4-Jun-10	04.38	5-Jun-10	17.33	Replacement of Faulty Disc Insulator String
400KV	Kalwa-Padgha CKT I	4-Jun-10	09.00	4-Jun-10	18.20	Replacement of B phase LA
400KV	400/220KV 315MVA ICT at Akola.	4-Jun-10	12.30	4-Jun-10	14.56	Testing work
400KV	400/220KV 315 MVA ICT-I at padgha	4-Jun-10	08.30	4-Jun-10	19.35	Maintenance work
400KV	Chandrapur-Khaparkheda	4-Jun-10	18.10	5-Jun-10	11.00	Over Voltage
400KV	Akola-Aurangabad--II	4-Jun-10	17.13	5-Jun-10	09.37	To control A'Bad ICT Loading
400KV	Chandrapur-Parli -I	4-Jun-10	06.27	5-Jun-10	04.59	Replacement of Disc Insulator
400KV	400/220 KV,105 MVA Spare ICT at Akola.	4-Jun-10	09.55	4-Jun-10	15.35	Premansoon Maint.Work
400KV	Kolhapur-Mapusa Ckt I	5-Jun-10	00.07	5-Jun-10	07.35	Over Voltage
400KV	Dhule-Sar'Sarovar - II	5-Jun-10	00.50	5-Jun-10	09.15	Over Voltage
400KV	Akola - Aurangabad - I	5-Jun-10	09.38	7-Jun-10	17.04	Sparking in Line Reactor
400KV	Chandrapur-parli - III	5-Jun-10	07.51	5-Jun-10	21.37	Tripped on Over Voltage, Outage availed
400KV	Chandrapur - Parli - II	5-Jun-10	07.51	5-Jun-10	08.14	Over Voltage

400KV	Akola - Wardha - I	5-Jun-10	15.51		Continued.	Due to line loading
400KV	Kolhapur-Karad -I	5-Jun-10	09.16	5-Jun-10	18.25	Replacement of Faulty Disc Insulator
400KV	Kalwa - Lonikand	5-Jun-10	09.56	5-Jun-10	18.36	Replacement defective Insulator String
400KV	N.Koyna-jaigad-I	5-Jun-10	06.27	5-Jun-10	15.03	Jumper work
400KV	Bhusawal- Aurangabad	5-Jun-10	17.35	11-Jun-10	17.02	To control Waluj ICT Loading
400KV	Chandrapur - Parli - II	6-Jun-10	07.00	6-Jun-10	22.38	Replacement of Faulty Disc Insulator String
400KV	400/220 KV,600 MVA ICT-I @ Kalwa	6-Jun-10	06.58	6-Jun-10	10.41	To Wrap polythene paper to Buchloz,OLTC,PRV
400KV	400/220 KV,600 MVA ICT-I @ Kalwa	6-Jun-10	10.51	6-Jun-10	19.07	To Wrap polythene paper to Buchloz,OLTC,PRV
400KV	Dhule-Sar'Sarovar - II	6-Jun-10	23.44	7-Jun-10	09.15	Over Voltage
220KV	220/132 KV,100 MVA ICT-I At Kalmeshwar	20-Feb-10	10.34	4-Jun-10	16.04	Repl.of ICT by 200 MVA New ICT.
220KV	220/132kv 100MVA ICT-III at padegaon	12-May-10	13.30	2-Jun-10	11.27	Replacement of 100 MVA ICT By 200 MVA ICT.
220KV	Purti - Bhugaon	31-May-10	02.58	31-May-10	04.22	Tripped due to B-Ph CT of Khaparkheda ckt.burst at Purti.
220KV	Khaperkheda-Purti	31-May-10	02.58	31-May-10	18.30	B Ph CT Burst at Purti.
220KV	Talandge - Sawantwadi	31-May-10	04.17	31-May-10	15.10	Distanace Protection,Declared Faulty.
220KV	Momewadi -Halkarni	31-May-10	07.37	31-May-10	19.34	Stringing work.
220KV	Halkarni-Tillari	31-May-10	07.18	1-Jun-10	14.58	Stringing work.
220KV	Hinganghat-Bhugaon	31-May-10	11.40	31-May-10	19.07	To take A/R scheme in service.
220KV	220/22KV 50MVA T/F at Theur	1-Jun-10	03.57	1-Jun-10	05.07	Bus fault.
220KV	220/132 KV 200 MVA ICT - II at Theur	1-Jun-10	03.57		Continued.	Oil tank burst.
220KV	Karad-Wathar	1-Jun-10	04.55	1-Jun-10	12.39	Tripped on Dist.Protection.
220KV	220/132,200 MVA Tr.-I @ Theur.	1-Jun-10	03.57	1-Jun-10	16.08	Bus fault.
220KV	Lonikand-Theur - I	1-Jun-10	03.57	1-Jun-10	05.00	Bus fault.
220KV	Lonikand-Theur CKT. II	1-Jun-10	03.57	1-Jun-10	07.32	Bus fault.
220KV	Theur - Magarpatta	1-Jun-10	03.57	1-Jun-10	08.10	Bus fault.
220KV	Chinchwad-Theur	1-Jun-10	03.57	1-Jun-10	07.37	Bus fault.
220KV	Nasik-Bablsr Ckt I	1-Jun-10	17.37	1-Jun-10	19.08	Tripped on dist. protection Z-I.
220KV	Chinchwad - Hinjewadi	1-Jun-10	16.15	1-Jun-10	16.35	Tripped on dist.protection.
220KV	Babaleshwar - Nagar - I	1-Jun-10	17.30	1-Jun-10	18.51	Tripped on dist protection Z-I.
220KV	Nasik-Bablsr Ckt II	1-Jun-10	17.30	1-Jun-10	19.02	Tripped on Dist. Protection Z-I.
220KV	Dhule-Chalisgaon	1-Jun-10	19.06	1-Jun-10	19.48	Tripped on dist.protection.
220KV	Pirangut - Hinjewadi - II	1-Jun-10	16.16	1-Jun-10	17.10	Tripped on dist.protection.
220KV	Versova-Boiser	1-Jun-10	06.10	1-Jun-10	08.45	Attending Hot Spot.
220KV	Karad II-Karad I	1-Jun-10	10.00	1-Jun-10	17.30	LA Replacement.
220KV	220/100KV,100MVA ICT-IV at K'gaon	1-Jun-10	11.43	1-Jun-10	16.28	Premonsoon Maintenance work.
220KV	Vankuswadi-KDPH	1-Jun-10	11.40	1-Jun-10	17.00	Insulator replacement.
220KV	220/132 KV 200 MVA ICT-I at Harangul S/S.	1-Jun-10	07.05	1-Jun-10	11.25	Q.M.Work
220KV	Khaparkheda-Ambazari ckt - I	1-Jun-10	09.14	1-Jun-10	15.45	Q.M.Work.
220KV	220KV Bus Coupler at Khaperkheda	1-Jun-10	06.13	1-Jun-10	13.13	Measurement of Tan Delta of CT.
220KV	220KV TBC at Harangul	1-Jun-10	09.30	1-Jun-10	11.30	Q.M.Work
220KV	15.75/220KV 250 MVA G.T.I at Khaparkheda	1-Jun-10	16.23	1-Jun-10	19.30	To attend B-Ph CT jumper replacement work.
220KV	220/100 KV,200 MVA ICT-IV At Apta	1-Jun-10	10.55	1-Jun-10	16.38	Premonsoon Maintenance work.
220KV	Padgha-Boiser(PGCIL)	2-Jun-10	01.08	2-Jun-10	13.28	Tripped on Dist.Protection.
220KV	Momewadi-Halkarni	2-Jun-10	11.15	2-Jun-10	13.14	To attend heavy sparking.
220KV	Kalwa-Nasik III	2-Jun-10	08.52	2-Jun-10	18.01	Insulator replacement work.
220KV	Chandrapur-Chandrapur MIDC	2-Jun-10	12.21	2-Jun-10	12.51	Dist.Protection operated Z-1,R-Ph dist.2.5 KM.
220KV	Warora-Wardha	2-Jun-10	15.56	2-Jun-10	16.19	Dist.protection Operated.
220KV	220/132 KV,200 MVA ICT @ Bale	2-Jun-10	10.15	2-Jun-10	13.15	Testing and Q.M.Work
220KV	Jejuri - Baramati	3-Jun-10	00.24	3-Jun-10	06.15	Cold welding work of R phase CT due to oil leakage
220KV	Karad-Vita-II	3-Jun-10	10.37	3-Jun-10	10.54	Distance Protection
220KV	Kolhapur-Karad-IV	3-Jun-10	06.13	3-Jun-10	17.48	Distance Protection

220KV	Wardha - Yawatmal	3-Jun-10	07.49	3-Jun-10	08.13	Distance Protection
220KV	Pusad - Yavatmal	3-Jun-10	07.49	3-Jun-10	08.14	Distance protection
220KV	Lonikand-Khadki	3-Jun-10	06.42	3-Jun-10	13.23	Reconductoring of Span No.30,31 & 63-68
220KV	Kalwa-Nasik III	3-Jun-10	08.32	3-Jun-10	18.58	Insulator replacement work
220KV	Talangade-Ichalkaranj -II	3-Jun-10	12.30	3-Jun-10	15.59	Tan delta measurement
220KV	220/132 KV, 100 MVA -ICT @ Bale.	3-Jun-10	13.15		Continued.	Augumentation of ICT by 200MVA ICT
220KV	Theur-Jejuri	3-Jun-10	10.38	3-Jun-10	16.23	Jumpering work
220KV	Phursungi-Magarpatta	3-Jun-10	10.37	3-Jun-10	16.23	Jumpering work and LILO work
220KV	Apta-Bombay Dyeing	3-Jun-10	15.07	3-Jun-10	15.20	Gas Filling work
220KV	Main Bus at Lonand	3-Jun-10	11.56	3-Jun-10	16.00	Paralled operation of 220/132KV 200MVA ICT I&II
220KV	220/100 KV,125 MVA ICT-III at Trombay S/S.	3-Jun-10	12.38	3-Jun-10	13.43	To attend H.V.Bushing oil leakage
220KV	BBSR-Waluj	3-Jun-10	17.39	3-Jun-10	18.52	Red Hot Spot
220KV	Hinganghat-Bhugaon	3-Jun-10	12.08	3-Jun-10	13.45	Cable replacement from CT MV Box to Panel
220KV	New Parli -Beed ckt-II	3-Jun-10	11.02	3-Jun-10	13.53	Red Hot Spot
220KV	Karad-Pophali	4-Jun-10	07.20	4-Jun-10	11.47	Replacement of faulty Disc Insulator
220KV	Trombay - Tifil	4-Jun-10	09.47	4-Jun-10	18.49	Replacement of Conductor
220KV	Kolhapur - Karad - II	4-Jun-10	10.32	4-Jun-10	18.30	Replacement of Faulty Insulator
220KV	Kalwa-Nasik III	4-Jun-10	08.26	4-Jun-10	18.43	Insulator replacement
220KV	Momewadi -Halkarni	4-Jun-10	06.18	4-Jun-10	18.33	Making Tapping arrangement for Kolhapur-Ponda-I
220KV	Kharghar-TSS	4-Jun-10	09.28	4-Jun-10	18.29	Replacement of Insulator
220KV	220/132 KV,150 MVA T/F-I at 220 KV Boiser	4-Jun-10	13.40	4-Jun-10	17.15	Premansoon maint.work
220KV	Mudsungi-Amona	4-Jun-10	06.25	4-Jun-10	18.00	Making Tapping arrangement for Kolhapur-Ponda-I for 220KV Halkarni
220KV	ONGC-JNPT	4-Jun-10	09.50	4-Jun-10	10.15	Distance Protection
220KV	Bhoisor - Bhoisor PGCIL-II	4-Jun-10	10.10	4-Jun-10	10.52	Maintenance work
220KV	220/100KV 125MVA ICT-I at Jambhul	4-Jun-10	09.36	4-Jun-10	16.35	Maintanance work
220KV	Nasik-Kalwa-III	5-Jun-10	08.36	5-Jun-10	19.07	Conductor replacement
220KV	220/132,100 MVA ICT - I @ A'Nagar	5-Jun-10	09.20	5-Jun-10	13.02	Q.M.Work
220KV	220KV Aux.Bus at Lamboti	5-Jun-10	10.05	5-Jun-10	14.40	For Fixing of 220KV Isolator Blades
220KV	220/132 KV 200 MVA T/F @ Raymond	5-Jun-10	09.15	5-Jun-10	13.26	Premansoon maint.work
220KV	Padgha-Temghar	6-Jun-10	06.42	6-Jun-10	08.15	B Ph.PT burst at Temghar.
220KV	K'gaon-Dasturi	6-Jun-10	05.23	6-Jun-10	07.25	Bus Bar Protection operated at Dasturi
220KV	Lote - Dasturi	6-Jun-10	05.23	6-Jun-10	08.25	Bus Bar Prot.operated at Dasturi end
220KV	Pedambe - Pophali	6-Jun-10	06.35	6-Jun-10	18.30	Main Bus-I outage at Pedambe
220KV	Pedambe - Mahad	6-Jun-10	06.25	6-Jun-10	18.40	Main Bus-I outage at Pedambe
220KV	Pedambe-Newkoyna	6-Jun-10	06.30	6-Jun-10	18.50	Main Bus-I outage at Pedambe
220KV	Main Bus Section- I at Pedambe	6-Jun-10	07.25	6-Jun-10	18.25	Replacement of support Insulator
220KV	Temghar-Colourchem	6-Jun-10	06.42	6-Jun-10	08.00	B phase PT Burst
220KV	Kalwa-Colourchem	6-Jun-10	06.42	6-Jun-10	07.23	B Phase PT Burst
220KV	Nasik-Navsari -II	6-Jun-10	17.35	7-Jun-10	06.00	Location no.204,Y phase suspension string replace
220KV	220/66KV,150MVA ICT-I at Gadchandur	6-Jun-10	17.01	6-Jun-10	19.02	H.V.Main Breaker replaced
132KV	Malegaon-Resod	31-May-10	11.35	31-May-10	18.30	Replacement of LA.
132KV	Umarkhed-Tamsa	31-May-10	08.55	31-May-10	13.20	To attend Red Hot at Loc No.1.
132KV	Theur - Phursungi	1-Jun-10	03.57	1-Jun-10	06.08	Bus fault.
132KV	Theur-Phanaswadi	1-Jun-10	03.57	1-Jun-10	06.33	Bus fault.
132KV	Theur-Kharadi	1-Jun-10	03.57	1-Jun-10	06.10	Bus fault.
132KV	Pachora-Chalisgaon Ckt.II.	2-Jun-10	09.18	2-Jun-10	09.48	Dist.Protection operated,Z-2.(dist.47 Km.)
132KV	Bhusawal - Pachora	2-Jun-10	09.18	2-Jun-10	09.34	Dist.Protection operated Z-2.
132KV	Parbhani-Pathari	3-Jun-10	18.30	3-Jun-10	18.47	Distance Protection
132KV	Boiser - Viraj	4-Jun-10	11.25	4-Jun-10	18.36	R.M.Work
132KV	132 KV Interconnector I at Bhusawal	5-Jun-10	15.50	5-Jun-10	16.06	Tripped while taking cold test of Main CB of 132KV B/C
132KV	132 KV Interconnector II at Bhusawal	5-Jun-10	15.50	5-Jun-10	16.06	Tripped while taking Cold test of Main CB of 132KV B/C
132KV	Bhusawal - Pachora	5-Jun-10	23.40	6-Jun-10	00.15	H/T to attend Red Hot on CT Clamp
132KV	Dhule-Sakri	6-Jun-10	17.00	6-Jun-10	17.20	Tripped on 33KV Feeder Fault
132KV	Nanded - Tamsa	6-Jun-10	10.30	6-Jun-10	20.56	Distance Protection
100KV	Kalwa-Reliable	2-Jun-10	10.25	2-Jun-10	16.40	Wave trap jumper open.
100KV	Kolshet-Vasai	2-Jun-10	12.55	2-Jun-10	13.00	Due to heavy sparking on isolator.