

LINE OUTAGES FOR THE WEEK

FROM 5-Jul-10 TO 11-Jul-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE I -CHDPR	8-Jul-10	21.05	8-Jul-10	01.46	Problem in tap changer of Y-ph convertor X'mer.
400KV	Kolhapur-Mapusa Ckt I	15-Jun-10	22.36	6-Jul-10	16.26	Over Voltage.
400KV	Akola - Wardha - II	16-Jun-10	14.53	7-Jul-10	11.04	Due to Line Loading.
400KV	Dhule-Sar'Sarovar - I	26-Jun-10	17.37	8-Jul-10	11.53	Over Voltage
400KV	Karad-Kolhapur-II	2-Jul-10	18.03	9-Jul-10	10.24	Over Voltage
400KV	Chandrapur - Parli - II	3-Jul-10	18.52	5-Jul-10	03.19	Over Voltage
400KV	C'pur-Parli II	6-Jul-10	01.20	6-Jul-10	05.34	Over Voltage.
400KV	Chandrapur-Khaparkhedda	6-Jul-10	15.16	6-Jul-10	18.05	Numerical Relay Testing Work of Line,Ckt is Ready for Charging.
400KV	Lonikand-Karad	6-Jul-10	21.48	7-Jul-10	08.43	Over Voltage.
400KV	Kolhapur-Mapusa-II	6-Jul-10	16.31	7-Jul-10	13.23	Hand Tripped.
400KV	Akola - Aurangabad - I	7-Jul-10	00.20	8-Jul-10	10.57	Main & Tie Breaker Trip.
400KV	Koradi-Satpur	7-Jul-10	21.30	7-Jul-10	21.53	Trip from Satpur end on PDR.
400KV	400/220KV, 500MVA ICT at Lamboti	7-Jul-10	12.25	7-Jul-10	14.30	Tap changing work.
400KV	Akola - Wardha - I	7-Jul-10	11.00		Continued.	Changeover.
400KV	Kolhapur-Mapusa-II	7-Jul-10	22.22	9-Jul-10	11.17	Over Voltage.
400KV	New Koyna-Jaigad II	7-Jul-10	17.51	7-Jul-10	18.37	New Line First Time Charge.
400KV	400/220 KV 500 MVA ICT-I at Jejuri	8-Jul-10	00.38	8-Jul-10	06.42	Installation of 33KV 3 Nos.of PT's and testing work.
400KV	Koradi-Satpur	8-Jul-10	01.24	8-Jul-10	01.33	Trip from Satpur end on PDR.
400KV	400/220 KV,315 MVA ICT-II at Lonikand	8-Jul-10	07.57	8-Jul-10	19.49	Replacement of LV side R-ph,LA.
400KV	400/220 KV, 500 MVA ICT - II at Jejuri	8-Jul-10	11.12	8-Jul-10	16.30	Installation of 33KV PT & testing work.
400KV	Main Bus - I @ 400 KV Jejuri	8-Jul-10	16.41	8-Jul-10	17.31	Testing of spare ICT and commissioning work.
400KV	Kalwa - Lonikand	8-Jul-10	18.15	10-Jul-10	19.57	Retrofitting of Relay.
400KV	Bus Coupler at 400 KV Kolhapur	8-Jul-10	11.57	9-Jul-10	17.50	To attend Hot Spot.
400KV	Parli-Solapur	8-Jul-10	23.42	9-Jul-10	12.45	Tripped on O/V.
400KV	Karad-Solapur(Lamboti)	8-Jul-10	23.42	9-Jul-10	20.02	Tripped on O/V.
400KV	Dhule-Sar'Sarovar - I	8-Jul-10	23.28	9-Jul-10	19.20	H/T for O/V.
400KV	400/220KV,500MVA ICT at Akola	9-Jul-10	12.50	9-Jul-10	14.39	For Changing of Tap Position.
400KV	Akola-Bhusawal	9-Jul-10	08.31	9-Jul-10	19.47	Q.M.Work
400KV	B Bus at Telangade	9-Jul-10	11.45	9-Jul-10	17.50	Isolator replacement.
400KV	Karad - Kolhapur - I	9-Jul-10	10.51	9-Jul-10	10.58	Hand Tripped.
400KV	C'pur-Parli II	9-Jul-10	22.01	10-Jul-10	07.31	Over Voltage.
400KV	400/220 KV 315 MVA ICT at Akola	9-Jul-10	15.12	9-Jul-10	17.07	For Changing of Tap Position.
400KV	Padgha-Bhoisor (PGCIL)	9-Jul-10	10.59	9-Jul-10	14.36	Red HoT on R-Ph conductor clamp.
400KV	Akola - Aurangabad - II	9-Jul-10	14.59	9-Jul-10	15.27	Trip On O/V.
400KV	Akola - Wardha - II	9-Jul-10	14.59	10-Jul-10	09.27	Trip On O/v.
400KV	Wardha - Seoni	9-Jul-10	14.59	9-Jul-10	15.37	Trip On O/V.
400KV	Akola-Koradi	9-Jul-10	14.59	9-Jul-10	15.35	Trip On O/V.
400KV	400/220 KV 315 MVA ICT II AT CHAKAN	9-Jul-10	15.58	9-Jul-10	20.08	Maintenance Work.
400KV	Kolhapur-Mapusa Ckt I	9-Jul-10	10.57	10-Jul-10	09.43	Trip.
400KV	Dhule-Sar'Sarovar - I	9-Jul-10	22.32	10-Jul-10	09.25	H/T For O/V.
400KV	400/220KV 315MVA ICT-III at Karad.	9-Jul-10	10.36	9-Jul-10	10.41	Hand Tripped.
400KV	Dhule-Khandwa I	10-Jul-10	10.09		Continued.	Over Voltage
400KV	Bus Coupler at New Koyna	10-Jul-10	15.38	10-Jul-10	16.23	SF6 Gas filling
400KV	New Koyna - Dabhol - II	10-Jul-10	16.28	10-Jul-10	16.45	Filling of SF6 Gas (taken on TBC)
400KV	Dabhol-Nagothane - II	10-Jul-10	16.46		Continued.	Charged 400KV Nagothane-Dabhol-II line Bay at N'thane end only
400KV	Chandrapur - Parli - II	10-Jul-10	22.28	11-Jul-10	09.35	Over Voltage
400KV	Koradi - Bhusawal	10-Jul-10	09.54	10-Jul-10	17.56	Quarterly Maintenance Work.
400KV	Dhule-Sar'Sarovar - I	10-Jul-10	23.00		Continued.	Over Voltage
400KV	Kolhapur-Mapusa-II	10-Jul-10	23.49		Continued.	Over Voltage

400KV	Dabhol-New Koyna-I	11-Jul-10	10.36	11-Jul-10	11.02	Filling of SF6 Gas and oil in C.B.at New Koyna(ckt on TBC)
400KV	Wardha - Akola - II	11-Jul-10	13.07		Continued.	Over Voltage
400KV	Dhule-Sar'Sarovar - I	11-Jul-10	14.40	11-Jul-10	18.40	Over Voltage
400KV	Dhule-S'Sarovar I	11-Jul-10	23.18		Continued.	Over Voltage
400KV	Chandrapur - Parli - II	11-Jul-10	23.28	12-Jul-10	04.48	Replacement of Line Matching Units
220KV	Kandalgaon - Pophali	5-Jul-10	08.25	5-Jul-10	16.05	Maint.Work.
220KV	220/132KV,200MVA ICT-II at Amravati	5-Jul-10	10.24		Continued.	Replacement of CT's & L A'S.
220KV	Dhamangaon - Rly TSS - I	5-Jul-10	10.25	5-Jul-10	13.16	Maint.Work.
220KV	Kalmeshwar-Ambazari	5-Jul-10	05.59	5-Jul-10	18.02	Distance Protection.
220KV	Warora-Wardha	5-Jul-10	10.49	5-Jul-10	11.53	Distance Protection.
220KV	220/66 KV, 50 MVA ICT-I At Warora	5-Jul-10	17.50	5-Jul-10	23:21	REF Protection Operated.
220KV	Kolhapur - Karad - II	5-Jul-10	19.52	11-Jul-10	09.18	Due to Breaker Compressor Problem.At Karad Line on TBC.
220KV	220/100KV,125MVA ICT-III at Kalwa	6-Jul-10	07.55	6-Jul-10	09.42	Attending C.T.Clamp Hot Spot.
220KV	220/132 KV 150 MVA ICT - I @ NSK.	6-Jul-10	10.18	6-Jul-10	12.59	L V C T Tandelta Measurment Work.
220KV	220/100KV,100MVA ICT-IV at K'gaon	6-Jul-10	08.25	6-Jul-10	17.50	WTI and OTF Replacement Work.
220KV	Karad-Oglewadi-I	6-Jul-10	11.42	6-Jul-10	15.55	Q.M.Work.
220KV	Nasik-Bablsr - II	6-Jul-10	11.10	6-Jul-10	18.49	Replacement of L A Relay.
220KV	Bale-Murud	6-Jul-10	11.30	6-Jul-10	17.58	Retrofitting Work.
220KV	220/33 KV 50 MAV T/F- II @ Peth	6-Jul-10	09.40	6-Jul-10	12.10	Q.M.Work.
220KV	Chandrapur-Chandrapur MIDC	6-Jul-10	08.50	7-Jul-10	20.15	Line Taken on TBC.
220KV	Parli-Usmanabad	6-Jul-10	12.22		Continued.	CKT on TBC for main BKR Repl.work.
220KV	220KV C'pur-C'pur MIDC at 400 KV C'pur	6-Jul-10	08.50	7-Jul-10	20.15	Wiring work of Auto reclosing ckt,R.M.work
220KV	Lamboti - Pandharpur	7-Jul-10	09.22	7-Jul-10	16.27	Back up Relay Retrofitting Work.
220KV	Vita - Pandharpur	7-Jul-10	16.25	7-Jul-10	19.58	Back up Relay Retrofitting Work.
220KV	KANHAN - BHANDARA CKT II	7-Jul-10	10.12	7-Jul-10	12.50	Q.M.Work
220KV	Bus Coupler at Koradi	7-Jul-10	09.25	7-Jul-10	20.33	Q.M.Work.
220KV	Gadchiroli - Virur	7-Jul-10	14.24	7-Jul-10	15.55	Replacement of Relay.
220KV	Kalmeshwar - Pandurna	7-Jul-10	16.15	8-Jul-10	17.42	Tripped on PDR,Trial failed at 16.59 Hrs.
220KV	Main Bus at Dhamangaon	7-Jul-10	11.50	7-Jul-10	13.28	Alignment of TSS I ckt bus side isolator.
220KV	Babaleshwar - Alephata	8-Jul-10	11.35	8-Jul-10	17.51	Replacement of faulty insulator.
220KV	Theur - Magarpatta	8-Jul-10	10.14	8-Jul-10	16.08	Q.M.Work.
220KV	Jindal - Ghatghar	8-Jul-10	10.35	8-Jul-10	17.22	Jumper crimping & Q.M.Work.
220KV	Washala-Ghatghar	8-Jul-10	09.00	8-Jul-10	19.12	Line maint.& R.M.Work
220KV	Jejuri-Jejuri I	8-Jul-10	19.31	8-Jul-10	14.38	Q.M.Work.
220KV	Kandalgaon-Khargar	8-Jul-10	13.30	8-Jul-10	18.06	Testing work.
220KV	220/132 KV 100 MVA ICT-II @ Parbhani	8-Jul-10	10.02	8-Jul-10	18.44	Oil Regeneration work.
220KV	Dhamangaon - Badnera	8-Jul-10	19.35	8-Jul-10	20.25	Due to heavy sparking on R-Ph line isolator.
220KV	Nigade - Peth	9-Jul-10	08.55	9-Jul-10	11.58	Insulator replacement.
220KV	Uran-Kharghar-I	9-Jul-10	09.10	9-Jul-10	19.31	Commissioning of Auto reclose scheme at Khargar.
220KV	Padgha - Jindal	9-Jul-10	09.31	9-Jul-10	17.12	CRM,Tan-delta measurement of CT.
220KV	220/132 KV,100 MVA T/F- II @ Malegaon	9-Jul-10	10.37	9-Jul-10	12.35	CT leakage work.
220KV	Kolhapur - Peth	9-Jul-10	12.45	9-Jul-10	15.05	Replacement of R-Ph CT jumper.
220KV	Main Bus @ Tillary.	9-Jul-10	14.30	9-Jul-10	17.22	Attending Bus Side Isolator Work.
220KV	Kalwa-C'chem	9-Jul-10	15.56	9-Jul-10	20.01	Repl.of back-up relay at C'chem.
220KV	Kalwa-Nasik III	9-Jul-10	15.53	9-Jul-10	21.17	Rectification of wave trap problem at Kalwa.
220KV	220/132 KV 200 MVA ICT IV at Padegaon.	9-Jul-10	11.04	9-Jul-10	16.05	Q.M.Work.
220KV	Kalmeshwar - Pandurna	10-Jul-10	08.21	10-Jul-10	09.01	Distance Protection
220KV	BBSR II- BBSRL CKT. I	10-Jul-10	09.05	10-Jul-10	17.07	Line Maint.work
220KV	220/132 KV 150 MVA ICT - I @ NSK.	10-Jul-10	09.45	10-Jul-10	16.46	R&B phase LV CT replacement
220KV	220 KV Bus Coupler at New Koyna	10-Jul-10	10.29	10-Jul-10	11.24	Attending oil leakage problem

132KV	Kawlewada-Gondia-II	6-Jul-10	18.50	6-Jul-10	19.15	Dist.Prot.
132KV	Bhandara-Madgi CKT.II	6-Jul-10	20.25	6-Jul-10	20.35	Dist.Prot.
132KV	Narsi-Degloor	8-Jul-10	01.35	8-Jul-10	14.10	Under B/Dn,LBT 2.8 Mw.
132KV	Kanhan - Mouda	10-Jul-10	10.30	10-Jul-10	11.05	Distance protection