

LINE OUTAGES FOR THE WEEK

FROM 4-Jul-11 TO 10-Jul-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	Chandrapur-Padaghe Pole - II	10-Jul-11	17.01	10-Jul-11	21:40	Trip Smonthing Reactor Pressure Ready for Charge @ 21.00 Hrs.
400KV	Kolhapur - Mapusa - I	2-Jul-11	17.57	4-Jul-11	11.30	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	2-Jul-11	22.23	5-Jul-11	09.48	Over Voltage.
400KV	Karad - Kolhapur - I	3-Jul-11	17.22	4-Jul-11	09.18	Over Voltage.
400KV	Bhusawal- Aurangabad	3-Jul-11	18.38	4-Jul-11	07.15	Over Voltage.
400KV	400/220KV 167MVA Spare ICT at Kalwa	4-Jul-11	09.05	4-Jul-11	12.25	Tand demonstration.
400KV	Chakan-Talegaon(PG)	4-Jul-11	15.46	4-Jul-11	18.44	Jumping work at Talegaon.
400KV	Kolhapur - Mapusa - II	4-Jul-11	17.37	5-Jul-11	10.10	Over Voltage.
400KV	Karad-Kolhapur-II	4-Jul-11	17.15	7-Jul-11	12:51	Over Voltage.
400KV	Bhusawal- Aurangabad	4-Jul-11	18.40	5-Jul-11	07.38	Over Voltage.
400KV	Dhule - S'Sarovar- II	5-Jul-11	00.10	5-Jul-11	12.33	Over Voltage.
400KV	Chandrapur - Khaparkheda	5-Jul-11	07.27	5-Jul-11	23.50	Replacement of B ph.CT and CVT
400KV	Bhusawal- Aurangabad	5-Jul-11	19.19	6-Jul-11	11.09	Over Voltage.
400KV	Dhule-S'Sarovar I	5-Jul-11	16.10	5-Jul-11	21.01	Over Voltage.
400KV	Kolhapur - Mapusa - I	5-Jul-11	17.42	6-Jul-11	10.07	Over Voltage.
400KV	Dhule - S'Sarovar- II	5-Jul-11	20.46	6-Jul-11	13.17	Distance protection.
400KV	Dhule-S'Sarovar I	5-Jul-11	21.01	7-Jul-11	17:25	Ready for charging.
400KV	Dhule-Sar'Sarovar - I	5-Jul-11	21.01	8-Jul-11	08.57	Distance Protection.
400KV	Padgha - Talegaon (PG)	6-Jul-11	01.11	6-Jul-11	01.34	Distance Protection.(Padgha end only)
400KV	Padgha - Talegaon (PG)	6-Jul-11	02.51	6-Jul-11	08.42	Distance Protection.
400KV	Chakan-Talegaon(PG)	6-Jul-11	02.29	6-Jul-11	09.33	Distance Protection.
400KV	C'pur-Parli II	6-Jul-11	00.47	6-Jul-11	02.42	Distance Protection.
400KV	Lonikand- Koyna Stage IV	6-Jul-11	00.57	6-Jul-11	06.33	Over Voltage.
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	6-Jul-11	11.43	6-Jul-11	14.06	Isolator Maintenance Work.
400KV	Main Bus - I @ Lamboti.	6-Jul-11	14.44	6-Jul-11	16.16	Maintenance work.
400KV	Bhusawal- Aurangabad	6-Jul-11	17.59		Continued.	Over Voltage.
400KV	Wardha - Akola - I	6-Jul-11	18.16		Continued.	Over Voltage.
400KV	Kolhapur - Mapusa - II	6-Jul-11	18.07		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	6-Jul-11	11.08	6-Jul-11	17.59	Isolator replacement work.(Ckt is on TBC)
400KV	Dhule - S'Sarovar- II	7-Jul-11	00.06	7-Jul-11	08:46	Over Voltage.
400KV	Lonikand - Parli - II	7-Jul-11	07:02	7-Jul-11	19:14	Relay testing work at Lonikand.
400KV	Chandrapur - Parli - III	7-Jul-11	08:22	7-Jul-11	17:27	Relay testing work and corona ring repla.
400KV	400/220KV,315 MVA ICT-I At Lonikand.	7-Jul-11	08:31	7-Jul-11	17:57	Relay testing work.
400KV	Chakan-Talegaon(PG)	7-Jul-11	10:57	7-Jul-11	14:05	Y ph line repaire tightning work.
400KV	New Koyna - Koyna Stage IV - II	7-Jul-11	10:39	7-Jul-11	14:33	Line taken on TBC, isolator checking work.
400KV	Kolhapur-Karad -I	7-Jul-11	12:57		Continued.	Over Voltage.
400KV	Padgha - Babaleshwar - II	7-Jul-11	21:06	8-Jul-11	12.19	Distance Protection.
400KV	Lonikand- Koyna Stage IV	7-Jul-11	22:31	8-Jul-11	07.50	Over Voltage.
400KV	Dhule - S'Sarovar- II	7-Jul-11	23:05	9-Jul-11	06.08	Over Voltage.
400KV	400/132KV 200 MVA ICT-II @ Bhusawal	7-Jul-11	14:50	7-Jul-11	18:52	To attend Air compressor leakage. (ICT LV side is on TBC)
400KV	400 / 6.9 KV 80 MVA station T/F at Deepna	7-Jul-11	12:56	7-Jul-11	16:50	Rectification of hanging over problem of diff. relay.
400KV	Lonikand- Koyna Stage IV	8-Jul-11	21.38	9-Jul-11	08.30	Over Voltage.
400KV	Bablsr-Aurangabad	8-Jul-11	02:38	8-Jul-11	18.30	Trip on high voltage.
400KV	400/220KV 315MVA ICT-II @ Aurangabad.	8-Jul-11	11.01	8-Jul-11	17.07	Q.M.Work.
400KV	Akola - Aurangabad - I	8-Jul-11	20.31		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	8-Jul-11	23.02		Continued.	Over Voltage.
400KV	Wardha - Akola - II	9-Jul-11	00.03		Continued.	Over Voltage.

400KV	Dhule - Babhaleshwar - I	9-Jul-11	00.10	9-Jul-11	08.38	Over Voltage.
400KV	Lonikand- Koyna Stage IV	9-Jul-11	22.05	10-Jul-11	08.15	Over Voltage.
400KV	Lonikand- Koyna Stage IV	10-Jul-11	22.05		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	10-Jul-11	23.33		Continued.	Over Voltage.
220KV	220/110KV 200MVA ICT-II at Mudshingi	10-Apr-11	18.10	4-Jul-11	14.20	Diff.Prot.Defective B Phase LA replaced
220KV	Babaleshwar - Bhenda	1-Jul-11	10:05	7-Jul-11	20:10	Tower Shifting work.
220KV	Bale-Murud	2-Jul-11	06:00	7-Jul-11	18.32	To Control Parli ICT Loading.
220KV	Bale-Osmanbad	2-Jul-11	06:00	8-Jul-11	00:16	To Control Parli ICT Loading.
220KV	Mudshingi - Peth	4-Jul-11	10.20	4-Jul-11	14.58	Q.M.Work
220KV	Apta-HOC	4-Jul-11	11.42	4-Jul-11	17.39	Bay maintenance work.
220KV	Ambazari-Amravati	4-Jul-11	10.48	4-Jul-11	16.13	Q.M.Work
220KV	Khaperkheda - Ambazari - II	4-Jul-11	12.28	4-Jul-11	14.43	To attend sparking on SCADA TB.
220KV	Bus Coupler Breaker @ New Koyna	4-Jul-11	22.30	4-Jul-11	23.02	O/C,E/F Trip.
220KV	Karad-Oglewadi-I	5-Jul-11	10.25	5-Jul-11	14.35	Q.M.Work
220KV	Vita - Miraj	5-Jul-11	10.15	5-Jul-11	15.20	Q.M.Work
220KV	Miraj -Ichalkarajni	5-Jul-11	11.40	5-Jul-11	18.00	To attend D.C. leakage,
220KV	Babaleshwar - Nagar - II	5-Jul-11	21.56	7-Jul-11	11.11	Distance protection.
220KV	Koradi - Ambazari - II	5-Jul-11	10.00	8-Jul-11	17.38	Transfer of the Control from Existing C R Panels to BCR's & Scada.
220KV	Virur - Gadchiroli	6-Jul-11	02.20	6-Jul-11	11.58	Distance Protection.
220KV	Gangapur-Valve	6-Jul-11	00.43	6-Jul-11	06.50	Distance Protection,declared faulty.
220KV	Kalwa-Colourchem	6-Jul-11	06.40	6-Jul-11	09.07	To attend red hot spot at LILO location 1B.
220KV	Kalwa - Airoli - Knowledge Park.	6-Jul-11	06.54	6-Jul-11	09.00	To attend red hot spot at LILO location 1B.
220KV	Karad-Pedambe	6-Jul-11	09.05	6-Jul-11	18.57	Stringing work of 400KV Jaigad-Karad D/C line.
220KV	Usmanabad --Bale	6-Jul-11	09.48	6-Jul-11	18.33	Providing and fixing of vibration damper.
220KV	Dhule - Malegaon	7-Jul-11	02.49	7-Jul-11	03.10	Distance protection.
220KV	Bale-Osmanbad	7-Jul-11	07:02	7-Jul-11	19:14	Removing and fixing of vibration damper.
220KV	Main Bus - I at Nagothane	7-Jul-11	10:14	7-Jul-11	15:28	220 KV Isolator alignment work.
220KV	Karad-Pedambe	7-Jul-11	09:15	7-Jul-11	15:40	Stringing work between loc. no. 309 and 310.
220KV	Main Bus-II At 220 KV BBLSR	7-Jul-11	11:52	7-Jul-11	20:10	Extension of 220 KV Main Bus - II.
220KV	Chinchwad-Urse	7-Jul-11	11:56	7-Jul-11	17:54	Q.M. work, line taken on TBC.
220KV	Jejuri-Phursungi	7-Jul-11	15:12	7-Jul-11	17:16	Relay testing work.
220KV	Jejuri - Parvati	7-Jul-11	09:34	7-Jul-11	14:11	Corrective action for problem of cross connection of Jumper.
220KV	220/33 KV,50 MVA T/F - I & II at Wankuswa	7-Jul-11	21:50	7-Jul-11	22:25	O. C. Earth Fault.
220KV	220/132KV 200 MVA ICT I at Chalisgaon	7-Jul-11	11:38	7-Jul-11	12:47	For disconnecting of 132 KV TBC isolator to C.T. Jumper L.V. side.
220KV	220/132 KV 200 MVA ICT- II @ Harangul	7-Jul-11	13:30	7-Jul-11	14:12	To cover prv relay on ICT for protection from rain.
220KV	Main Bus 132 KV at Nanded	7-Jul-11	08:20	7-Jul-11	18:35	Conversion of single Bus yo twin Bus.
220KV	Dhule - Malegaon	7-Jul-11	02:49	7-Jul-11	03:10	Distance Protection operated Zone - I (R ph.)
220KV	Padgha-Jambhul	8-Jul-11	12.15	8-Jul-11	17.01	Distance Relay Testing Work.
220KV	Boiser-PGCIL-I	8-Jul-11	11.21	8-Jul-11	11.34	Without Indication.
220KV	Boisor - Dahanu	8-Jul-11	13.16	8-Jul-11	13.39	D C Leakage.
220KV	Tarapur - Boiser	8-Jul-11	15.53	8-Jul-11	16.13	Attending D C Leakage.
220KV	Boisor-Versova	8-Jul-11	13.44	8-Jul-11	14.25	Attending D C Leakage.
220KV	220/100 KV 200 MVA ICT - IV @ Apta	8-Jul-11	15.00	8-Jul-11	19.26	PDR Relay Testing.
220KV	220/132 KV 200 MVA ICT - I @ Nanded	8-Jul-11	10.40	8-Jul-11	16.30	Jumpering Work.
220KV	Usmanabad --Bale	8-Jul-11	07.02	8-Jul-11	18.24	Providing & Fixingof Vibration Dampers for Line from Loc no.47-153
220KV	Virur - Gadchiroli	8-Jul-11	01.48	8-Jul-11	02.20	Distance Protection Operated Z-I Rh.
220KV	Bale-Murud	8-Jul-11	07.02	8-Jul-11	21.44	Parly ICT Loading Control.

220KV	Bale-Usmanabad	9-Jul-11	07.13	9-Jul-11	12.25	Removing & Fixing of Vibration Damper.
220KV	BBLSR-A"Nagar II	9-Jul-11	09.00	9-Jul-11	14.15	Maintenance Work.
220KV	Bableshtar-Nasik-I	9-Jul-11	12.00	9-Jul-11	16.00	Auto Recloser Testing Work.
220KV	Bale-Murud	9-Jul-11	07.13	9-Jul-11	18.48	Control Loading Parly ICT.
220KV	Virur - Gadchiroli	9-Jul-11	19.52	9-Jul-11	20.15	Distance Protection Operated Z-I R Ph.
220KV	Kandalgaon-Koyna	10-Jul-11	07.30	10-Jul-11	12.15	Bus Section Outage @ Koyna -I.
220KV	Pophali - Pedambe	10-Jul-11	07.23	10-Jul-11	12.20	Bus Section Outage @ Koyna - I.
220KV	Bus Section - I @ Pophali	10-Jul-11	07.40	10-Jul-11	12.20	Bus Section Outage @ Koyna - I.To Attend Hot Spot.
220KV	Kalwa - Salshet - III	10-Jul-11	09.10	10-Jul-11	13.31	Attending Hot Spot @ R & B Ph.C T .
220KV	Boisor - Dahanu	10-Jul-11	19.40	10-Jul-11	20.07	Tripped @ Boisar Without any Indication.
220KV	Mahad-Nagothane	10-Jul-11	23.27		Continued.	Tripped @ Mahad End Only on PDR.
132KV	Virur-Ashti	6-Jul-11	02.20	6-Jul-11	02.50	Distance Protection.
132KV	Pachora - Chalisgaon - I	6-Jul-11	09.01	6-Jul-11	11.51	Jumpering work of aux.bus isolator.
132KV	Pachora-Chalisgaon Ckt.II.	6-Jul-11	11.56	6-Jul-11	13.27	Jumpering work of aux.bus isolator.
132KV	Mankapur - Uppalwadi	6-Jul-11	10.53	6-Jul-11	13.15	Maint. and tan delta measurement.
132KV	Padegaon - Paithan	6-Jul-11	20.20	7-Jul-11	10.01	Distance protection.
132KV	Dondaicha - Sahada	6-Jul-11	22.00	7-Jul-11	08.20	Distance protection.
132KV	Nandurbar - Visarwadi	7-Jul-11	04:00	7-Jul-11	04:30	Distance Protection operated Zone - I.
132KV	Paras - Warwat Bakal	7-Jul-11	06:02	7-Jul-11	12:55	Distance Protection operated Zone - I.(R ph.)
132KV	Nandurbar - Visarwadi	7-Jul-11	12:00	7-Jul-11	12:05	Backup Protection operated O/C & E/F.
132KV	Kawalewada-Gondia-I	7-Jul-11	12:34	7-Jul-11	12:50	Backup Protection operated O/C & E/F.
132KV	Gondia - Amgaon Railway	7-Jul-11	12:34	7-Jul-11	14:15	Backup Protection operated.
132KV	Amravati - Akola	7-Jul-11	15:53	7-Jul-11	16:02	Distance Protection operated Zone - II(B ph.)
132KV	Amravati - Achalpur	7-Jul-11	20:02	8-Jul-11	13.15	R ph. E/F break down declared, trial failed at 20:20 Hrs.
132KV	Pusad - Umarkhed	7-Jul-11	22:33	7-Jul-11	22:42	Distance Protection operated Zone - I (R ph.)
132KV	Pusad - Umarkhed	8-Jul-11	01.55	8-Jul-11	02.11	Distance Protection Operated Z-I R Ph.
132KV	Boiser - Viraj	10-Jul-11	22.01	11-Jul-11	05.40	Y Ph C T Burst @ Viraj.
110KV	Rethre - Borgaon	7-Jul-11	09:37	7-Jul-11	13:00	Dist. Protn.
100KV	Chinchwad - Talegaon	7-Jul-11	12:45	7-Jul-11	15:02	Line Maint. work.