

LINE OUTAGES FOR THE WEEK

FROM 2-Jul-12 TO 8-Jul-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole I Padgha	2-Jul-12	18.41	2-Jul-12	19.30	Replaacement of RHLA card.
400KV	50MVAR Reactor C'Pur - Parli -I at Parli end	16-Apr-12	16.50	6-Jul-12	12.46	Filtration work
400KV	400/220 KV 315 MVA ICT- I @ Dhule	18-Jun-12	10.40	3-Jul-12	15.56	Cable Termination of CP and RP from new yard.Kept on humming.
400KV	Kolhapur - Mapusa - I	27-Jun-12	22.06	2-Jul-12	09.14	Over Voltage.
400KV	Deepnagar-Aurangabad-I	28-Jun-12	12.05	3-Jul-12	15.17	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	1-Jul-12	00.26	4-Jul-12	14.25	Over Voltage.
400KV	Karad-Kolhapur-II	1-Jul-12	16.10	2-Jul-12	09.23	Over Voltage.
400KV	Kolhapur-Solapur (PG) II	1-Jul-12	21.59	4-Jul-12	06.49	Over Voltage.
400KV	Parli-Parli (PGCIL) I	1-Jul-12	23.51	6-Jul-12	11.30	Over Voltage.
400KV	Bablsr-Padgha Ckt I	2-Jul-12	04.00	2-Jul-12	04.08	Dist.Protection Z-I.
400KV	Bblswr - Padgha - II	2-Jul-12	02.21	2-Jul-12	18.59	Dist.Protection Z-I.
400KV	Kolhapur-Mapusa-II	2-Jul-12	17.50	3-Jul-12	10.52	Over Voltage.
400KV	400/220 KV 500 MVA ICT-I @ Deepnagar	2-Jul-12	09.41	2-Jul-12	12.12	Replacement of disc insulator.
400KV	Bablsr-Padgha Ckt I	3-Jul-12	10.25	3-Jul-12	16.17	Replacement of Insulator
400KV	Karad - Kolhapur - I	3-Jul-12	14.18	4-Jul-12	09.31	Testing work
400KV	Aurangabad-Deepnagar-II	3-Jul-12	15.29		Continued.	Over Voltage
400KV	Akola - Wardha - II	3-Jul-12	22.13	7-Jul-12	19.35	Over Voltage
400KV	Dhule - S'Sarovar- II	3-Jul-12	22.31	9-Jul-12	09.17	Over Voltage
400KV	Kolhapur - Mapusa - I	3-Jul-12	21.55	6-Jul-12	11.12	Over Voltage
400KV	Koradi-Satpur	3-Jul-12	22.54	3-Jul-12	23.22	Distance Protection
400KV	400/220KV 500 MVA ICT III at Parli II	3-Jul-12	13.28	6-Jul-12	20.27	33KV PT Replacement.
400KV	Karad - Kolhapur - II	4-Jul-12	06.12	6-Jul-12	11.03	Over Voltage
400KV	Dhule-Sar'Sarovar - I	4-Jul-12	22.47	13-Jul-12	11.28	Over Voltage
400KV	Kolhapur-Solapur (PG) II	4-Jul-12	09.47		Continued.	PGCIL Work
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	4-Jul-12	17.48	5-Jul-12	13.25	Y Phase CVT Burst
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	4-Jul-12	11.41	4-Jul-12	17.48	Q.M.Work
400KV	400/220 KV Spare 167 MVA ICT At Chakan	5-Jul-12	09.59	5-Jul-12	14.28	Maintenance work.
400KV	Koradi-Bhilai	5-Jul-12	12.03	5-Jul-12	14.40	For taking reactor I/S.
400KV	Koradi-Bhilai	5-Jul-12	17.04	5-Jul-12	17.33	For connecting another testing instrmt in fault phase.
400KV	Koradi-Bhilai	5-Jul-12	22.15	5-Jul-12	22.24	For taking reactor I/S.
400KV	400/220 KV Spare ICT @ Babaleshwar	5-Jul-12	10.38		Continued.	Maintenance work.
400KV	Parly(PG)- Solapur(PG) - I	5-Jul-12	18.17	7-Jul-12	19.01	Over Voltage
400KV	Karad - Kolhapur - II	6-Jul-12	00.33	6-Jul-12	11.03	H.T. For O/V.
400KV	Bableswhar-Aurangabad	6-Jul-12	13.10	9-Jul-12	09.55	Repl.of operating mechanism of isolator.(Ready for charging 18.40 hrs)
400KV	Bus Coupler @ Aurangabad	6-Jul-12	13.24	6-Jul-12	14.12	Attending air leakages.
400KV	400/220KV 315 MVA ICT-I @ Padgha	6-Jul-12	08.43	6-Jul-12	17.42	Repl.of B & Y Ph.LV side CT.
400KV	400/220 KV315 MVA ICT-I @ BBLR	6-Jul-12	09.49	12-Jul-12	14.59	Dismantling of Y-Ph unit and re-erection of Y-Ph unit for overhauling
400KV	Karad - Kolhapur - I	6-Jul-12	16.06	7-Jul-12	09.09	Over Voltage.
400KV	Kolhapur - Mapusa - II	6-Jul-12	18.03	7-Jul-12	20.04	Over Voltage.
400KV	400/220KV 500 MVA ICT III at Parli II	6-Jul-12	20.45	7-Jul-12	13.50	Due to load not sharing properly.
400KV	400/220KV 315MVA ICT-III at Karad.	6-Jul-12	00.30	10-Jul-12	15.12	On TBC due to breaker air leakage.
400KV	Karad - Newkoyna - I	7-Jul-12	02.03	7-Jul-12	09.21	Over Voltage.
400KV	Akola - Aurangabad - I	7-Jul-12	02.09	7-Jul-12	09.09	Over Voltage.
400KV	Karad-Jaigad II	7-Jul-12	09.40	7-Jul-12	11.35	ABT meter installation work.
400KV	Chandrapur - Parli - I	7-Jul-12	11.39	7-Jul-12	12.47	To take reactor in service.
400KV	Karad - Kolhapur - II	7-Jul-12	16.42	8-Jul-12	10.25	Over Voltage.
400KV	Kolhapur - Mapusa - I	7-Jul-12	23.28	8-Jul-12	10.36	Over Voltage.
400KV	Aus.Bus at Koradi	7-Jul-12	09.53	7-Jul-12	16.30	Aligment of aux.bus petagraph isolator.

400KV	Akola - Wardha - I	8-Jul-12	04.34	8-Jul-12	10.22	Over Voltage.
400KV	Karad-Jaigad II	8-Jul-12	15.32	8-Jul-12	19.27	Dist.Prot.Z-I.
400KV	Karad - Kolhapur - II	8-Jul-12	16.10	9-Jul-12	09.18	Over Voltage.
400KV	Kolhapur - Mapusa - I	8-Jul-12	17.43	9-Jul-12	10.50	Over Voltage.
220KV	Dhule-Chalisgaon	22-Jun-12	15.12	4-Jul-12	12.47	To avail outage of 315 MVA ICT-I.
220KV	Apta-Uran-III	30-Jun-12	07.58	4-Jul-12	13.48	Shifting the aux.isolator,CT line isolator from RCC structure to new G.I.str
220KV	Phursungi -Theur - II	2-Jul-12	12.58	2-Jul-12	14.50	Hot spot attended.
220KV	Main bus section I I and III at Mudshingi.	2-Jul-12	09.25	2-Jul-12	12.57	Isolator maintenance.
220KV	Karad-Kolhapur - II	2-Jul-12	08.57	2-Jul-12	17.42	Due to bus outage at 22oKV Mudshingi.
220KV	Karad-Mudsingi-IV	2-Jul-12	08.58	2-Jul-12	13.05	Due to bus outage at 220KV Mudshingi.
220KV	Main Bus at Tilawani	2-Jul-12	13.55	2-Jul-12	18.27	Jumper replacement work.
220KV	Halkarni-Mahalaxmi	2-Jul-12	14.22	2-Jul-12	15.55	Hot spot attended.
220KV	Lamboti-Bale-II	2-Jul-12	16.43	2-Jul-12	18.25	Upgradation work of line 29C Aux,isolator.
220KV	220/132 KV 200 MVA ICT @ Amravati	2-Jul-12	09.02	2-Jul-12	12.57	Measurement of tan delta of HV and LV CT.
220KV	220/132KV,200MVA ICT-III At Nanded.	2-Jul-12	12.39	2-Jul-12	14.50	Testing work of CT.
220KV	Trombay-Dharavi-VI	2-Jul-12	19.52	2-Jul-12	19.42	Incliment weather.
220KV	Trombay-Cornac-V	2-Jul-12	19.48	2-Jul-12	20.37	Incliment weather.
220KV	Trombay Salsette-Dharavi-9	2-Jul-12	19.52	3-Jul-12	21.12	Incliment weather.
220KV	Parly - Harangool - I	2-Jul-12	09.34	3-Jul-12	17.53	Overhauling of Ckt Breaker
220KV	Vita-Mhaisal	3-Jul-12	03.35	3-Jul-12	11.38	Distance protection.
220KV	Wadkhal-NDIL-3	3-Jul-12	11.23	3-Jul-12	18.05	Maint.work
220KV	Vita - Miraj	3-Jul-12	12.45	3-Jul-12	15.35	Q.M.work
220KV	Khaperkheda-Purti	3-Jul-12	11.28	3-Jul-12	13.54	Hot Spot
220KV	Parly - Harangool - I	3-Jul-12	09.34	3-Jul-12	17.53	Overhauling of Ckt.Breaker
220KV	Nasik-Raymond	4-Jul-12	09.05	4-Jul-12	18.11	Replacement of Flashover Insulator
220KV	Vita - Pandharpur	4-Jul-12	11.00	4-Jul-12	20.50	Replacement of Faulty Disc Insulator
220KV	Main Bus at Malinagar	4-Jul-12	10.05	4-Jul-12	18.10	Q.M.Work
220KV	Hinganghat-Bhugaon	4-Jul-12	08.56	4-Jul-12	16.49	Hopt Spot
220KV	Ghodbhundar - Gorai	4-Jul-12	13.42	4-Jul-12	23.09	Safeguarding of 220KV Cable
220KV	Main Bus at Hinganghat	4-Jul-12	10.02	4-Jul-12	16.46	Replacement of Damaged Jumper
220KV	Warora-Hinganghat	4-Jul-12	09.56	4-Jul-12	16.46	Main Bus outage at Hinganghat
220KV	Kaparkheda-Kalmeshwar	4-Jul-12	10.50	4-Jul-12	13.47	Fixing of Nut Bolt
220KV	Lonikand -Theur - II	5-Jul-12	14.16	5-Jul-12	17.57	Attending Hot Spot.
220KV	Padghe - Nashik - II	5-Jul-12	09.09	5-Jul-12	17.05	Maintenance work.
220KV	Kharghar - Kalwa	5-Jul-12	11.12	5-Jul-12	16.00	Attending hot spot.
220KV	Pirangut-Hinjewadi	5-Jul-12	10.00	5-Jul-12	17.50	Half yearly maint. work.
220KV	Karad-Mudsingi-IV	5-Jul-12	12.01	5-Jul-12	16.45	extn. of P.T. supply for seperate metering.
220KV	Babaleswar - Ranjangaon	5-Jul-12	12.50	5-Jul-12	19.14	Q.M. work.
220KV	Girwali - Parbhani	5-Jul-12	08.13	5-Jul-12	18.58	Restrining in between Loc37(A) And (38)of Girwali to Parbhani D/C line.
220KV	New Parli-Nanded	5-Jul-12	07.34	5-Jul-12	17.37	Restrining in between Loc 37(A) and 38 of New Parli to Nanded D/C Lir
220KV	Chandrapur-Sicom - II	6-Jul-12	10.18	6-Jul-12	16.51	Measurement of tan delta of CT and Q.M.Work.
220KV	Trombay-Mulund	6-Jul-12	11.10	6-Jul-12	16.40	Jumper Nut replacement work.
220KV	220/132 KV 200 MVA ICT- I @ Bale	6-Jul-12	18.35	6-Jul-12	20.29	Testing work.
220KV	Kanhan - Umred	6-Jul-12	15.24	6-Jul-12	18.01	Measurement tan delta.
220KV	Hingoli-Parbhani	6-Jul-12	15.29	6-Jul-12	16.22	Measurement tan delta.
220KV	220/132 KV 200 MVA ICT - II @ Parbhani	6-Jul-12	10.26	6-Jul-12	17.53	Measurement tan delta.
220KV	Half Bus Sec.II at Sawangi	6-Jul-12	12.15	6-Jul-12	19.48	Maint.of 220KV Main bus isolator 29A of 100MVA ICT II.
220KV	Apta-Nagothane	7-Jul-12	08.01	7-Jul-12	18.14	Shifting of CT,s from RCC structure.
220KV	Trombay(T)-Trombay(M)Tie-II	7-Jul-12	08.25	10-Jul-12	18.30	Relay commissioning and protection upgradation.

220KV	Theur - Magarpatta	7-Jul-12	09.03	7-Jul-12	15.11	Maintenance work.
220KV	Trombay-Kalwa	7-Jul-12	10.34	7-Jul-12	15.21	Jumper replacement.
220KV	Dondaicha - Shahada	7-Jul-12	11.45	7-Jul-12	17.10	Q.M.Work
220KV	220/33 KV 50 MVA T/F - II @ Chitegaon.	7-Jul-12	11.10	7-Jul-12	15.08	Connecting of LV side power cable.
220KV	Koradi-Butibori	7-Jul-12	15.55	7-Jul-12	16.49	Bus bar protection operated.
220KV	Butibori-Indorama	7-Jul-12	15.55	7-Jul-12	16.55	Bus bar protection operated.
220KV	Butibori-INOX Ckt.	7-Jul-12	15.55	7-Jul-12	16.51	Bus bar protection operated.
220KV	Main Bus- I @ Butibori	7-Jul-12	15.55	7-Jul-12	16.49	Bus bar protection operated.
220KV	220/33 KV 50 MVA T/F - III @ Butibori	7-Jul-12	15.55	7-Jul-12	16.54	Bus bar protection operated.
220KV	Butibori MIDC-VIPL-II	7-Jul-12	15.55	7-Jul-12	16.52	Bus bar protection operated.
220KV	Bus Coupler at Butibori	7-Jul-12	15.55	7-Jul-12	16.51	Bus bar protection operated.
220KV	Boiser PGCIL-Boiser II	8-Jul-12	08.20	8-Jul-12	11.15	Hot Spot Work.
132KV	Nardhane - Shirpur	3-Jul-12	22.00	3-Jul-12	22.25	Distance Protection
132KV	Bus Section -II at Boiser	6-Jul-12	11.05	6-Jul-12	14.42	Repl.of E/W tension clamp pin.
110KV	Vikroli-Dharavi	2-Jul-12	20.06	2-Jul-12	20.08	Incliment weather.
110KV	Chembur-Lodhivali	2-Jul-12	19.58	2-Jul-12	20.13	Incliment weather.
110KV	Salsette Dharavi-Vkroli	2-Jul-12	20.04	3-Jul-12	03.59	Incliment weather.
110KV	Khopoli-Lodhivali,Chembur-Mankhurd	2-Jul-12	19.58	2-Jul-12	20.17	Incliment weather.
110KV	Trombay-Dharavi-I	2-Jul-12	20.02	2-Jul-12	20.04	Incliment weather.
110KV	Trombay-Cornac-III	2-Jul-12	20.02	2-Jul-12	20.34	Incliment weather.