

LINE OUTAGES FOR THE WEEK

FROM 1-Aug-11 TO 7-Aug-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Karad - Kolhapur - I	25-Jul-11	22.08	6-Aug-11	09.15	Over Voltage.
400KV	Akola - Aurangabad- II	26-Jul-11	20.52		Continued.	Over voltage.
400KV	Akola - Wardha - I	26-Jul-11	23.53		Continued.	Over Voltage.
400KV	Kolhapur-Mapusa-II	29-Jul-11	23.28	2-Aug-11	09.52	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	30-Jul-11	23.31	1-Aug-11	09.22	Over Voltage.
400KV	Karad - Solapur (PGCIL)	31-Jul-11	22.08	1-Aug-11	07.05	Over Voltage.
400KV	Akola - Wardha - II	31-Jul-11	22.03		Continued.	Over Voltage
400KV	Dhule-Sar'Sarovar - II	31-Jul-11	23.04	2-Aug-11	08.23	Over Voltage.
400KV	Bhusawal- Aurangabad	31-Jul-11	21.55	1-Aug-11	07.45	Over Voltage.
400KV	Bhusawal- Aurangabad	1-Aug-11	22.28	2-Aug-11	06.43	H/T due Over voltage.
400KV	Karad - Solapur (PGCIL)	1-Aug-11	22.40	2-Aug-11	06.44	H/T due to Over voltage.
400KV	400/220KV, 315MVA ICT-I @ New Koyna.	1-Aug-11	10.30	1-Aug-11	17.38	Maintenance works.
400KV	Dhule-S'Sarovar I	1-Aug-11	23.37	4-Aug-11	08.48	H/T for O/V.
400KV	Akola - Aurangabad - II	1-Aug-11	12.04	1-Aug-11	18.25	Opp. outage W.T. jumper tightening and amp work.
400KV	Kolhapur - Mapusa - I	2-Aug-11	18.13		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	2-Aug-11	22.10	3-Aug-11	07.33	Over Voltage.
400KV	400 KV Bus Coupler @ New Koyna	2-Aug-11	12.20	2-Aug-11	18.12	To attend D.C.leakage.
400KV	Karad - Solapur (PGCIL)	2-Aug-11	22.38	3-Aug-11	07.15	Over Voltage.
400KV	Main Bus-II at Chakan	3-Aug-11	11.50	3-Aug-11	15.41	Maintenance Work.
400KV	Main Bus - II @ Lamboti	3-Aug-11	11.04	3-Aug-11	14.56	Q.M.Work.
400KV	Bhusawal- Aurangabad	3-Aug-11	21.55	4-Aug-11	07.56	Over Voltage.
400KV	Chandrapur - Parly - III	3-Aug-11	15.01	3-Aug-11	15.51	Distance protection.
400KV	Dhule - S'Sarovar- II	3-Aug-11	23.04	5-Aug-11	06.16	Over Voltage
400KV	Lonikand- Koyna Stage IV	3-Aug-11	22.32	4-Aug-11	08.18	Over Voltage.
400KV	Karad - Solapur (PGCIL)	4-Aug-11	00.11	4-Aug-11	06.58	Over Voltage,
400KV	Lonikand - Chakan	4-Aug-11	08.35	4-Aug-11	16.20	Relay testing work.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	4-Aug-11	10.02	4-Aug-11	16.55	Testing Work.
400KV	Chandrapur - Parly - III	4-Aug-11	10.41	4-Aug-11	13.56	To attend break down of E/W at Loc.No.316 and 317.
400KV	Bus Coupler at 400KV Karad.	4-Aug-11	12.40		Continued.	400KV Jaigad-Karad stringing work.Upto 9.8.11.
400KV	Padgha - Kharghar	4-Aug-11	14.58	4-Aug-11	15.53	Attending hot spot. Taken on TBC.
400KV	Chandrapur - Bhadravati-IV	4-Aug-11	08.06	4-Aug-11	17.22	RTU DC project work by PGCIL.
400KV	400/220KV,100 MVA Spare Unit at Korady	4-Aug-11	16.28		Continued.	To attend buchholz alarm problem.
400KV	Bhusawal- Aurangabad	4-Aug-11	21.54	5-Aug-11	06.19	Over Voltage.
400KV	Karad - Solapur (PGCIL)	4-Aug-11	23.40	5-Aug-11	06.14	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	4-Aug-11	22.50	6-Aug-11	07.51	Over Voltage.
400KV	Lonikand- Koyna Stage IV	4-Aug-11	22.17	5-Aug-11	07.29	Over Voltage.
400KV	Bhusawal- Aurangabad	5-Aug-11	13.20	6-Aug-11	07.46	Over Voltage
400KV	New Koyna - Dabhol - II	5-Aug-11	13.48	6-Aug-11	02.29	Sparking on Wave Trap
400KV	Padgha - Babaleshwar - II	5-Aug-11	09.21	5-Aug-11	18.00	Bay Maint.work
400KV	Bus Coupler @ New Koyna	5-Aug-11	10.06	5-Aug-11	13.32	D.C.Leakage
400KV	400/220KV,500MVA ICT-III At Kalwa.	5-Aug-11	10.14	5-Aug-11	20.33	Commissioning of Temp.control Meter
400KV	Dhule - S'Sarovar- II	5-Aug-11	23.06	6-Aug-11	11.58	Over Voltage
400KV	400/220KV 315MVA ICT-II @ New Koyna	5-Aug-11	15.15	5-Aug-11	17.38	For attending Red Hot B phase Isolator(taken on TBC)
400KV	Lonikand- Koyna Stage IV	5-Aug-11	01.01	6-Aug-11	06.53	Over Voltage
400KV	Karad - Solapur (PGCIL)	5-Aug-11	22.11	6-Aug-11	05.47	Over Voltage
400KV	Chandrapur - Parli - II	6-Aug-11	08.03	6-Aug-11	21.09	Replacement of 3 No's C V T.
400KV	Karad - Kolhapur - II	6-Aug-11	16.37	6-Aug-11	18.56	Attending Hot Spot.

400KV	Bhusawal- Aurangabad	6-Aug-11	18.07	7-Aug-11	07.58	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	6-Aug-11	17.39	7-Aug-11	09.02	Over Voltage.
400KV	Karad - Solapur (PGCIL)	6-Aug-11	17.40	7-Aug-11	06.17	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	6-Aug-11	23.39	7-Aug-11	08.04	Over Voltage.
400KV	Karad - Kolhapur - II	6-Aug-11	22.58		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	7-Aug-11	21.44	8-Aug-11	07.07	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	7-Aug-11	14.06	8-Aug-11	07.16	Over Voltage.
400KV	Karad - Solapur (PGCIL)	7-Aug-11	22.10	8-Aug-11	06.58	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	7-Aug-11	23.53	9-Aug-11	08.55	Over Voltage.
220KV	Bus Coupler @ WPCL	7-Jun-11	17.22		Continued.	As being normally kept open.
220KV	220/100KV 125 MVA ICT-I @ Kalwa	19-Jun-11	13.45	5-Aug-11	17.38	Buchholz Augmentation by 200 MVA.Expected in Sept.2011.
220KV	100 KV Group Breaker - II at 220 kv Trombay	28-Jul-11	08:56		Continued.	CT Replacement work (up to 10/08/2011)
220KV	Urse-Sahara	1-Aug-11	05.50	1-Aug-11	06.30	Distance Protection.
220KV	Main Bus Section-I @ Mudshingi	1-Aug-11	09.15	1-Aug-11	12.33	Red hot on main bus isolator.
220KV	220/100KV 200MVA ICT-I at Mudshingi	1-Aug-11	09.15	1-Aug-11	12.34	Main Bus I outage.
220KV	220/33 KV, 50 MVA T/F @ Mudsingi	1-Aug-11	09.13	1-Aug-11	12.40	Main Bus I outage.
220KV	Urse-Sahara	1-Aug-11	13.03	1-Aug-11	17.20	Tauras measurement.
220KV	Kolhapur-Sawantwadi	1-Aug-11	12.32	1-Aug-11	12.54	Distance protection.
220KV	220 Kv Bus Section @ Temghar	1-Aug-11	12.08	1-Aug-11	12.48	To close Bus-Section Isolator.
220KV	220KV Half Bus Section I at Akola	1-Aug-11	11.10	1-Aug-11	15.40	Jumping work of 220 KV isolator of Balapur bay I.
220KV	220/132 KV,200 MVA ICT-II At Chalisgaon	1-Aug-11	09.55	1-Aug-11	12.33	For reconnecting the CT to line isolator jumpers after replacement
220KV	220/33KV 50 MVA T/F- I @ Jalna	1-Aug-11	11.06	1-Aug-11	18.55	Testing work.
220KV	220/66KV 50 MVA ICT- II @ Warora	1-Aug-11	10.30	1-Aug-11	18.06	Measurement of Tan Delta of HV C.T.
220KV	220/33 KV 100 MVA ICT - II @ Jamde	1-Aug-11	09.37	1-Aug-11	11.08	To attend Red hot on 'R' phase C.T.
220KV	Versova-Dhanu	2-Aug-11	06.17	2-Aug-11	15.08	Tripped on distance protection.
220KV	Karad Mudsingi-II	2-Aug-11	10.02	2-Aug-11	13.28	Q.M.Work
220KV	220 KV Bus @ Kandalgaon	2-Aug-11	10.00	2-Aug-11	17.45	Commissioning of new GIS Bus sectionaliser II.
220KV	Kandalgaon - Pirangut	2-Aug-11	09.37	2-Aug-11	19.05	Bus Outage at Kandalgaon.
220KV	Kandalgaon - Pophali	2-Aug-11	10.01	2-Aug-11	18.15	Bus Outage at Kandalgaon.
220KV	Kandalgaon - ONGC	2-Aug-11	09.46	2-Aug-11	19.31	Bus Outage at Kandalgaon.
220KV	Kandalgaon-Bhira	2-Aug-11	09.36	2-Aug-11	17.54	Bus Outage at Kandalgaon.
220KV	Kandalgaon - Topworth	2-Aug-11	09.42	2-Aug-11	19.40	Bus Outage at Kandalgaon.
220KV	Kandalgaon - Dasturi	2-Aug-11	09.38	2-Aug-11	19.02	Bus Outage at Kandalgaon.
220KV	Kandalgaon - Sonalloy	2-Aug-11	09.33	2-Aug-11	20.10	Bus Outage at Kandalgaon.
220KV	220/100 KV 100 MVA T/F - IV @ Kandalgaon	2-Aug-11	09.25	2-Aug-11	18.40	Bus Outage at Kandalgaon.
220KV	220/100KV 50 MVA T/F- III @ Kandalgaon	2-Aug-11	09.25	2-Aug-11	18.40	Bus Outage at Kandalgaon.
220KV	220/22 KV 50 MVA T/F-I @ K'gaon	2-Aug-11	09.54	2-Aug-11	18.20	Bus Outage at Kandalgaon.
220KV	Kalwa-Temghar	2-Aug-11	14.20	2-Aug-11	18.00	Testing work at Temghar.
220KV	Versova-Gorai	2-Aug-11	13.18	2-Aug-11	13.57	LBB Operated.
220KV	Pedambe-Newkoyana	3-Aug-11	10.00	3-Aug-11	15.00	Maintenance Work.
220KV	Sahara-Urse	3-Aug-11	10.02	3-Aug-11	17.02	String insulator replacement.
220KV	Talangade - Mudshingi - I	3-Aug-11	10.00	3-Aug-11	12.16	Q.M.Work.
220KV	Bale-Usmanabad	3-Aug-11	19.09	3-Aug-11	19.16	To control Parli ICT loading.
220KV	Vita - Lamboti	3-Aug-11	10.06	3-Aug-11	16.42	Q.M.Work
220KV	Bale-Murud	3-Aug-11	19.09	3-Aug-11	19.21	To control Parli ICT loading.
220KV	Hingoli-Pusad	3-Aug-11	16.09	4-Aug-11	11.38	To control 220KV Wardha- Y'Mal L/L.
220KV	220/100KV,200MVA ICT-I at Borivali.	3-Aug-11	15.55	3-Aug-11	17.36	Buchholz.

220KV	Vankuswadi-KDPH	3-Aug-11	15.05	4-Aug-11	01.10	To control Parli ICT loading.
220KV	Pophali - KDPH	3-Aug-11	15.05	4-Aug-11	01.15	Distance protection.
220KV	220/132 KV 200 MVA ICT @ Kawlewada	3-Aug-11	13.06	3-Aug-11	18.06	Q.M.Work
220KV	Pusad - Bhugaon	3-Aug-11	15.55	4-Aug-11	11.23	B ph.conductor broken at 113km from Pusad.
220KV	Virur - Rly TSS - I	3-Aug-11	09.52	3-Aug-11	15.27	Q.M.Work
220KV	220KV Half Main Bus Section-II at Sicom,	3-Aug-11	12.55	3-Aug-11	17.05	To attend hot spot.
220KV	Versova-Boiser	4-Aug-11	06.30	4-Aug-11	08.15	Attending chattering sound from CVT.
220KV	Lonand - Baramati	4-Aug-11	08.30	4-Aug-11	19.52	Replacement of faulty insulator Loc.No.134.
220KV	Bus Section - II @ Telco	4-Aug-11	10.15	4-Aug-11	19.14	Testing work.
220KV	Telco-Chinchwad	4-Aug-11	10.13	4-Aug-11	22.30	Replacement of relay.
220KV	Jejuri (New) - Phursungi - II	4-Aug-11	15.26	4-Aug-11	18.33	Attending hot spot on B ph.CT.
220KV	Abhijeet-Wardha-I	4-Aug-11	05.14		Continued.	To control Wardha-Y'mal line loading.
220KV	Aarey-Borivali-I	5-Aug-11	02.12	5-Aug-11	03.39	To attend hot spot.
220KV	Babhaleshwar-Nasik-II	5-Aug-11	09.15	5-Aug-11	20.55	Over Voltage
220KV	Padgha-Kamba	5-Aug-11	09.05	5-Aug-11	18.28	Bay Maint.Work
220KV	Pedambe - Pophali - II	5-Aug-11	09.40	5-Aug-11	11.25	Attending damaged conductor strands
220KV	Versova-Dhanu	5-Aug-11	09.26	5-Aug-11	16.20	Replacement of damaged Earthwire
220KV	Apta-Nagothane	5-Aug-11	11.17	5-Aug-11	14.45	Bay Maint.work
220KV	Telco-Chinchwad	5-Aug-11	11.22	5-Aug-11	22.57	Retrofitting of Relay
220KV	Malegaon-Satana	5-Aug-11	12.09	5-Aug-11	20.45	Distance Protection
220KV	Inter Connector @ Kalwa	5-Aug-11	09.21	5-Aug-11	18.10	Attending Hot Spot on CB
220KV	220/132 KV 200 MVA ICT - II @ Theur	5-Aug-11	10.57	5-Aug-11	17.05	Tandelta measurement and SFRA test
220KV	220/132 KV 250 MVA ICT at Ambazari	5-Aug-11	10.41		Continued.	ICT is to be replaced by 200 MVA ICT Upto 20.8.11.
220KV	Main Bus - I @ Aurangabad	5-Aug-11	10.50	5-Aug-11	18.20	Jumpering,Testing and Commissioning of Bus sectionlizer
220KV	Aurangabad - Padegaon - II	5-Aug-11	10.50	5-Aug-11	17.57	Jumpering,Testing and Commissioning of Bus sectionlizer
220KV	Versova - Goregaon	5-Aug-11	22.19	6-Aug-11	05.06	R phase CVT replacement
220KV	Baramati-Kalyani	6-Aug-11	08.45	6-Aug-11	18.10	Replacement of Flashover Insulator.
220KV	Main Bus-II At 220 KV BBLSR	6-Aug-11	11.27	8-Aug-11	19.40	Construction Works of L V Bay of New ICT Upto 10.8.11.
220KV	Telco-Chinchwad	6-Aug-11	10.00	6-Aug-11	21.26	C B Open @ Telco End Only,Relay Retrofitting Work.
220KV	Talangade-Ichalkaranji I	6-Aug-11	12.55	6-Aug-11	17.09	Q.M.Work @ Both End.
220KV	Pophali-K'gaon	6-Aug-11	14.30	6-Aug-11	20.55	For Y Ph Jumper Broken.
220KV	Bale-Murud	7-Aug-11	10.20	8-Aug-11	13.43	To Control Parly ICT Loading.
220KV	Bale-Osmanbad	7-Aug-11	10.20	8-Aug-11	13.43	To Control Parly ICT Loading.
220KV	Boiser - Borivali	7-Aug-11	09.48	7-Aug-11	15.18	Hot Spot.
220KV	Pedambe-Mahad	7-Aug-11	07.57	7-Aug-11	17.53	Isolator Maint.Work.
220KV	Koradi-Butibori	7-Aug-11	21.18		Continued.	Backup Protection Operated O/C & E/F
132KV	Girwali - Latur MIDC	19-Jul-11	11.09	3-Aug-11	10.23	Disc insulator strings replacement from LOC 32 to 82.
132KV	Chalisgaon - Manmad - I	1-Aug-11	14.40	1-Aug-11	16.55	Replacement of line isolator.
132KV	Kurkumbh - Daund	1-Aug-11	02.15	1-Aug-11	02.30	Trip from Kurkumbh end.
132KV	Chinchwad-Rahatri	1-Aug-11	08.39	1-Aug-11	16.56	Trip on dist. protection, conductor snapped.

132KV	Dondaicha - Nandurbar	2-Aug-11	01.25	2-Aug-11	02.45	Tripped due to flashover 'B' phase LA of 132 KV Dondaicha Ckt.
132KV	Hingoli-Hingoli II	2-Aug-11	10.52	2-Aug-11	10.58	Distance protection operated,Z-I,B-Ph.
132KV	Pench - Kanhan	2-Aug-11	07.30		Continued.	Height raising work for national highway work.
132KV	Pusad-Jambazar	3-Aug-11	20.32	3-Aug-11	20.53	Tripped at Pusad end only.
132KV	Dhule - Dhule	3-Aug-11	18.01	4-Aug-11	14.20	Y ph.conductor broken near 1st Tower.
132KV	Bhandara - Madgi -I	4-Aug-11	20.50	5-Aug-11	11.32	Low air pressure of C.B.
132KV	Chalisgaon - Manmad - I	5-Aug-11	12.18	5-Aug-11	17.00	Reconnecting CT to line Isolator Jumper
132KV	Jalgaon - Dhrangaon	5-Aug-11	08.15	6-Aug-11	10.15	Replacement of 132KV Bus Isolator
132KV	Mansar - Pench	6-Aug-11	22.08	7-Aug-11	22.20	O/C,E/F.
132KV	Paras-Malkapur	7-Aug-11	10.02	7-Aug-11	10.25	Transient Fault,R Ph.,O/C.
132KV	Amravati-Chandurbazar	7-Aug-11	18.40	7-Aug-11	19.00	Distance Protection Operated Z-I.
132KV	Pusad - Gunj	7-Aug-11	23.04	7-Aug-11	23.11	Backup Protection Operated O/C,E/F R Ph.
110KV	Borivali-Borivali Tata-II	7-Aug-11	08.39	7-Aug-11	14.38	Red Hot.
100KV	Kandalgaon-Roha-I	2-Aug-11	09.15	2-Aug-11	20.50	C.B.Problem at K'gaon.
100KV	Kandalgaon-Roha-II	2-Aug-11	09.15	3-Aug-11	22.43	C.B.Problem at K'gaon.
100KV	Kandalgaon - Mhasale	2-Aug-11	09.15	2-Aug-11	22.25	C.B.Problem at K'gaon.
100KV	K'gaon-Roha-II	4-Aug-11	15.58	4-Aug-11	17.43	Testing Work.