

LINE OUTAGES FOR THE WEEK

FROM 30-Aug-10 TO 5-Sep-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Akola - Aurangabad - I	21-Aug-10	06.06	4-Sep-10	12.28	Over Voltage.
400KV	Lonikand-Karad	29-Aug-10	06.20	30-Aug-10	10.49	Over Voltage
400KV	Koyna IV - Jejuri	30-Aug-10	23.38	31-Aug-10	09.18	Over Voltage.
400KV	Koradi - Kaparkheda	31-Aug-10	03.03	1-Sep-10	09.29	Over Voltage.
400KV	Akola - Wardha - II	1-Sep-10	01.48		Continued.	Over Voltage.
400KV	STG IV-New Koyna-II	22-Aug-10	07.30	1-Sep-10	09.08	Maintenance Work
400KV	Parli-Lonikand -I	3-Sep-10	05.33	4-Sep-10	08.46	Reactor backup port.operated at Lonikand.
400KV	Jejuri-Koyna STG-IV	5-Sep-10	04.44	5-Sep-10	09.40	Tripped on O/V.
400KV	Lonikand-Karad	5-Sep-10	07.52	5-Sep-10	09.10	Tripped on O/V.
400KV	New Koyna - Koyna Stage IV - II	22-Aug-10	07.30	30-Aug-10	16.30	Maint.Work,Ready for Charging.
400KV	STG IV-N.Koyna -I	1-Sep-10	09.40	8-Sep-10	13.50	Bay Maintenance
400KV	80 MVAR Bus Reactor @ Nagothane	1-Sep-10	10.47	1-Sep-10	18.05	To attend Isolator work
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	2-Sep-10	10.47	2-Sep-10	17.13	Q.M.Work.
400KV	400KV Bus A at Nagothane	3-Sep-10	10.45	3-Sep-10	21.43	Wave trap of Dabhol line II shifted from R to Y ph.
400KV	Lonikand-Karad	4-Sep-10	11.50	4-Sep-10	17.05	Relay testing work.
400KV	New Koyna - Dabhol - II	4-Sep-10	15.47	4-Sep-10	16.17	For filling of SF-6 gas,(line on TBC).
400KV	Chandrapur - Khaparkheda	5-Sep-10	11.54	5-Sep-10	19.30	Insulator string replacement.
400KV	Kolhapur - Mapusa - II	12-Aug-10	21.27	6-Sep-10	17.32	Over Voltage.
400KV	Bhusawal- Aurangabad	21-Aug-10	17.58	6-Sep-10	09.09	Over Voltage
400KV	Dhule - S'Sarovar - II	26-Aug-10	22.08	13-Sep-10	10.47	Over Voltage.
400KV	Karad - Kolhapur - II	27-Aug-10	23.01	15-Sep-10	13.01	Over Voltage.
400KV	Wardha - Akola - I	28-Aug-10	12.25	12-Sep-10	22.19	Change Over
400KV	Karad-Lamboti	28-Aug-10	22.44	30-Aug-10	10.27	Over Voltage
400KV	Lonikand- Koyna Stage IV	30-Aug-10	01.30	30-Aug-10	08.30	H/T for O/V.
400KV	Dhule - Babhaleshwar - I	30-Aug-10	22.50	31-Aug-10	10.36	Over Voltage.
400KV	Dhule-Khandwa-I	30-Aug-10	01.07	3-Sep-10	08.15	Over Voltage.
400KV	Karad-Lamboti	30-Aug-10	21.48	31-Aug-10	10.39	Over Voltage.
400KV	Karad-Lamboti	31-Aug-10	20.42	1-Sep-10	09.45	Over Voltage.
400KV	Lonikand- Koyna Stage IV	31-Aug-10	22.58	1-Sep-10	10.58	Over Voltage.
400KV	Karad-Lamboti	1-Sep-10	22.28	3-Sep-10	17.18	Over Voltage

400KV	Lonikand- Koyna Stage IV	1-Sep-10	23.31	4-Sep-10	11.29	Over Voltage
400KV	Dhule-S' Sarovar I	4-Sep-10	00.29	4-Sep-10	08.10	H/T for O/V.
400KV	Akola - Aurangabad - II	4-Sep-10	12.29		Continued.	Over Voltage.
400KV	Chandrapur - Khaparkheda	4-Sep-10	19.10	10-Sep-10	16.37	Over Voltage.Ready for charging @ 19.30 Hrs.dt 5'th Sept.
400KV	Karad-Lamboti	4-Sep-10	22.41	5-Sep-10	11.27	H/T for O/V.
400KV	Dhule-Sar'Sarovar - I	4-Sep-10	23.17	6-Sep-10	09.28	H/T for O/V.
400KV	Karad-Lamboti	5-Sep-10	22.06	6-Sep-10	11.40	H/T For O/V.
220KV	Kalwa-Mulund II	29-Aug-10	23.59	30-Aug-10	00.39	Tripped.taaken on TBC.
220KV	220/33 KV 50 MVA T/F I @ Boisar II	30-Aug-10	23.25	31-Aug-10	12.24	Y Ph L V Conductor Snapped.
220KV	Babaleshwar - Nagar - I	31-Aug-10	21.35	31-Aug-10	22.07	Dist.Prot.
220KV	220/100 KV T/F - IV @ Chinchwad	30-Aug-10	22.58	31-Aug-10	01.02	Shorting of Wire in Control Panel.
220KV	220/132KV 100MVA ICT-II @ Chalisgaon	31-Aug-10	15.04	1-Sep-10	09.10	H V Side Y Ph. L A Burst.
220KV	220/132 KV100 MVA ICT-I @ Chalisgaon	31-Aug-10	15.04	31-Aug-10	15.42	Bus Fault.
220KV	Babaleshwar - Chalisgaon	31-Aug-10	15.04	31-Aug-10	15.40	Bus Fault.
220KV	Chalisgaon - Malegaon	31-Aug-10	15.04	31-Aug-10	16.35	Bus Fault.
220KV	Dhule-Chalisgaon	31-Aug-10	15.04	31-Aug-10	16.11	Bus Fault.
220KV	Bhusawal - Chalisgaon - II	31-Aug-10	15.04	31-Aug-10	15.36	Bus Fault.
220KV	Chalisgaon-BSL-I	31-Aug-10	15.04	31-Aug-10	15.41	Bus Fault.
220KV	Bhigwan-BILT	1-Sep-10	07.20	1-Sep-10	10.50	Distance Protection
220KV	220/100KV 200MVA T/F - I at Apta	1-Sep-10	18.40	2-Sep-10	18.34	30D OLTC Buchholz Trip
220KV	Kalwa-Mulund II	2-Sep-10	10.13	2-Sep-10	10.40	Tripped without indication at kalwa end only(Taken on TBC)
220KV	Finolex-New Koyna	3-Sep-10	12.57	3-Sep-10	13.43	Dist.Protection
220KV	220 KV Bus Coupler @ Ambazari.	3-Sep-10	18.30	3-Sep-10	18.57	Tripped on O/C, E/F.
220KV	Pedambe - Tambati	5-Sep-10	14.02	5-Sep-10	14.50	Tripped on Dist.protection.
220KV	220/132 KV 100MVA ICT I at Pusad	5-Sep-10	18.21	5-Sep-10	19.03	Tripped on O/C and E/F protection Due to C.B.Problem of 132KV Gunj ckt.
220KV	220/132KV 100 MVA ICT II at Pusad	5-Sep-10	18.21	5-Sep-10	19.06	Tripped on O/C and E/F protection due to C.B.Problem of 132KV Gunj ckt.
220KV	Bus Section - II @ Nasik	30-Aug-10	11.02	5-Sep-10	15.28	Replacement of Bus Section - II c.b. & 6 No's of C T's.
220KV	Wada-Kolshet	30-Aug-10	12.17	30-Aug-10	21.50	Outage.
220KV	Padgha - Nalasopara	30-Aug-10	12.30	30-Aug-10	22.17	Insulator Replacement.(Bkr Charged from Padgha end only)
220KV	Boiser-PGCIL-I	30-Aug-10	06.14	31-Aug-10	09.25	Red Hot Attending.
220KV	Main Bus @ Mumewadi	30-Aug-10	09.55	30-Aug-10	16.09	Q.M.Work.
220KV	Vita - Pandharpur	31-Aug-10	09.27	31-Aug-10	18.20	Replacement of Insulator.
220KV	220/100 KV 200 MVA ICT-II @ Apta	31-Aug-10	11.53	31-Aug-10	18.15	Buchholz Relay Replacement.
220KV	Pedambe-Newkoyna	1-Sep-10	08.05	1-Sep-10	16.50	Bay Maintenance
220KV	Kalwa-Colourchem	1-Sep-10	10.27	1-Sep-10	18.47	To attend Hot Spot
220KV	Lote- Dasturi	1-Sep-10	14.45	1-Sep-10	17.33	Replacement of Faulty C.C.
220KV	220/132KV 200MVA ICT at Bale	1-Sep-10	10.00	1-Sep-10	14.10	R.M.Work
220KV	ONGC-JNPT	1-Sep-10	11.48	1-Sep-10	17.43	R.M.Work
220KV	Usmanabad --Bale	1-Sep-10	09.25	1-Sep-10	18.25	WT replacement work
220KV	Main Bus At Wardha	1-Sep-10	10.55	1-Sep-10	12.12	For connecting Jumpers of 220KV Bus Isolator
220KV	Hinganghat - Rly TSS - I	1-Sep-10	16.54	1-Sep-10	18.58	For testing of metering CT
220KV	Hinganghat - RLY TSS - II	1-Sep-10	12.37	1-Sep-10	16.35	For testing of Metering CT
220KV	Pedambe-Pophali I	2-Sep-10	08.00	2-Sep-10	17.20	Prev.maintenance work.
220KV	Boiser-Versova	2-Sep-10	07.31	2-Sep-10	12.00	Attended hot spot and Testing work.
220KV	Bus Coupler at Padgha	2-Sep-10	09.32	2-Sep-10	11.56	Attending hot spot.
220KV	Peth-Mudsingi-I	2-Sep-10	09.55	2-Sep-10	11.23	C.B.problem at Peth.
220KV	Hinjewadi-I-Chinchwad	2-Sep-10	10.25	2-Sep-10	17.11	To attend red hot at Hinjewadi-I S/S.
220KV	Badnera-Akola Ckt.I	2-Sep-10	10.05	2-Sep-10	13.05	Q.M.Work.
220KV	Badnera-Akola-II	2-Sep-10	13.24	2-Sep-10	16.41	Q.M.Work.
220KV	Pedambe - Mahad	3-Sep-10	08.05	3-Sep-10	17.10	To attend damaged Y Ph.conductor.
220KV	Talangade-Mudshingi	3-Sep-10	09.25	3-Sep-10	18.41	Coating of 220 KV Insulator string.
220KV	Talandgade-Ichalkaranj -II	3-Sep-10	10.52	3-Sep-10	17.16	Q.M.Work
220KV	220/100KV 125 MVA ICT-I @ Kalwa	3-Sep-10	08.15	3-Sep-10	10.15	For attending Y-Ph, T/F isolator clamp.
220KV	Nasik-Kalwa-III	3-Sep-10	13.15	3-Sep-10	16.58	Wave trap taken in to service.
220KV	Aurangabad-Chitegaon-I	3-Sep-10	08.14	3-Sep-10	18.49	Tower erection work.

220KV	Aurangabad-Chitegaon-II	3-Sep-10	08.15	3-Sep-10	20.00	Tower erection work.
220KV	220/132KV 100 MVA ICT II at Pusad	3-Sep-10	14.40	3-Sep-10	18.08	Measurement of tan delta of HV/LV side of ICT,HV/LV side of CT.
220KV	220/132 KV 100MVA ICT I at Pusad	3-Sep-10	09.30	3-Sep-10	13.45	Measurement of tan delta of HV/LV side of ICT,HV/LV side of CT.
220KV	Babaleshwar - Babaleshwar - I	4-Sep-10	06.16	4-Sep-10	23.16	Repl.of CTs by New CTs under LES.
220KV	Babaleshwar - Nagar - I	4-Sep-10	08.30	4-Sep-10	19.36	Repl. of faulty disc insulator.
220KV	Raymond-Washala	4-Sep-10	10.30	4-Sep-10	17.55	Maintenance work.
220KV	Kalwa - Khargar	4-Sep-10	10.29	4-Sep-10	14.19	To attend Dc leakage and'C'isolator alignment.
220KV	220/33 KV 50 MVA ICT-II @ Boisar	4-Sep-10	11.23	4-Sep-10	12.42	For jumper repl. work.
220KV	220/66KV 50 MVA ICT- II @ Warora	4-Sep-10	11.43	4-Sep-10	16.43	Q.M.Work.
220KV	Bus Section -II @ Pophali	5-Sep-10	07.15	5-Sep-10	17.30	R-Ph Main Bus Conductor Connecting To Junction Bay Second Stage Isolator
220KV	Chakan-Volkswagen	5-Sep-10	10.00	5-Sep-10	15.35	Q.M.Work
220KV	Kalwa-Nasik	1-Sep-10	10.34	1-Sep-10	13.24	H/T due to outage of Kalwa-Colourchem
220KV	220/132 KV 200 MVA ICT @ Ambazari	31-Aug-10	20.04	1-Sep-10	00.01	Due to sparking on 220KV Y phase Isolator
220KV	Kalwa - Khargar	31-Aug-10	13.15	31-Aug-10	15.54	Red Hot.
220KV	Mulund-Trombay	2-Sep-10	14.30	2-Sep-10	16.15	YPh.Bus isolator work.
220KV	Kalwa-Mulund	4-Sep-10	15.57	4-Sep-10	18.35	To attend Red Hot spot between CT and isolator.
220KV	Bus Coupler at Ambazari	3-Sep-10	20.55	4-Sep-10	12.02	Tripped on O/C,E/F.
132KV	Kalmeshwar-Hingna-II	28-Aug-10	14.10	31-Aug-10	21.00	Distance Protection
132KV	Ambazari-Kalmeshwar	28-Aug-10	17.12	31-Aug-10	21.00	Tripped
132KV	Paras-Malkapur	1-Sep-10	04.30	1-Sep-10	18.20	Tripped due to Y phase CT caught Fire at Paras
132KV	Sanaswadi-SPSL	2-Sep-10	05.05	2-Sep-10	10.30	Trip, R-N fault.
132KV	Kothrud-Phursungi	2-Sep-10	19.35	3-Sep-10	11.10	Distance protection.
132KV	Bhusawal - Jalgaon - II	3-Sep-10	20.09	3-Sep-10	20.48	Bus Bar Protection Operated.
132KV	Bhusawal - Nimbhora	3-Sep-10	20.09	3-Sep-10	20.47	Bus Bar Protection Operated.
132KV	Deepnagar-Khadka II	3-Sep-10	20.09	3-Sep-10	20.48	Bus Bar Protection Operated.
132KV	132 KV Kalmeshwar-Saoner	4-Sep-10	17.19	4-Sep-10	18.09	Dist.Protection
132KV	Pusad-Jambazar	5-Sep-10	18.21	5-Sep-10	19.14	Tripped due to C.B.problem of 132 KV Gunj ckt.
132KV	Pusad - Digras	5-Sep-10	18.21	5-Sep-10	19.15	Tripped due to C.B.problem of 132KV Gunj ckt.
132KV	Pusad-Umarkhed	5-Sep-10	18.21	5-Sep-10	19.26	Tripped due to C.B.problem of 132KV Gunj ckt.
132KV	Pusad - Gunj	5-Sep-10	18.21	5-Sep-10	22.00	C.B.problem.
132KV	Boiser - Viraj	3-Sep-10	10.18	3-Sep-10	16.56	Damaged conductor replacement work.
132KV	Bhusawal - Muktainagar	3-Sep-10	20.12	3-Sep-10	20.52	H/T For controlling line loading.
132KV	Kalmeshwar-Katol	4-Sep-10	10.32	4-Sep-10	12.22	To attending red hot spot.
132KV	Ujani-Umarga	5-Sep-10	13.15	5-Sep-10	14.15	Hot Spot on Y-Ph Isolator.