

LINE OUTAGES FOR THE WEEK

FROM 5-Sep-11 TO 11-Sep-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Kolhapur - Mapusa - II	27-Aug-11	22.09	5-Sep-11	19.35	Over Voltage
400KV	Akola - Bhusawal	1-Sep-11	21.52	5-Sep-11	21.45	Over Voltage.
400KV	Karad - Solapur (PGCIL)	3-Sep-11	09.06	9-Sep-11	14.21	Over voltage.
400KV	Solapur - Solapur (PG)	3-Sep-11	10.37	9-Sep-11	07.34	Over voltage.
400KV	Chandrapur - Parli - III	3-Sep-11	21.46	6-Sep-11	06.07	Over voltage.
400KV	Dhule-Khandwa-II	3-Sep-11	16.27	7-Sep-11	19.38	Over Voltage
400KV	Bhusawal- Aurangabad	3-Sep-11	13.32	10-Sep-11	16.16	Over Voltage
400KV	Dhule-S'Sarovar I	4-Sep-11	04.20	6-Sep-11	06.20	Over Voltage.
400KV	Lonikand- Koyna Stage IV	4-Sep-11	22.55	5-Sep-11	09.09	Over Voltage
400KV	Dhule - Babhaleshwar - I	5-Sep-11	14.03	5-Sep-11	14.10	Main Bus-II Outage at BBLSR
400KV	Padgha - Babaleshwar - II	5-Sep-11	21.20	5-Sep-11	23.44	Charging M.B-II@BBLSR for 1st time charging of 500MVA ICT-III
400KV	Koradi - Bhusawal	5-Sep-11	21.48	6-Sep-11	08.57	To attend Red Hot Spot at BSL end
400KV	Main Bus- II @ Babaleshwar	5-Sep-11	14.21	5-Sep-11	23.43	Connecting new 400KV M.B.II to existing M.B.II
400KV	Lonikand- Koyna Stage IV	5-Sep-11	23.15	6-Sep-11	07.35	Over Voltage
400KV	Kolhapur - Mapusa - I	5-Sep-11	23.19	7-Sep-11	09.24	Over Voltage
400KV	Kalwa - Padgha - II	6-Sep-11	01.05	6-Sep-11	06.13	Tripped at Kalwa end only.
400KV	Jejuri-Koyna STG-IV	6-Sep-11	05.35	6-Sep-11	08.48	Over Voltage
400KV	Jejuri-Koyna STG-IV	6-Sep-11	08.48	6-Sep-11	09.19	Distance Protection.
400KV	Chandrapur-Bhadravti - I	6-Sep-11	10.34	6-Sep-11	11.03	Distance Protection.
400KV	C'pur-Parli II	6-Sep-11	20.00	7-Sep-11	07.22	Over Voltage.
400KV	Akola - Bhusawal	6-Sep-11	23.00		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	6-Sep-11	22.33	7-Sep-11	08.39	Over Voltage
400KV	Dhule-Sar'Sarovar - II	7-Sep-11	00.49	7-Sep-11	10.15	Over Voltage.
400KV	400/220 KV 315 MVA ICT- I @ Nagothane	7-Sep-11	10.43	7-Sep-11	14.48	Bay maint.testing work.
400KV	Main Bus - I @ Lamboti.	7-Sep-11	12.06	7-Sep-11	15.19	Q.M.Work
400KV	400/220 KV 500 MVA ICT-II at Lamboti	7-Sep-11	12.06	7-Sep-11	15.20	Q.M.Work
400KV	400/220KV 315MVA ICT-I at Kharghar	7-Sep-11	09.10	10-Sep-11	16.10	NDR.
400KV	Jejuri-Koyna STG-IV	7-Sep-11	22.02	8-Sep-11	09.03	Over Voltage.
400KV	Koradi-Khaparkheda II	7-Sep-11	13.07	7-Sep-11	14.32	Ckt on TBC,attend SF6 gas leakage.
400KV	Chandrapur - Parli - III	7-Sep-11	23.47	8-Sep-11	07.16	Over Voltage.
400KV	Dhule-Khandwa-I	7-Sep-11	23.53	9-Sep-11	06.35	Over Voltage.
400KV	Kolhapur - Mapusa - II	7-Sep-11	22.56	8-Sep-11	10.22	Over voltage.
400KV	Lonikand- Koyna Stage IV	8-Sep-11	21.26	9-Sep-11	09.57	Over Voltage.
400KV	Kolhapur - Mapusa - I	8-Sep-11	22.31		Continued.	Over Voltage.
400KV	Bus Coupler @ Babaleshwar	8-Sep-11	08.51	8-Sep-11	12.50	For charging of new ICT-III.
400KV	400/220KV 500MVA ICT-III at Bableshwar	8-Sep-11	10.00	8-Sep-11	10.08	New ICT charge,(kept on humming)
400KV	Karad-New Koyna II	8-Sep-11	09.17	8-Sep-11	16.59	Commissioning of New Bus at Karad.
400KV	Parli - Chandrapur - III	8-Sep-11	22.58	9-Sep-11	05.50	Over Voltage.
400KV	Jejuri-Koyna STG-IV	8-Sep-11	23.02	9-Sep-11	07.32	Over Voltage.
400KV	400/220KV 500MVA ICT-III at Bableshwar	8-Sep-11	10.08	10-Sep-11	20.05	New ICT(Load Taken)
400KV	New Koyna - Koyna Stage IV - II	9-Sep-11	04.58	9-Sep-11	07.47	Over Voltage.
400KV	Jejuri-Koyna STG-IV	9-Sep-11	21.36	10-Sep-11	07.50	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	9-Sep-11	21.36	10-Sep-11	10.50	Over Voltage.
400KV	400/220 KV 315 MVA ICT - I @ Aurangaba	9-Sep-11	13.17	9-Sep-11	15.29	Repl.of Oil Drainage Valve(ICT is on TBC)
400KV	Karad - Solapur (PGCIL)	9-Sep-11	22.45	10-Sep-11	16.10	Over Voltage.
400KV	C'pur-Parli II	10-Sep-11	00.41	10-Sep-11	07.33	Over Voltage.
400KV	Dhule-Khandwa-II	10-Sep-11	00.48	10-Sep-11	08.51	Over Voltage

400KV	Karad - Solapur (PGCIL)	10-Sep-11	18.24		Continued.	Over Voltage
400KV	400/220 KV 315MVA ICT-II @ Karad	10-Sep-11	11.00	10-Sep-11	16.09	Hot Spot and Q.M.work
400KV	Bhusawal- Aurangabad	10-Sep-11	22.59	11-Sep-11	07.54	Over Voltage
400KV	Dhule-Khandwa-I	10-Sep-11	22.47	11-Sep-11	09.16	Over Voltage
400KV	Chandrapur - Parli - III	10-Sep-11	22.11	11-Sep-11	05.34	Over Voltage
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	11-Sep-11	08.47	11-Sep-11	13.18	To attend Red Hot
400KV	Bhusawal- Aurangabad	11-Sep-11	17.37		Continued.	Over Voltage
400KV	Lonikand- Koyna Stage IV	11-Sep-11	22.55		Continued.	Over Voltage
400KV	Dhule-Sar'Sarovar - I	11-Sep-11	23.13		Continued.	Over Voltage
220KV	Chandrapur - Warora	2-Sep-11	12.47	5-Sep-11	00.05	To control WRR-WRD Hinganghat loading.
220KV	Dhule-Chalisgaon	4-Sep-11	10.05	8-Sep-11	11.30	Bus side Isolator replacement work(Ckt charged Through TBC)
220KV	220/132 KV 200 MVA ICT - II @ Parbhani	4-Sep-11	18.40	5-Sep-11	12.17	PRV Operated
220KV	Pedambe-Kharepatan	5-Sep-11	03.45	5-Sep-11	16.00	Distance Protection(Declared Faulty)
220KV	Pophali - Kandalgaon	5-Sep-11	05.45	5-Sep-11	06.30	Distance Protection
220KV	Pedambe - Pophali	5-Sep-11	10.45	5-Sep-11	14.30	Red Hot Spot
220KV	Talandgade-Ichalkaranj -II	5-Sep-11	10.50	5-Sep-11	17.02	Q.M.Work
220KV	Pophali - Kandalgaon	5-Sep-11	13.00	5-Sep-11	13.40	R Phase E/F
220KV	220/132 KV 200 MVA ICT - II @ Malegaon	5-Sep-11	13.51	5-Sep-11	19.43	Tan Delta Measurement
220KV	New Paras TPS - Chikhali - I	5-Sep-11	10.09	5-Sep-11	15.12	Bus Section I Outage for Jumpering work
220KV	220/132 KV 100 MVA T/F - II @ Peth	6-Sep-11	10.00	6-Sep-11	14.05	R.M.Work.
220KV	Miraj -Ichalkarajni	6-Sep-11	09.51	6-Sep-11	14.45	R.M.Work.
220KV	Karad - Miraj	6-Sep-11	14.36	6-Sep-11	17.28	R.M.Work.
220KV	Pedambe-Pophali I	6-Sep-11	21.35	6-Sep-11	22.35	To Attend R Ph. C T Jumper Red Hot.
220KV	220 KV Bus Coupler @ New Koyna	6-Sep-11	21.18	6-Sep-11	21.48	Over Current.
220KV	Lote - N.Koyna	6-Sep-11	21.18	7-Sep-11	01.24	Distance Protection.
220KV	Lote- Dasturi	6-Sep-11	21.18	6-Sep-11	22.35	Distance Protection.
220KV	220/132 KV 200 MVA ICT - II @ Malegaon	6-Sep-11	10.52	6-Sep-11	22.41	L V Side Twin Conductor Work.
220KV	220/22KV 50 MVA T/F III at Chakan	6-Sep-11	22.23	6-Sep-11	23.12	R Ph.C T Burst of 22KV Bus Section.
220KV	Padgha - Nalasopara	7-Sep-11	11.20	7-Sep-11	16.04	Red Hot attending work.
220KV	Vita - Pandharpur	7-Sep-11	10.40	7-Sep-11	14.12	Q.M.Work
220KV	220/132 KV 200 MVA ICT - II @ Bale	7-Sep-11	14.25	7-Sep-11	15.25	Checking of D.C.leakage.
220KV	220/132 KV 200 MVA ICT- I @ Bale	7-Sep-11	15.28	7-Sep-11	16.54	Checking of D.C.earth leakage.
220KV	220/132 KV 200 MVA ICT - II @ Malegaon	7-Sep-11	10.18	7-Sep-11	18.12	Twin conductor replacement.
220KV	Sahara-Urse	7-Sep-11	20.13	8-Sep-11	05.16	Dist.Protection
220KV	Virur - Railway TSS-II	7-Sep-11	13.25	7-Sep-11	14.50	Replacement of faulty disc insulator.
220KV	Tillary-Amona	8-Sep-11	12.32	8-Sep-11	17.22	Red Hot on Y-Ph.
220KV	Wardha - Yawatmal	8-Sep-11	11.16	8-Sep-11	14.25	To attend Hot Spot and CT tan delta measurement work.
220KV	220/132 KV,200 MVA ICT-II At Chalisgaon	8-Sep-11	11.58		Continued.	ICT taken on TBC for bus isolator replacement work.
220KV	Khaparkheda-Kawlewada-I	8-Sep-11	14.08	10-Sep-11	13.20	BKR O/H Work,taken on TBC.
220KV	Pophali - Kandalgaon	9-Sep-11	08.05	9-Sep-11	15.40	Preventive maintenance.
220KV	Wada-Kolshet	9-Sep-11	09.11	9-Sep-11	18.44	Red Hot and R.M.Work
220KV	Dhule - Malegaon	9-Sep-11	09.52	9-Sep-11	13.30	Q.M.Work
220KV	Babaleshwar - Nagar - II	9-Sep-11	10.41	9-Sep-11	17.30	Taking Auto recloser scheme in service.
220KV	Kandalgaon-Bhira	9-Sep-11	11.25	9-Sep-11	18.30	Stringing of conductor of new 220KV Vile-Bhagad line.
220KV	Jambhul - Anandnagar	9-Sep-11	11.05	9-Sep-11	16.40	Attended hot spot on wave trap.
220KV	Boiser - Tarapur	9-Sep-11	10.23	9-Sep-11	13.54	R.M.Work and Testing work
220KV	Wardha - Deoli (PGCIL)	9-Sep-11	11.13	9-Sep-11	16.38	Attended hot spot.

220KV	Trombay-Kalwa	9-Sep-11	17.10	9-Sep-11	17.27	Distance protection.
220KV	Kalmeshwar-Ambazari	9-Sep-11	08.49	9-Sep-11	18.50	Replacement of Disc Insulator
220KV	Virur - Gadchiroli	9-Sep-11	12.45	9-Sep-11	15.09	Signature Analysis
220KV	Bhugaon-Pusad	9-Sep-11	14.30	9-Sep-11	15.23	Fixing of Nut to R phase String
220KV	220/132 KV 200 MVA ICT - I @ Kalmeshwa	9-Sep-11	11.19	9-Sep-11	13.48	To attend CT Problem
220KV	Pusad-Nanded	9-Sep-11	14.26	9-Sep-11	15.36	In view of Pusad-Bhugaon Outage
220KV	Hingoli-Pusad	9-Sep-11	11.04	9-Sep-11	16.53	In view of Wardha-Deoli outage
220KV	220/132 KV 200 MVA ICT -IV. at Padegaon	9-Sep-11	10.16	9-Sep-11	16.00	Q.M.Work
220KV	Raymond-Washala	10-Sep-11	10.00	10-Sep-11	15.56	Carrier Prot.commissioning work
220KV	220/100 KV 200 MVA T/F IV @ Apta	10-Sep-11	10.57	10-Sep-11	16.13	LV Breaker problem and Q.M.Work
220KV	220/132 KV,200MVA ICT-I at Nasik GCR	10-Sep-11	09.08	10-Sep-11	14.45	SFRA Test and Tan Delta measurement
220KV	Bus Coupler at BBLSR	10-Sep-11	18.10	10-Sep-11	21.39	To take New ICT-III in service
220KV	Kalmeshwar-Ambazari	10-Sep-11	08.35	10-Sep-11	18.09	Repl.of Cut point Disc Insulator
220KV	Boiser-Versova	11-Sep-11	06.48	11-Sep-11	09.54	C.T.Replacement
220KV	Babaleswar - Nagar - I	11-Sep-11	19.54	11-Sep-11	21.19	Breaker problem
220KV	Karad - Kiniwathar	11-Sep-11	21.15	12-Sep-11	05.55	Distance Protection
220KV	Wardha - Deoli (PGCIL)	11-Sep-11	09.55	11-Sep-11	15.00	Jumpering work
220KV	Hingoli-Pusad	11-Sep-11	10.10	11-Sep-11	15.07	In view of Wardha-Deoli outage
220KV	Miraj-Maisal	11-Sep-11	23.18	12-Sep-11	00.15	Distance Protection
132KV	Ambazari-Arvi	4-Sep-11	23.50	5-Sep-11	00.50	Distance Protection
132KV	Pusad - Umarkhed	5-Sep-11	00.20	5-Sep-11	00.27	Distance Protection
132KV	Daund-Shrigonda	5-Sep-11	05.10	5-Sep-11	05.20	Distance Protection
132KV	Kalmeshwar-Saoner	5-Sep-11	17.55	5-Sep-11	18.05	Distance Protection
132KV	Mansar - PENCH	6-Sep-11	10.55	6-Sep-11	19.10	Breaker Overhoulng Work.
132KV	Mul-Sindewahi	7-Sep-11	13.45	8-Sep-11	11.05	Breaker pole replacement.
132KV	Akola - Paras-II	9-Sep-11	03.15	9-Sep-11	03.31	Distance Protection
132KV	Ambazari - Mankapur	9-Sep-11	12.15	9-Sep-11	13.12	Tripped while Testing work
132KV	Hingna-Mankapur-I	9-Sep-11	12.15	9-Sep-11	13.12	Tripped while Testing work
132KV	Paras - Warwat Bakal	9-Sep-11	22.45	10-Sep-11	12.55	R Phase E/F (Declared Faulty)
132KV	Parbhani - Pathri	10-Sep-11	13.34	10-Sep-11	14.50	Replacement of R phase Disc
132KV	Gondia - Amgaon Railway	11-Sep-11	16.20	11-Sep-11	16.27	Backup Protection
132KV	Nanded - Umri	11-Sep-11	04.52	11-Sep-11	04.58	Distance Protection
110KV	Pandharpur - Barshi	6-Sep-11	15.00	6-Sep-11	15.05	Transient Fault.