

LINE OUTAGES FOR THE WEEK

FROM 4-Oct-10 TO 10-Oct-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Wardha - Akola - I	21-Sep-10	17.45	8-Oct-10	17.53	Interchange
400KV	Kolhapur-Mapusa-II	1-Oct-10	22.14	4-Oct-10	10.30	Over Voltage.
400KV	Karad - Kolhapur - I	2-Oct-10	23.12	7-Oct-10	09.00	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	3-Oct-10	13.44	4-Oct-10	08.24	For Dhule ICT loading.
400KV	Bhusawal- Aurangabad	3-Oct-10	18.02	11-Oct-10	09.01	Over Voltage.
400KV	Karad-Lamboti	3-Oct-10	20.08	4-Oct-10	11.38	Over Voltage.
400KV	Akola - Aurangabad- II	3-Oct-10	17.38	22-Oct-10	14.43	Over Voltage.
400KV	Lonikand- Koyna Stage IV	4-Oct-10	00.04	4-Oct-10	08.28	Over Voltage
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	4-Oct-10	12.10	4-Oct-10	16.12	Q.M and Testing work.
400KV	400/220KV 315MVA ICT-II @ New Koyna	4-Oct-10	11.43	5-Oct-10	18.38	NDR Operated.
400KV	Chandrapur - Parli - I	4-Oct-10	15.50	4-Oct-10	16.24	Distance protection.
400KV	Dabhol-Nagothane - II	4-Oct-10	18.35	4-Oct-10	19.22	Distance protection.
400KV	Kolhapur - Mapusa - I	4-Oct-10	22.44	5-Oct-10	09.31	Over Voltage
400KV	Dhule - S'Sarovar- II	4-Oct-10	22.45	5-Oct-10	10.38	Over Voltage.
400KV	Karad-Lamboti	4-Oct-10	23.31	5-Oct-10	08.38	Over Voltage.
400KV	Lonikand- Koyna Stage IV	5-Oct-10	00.03	5-Oct-10	08.40	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	5-Oct-10	16.24	6-Oct-10	13:17	Main I and II protection operated R Ph.
400KV	Padgha -Tarapur - I	5-Oct-10	18.46	5-Oct-10	19.32	Distance protedtion,Main I and II protection operated.
400KV	Kolhapur - Mapusa - II	5-Oct-10	22.07	6-Oct-10	09:50	Over Voltage.
400KV	Lonikand- Koyna Stage IV	5-Oct-10	22.51	6-Oct-10	08:21	Over Voltage.
400KV	Parli - Solapur	6-Oct-10	08:59	6-Oct-10	23:25	For WRTMPL line crossing.
400KV	Karad - Solapur(Lamboti)	6-Oct-10	08:40	7-Oct-10	09.35	For WRTMPL line crossing.
400KV	Padgha - Babaleshwar - II	6-Oct-10	09:33	6-Oct-10	19:10	Insulator string Repl.
400KV	Lonikand- Koyna Stage IV	6-Oct-10	23:57	7-Oct-10	08.16	Over Voltage.
400KV	Dhule-S'Sarovar I	6-Oct-10	13:46	7-Oct-10	15.58	Over Volatge.
400KV	Karad - Kolhapur - II	7-Oct-10	02:48	13-Oct-10	16.20	Over Voltage.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	7-Oct-10	09.55	7-Oct-10	19.30	Q.M.Work,Attending Hot Spot.
400KV	400/220KV 315MVA ICT-II @ New Koyna	7-Oct-10	10.19	7-Oct-10	17.16	Cable Replacement Work.
400KV	Dabhol-Nagothane - II	7-Oct-10	19.06	7-Oct-10	19.36	Trip.
400KV	Lonikand- Koyna Stage IV	7-Oct-10	23.57	8-Oct-10	08.47	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	8-Oct-10	00.18	8-Oct-10	10.44	Over Voltage.
400KV	Padgha - Nagothane - I	8-Oct-10	09.03	8-Oct-10	18.13	Bay Maintenance Work.
400KV	Wardha - Akola - II	8-Oct-10	17.55		Continued.	Normal Changeover.
400KV	Kolhapur - Mapusa - I	8-Oct-10	23.21	9-Oct-10	11.43	Over Voltage.
400KV	Lonikand- Koyna Stage IV	9-Oct-10	00.49	9-Oct-10	08.13	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	9-Oct-10	01.05	9-Oct-10	11.43	Over Voltage.
400KV	Lonikand- Koyna Stage IV	9-Oct-10	23.35	10-Oct-10	08.40	Over Voltage.
400KV	Kolhapur-Mapusa-II	9-Oct-10	22.55	11-Oct-10	11.29	Over Voltage.
400KV	Dhule - S'Sarovar- II	9-Oct-10	23.40	10-Oct-10	08.28	Over Voltage.
400KV	400/220 KV 500 MVA ICT-II at Lamboti	10-Oct-10	15.28		Continued.	Y-Ph Buchloz.
400KV	Lonikand- Koyna Stage IV	10-Oct-10	23.48	11-Oct-10	08.31	Over Voltage.
220KV	Main breaker of Chalisgaon-Malegaon Ckt.	27-Sep-10	11.07	15-Oct-10	10.40	Main breaker replacement.Ckt.is on TBC.
220KV	220/132 KV 100 MVA ICT @ Parli - I	1-Oct-10	11.26	5-Oct-10	11.33	Replacement of isolator.
220KV	220/132 KV 100 MVA ICT @ Bhandara	2-Oct-10	17.28	4-Oct-10	16.58	L.V.Bkr.replacement work.
220KV	Pedambe-Kharepatan	3-Oct-10	19.37	4-Oct-10	17.40	Distance protection.

220KV	220/132 KV 250 MVA ICT at Ambazari	3-Oct-10	06.00	6-Oct-10	14.13	Oil filtration of ICT.
220KV	Bablesghwar-Nasik-I	4-Oct-10	07.50	5-Oct-10	23.10	For repl. of old Aux.Bus(29C)isolator and line isolator(29D)
220KV	Karad - Nigade	4-Oct-10	10.54	4-Oct-10	15.34	Q.M.Work.
220KV	Kalwa - Borivali	4-Oct-10	16.31	4-Oct-10	18.21	Replacement of isolator work.
220KV	Apta-Kalwa	4-Oct-10	14.00	4-Oct-10	14.56	Distance protection.
220KV	Kalwa-Taloja	4-Oct-10	14.00	4-Oct-10	14.33	Distance protection.
220KV	Nasik - Ghatghar	4-Oct-10	16.07	4-Oct-10	16.42	Distance protection.
220KV	Akola - Badnera - I	4-Oct-10	09.39	4-Oct-10	16.57	Maintenance of line side isolator and Q.M.work.
220KV	Main Bus-I & Bus Section @ Parli - I	4-Oct-10	11.34	4-Oct-10	18.42	Replacement of Main Bus-I section isolator clamp.
220KV	RLY TSS CKT-I AT WARORA	4-Oct-10	13.25	4-Oct-10	16.30	Testing work of CT and PT.
220KV	Karad-Pedambe	5-Oct-10	09.15	5-Oct-10	15.32	Disc insulator replacement .
220KV	Main Bus-I at Lonand	5-Oct-10	09.00	5-Oct-10	10.10	Isolator jumper replacement of kandalgaon line.
220KV	220/100KV 100 MVA ICT- II @ Tambati	5-Oct-10	09.00	5-Oct-10	18.45	Breaker overhauling and bay maintenance work.
220KV	Pawas-Kharepatan	5-Oct-10	12.10	5-Oct-10	14.03	Maintenance of air compressor of C.B.
220KV	Pawas-New Koyna	5-Oct-10	14.18	5-Oct-10	16.02	Maintenance of air compressor of line C.B
220KV	Main Bus-II At Aurangabad.	5-Oct-10	10.31	5-Oct-10	19.30	Dismantling work of jumper of Jalna feeder.
220KV	Chandrapur- Rly TSS - II	5-Oct-10	11.17	5-Oct-10	18.16	Removing of energy meter.
220KV	220/132 KV 200 MVA ICT-I @ Harangul	5-Oct-10	15.20	5-Oct-10	18.56	Y Ph.OLTC replacement work.
220KV	220KV TBC At 400Kv Koradi	5-Oct-10	09.50	11-Oct-10	17.00	Replacement of 29(C)isolator of 220KV TBC.
220KV	220/132KV,200MVA ICT.III at Nanded	5-Oct-10	10.06	5-Oct-10	12.50	For attending oil leakage from OLTC.
220KV	Parli-Usmanabad	5-Oct-10	10.06	5-Oct-10	18.02	W.T.commissioningwork.
220KV	220/132 KV 100 MVA ICT- II @ Kanhan	5-Oct-10	15.49	5-Oct-10	18.53	Differential protection operated.
220KV	Mulund-Trombay	5-Oct-10	16.15	5-Oct-10	22:50	Distance protection.
220KV	Nerul -Sonkhar	6-Oct-10	07:04	6-Oct-10	09:08	Hot Spot on R and B ph Br clamp.
220KV	Kandalgaon - Pirangut	7-Oct-10	06:08	7-Oct-10	17.35	Earth wire Repl.
220KV	Bablesghwar-Nasik-I	7-Oct-10	08.14	7-Oct-10	14.32	Alignment of Line Isolator.
220KV	Mudshini - Talangade - II	7-Oct-10	09.20	7-Oct-10	10.36	Coating of Midson 570.
220KV	Wada-Kolshet	7-Oct-10	10.05	7-Oct-10	11.45	R.M.Work, Tandelta Measurment.
220KV	Kharepatan-Pawas	7-Oct-10	11.00	7-Oct-10	14.45	Replacement of Flashover Line Insulator @ Loc.No.192.
220KV	Kolhapur - Peth	7-Oct-10	17.30	7-Oct-10	18.40	Bkr.Problem,Compreser Work.
220KV	Lonand - Baramati	7-Oct-10	09.00	7-Oct-10	18.55	Bird Guard Fixing,
220KV	Apta-Kalwa	7-Oct-10	02.14	7-Oct-10	16.25	Ph to Ph Fault.
220KV	Bombaydying-Sahara	7-Oct-10	15.05	7-Oct-10	15.10	Distance Protection.
220KV	Pedambe - Tambati	7-Oct-10	15.42	7-Oct-10	16.24	Trip.
220KV	Pusad - Nanded	7-Oct-10	10.31	7-Oct-10	10.45	Quarterly Maintainance Work.
220KV	Parli-Usmanabad	7-Oct-10	10.19	12-Oct-10	11.20	Replacement of Aux Bus Side & Line Side Isolator Work.
220KV	220/132 KV 100 MVA ICT-II @ Parbhani	7-Oct-10	11.35	7-Oct-10	15.26	Civil Foundain Work.
220KV	Wardha - Yawatmal	7-Oct-10	14.23	7-Oct-10	16.24	Attending Main Bkr Air Comperssor Probelm. Ckt Was on TBC.
220KV	220 KV Main Bus @ Amravati	7-Oct-10	18.56	7-Oct-10	20.40	Replacement of 110 KV DC Battery Charger
220KV	Babhalesghwar-Nasik-II	8-Oct-10	07.27	8-Oct-10	20.27	Replacement of Line Isolator & Earth Isolator.
220KV	Bhoisor - Borivali	8-Oct-10	07.24	8-Oct-10	11.43	Hot Spot Loc. No.138.
220KV	Borivali-Aarey-II	8-Oct-10	05.50	8-Oct-10	07.35	Hot Spot.
220KV	Kalwa I-Taloja	8-Oct-10	10.03	8-Oct-10	20.59	Erection of Wave Trap & C C @ Kalwa.
220KV	Tifil-Trombay	8-Oct-10	10.18		Continued.	Erection & Stringing of M/C Towers (Loc.22-40)
220KV	220/132 KV,100 MVA T/F- II @ Malegaon	8-Oct-10	08.38	8-Oct-10	16.45	R.M.Work.
220KV	220/22 KV 50 MVA T/F - I @ Kalwa	8-Oct-10	08.44	8-Oct-10	16.34	H V Bushing Replacement.
220KV	Aurangabad - Babalesghwar	8-Oct-10	10.50	8-Oct-10	15.51	Replacement of E/W.
220KV	Aurangabad - Bhenda	8-Oct-10	10.58	8-Oct-10	16.30	Line Maintenance Work.
220KV	N.Koyna-Phinolex	8-Oct-10	11.22	8-Oct-10	18.18	Distance Protection.
220KV	Bhoisor-Bhoisor(PGCIL)-I	8-Oct-10	08.03	8-Oct-10	08.22	Change Over A Bus to B Bus.

220KV	Tarapur - Boiser	8-Oct-10	09.11	8-Oct-10	11.40	Isolator Alignment Work.
220KV	A Bus @ Boiser	8-Oct-10	10.20	11-Oct-10	11.49	CRM, Timing Bus Isolator Alignment Work.
220KV	Khaparkheda-Ambazari - I	8-Oct-10	07.06	8-Oct-10	16.45	Replacement of C T.
220KV	Aurangabad - Padegaon - II	8-Oct-10	10.24	8-Oct-10	19.11	Replacement of Jumper.
220KV	Chandrapur-Warora - I	8-Oct-10	14.05	8-Oct-10	14.34	Bus Fault.
220KV	Warora-Wardha	8-Oct-10	14.05	8-Oct-10	15.04	Bus Fault.
220KV	Warora-Hinganghat	8-Oct-10	14.05	8-Oct-10	15.08	Bus Fault.
220KV	RLY TSS CKT-I AT WARORA	8-Oct-10	14.05	8-Oct-10	14.35	Bus Fault.
220KV	Warora - Wardha Power - II	8-Oct-10	14.05	9-Oct-10	03.52	B Ph. C T Burst @ Warora Causing Bus Fault.
220KV	Warora - Wani	8-Oct-10	14.05	8-Oct-10	14.57	Bus Fault.
220KV	Warora - Rly TSS - II	8-Oct-10	14.05	8-Oct-10	14.35	Bus Fault.
220KV	220/66 KV 50 MVA T/F - I @ Warora	8-Oct-10	14.05	8-Oct-10	14.34	Bus Fault.
220KV	220/66 KV 50 MVA T/F - II @ Warora	8-Oct-10	14.05	8-Oct-10	14.34	Bus Fault.
220KV	220/33 KV 50 MVA T/F @ Warora	8-Oct-10	14.05	8-Oct-10	14.34	Bus Fault.
220KV	Pedambe - Pophali - II	9-Oct-10	07.55	9-Oct-10	17.40	Bay maint.work.
220KV	Boisor - Dahanu	9-Oct-10	08.07	9-Oct-10	10.00	A bus isolator alignment work.
220KV	Kandalgaon - Pirangut	9-Oct-10	06.36	9-Oct-10	18.28	Replacement of E/W.
220KV	Pirangut - Hinjewadi - II	9-Oct-10	06.36	9-Oct-10	18.25	Replacement of E/W.
220KV	Babaleshwar II - Babaleshwar - I	9-Oct-10	09.16	9-Oct-10	18.03	Q.M.Work
220KV	Bombay Dyeing - Sahara	9-Oct-10	14.25	9-Oct-10	16.23	Distance Protection.
220KV	Apta-Bombay Dyeing	9-Oct-10	14.25	9-Oct-10	15.45	At B'bay dying end only.
220KV	220/33 KV 100 MVA ICT - II @ Jamde	9-Oct-10	12.00	9-Oct-10	13.40	For oil filling to OLTC tank and air release from Bucholz.
220KV	Bus Coupler at Butibori	9-Oct-10	11.40	10-Oct-10	17.23	Breaker over hauling work.
220KV	KDPH-Wankuswadi	10-Oct-10	04.10	10-Oct-10	14.15	Distance Protection.
220KV	Boiser-Versova	10-Oct-10	07.00	10-Oct-10	11.42	A Bus isolator maintenance work.
220KV	Boisor - Dahanu	10-Oct-10	12.26	10-Oct-10	14.15	A Bus isolator maintenance work.
220KV	Pedambe-Tambati	10-Oct-10	08.35	10-Oct-10	19.05	Bay maint.work.
220KV	Babaleshwar - Nagar - I	10-Oct-10	08.00	10-Oct-10	08.30	Load trimming scheme operated.
220KV	Babaleshwar - Nagar - II	10-Oct-10	08.00	10-Oct-10	08.43	Load trimming scheme operated.
220KV	Miraj-Maisal	10-Oct-10	14.27	10-Oct-10	17.45	Y-Ph line isolator sparking.
220KV	Bhoisor-Bhoisor(PGCIL)-I	10-Oct-10	14.38	10-Oct-10	18.45	A Bus isolator maintenance work.
132KV	132 KV Main Bus @ Amravati	7-Oct-10	18.35	7-Oct-10	20.46	Replacement of 110KV DC Battery Charger.
132KV	Paras - Akot	7-Oct-10	18.00	7-Oct-10	18.37	Back up Protection O/C.
132KV	Boiser - Boiser MIDC - II	8-Oct-10	12.35	8-Oct-10	18.15	Replacement of Conductor.
132KV	Amravati - Achalpur	8-Oct-10	14.33	8-Oct-10	14.40	D C System Failed.
132KV	Bhandara-Tekepar	9-Oct-10	23.55	10-Oct-10	00.10	Back up protection operated.
132KV	Nardhane - Shirpur	10-Oct-10	12.00	10-Oct-10	16.40	Armouring of Y and B Ph.
100KV	Kalwa - Salshet - I	5-Oct-10	15.44		Continued.	ICT overlading at Kalwa.