

LINE OUTAGES FOR THE WEEK

FROM 3-Oct-11 TO 9-Oct-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Akola - Aurangabad - I	24-Sep-11	13.27	7-Oct-11	16.58	Over Voltage.
400KV	Kolhapur - Mapusa - I	1-Oct-11	21.06	3-Oct-11	08.26	Over Voltage.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	2-Oct-11	12.24	3-Oct-11	05.25	Buchholz Trip.
400KV	Bhusawal- Aurangabad	2-Oct-11	22.14	3-Oct-11	09.13	Over voltage.
400KV	Main Bus- I @ 400 KV Parli	3-Oct-11	08.04	3-Oct-11	14.32	Replacement of A & B Ph. Interconnector Jumper
400KV	Lonikand - Parli - II	3-Oct-11	07.57	3-Oct-11	21.48	Replacement of A & B Ph. Interconnector Jumper
400KV	Chandrapur - Parli - I	3-Oct-11	07.33	3-Oct-11	15.44	Taken on TBC Due to 29B Isolator.
400KV	Bhusawal- Aurangabad	3-Oct-11	22.21	4-Oct-11	05.50	Over Voltage.
400KV	Karad-Kolhapur-II	3-Oct-11	17.36	8-Oct-11	11.04	Over Voltage.
400KV	Bus Coupler @ Parli	3-Oct-11	08.03	3-Oct-11	14.32	Replacement of A & B Ph. Interconnector Jumper
400KV	Kolhapur - Mapusa - II	4-Oct-11	01.25	4-Oct-11	09.46	Over Voltage.
400KV	Khaparkheda - Chandrapur	4-Oct-11	08.01	4-Oct-11	17.40	Testing Work @ Khaparkheda.
400KV	Kolhapur - Mapusa - I	4-Oct-11	17.54	5-Oct-11	09.59	Over Voltage.
400KV	Bhusawal- Aurangabad	4-Oct-11	23.31	5-Oct-11	05.08	Over Voltage.
400KV	400/220KV,100 MVA Spare Unit at Korady	4-Oct-11	10.50		Continued.	Buchholz Alarm Recieved.
400KV	New Koyana - Karad - I	5-Oct-11	05.07	5-Oct-11	07.33	Taken on TBC Red Hot.
400KV	Karad - Newkoyana - I	5-Oct-11	05.07	5-Oct-11	07.34	Taken on own breaker.
400KV	Babaleshwar - Dhule - I	5-Oct-11	12.29	5-Oct-11	18.41	Attend Red hot spot.
400KV	Chandrapur - Khaparkheda	5-Oct-11	14.21	5-Oct-11	17.46	SOTF.
400KV	Babaleshwar - Dhule - I	5-Oct-11	18.54	5-Oct-11	19.08	To attending sparking on Y-Ph isolator.
400KV	Karad - Solapur (PGCIL)	5-Oct-11	17.30	6-Oct-11	11.27	Over Voltage.
400KV	Bhusawal- Aurangabad	5-Oct-11	22.58	6-Oct-11	11.34	Over Voltage.
400KV	Kolhapur - Mapusa - II	5-Oct-11	22.40	7-Oct-11	11.45	Over Voltage.
400KV	Parli-Parli (PGCIL) I	5-Oct-11	17.20	5-Oct-11	17.29	New line charged.
400KV	Parli (PG)-Bhadravati I	5-Oct-11	20.32	5-Oct-11	20.41	New line charged.
400KV	Chandrapur - Khaparkheda	5-Oct-11	07.15	5-Oct-11	17.46	Dist.Prot.operated,Z-2.
400KV	400/220KV 500MVA ICT-III at Bableshwar	6-Oct-11	02.05	6-Oct-11	03.15	For shifting from 400KV Bus-II to 400KV Bus-I.
400KV	Parli (PG)-Bhadravati I	6-Oct-11	05.58	6-Oct-11	08.20	Over Voltage.
400KV	Parli (PG)-Bhadravati I	6-Oct-11	08.32	8-Oct-11	12.03	Over Voltage.
400KV	Bhusawal- Aurangabad	6-Oct-11	21.50	7-Oct-11	08.42	Over Voltage.
400KV	Karad - Solapur (PGCIL)	6-Oct-11	23.10	7-Oct-11	08.24	Over Voltage.
400KV	Akola - Wardha - II	6-Oct-11	23.08		Continued.	Over Voltage.
400KV	400/220KV 315 MVA ICT- II @ Padgha	7-Oct-11	08.30	8-Oct-11	07.00	Replacement of Y ph.bushing.
400KV	400/220KV,500 MVA ICT-III At A'bad.	7-Oct-11	10.40	7-Oct-11	14.43	Q.M.Work
400KV	Main Bus-I at Deoli (PGCIL)	7-Oct-11	10.39	7-Oct-11	18.24	Stringing work adjacent to 400KV M.B-I in proposed Adani bay..
400KV	Padgha - Kharghar	7-Oct-11	14.35	7-Oct-11	17.31	Attending Hot Spot on B bus Y ph. PG isolator.
400KV	Akola-Aurangabad-II	7-Oct-11	16.59	9-Oct-11	11.30	Over Voltage.
400KV	Karad - Solapur (PGCIL)	7-Oct-11	19.45	8-Oct-11	06.56	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	7-Oct-11	23.43		Continued.	Over Voltage.
400KV	Kolhapur - Mapusa - I	7-Oct-11	22.31	8-Oct-11	09.15	Over Voltage.
400KV	Lonikand - Chakan	7-Oct-11	22.00	7-Oct-11	23.51	Due to opening 89 D isolator on account of heavy rain & wind.
400KV	400/220 KV315 MVA ICT-I @ BBLR	8-Oct-11	08.15	9-Oct-11	13.02	Attending oil leakage of R ph.CT.
400KV	Parli (PGCIL)-Bhadravati-II	8-Oct-11	20.20	8-Oct-11	20.31	Newly commissioned on 08.10.2011 at 20.31 hrs.
400KV	Karad - Kolhapur - I	8-Oct-11	17.22		Continued.	To control Over Voltage.
400KV	Kolhapur - Mapusa - I	8-Oct-11	20.55	9-Oct-11	11.24	To control Over Voltage.
400KV	Parli-Solapur (PGCIL)-II	8-Oct-11	15.30	15-Oct-11	15.33	Newly commissioned on 08.10.2011 at 15.33 hrs.
400KV	Parli (PG)-Bhadravati I	8-Oct-11	19.50		Continued.	Tripped.

400KV	Parli-Parli (PGCIL)-II	8-Oct-11	18.00	8-Oct-11	18.44	Newly commissioned on 08.10.2011 at 18.44 hrs.
400KV	Parli-Parli (PGCIL)-II	8-Oct-11	19.20		Continued.	H/T due to CVT fuse blown off at PGCIL end.
400KV	Parli (PGCIL)-Bhadravati-II	8-Oct-11	22.14		Continued.	Over Voltage.
400KV	Parli-Solapur (PGCIL) Ckt.II	8-Oct-11	15.30	8-Oct-11	15.33	Newly commissioned on 08.10.2011 at 15.33 hrs.
400KV	Bhusawal- Aurangabad	9-Oct-11	00.04	9-Oct-11	05.30	Over Voltage.
400KV	400/220KV 315 MVA ICT- II @ Padgha	9-Oct-11	03.17	9-Oct-11	19.35	Tripped main buchholz.
400KV	New Koyna - Stage IV	9-Oct-11	16.48	9-Oct-11	18.16	Distance Protection
400KV	Karad - Solapur (PGCIL)	9-Oct-11	19.35		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - II	9-Oct-11	22.07		Continued.	Over Voltage
220KV	Main Bus - II Talangde	26-Sep-11	10.20	3-Oct-11	12.53	Q.M.Work of Bus Coupler Bay,Repl.of B Ph. C T of Bus Coupler.
220KV	Babaleshwar - Ranjangaon	2-Oct-11	22.30	3-Oct-11	00.03	Distance protection.B ph.
220KV	Abhijeet-Wardha-I	2-Oct-11	10.38	5-Oct-11	08.17	To control Koradi ICT loading.
220KV	Abhijeet - Wardha ckt - II	2-Oct-11	10.39	5-Oct-11	08.17	To control Koradi ICT loading.
220KV	Hinganghat-Bhugaon	3-Oct-11	00.14	3-Oct-11	00.33	Distance protection.Z1
220KV	Mudshingi - Peth	3-Oct-11	09.51	3-Oct-11	12.45	Maintenance Work.
220KV	Dhule - Amalner	3-Oct-11	09.30	3-Oct-11	14.00	Jumper Tighting.
220KV	Main Bus - I @ Talangade	3-Oct-11	12.56	5-Oct-11	16.20	Erection of jumper of A Bus Isolator of New 220KV Sawantwadi-II B
220KV	220 KV Junction Breaker(B/C) @ Koyna I a	3-Oct-11	13.20	3-Oct-11	15.35	Hot Spot.
220KV	Amalner - Dondaicha	3-Oct-11	14.25	3-Oct-11	16.43	Replacement of Y & B Ph. Jumper.
220KV	Butibori-INOX	3-Oct-11	08.16	3-Oct-11	16.17	Measurment of Tan Delta of C T ,Routine Maintainance Work.
220KV	220/66KV 50 MVA ICT- II @ Wardha	3-Oct-11	10.37	3-Oct-11	14.38	Measurment of Tan Delts of ICT Bushing: Attend Hot Spot on HV/L
220KV	Badnera-Amravati	3-Oct-11	11.52	3-Oct-11	12.10	Distance Protection Operated Z-I Tripped @ Badnera End
220KV	220/132KV 200MVA ICT @ Beed	3-Oct-11	13.00	3-Oct-11	19.15	Replacement of Air Cell Ballon.
220KV	Lonand - Jejuri	4-Oct-11	13.00	4-Oct-11	18.00	Red Hot.
220KV	Vita-Maisal	4-Oct-11	18.45	4-Oct-11	21.54	Due to Fault in Maisal .
220KV	Miraj-Maisal	4-Oct-11	18.30	5-Oct-11	13.35	R Ph.Jumper Broken.(Loc.no 68 R-Ph Decapping)
220KV	220/132KV 200MVA ICT @ Beed	4-Oct-11	12.05	4-Oct-11	13.15	Quarterly Maintainance Work of ICT.
220KV	Hinganghat-Bhugaon	4-Oct-11	14.15	4-Oct-11	17.18	Repairing of Y Ph. Jumper of W.T.
220KV	Girwali - Parly - II	4-Oct-11	10.53	4-Oct-11	13.51	Repairing of Distance Relay.
220KV	Girawli-Parli-III	4-Oct-11	14.07	4-Oct-11	17.14	Repairing of Distance Relay.
220KV	Girwali - Parly - IV	4-Oct-11	17.23	4-Oct-11	18.31	Repairing of Distance Relay.
220KV	Wardha-RLY TSS I	4-Oct-11	11.02	4-Oct-11	15.41	Commissioning of BusBar Scheme.Measurment of Tan Delta of C T
220KV	Wardha-Rly.TSS-II	4-Oct-11	16.10	4-Oct-11	18.56	Commissioning of BusBar Scheme.Measurment of Tan Delta of C T
220KV	Kanhan - Bhandara - I	4-Oct-11	12.47	4-Oct-11	12.59	R, B Ph. O/C.
220KV	Girawli - Parly - IV	4-Oct-11	15.15	4-Oct-11	15.36	D/P Inoperative Alarm Received.
220KV	Lote - N.Koyna	5-Oct-11	02.01	5-Oct-11	02.47	O/C Earth Fault Protection.
220KV	Lote- Dasturi	5-Oct-11	02.01	5-Oct-11	02.50	Distance Protection.
220KV	Mumewadi-Halkarni-II	5-Oct-11	02.38	5-Oct-11	03.07	Distance Protection.
220KV	Mumewadi-Halkarni-II	5-Oct-11	05.45	5-Oct-11	14.34	Back up Earth Fault.
220KV	220 KV Bus @ New Koyna	5-Oct-11	02.01	5-Oct-11	02.47	O/C Earth Fault Protection.
220KV	Newkoyna -Lote-Parsuram	5-Oct-11	10.51	5-Oct-11	19.03	BKR Replacement work.
220KV	220 KV Bus at Wardha	5-Oct-11	07.15	5-Oct-11	07.40	R-Ph LA Burst,220/66KV 50Mva T/F.
220KV	Vita - Lamboti	5-Oct-11	13.13	6-Oct-11	04.55	Dist.Protection.
220KV	220/100 KV 100 MVA T/F - IV @ Kandalgaon	5-Oct-11	14.19	5-Oct-11	15.15	Due to heay lightening and storm.
220KV	220/100KV 50 MVA T/F- III @ Kandalgaon	5-Oct-11	14.19	5-Oct-11	19.20	Due to heay lightening and storm.
220KV	220 KV Interconnector @ Kalwa.	5-Oct-11	18.24	5-Oct-11	18.40	Wave trap of 220KV Kalwa-Taloja burst.
220KV	Kalwa I-Taloja	5-Oct-11	18.23	6-Oct-11	03.14	Wave trap of 220KV Kalwa-Taloja burst.

220KV	Apta-Uran-II	5-Oct-11	17.43	5-Oct-11	22.57	Dist.Prot.(Taken on TBC at Apta end.)
220KV	Butibori - Sun Vijay	5-Oct-11	10.10	5-Oct-11	16.35	Measurement of tandelta of CT measurement of contact resssistance
220KV	Gadchandur-Virur-I	5-Oct-11	14.44	5-Oct-11	18.24	Retrofitting work.
220KV	Hingoli-Pusad	5-Oct-11	08.21	5-Oct-11	13.07	To control Wardha-Y'mal L/L.
220KV	Borivali -Tarapur	6-Oct-11	09.39	6-Oct-11	15.55	Distance protection B ph.
220KV	Tarapur Main Bus Zone-II	6-Oct-11	09.39	6-Oct-11	19.09	Tripped along with Borivali-tarapur.
220KV	Tarapur-Vapi	6-Oct-11	09.39	6-Oct-11	18.58	Tripped along with Borivali-Tarapur line.
220KV	Theur - Magarpatta	6-Oct-11	09.40	6-Oct-11	17.25	Q.M.Work
220KV	Main Bus @ Lote	6-Oct-11	13.02	6-Oct-11	14.30	Breaker earth wire replacement.
220KV	Lote - N.Koyna	6-Oct-11	13.02	6-Oct-11	14.30	Breaker earth wire replacement.
220KV	Lote - Dasturi	6-Oct-11	13.02	6-Oct-11	14.35	Breaker earth wire replacement.
220KV	Khaperkheda - Wardha.	6-Oct-11	13.13	7-Oct-11	15.19	Distance protection Z-1.Declared faulty.
220KV	220/110,100MVA T/F-I at Jambul.	7-Oct-11	09.50	7-Oct-11	17.10	R.M.Work.
220KV	220/132 KV 200 MVA ICT - I @ Babaleshw	7-Oct-11	10.32	7-Oct-11	18.30	SFRA and Tan delta measurement.
220KV	New Koyna-Pophali	7-Oct-11	11.10	7-Oct-11	13.49	Replacement of display card.
220KV	Nagothane - SPCL	7-Oct-11	11.10	7-Oct-11	13.32	Attending Hot Spot in isolator jumper.
220KV	Pedambe-Pophali I	7-Oct-11	14.15	7-Oct-11	16.50	Replacement of relay card.
220KV	Nagothane-IPCL	7-Oct-11	14.56	7-Oct-11	16.46	R.M.Work
220KV	Karad-Pedambe	7-Oct-11	15.42	7-Oct-11	16.00	Distance protection.
220KV	Jejuri - Parvati	7-Oct-11	15.46	7-Oct-11	16.03	Distance protection.
220KV	220/132KV 200MVA ICT-II at Dhule	7-Oct-11	06.00	7-Oct-11	07.00	'R'Ph.CT burst and LBB operated.
220KV	220/132KV,200 MVA ICT-I at Dhule	7-Oct-11	06.38	7-Oct-11	07.00	'R'Ph.CT burst and LBB operated.
220KV	Dhule-Chalisgaon	7-Oct-11	14.28	7-Oct-11	15.33	Distance protection.
220KV	Chalisgaon - Malegaon	7-Oct-11	14.28	8-Oct-11	12.56	Distance protection Zone1 operated.
220KV	Khapakheda - Koulawada - II	7-Oct-11	10.07	7-Oct-11	19.05	Attending Hot Spot.
220KV	220/132KV 200 MVA ICT- III @ Padegaon	7-Oct-11	10.43	7-Oct-11	18.30	Q.M.Work
220KV	Girawli - Parly - IV	7-Oct-11	09.37	7-Oct-11	15.00	Tightning of arcing horn at Loc.No30 and 29.
220KV	MUDSHINGI-CHIKODI	7-Oct-11	12.50	7-Oct-11	13.05	Distance protection.
220KV	BBLSR-A"Nagar II	8-Oct-11	09.34	8-Oct-11	16.12	Fixing of bird guard.
220KV	Uran-Apta-II	8-Oct-11	11.12	8-Oct-11	14.49	To attend red hot.
220KV	Nasik - Ghatghar	8-Oct-11	10.25	8-Oct-11	18.22	Replacement of insulator.
220KV	BBLSR-Waluj	8-Oct-11	10.51	8-Oct-11	14.20	Q.M.Work
220KV	Pophali - KDPH	8-Oct-11	10.20	9-Oct-11	00.05	Crimping of clamp and connector.
220KV	Mahape-Tifil	8-Oct-11	12.05	8-Oct-11	21.26	Attending of oil leakage of B ph.CT.
220KV	Nivali-Pawas	8-Oct-11	11.35	8-Oct-11	12.40	To attend red hot.
220KV	220/132KV 200MVA ICT-II at BBLSR	8-Oct-11	13.25	8-Oct-11	17.45	SFRA and tan delta measurement.
220KV	PADGHA-BOISER (PGCIL)	8-Oct-11	09.14	8-Oct-11	12.46	To attend red hot.
220KV	Kalwa-Colourchem	8-Oct-11	15.05	8-Oct-11	16.30	Distance protection.
220KV	Pedambe-Mahad	8-Oct-11	17.15	8-Oct-11	17.55	Distance protection.
220KV	Vita - Lamboti	8-Oct-11	16.43		Continued.	H/T Vita end for control Over Voltage.

220KV	Dahanu-Bhoisor	9-Oct-11	09.48	9-Oct-11	14.53	Replacement of Vibration Damper
220KV	Pophali - KDPH	9-Oct-11	09.35	9-Oct-11	18.05	Replacement of Clamps Connector
220KV	Karad-Pedambe	9-Oct-11	11.50	9-Oct-11	12.17	Distance Protection
132KV	Telgaon - Majalgaon	3-Oct-11	11.25	3-Oct-11	11.35	Back up O/C Protection Operated.
132KV	Chandurbazar - Achalpur	3-Oct-11	11.58	3-Oct-11	12.10	Distance Protection Operated Z-I B Ph.
132KV	Himayatnagar-Kinwat	4-Oct-11	05.30	4-Oct-11	05.45	Distance Protection.
132KV	Jalgaon - Dhrangaon	5-Oct-11	14.25	5-Oct-11	14.35	Dist.Prot.Operated,Z-1,R-Ph.
132KV	Jalgaon - Dhrangaon	5-Oct-11	16.37	5-Oct-11	16.57	Dist.Prot.Operated,Z-1,R-Ph.
132KV	Hingoli-Kurunda	7-Oct-11	19.13	7-Oct-11	19.43	Distance protection.
132KV	Dhule-Nardhane	7-Oct-11	06.00	7-Oct-11	06.42	'R'Ph.CT burst and LBB operated.
132KV	Dhule-Sakri	7-Oct-11	06.00	7-Oct-11	06.43	'R'Ph.CT burst and LBB operated.
132KV	Dhule-Dondaicha - I	7-Oct-11	06.00	7-Oct-11	13.17	'R'Ph.CT burst and LBB operated.
132KV	Dhule - Dondaicha - II	7-Oct-11	06.00	7-Oct-11	07.00	'R'Ph.CT burst and LBB operated.
132KV	Padegaon-Waluj-I	7-Oct-11	10.30	7-Oct-11	17.38	Q.M.Work
132KV	Dondaicha - Sahada	9-Oct-11	11.50	9-Oct-11	12.25	Distance Protection
110KV	Kalyan-Salsette I	3-Oct-11	10.14	3-Oct-11	14.06	Sparking on Line Side GOD @ Salsette.
100KV	Kalwa-Pal	2-Oct-11	20.34	3-Oct-11	09.10	Dist portection B ph.(Trial taken,declared faulty.)
100KV	Kalwa-Standard	4-Oct-11	06.19	4-Oct-11	08.52	Red Hot.
100KV	Kandalgaon-Roha-I	5-Oct-11	14.19	5-Oct-11	15.40	Due to heay lightening and storm.
100KV	Kandalgaon-Roha-II	5-Oct-11	14.19	5-Oct-11	15.23	Due to heay lightening and storm.
100KV	Kandalgaon - Mhasale	5-Oct-11	14.19	5-Oct-11	15.17	Due to heay lightening and storm.
100KV	Kandalgaon - Mhasale	9-Oct-11	17.34	9-Oct-11	17.44	Distance protection