

LINE OUTAGES FOR THE WEEK

FROM 1-Nov-10 TO 7-Nov-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Karad - Kolhapur - II	14-Oct-10	23.19	2-Nov-10	09.31	Over Voltage.
400KV	Dhule - S'Sarovar- II	26-Oct-10	13.58	2-Nov-10	14.45	Over Voltage.
400KV	Kolhapur - Mapusa - I	27-Oct-10	22.55	1-Nov-10	10.02	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	28-Oct-10	23.06	3-Nov-10	15.12	Over Voltage.
400KV	Lonikand- Koyna Stage IV	1-Nov-10	00.31	1-Nov-10	07.44	Over Voltage.
400KV	Koyna Stg.IV--New Koyna-II	1-Nov-10	23.57	2-Nov-10	08.31	Over Voltage.
400KV	Kolhapur-Mapusa-II	1-Nov-10	22.45		Continued.	Over Voltage.
400KV	400/220KV 315MVA ICT-II @ BBLSR	2-Nov-10	00.05	2-Nov-10	05.10	For topping of oil in 'Y'Ph. unit.
400KV	Dabhol - Nagothane - I	2-Nov-10	09.42	2-Nov-10	17.21	Bay maintenance and testing work.
400KV	Karad-Kolhapur-II	2-Nov-10	23.17	3-Nov-10	11.33	Over Voltage.
400KV	Dhule - S'Sarovar- II	2-Nov-10	23.19	6-Nov-10	18.10	Over Voltage.
400KV	Lonikand- Koyna Stage IV	3-Nov-10	01.49	3-Nov-10	07.37	Over Voltage
400KV	400/220KV,500MVA ICT-III At Kalwa.	3-Nov-10	06.25	4-Nov-10	16.10	Kept on humming from HV side.
400KV	Lonikand- Koyna Stage IV	3-Nov-10	23.52	4-Nov-10	09.38	Over Voltage
400KV	Karad - Kolhapur - II	3-Nov-10	22.49	6-Nov-10	11.00	Over Voltage.
400KV	400/220KV ICT- I @ Lonikand	4-Nov-10	07.10	4-Nov-10	13.05	Attending Hot Spot & Maint.Work.
400KV	400/220KV 315MVA ICT- I @ Chandrapur	4-Nov-10	08.48	4-Nov-10	13.03	Replacement of MICRO Switch of PRV.
400KV	Padgha - Babaleshwar - II	5-Nov-10	14.04		Continued.	Over Voltage
400KV	Dabhol-Nagothane-II	5-Nov-10	15.07	5-Nov-10	18.47	Distance Protection
400KV	New Koyna - Koyna Stage IV - II	5-Nov-10	23.25		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	5-Nov-10	23.56	6-Nov-10	05.39	Over Voltage
400KV	Padgha - Nagothane- II	5-Nov-10	15.45	6-Nov-10	10.57	Distance Protection.
400KV	Jejuri-Koyna STG-IV	6-Nov-10	00.11	6-Nov-10	12.04	Over Voltage
400KV	Karad - Kolhapur - I	6-Nov-10	00.11		Continued.	Over Voltage
400KV	Dabhol-Nagothane-II	6-Nov-10	00.11	6-Nov-10	09.05	Distance Protection
400KV	Dhule-Sar'Sarovar - I	6-Nov-10	00.02	6-Nov-10	08.53	Over Voltage
400KV	Dabhol-Nagothane - II	6-Nov-10	11.59	6-Nov-10	17.57	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	6-Nov-10	22.11		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	7-Nov-10	00.23	7-Nov-10	06.13	Over Voltage.
400KV	Karad - Kolhapur - II	7-Nov-10	00.23	7-Nov-10	12.12	Over Voltage.
400KV	400/220KV,315MVA ICT-I at Karad	7-Nov-10	20.06		Continued.	To Attend Red Hot on H V Side Neutral C T Clamp.
400KV	Bhusawal- Aurangabad	7-Nov-10	21.26		Continued.	Over Voltage.
400KV	Karad-Lamboti	7-Nov-10	23.25		Continued.	Over Voltage.
400KV	Karad - Kolhapur - II	7-Nov-10	23.25		Continued.	Over Voltage.
220KV	Kharghar-Uran-I	29-Oct-10	10:02	1-Nov-10	08.48	Breaker problem, line on TBC.

220KV	Warora - Wardha Power - II	30-Oct-10	17.38	2-Nov-10	23.17	R @ Y Ph C T Burst.
220KV	Uran-Kharghar-II	1-Nov-10	12.55	3-Nov-10	08.25	Line on TBC,main breaker overhauling work.
220KV	Jejuri-Jejuri I	1-Nov-10	13.17	3-Nov-10	12.31	Line taken on TBC,main breaker overhauling work
220KV	Kalwa - Salsket - IV	1-Nov-10	13.02	1-Nov-10	15.39	Taken on TBC.To attend red hot.
220KV	Babhaleshwar-Nasik-II	1-Nov-10	13.00	2-Nov-10	12.50	Taken on TBC,isolator 29A and 29B main work.
220KV	220 KV Main Bus - I @ Chandrapur.	1-Nov-10	08.14	2-Nov-10	19.34	Measurement of tan delta and relay testing work.
220KV	Hinganghat-Bhugaon	1-Nov-10	12.25	1-Nov-10	17.08	Replacement of WT.
220KV	Rly TSS - Kalmeshwar - I	1-Nov-10	11.32	1-Nov-10	16.36	Q.M.Work.
220KV	BBLSR-Chalisgaon	1-Nov-10	13.28	1-Nov-10	18.34	H/T at BBLSR end only to control Dhule ICT loading
220KV	Pophali-K'gaon	2-Nov-10	13.30	2-Nov-10	14.15	Distance protection R Ph.to N
220KV	Nerul -Sonkhar	2-Nov-10	08.55	2-Nov-10	10.10	Red hot-R C.T line side.
220KV	220/100 KV 100 MVA T/F - IV @ Kandalgaon	2-Nov-10	09.50	2-Nov-10	12.15	Sparking at neutral earthing.
220KV	220/110KV 100MVA T/F- I @ Miraj	2-Nov-10	09.35	2-Nov-10	13.20	C.T.leakage and Q.M.work.
220KV	Lote - N.Koyna	2-Nov-10	10.55	2-Nov-10	15.28	R Ph.CT leakaage.
220KV	Vankuswade-Maiharpath	2-Nov-10	10.10	2-Nov-10	16.45	Q.M.Work
220KV	ICL - Harangool Ckt.II	2-Nov-10	14.30	2-Nov-10	17.30	Main breaker maintenance work.Ckt was on TBC.
220KV	220KV TBC @ Harangul	2-Nov-10	11.00	2-Nov-10	13.00	Q.M.Work
220KV	220/132 KV 200 MVA ICT - I @ Kalmeshwar	2-Nov-10	12.27	2-Nov-10	17.26	Testing of LV side dirctional O/C and E/F relay.
220KV	Khaparkheda-Ambazari - I	2-Nov-10	08.24	2-Nov-10	17.54	Laying of earth wire from Loc.no.43-55
220KV	220/132 KV,100MVA ICT-II At Padegaon.	2-Nov-10	09.35	2-Nov-10	18.12	Replacement of CTs under LES.
220KV	Chandrapur-Wani Ckt At 400KV C'pur.	2-Nov-10	22.18	3-Nov-10	10.50	To attend isolator problem.Ckt taken on TBC.
220KV	Apta-Kalwa	3-Nov-10	00.09	3-Nov-10	05.01	H/T due to R Ph.jumper damage.
220KV	Kalwa - Ghatghar	3-Nov-10	00.17	3-Nov-10	05.56	H/T from Kalwa end only.
220KV	Virur - Gadchiroli	3-Nov-10	01.04	3-Nov-10	01.16	Distance protection.B Ph.
220KV	Karad-M'peth	3-Nov-10	10.23	3-Nov-10	12.31	Red hot on bus-II isolator R Ph.
220KV	Uran - JNPT	3-Nov-10	10.59	3-Nov-10	16.58	Line maintenance work.
220KV	NewKoyna - Pawas	3-Nov-10	11.47	3-Nov-10	15.37	Red hot Y Ph.C.C
220KV	Trombay - Salsett - I	3-Nov-10	15.54	3-Nov-10	16.12	Distance protection.
220KV	Trombay-Dharavi	3-Nov-10	16.11	3-Nov-10	16.23	Distance protection.
220KV	Karad - Miraj	3-Nov-10	21.21	4-Nov-10	14.23	Distance protection.
220KV	220/132 KV 200 MVA ICT @ Kawlewada	3-Nov-10	10.00	3-Nov-10	14.58	R.M.Work.
220KV	Khaparkheda-Ambazari - I	3-Nov-10	09.26	3-Nov-10	18.08	Remaining E/W replacement work.
220KV	220 KV TBC @ Koradi	3-Nov-10	11.05	3-Nov-10	16.40	Measurement of Tan delta of CT.
220KV	220KV Main Bus At Umred	3-Nov-10	11.10	3-Nov-10	17.35	To connect newly constructed bay of SVSL
220KV	220KV Auxiliary bus at Umred.	3-Nov-10	11.10	3-Nov-10	17.35	To connect newly constructed bay of SVSL
220KV	Trombay Sonkhar	3-Nov-10	10.44	3-Nov-10	10.55	Distance protection.
220KV	Lonikand-Kathapur	4-Nov-10	05.09	4-Nov-10	12.17	Distance protection.
220KV	Mudshingi - Karad - II	4-Nov-10	10.02	4-Nov-10	11.59	Q.M.Work.
220KV	220/132KV 100 MVA ICT- I @ Parbhani	4-Nov-10	10.05	4-Nov-10	14.09	Quarterly Maintainance Work.
220KV	Bhugaon - LLOYD - I	4-Nov-10	19.18	4-Nov-10	20.10	Replacement of Consumer Meter by DISCOM.

220KV	Bhoisor-Bhoisor(PGCIL)-I	4-Nov-10	08.05	4-Nov-10	13.16	Taken on TBC To Attend Hot Spot.
220KV	Trombay-Kalwa	5-Nov-10	08.10	5-Nov-10	11.00	Main Bus-I outage at Trombay
220KV	Trombay Sonkhar	5-Nov-10	07.57	5-Nov-10	11.25	Main Bus-I outage at Trombay
220KV	Trombay - Tata Tie - II	5-Nov-10	07.48	5-Nov-10	12.06	Main Bus-I outage at Trombay
220KV	220/100 KV125 MVA ICT-III @Trombay	5-Nov-10	08.08	5-Nov-10	12.04	Main Bus-I outage at Trombay
220KV	Apta-Tambati	5-Nov-10	12.55	5-Nov-10	13.15	Distance Protection
220KV	Chinchwad - Parvati	5-Nov-10	13.12	5-Nov-10	13.34	Distance Protection
220KV	Dhule-Chalisgaon	5-Nov-10	14.40	5-Nov-10	15.33	Distance Protection
220KV	Chalisgaon - Malegaon	5-Nov-10	14.40	5-Nov-10	14.56	Distance Protection
220KV	NewKoyna - Pawas	5-Nov-10	17.43	5-Nov-10	18.16	Distance Protection
220KV	NewKoyna - Pawas	5-Nov-10	18.36	6-Nov-10	12.16	Distance Protection
220KV	Main Bus-I at Trombay	5-Nov-10	08.13	5-Nov-10	10.58	Attending Red Hot of R Phase Isolator
220KV	Trombay-Kharghar	5-Nov-10	08.02	5-Nov-10	11.21	Main Bus-I outage at Trombay
220KV	Pusad-Parbhani	5-Nov-10	10.15	5-Nov-10	22.29	To control load on C'Pur-Warora line
220KV	Kalwa - Salshet - III	6-Nov-10	11.46	6-Nov-10	13.16	Hot Spot on B Ph Breaker Clamp.(Line on TBC)
220KV	Chinchwad - Parvati	6-Nov-10	13.04	6-Nov-10	14.25	Replacement of R Ph Suspension String @ Loc. No.51.
220KV	Mahad-Nagothane	6-Nov-10	13.24	6-Nov-10	16.47	Distance Protection R Ph to Earth.
220KV	Chandrapur-Gadchandur	6-Nov-10	10.33	6-Nov-10	13.13	To Attend Hot Spot on 20A Isolator.(Ckt on TBC)
220KV	Pusad-Parbhani	6-Nov-10	10.07	6-Nov-10	14.58	To Control C'pur-WRR Loading.
220KV	Babaleshwar - Chalisgaon	6-Nov-10	15.36	6-Nov-10	21.04	To Control Dhule ICT Loading.
220KV	Kalwa - Borivali	7-Nov-10	09.58	7-Nov-10	11.42	Distance Protection.
220KV	220/132 KV 200 MVA ICT - V @ Nasik (OCR) N	7-Nov-10	21.50		Continued.	L V Side Control Ckt Problem.
132KV	Girwali - Gangakhed	1-Nov-10	03.19	1-Nov-10	03.42	Distance protection Zone-I Y Ph.
132KV	Paras-Patur	4-Nov-10	13.46	4-Nov-10	14.12	Distance Protection.
132KV	Harangul - Ujni	5-Nov-10	14.20	5-Nov-10	15.00	Distance Protection
132KV	Akola - Paras - I	5-Nov-10	05.14	5-Nov-10	05.29	Backup Protection operated
132KV	Ambazari - Amravati	6-Nov-10	00.26	6-Nov-10	13.55	Distance Protection. R Ph.
110KV	Pedambe-- Ratnagiri	5-Nov-10	17.38	5-Nov-10	18.45	Distance Protection
110KV	Ratnagiri - Pedambe	6-Nov-10	14.45	7-Nov-10	14.10	Distance Proection Conductor Snapped @ Loc.204.
100KV	Kalwa - Salshet - I	5-Oct-10	15.44	4-Nov-10	20.40	ICT overlading at Kalwa.
100KV	Taloja-Taloja-II	2-Nov-10	16.43	2-Nov-10	16.55	Distance protection.
100KV	Kalwa-Kalyan	4-Nov-10	19.18	5-Nov-10	02.24	Distenance Protection.
100KV	Kalwa-Nocil I	4-Nov-10	19.18	5-Nov-10	03.12	Distanace Protection.