

LINE OUTAGES FOR THE WEEK

FROM 29-Nov-10 TO 5-Dec-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE I -CHDPR	30-Nov-10	22.13	1-Dec-10	00.30	Outage at Padghe end for open line test.
400KV	Kolhapur - Mapusa - I	24-Nov-10	22.32	1-Dec-10	11.24	Over Voltage
400KV	Dhule-Sar'Sarovar - I	25-Nov-10	01.38	29-Nov-10	10.06	Over Voltage
400KV	Karad - Kolhapur - II	27-Nov-10	22.05	29-Nov-10	11.50	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	27-Nov-10	23.13	30-Nov-10	08.35	Over Voltage.
400KV	Akola - Aurangabad- II	28-Nov-10	16.49	2-Dec-10	13.17	Changeover.
400KV	Bhusawal- Aurangabad	28-Nov-10	23.40	29-Nov-10	04.40	Over Voltage.
400KV	Akola - Wardha - II	28-Nov-10	18.37	5-Dec-10	11.06	Change over
400KV	Chandrapur - Khaparkheda	29-Nov-10	04.16	29-Nov-10	12.16	Distance protection operated.
400KV	Koradi - Bhusawal	29-Nov-10	04.16	29-Nov-10	04.21	At Koradi end only B/U protection operated.
400KV	Lonikand- Koyna Stage IV	29-Nov-10	01.58	29-Nov-10	08.14	Over Voltage.
400KV	Dhule-S'Sarovar I	29-Nov-10	22.25	30-Nov-10	08.11	Over Voltage.
400KV	Karad - Kolhapur - II	29-Nov-10	22.44	30-Nov-10	08.29	Over Voltage.
400KV	Bhusawal- Aurangabad	29-Nov-10	23.20	30-Nov-10	06.08	Over Voltage.
400KV	Lonikand- Koyna Stage IV	30-Nov-10	01.18	30-Nov-10	07.50	Over Voltage.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	30-Nov-10	00.05	30-Nov-10	20.22	Newly erected.
400KV	Karad - Kolhapur - I	30-Nov-10	22.49	1-Dec-10	12.32	Over Voltage.
400KV	Dhule - S'Sarovar- II	30-Nov-10	22.40	1-Dec-10	18.26	Over Voltage
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	30-Nov-10	20.40	30-Nov-10	21.55	Kept on humming.Charged from HV side only.
400KV	Dhule-S'Sarovar I	1-Dec-10	00.13	1-Dec-10	08.05	Over Voltage
400KV	Karad - Kolhapur - II	1-Dec-10	20.55	2-Dec-10	10.45	Over Voltage.
400KV	Kolhapur - Mapusa - II	1-Dec-10	22.46	3-Dec-10	12.27	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	1-Dec-10	23.04	2-Dec-10	08.54	Over Voltage.
400KV	Lonikand - Chakan	2-Dec-10	07.19	2-Dec-10	19.00	Tan delta,relay testing work.
400KV	400/220KV 315MVA ICT-II @ BBLSR	2-Dec-10	00.17	2-Dec-10	04.38	Tightening of Y & B Ph.Bushing Terminal Clamp.
400KV	Lonikand - Jejuri	2-Dec-10	09.16	2-Dec-10	12.14	Attending hot spot.
400KV	400/220 KV315 MVA ICT-I @ BBLR	2-Dec-10	10.46		Continued.	For repl.of 33 KV bushing of R,Y,and B ph.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	2-Dec-10	14.02	2-Dec-10	21.02	For removing faulty oil pump motor of Y and B ph.
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	2-Dec-10	13.08	4-Dec-10	16.20	LV of ICT-I H/T.Full load taken on ICT-II.
400KV	Karad - Kolhapur - I	2-Dec-10	23.19	3-Dec-10	08.47	Over Voltage.
400KV	Bhusawal- Aurangabad	2-Dec-10	23.15	3-Dec-10	07.47	Over Voltage.
400KV	Dhule - S'Sarovar- II	2-Dec-10	17.11		Continued.	Over Voltage.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	2-Dec-10	10.52	2-Dec-10	17.35	To Remove the Gases.
400KV	Main Breaker @ Jejuri	3-Dec-10	11.45	3-Dec-10	15.31	DCRM Testing Demanstrans.
400KV	Padgha-Bhoisor (PGCIL)	3-Dec-10	11.58	3-Dec-10	18.40	Q.M.Work.
400KV	Akola - Bhusawal	3-Dec-10	08.21	3-Dec-10	19.32	Replacement of L A & Maint.Work.
400KV	Karad - Kolhapur - I	3-Dec-10	23.52	4-Dec-10	09.13	Over Voltage.
400KV	Kolhapur - Mapusa - II	3-Dec-10	22.43	4-Dec-10	08.18	Over Voltage.
400KV	Bhusawal- Aurangabad	3-Dec-10	23.44	4-Dec-10	06.47	Over Voltage.
400KV	Bablsr-Padgha Ckt I	4-Dec-10	10.41	4-Dec-10	13.30	Attending Red Hot on Y Ph. C T Clamp.
400KV	Newkoyna - Jaigad - I	4-Dec-10	14.36	4-Dec-10	16.00	SF-6 Gas Filling.
400KV	Karad - Kolhapur - II	4-Dec-10	22.04	5-Dec-10	11.16	Over Voltage.
400KV	Kolhapur - Mapusa - II	4-Dec-10	23.14		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	4-Dec-10	23.27	5-Dec-10	04.40	Over Voltage.

400KV	Karad - Kolhapur - II	5-Dec-10	23.42		Continued.	Over Voltage.
220KV	220/132 KV 150 MVA ICT - I @ NSK.	10-Nov-10	09.40	2-Dec-10	16.33	Augmentation of existing 150 MVA ICT by new 200MVA ICT.
220KV	220/132 KV 200 MVA ICT - II @ Theur	20-Nov-10	21.32	30-Nov-10	12.55	Differential Protection.
220KV	Bus Section - II @ Pedambe	29-Nov-10	08.45	29-Nov-10	12.19	Attending Bus conductor at R-Ph clamp of 220 KV Karad line.
220KV	Uran - HOCL	29-Nov-10	10.15	29-Nov-10	17.55	R.M.Work
220KV	Uran - JNPT	29-Nov-10	11.55	29-Nov-10	19.08	CVT replacement.
220KV	Kalwa - Ghatghar	29-Nov-10	09.48	29-Nov-10	17.55	Insulator replacement.
220KV	Waluj-Jalna-II	29-Nov-10	09.00	29-Nov-10	18.46	Stringing of 400 KV BSL-Waluj D/C line bet. loc.519-520.
220KV	Waluj-Jalna I	29-Nov-10	09.00	30-Nov-10	18.46	Stringing of 400 KV BSL-Waluj D/C line bet. loc.519-520.
220KV	Waluj-Chitegaon I	29-Nov-10	08.16	29-Nov-10	19.09	Stringing of 400 KV BSL-Waluj D/C line bet. loc.519-520.
220KV	Waluj-Chitegaon II	29-Nov-10	08.18	29-Nov-10	19.04	Stringing of 400 KV BSL-Waluj D/C line bet. loc.519-520.
220KV	Talandage-Insuli	29-Nov-10	10.45	29-Nov-10	16.50	Repair of damage conductor.
220KV	Pusad-Parbhani	29-Nov-10	11.24	29-Nov-10	14.22	To control 220 KV Chandrapur-Warora line loading.
220KV	Pusad-Parbhani	29-Nov-10	22.45	29-Nov-10	14.04	To control 220 KV Chandrapur-Warora line loading.
220KV	Usmanabad --Bale	29-Nov-10	13.35	29-Nov-10	17.50	A/R relay testing work.
220KV	220/132 KV 100 MVA ICT @ Shahada	29-Nov-10	16.10		Continued.	Main buchholz protection operated.
220KV	220/100KV 125 MVA ICT-I @ Kalwa	30-Nov-10	08.38	30-Nov-10	16.14	Attending oil leakage in main body.
220KV	Nagothane-Mahad	30-Nov-10	10.05	2-Dec-10	18.11	C.B.overhauling work.
220KV	Main Bus @ Vita	30-Nov-10	11.33	30-Nov-10	16.15	Main Bus work.
220KV	220/132KV,200MVA T/F At Ogalewadi	30-Nov-10	12.10	30-Nov-10	18.00	Attend oil leakage.
220KV	Karad - Vita - I	30-Nov-10	11.31	30-Nov-10	17.00	Outage on main bus of 220KV Vita S/Stn.
220KV	Karad-Vita-II	30-Nov-10	11.32	30-Nov-10	16.50	Outage on main bus of 220 KV Vita S/Stn.
220KV	Karad-Vita-II	30-Nov-10	16.52	1-Dec-10	05.35	Conductor snapped.Declared faulty.
220KV	Dhule-Dondaicha-II	30-Nov-10	11.05	30-Nov-10	12.00	Bus bar protection operated.
220KV	Apta-Nagothane	30-Nov-10	20.05	1-Dec-10	04.00	Conductor snapped Apta S/stn.
220KV	Murud-Bale	30-Nov-10	12.00	30-Nov-10	15.50	R.M.Work
220KV	220/132 KV 200 MVA ICT-I @ Harangul	30-Nov-10	10.15	30-Nov-10	14.55	Q.M.Work.
220KV	220/132 KV 150 MVA ICT @ Bhandara	30-Nov-10	12.25	30-Nov-10	15.25	Maintenance work.
220KV	Main Bus At Murud	30-Nov-10	11.00	30-Nov-10	15.40	Q.M.Work
220KV	Dondaicha - Sahada	30-Nov-10	11.05	30-Nov-10	12.10	Master tripped,3ph.auto reclose relay operated.
220KV	Kandalgaon-Khargar	1-Dec-10	08.13	1-Dec-10	19.13	Stringing of one ckt.for lilo for M/S Topworth.
220KV	220/132 KV 200 MVA ICT- I @ Bale	1-Dec-10	10.05	1-Dec-10	12.09	Attending oil leakage.
220KV	Pophali - KDPH	1-Dec-10	11.15	5-Dec-10	23.45	To attend MOCB oil leakage at KDPH end.
220KV	Nigade - Peth	1-Dec-10	09.30	1-Dec-10	13.50	Q.M.Work
220KV	220/132 KV 200 MVA ICT-III @ Phursungi	1-Dec-10	12.48	1-Dec-10	13.05	LV Side.
220KV	220/132KV200MVA ICT IV @Phursungi	1-Dec-10	12.48	1-Dec-10	13.05	LV side.
220KV	Khargar-Topworth	1-Dec-10	00.01	1-Dec-10	19.12	Newly Commissioned Khargar-K'gaon LILO at M/S Topworth.
220KV	Topworth-K'gaon	1-Dec-10	00.01	1-Dec-10	19.13	Newly Commissioned Khargar-K'gaon LILO at M/S Topworth.
220KV	220/33KV 100 MVA T/F - III @ Jamde	1-Dec-10	18.15	1-Dec-10	23.45	SFRA Test.
220KV	220/33 KV 100 MVA ICT IV at Jamde	1-Dec-10	12.42		Continued.	PRV and Bucholz.
220KV	Chinchwad-Theur	2-Dec-10	08.52	2-Dec-10	19.10	Insulator string replacement.
220KV	Dahanu-Ghodbandar-II	2-Dec-10	08.52	2-Dec-10	17.54	Bay Maintenance work.
220KV	Kandalgaon - Pophali	2-Dec-10	09.45	2-Dec-10	18.35	Insulator replacement.
220KV	220 KV main bus-II at 400KV Chakan	2-Dec-10	16.10	4-Dec-10	11.17	New T/F,50 MVA jumpering work.
220KV	Chinchwad - Hinjewadi	2-Dec-10	12.31	2-Dec-10	13.56	Line testing work.
220KV	Kolhapur-Sawantwadi	2-Dec-10	00.20	2-Dec-10	20.04	Distance protection Trialtaken declared faulty

220KV	Padghe - Nashik - II	2-Dec-10	14.08	2-Dec-10	14.45	Distance protection.
220KV	Girwali - Parbhani	2-Dec-10	09.34	2-Dec-10	18.21	Commissioning of WT CC.
220KV	Karad-Pedambe	3-Dec-10	04.40	3-Dec-10	12.20	Distance protection.Declared faulty.
220KV	Vita - Karkamb - Lamboti	3-Dec-10	5.53	3-Dec-10	6:08	Dist. Prot.
220KV	Airoli-Knowledge park-Nasik	3-Dec-10	08.20	3-Dec-10	18.38	Insulator Replacement Work.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	3-Dec-10	10.01	3-Dec-10	12.48	R.M.Work.
220KV	Dahanu-Ghodbunder	3-Dec-10	08.47	3-Dec-10	18.08	Bay & Line Maint Work.
220KV	Kalwa-Colourchem	3-Dec-10	10.28	3-Dec-10	12.11	Attnding Red Hot.
220KV	Kalwa-Salsatt - II	3-Dec-10	09.19	3-Dec-10	12.11	R.M.Work.
220KV	Main Bus - I @ Dahanu	3-Dec-10	09.03		Continued.	Bus Maint.Work.
220KV	Kolhapur-Sawantwadi	3-Dec-10	20.13	4-Dec-10	21.26	Distance Protection.
220KV	Bhugaon-Wardha	3-Dec-10	12.17	3-Dec-10	16.13	Attending Oil Leakage of R Ph C T.
220KV	Nigade - Peth	4-Dec-10	05.30	4-Dec-10	05.35	Distance Protection.
220KV	Talangade - Mumewadi	4-Dec-10	09.50	4-Dec-10	20.50	For Attending Talangade-Sawantwadi Line.
220KV	Airoli-Knowledge park-Nasik	4-Dec-10	08.26	4-Dec-10	18.52	Insulator Replacement Work.
220KV	Uran-Apta-II	4-Dec-10	09.30	4-Dec-10	17.55	Insulator Replacement Work.
220KV	Babaleshwar - Babaleshwar - I	4-Dec-10	12.39	4-Dec-10	14.57	Insulator String Replacement.
220KV	Mudsungi-Amona	4-Dec-10	09.00	4-Dec-10	20.32	To Attend Fault on Kolhapur-Sawantwadi Line.
220KV	Karad - Miraj	4-Dec-10	20.28	4-Dec-10	23.04	Distance Protection,L A Burst @ Miraj.
220KV	Trombay - Tata Tie - II	5-Dec-10	09.37	5-Dec-10	18.40	Breaker Testing Work.
220KV	Trombay-Kalwa	5-Dec-10	10.00	5-Dec-10	18.09	Insulator Replacement.
220KV	Airoli-Knowledge park-Nasik	5-Dec-10	08.04	5-Dec-10	18.03	Insulator Replacement.
220KV	Boiser PGCIL-Boiser II	5-Dec-10	08.43	5-Dec-10	12.11	C T Jumper Replacement.
220KV	Hinganghat - Rly TSS - I	5-Dec-10	14.28	5-Dec-10	16.06	Isolator Alignment Work.
220KV	Hinganghat - RLY TSS - II	5-Dec-10	11.50	5-Dec-10	14.13	Isolator Alignment Work.
220KV	Kalmeshwar - Pandurna	5-Dec-10	19.01		Continued.	Main Bkr PDR Problem.(Ckt is on TBC)
220KV	Butibori-Abhijeet ckt.	5-Dec-10	15.00	5-Dec-10	16.11	Bus Bar Protection Operated on 33KV Feeder Fault.
220KV	Butibori - Sun Vijay	5-Dec-10	15.00	5-Dec-10	16.05	Bus Bar Protection Operated on 33KV Feeder Fault.
220KV	220/33 KV 50 MVA T/F-I @ Butibori	5-Dec-10	15.00	5-Dec-10	16.20	Bus Bar Protection Operated on 33KV Feeder Fault.
220KV	220/33 KV 50 MVA T/F-II @ Butibori	5-Dec-10	15.00	5-Dec-10	16.00	Bus Bar Protection Operated on 33KV Feeder Fault.
220KV	220 KV Main Bus -II @ Butiburi	5-Dec-10	15.00	5-Dec-10	16.00	Bus Bar Protection Operated on 33KV Feeder Fault.
220KV	Inox - Butibori	5-Dec-10	15.00	5-Dec-10	16.04	Bus Bar Protection Operated on 33KV Feeder Fault.
220KV	Kalmeshwar - Pandurna	5-Dec-10	17.56	5-Dec-10	19.01	Distance Protection Operated Zone-I.
220KV	220/33 KV 50 MVA T/F - III @ Butibori	5-Dec-10	15.00	5-Dec-10	16.22	On Over Loaded Since T/F-I & T/F-II Tripped on Feeder Fault.
132KV	Manmad - Malegaon	1-Dec-10	08.12	1-Dec-10	18.48	Distance Protection operated.
132KV	Bale-Degaon I	1-Dec-10	08.28	1-Dec-10	12.37	Distance Protection operated.
132KV	Bale-Degaon II	1-Dec-10	08.28	1-Dec-10	09.05	Distance Protection operated.
132KV	Phursungi-Phursungi I	1-Dec-10	12.48	1-Dec-10	13.15	132 KV Bus Bar Prot.operated.
132KV	Phursungi-Phursungi II	1-Dec-10	12.48	1-Dec-10	13.15	132 KV Bus Bar Prot.operated.
132KV	Phursungi-Kothrud	1-Dec-10	12.48	1-Dec-10	13.08	132 KV Bus Bar Prot.operated.
132KV	Phursungi-Kamthali	1-Dec-10	12.48	1-Dec-10	13.17	132 KV Bus Bar Prot.operated.
132KV	Phursungi-Mundawa	1-Dec-10	12.48	1-Dec-10	13.20	132 KV Bus Bar Prot.operated.
132KV	Mundawa-Kalyani	1-Dec-10	12.48	1-Dec-10	13.20	132 KV Bus Bar Prot.operated.
132KV	Mundawa-Bharat forge	1-Dec-10	12.48	1-Dec-10	13.20	132 KV Bus Bar Prot.operated.
132KV	132/11 KV 16 MVA T/F @ Kalmeshwar	5-Dec-10	10.08	5-Dec-10	13.25	To Attend Main Bkr Air Lkg,ICT HV Side on TBC.