

LINE OUTAGES FOR THE WEEK

FROM 11-Apr-11 TO 17-Apr-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE II - CHDPR	12-Apr-11	07.31	12-Apr-11	09.34	Trip on Reduced voltage at C'Pur end
400KV	Padgha - Chakan	7-Apr-11	07.00	15-Apr-11	16.43	LILO Arrangement @ 400 KV Talegaon PG S/S.
400KV	Dhule-Sar'Sarovar - I	10-Apr-11	00.10	12-Apr-11	09.01	Over Voltage.
400KV	Bhusawal- Aurangabad	10-Apr-11	20.16	11-Apr-11	05.52	Over Voltage.
400KV	Akola - Wardha - I	10-Apr-11	22.08	11-Apr-11	05.47	Over Voltage
400KV	Kolhapur - Mapusa - II	10-Apr-11	22.15	11-Apr-11	09.48	Over Voltage.
400KV	Karad-Kolhapur-II	10-Apr-11	18.21	11-Apr-11	10.32	Direct trip, auto reclose lockout.
400KV	Newkoyna - Jaigad - I	11-Apr-11	08.29	11-Apr-11	19.19	Insulator washing work
400KV	Bhusawal- Aurangabad	11-Apr-11	22.14	12-Apr-11	06.22	Over Voltage
400KV	Wardha - Akola - II	11-Apr-11	23.40	12-Apr-11	05.43	Over Voltage
400KV	Koradi - Kaparkheda	11-Apr-11	17.30	11-Apr-11	18.12	Distance Protection
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	12-Apr-11	00.18	12-Apr-11	03.09	Checking oil level of Conservator tank and Buchholz relay
400KV	Padgha - Nagothane - I	12-Apr-11	10.07	12-Apr-11	20.18	LA replacement
400KV	Newkoyna - Jaigad - I	12-Apr-11	08.40	12-Apr-11	21.14	Insulator cleaning
400KV	Dhule-Sar'Sarovar - I	12-Apr-11	18.12	13-Apr-11	10.51	Over Voltage
400KV	400/220 KV 315 MVA ICT - I @ Chakan	12-Apr-11	09.44	12-Apr-11	19.42	DGA system monitoring
400KV	400 KV Bus Coupler @ Chakan	12-Apr-11	14.52	12-Apr-11	17.55	Tan Delta testing
400KV	Bhusawal- Aurangabad	12-Apr-11	21.58	13-Apr-11	06.05	Over Voltage
400KV	Newkoyna - Jaigad - I	13-Apr-11	03.25	13-Apr-11	04.13	Distance Protection
400KV	Bus Coupler @ 400 KV Kolhapur	13-Apr-11	10.08	13-Apr-11	19.45	Q.M.Work.
400KV	400 KV Main Bus - II @ Lamboti.	13-Apr-11	12.16	13-Apr-11	22.09	Maintenance Work.
400KV	Bus Coupler @ New Koyna	13-Apr-11	10.02	13-Apr-11	19.44	To Attend Red Hot.
400KV	Solapur - Solapur (PG)	13-Apr-11	09.33	14-Apr-11	07.15	Replacement of Y Ph. C T,Ready for Charging since 22.00 Hrs.
400KV	400/220 KV 315MVA ICT-II @ Karad	13-Apr-11	17.33	13-Apr-11	18.32	NDR Operated.
400KV	400/220KV,315MVA ICT-I at Karad	13-Apr-11	17.39	13-Apr-11	19.35	NDR Operated.
400KV	Dhule-Sar'Sarovar - II	13-Apr-11	22.34	16-Apr-11	11.29	Over Voltage.
400KV	Bhusawal- Aurangabad	13-Apr-11	21.47	14-Apr-11	06.18	Over Voltage.
400KV	Auxiliary Bus @ Parly - II	13-Apr-11	06.30	13-Apr-11	22.32	Erection of Beam & Stringing of Aux.Bus for PGCIL Extension Work.
400KV	400/220 KV 500 MVA ICT - I @ Jejuri	14-Apr-11	09.55	14-Apr-11	10.45	Buchlloz Trip.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	14-Apr-11	09.55	14-Apr-11	11.40	Backup O/C.
400KV	400 KV Bus Coupler @ Chakan	14-Apr-11	12.28	16-Apr-11	18.11	Due to Unbalancing B Ph Current
400KV	Bhusawal- Aurangabad	14-Apr-11	21.46	15-Apr-11	05.48	Over Voltage.
400KV	Karad - Solapur (PGCIL)	14-Apr-11	06.25	14-Apr-11	07.22	Over Voltage While Taken Solapur-Solapur PG.
400KV	400/220 KV 100 MVA Spare Unit @ Koradi	14-Apr-11	09.18		Continued.	Shifting to Replace R Ph Unit of ICT-I.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	15-Apr-11	01.01	15-Apr-11	05.44	Replacement of 2 No.s OFI Meter of Y Ph ICT.
400KV	400/220KV 315 MVA ICT-I @ Padgha	15-Apr-11	09.00	15-Apr-11	18.47	C and Tan delta measurement of bushing.
400KV	Main Bus- I @ Aurangabad	15-Apr-11	10.32	15-Apr-11	19.14	Replacement of PG isolator of 29A R ph.of CT III.
400KV	Bhusawal- Aurangabad	15-Apr-11	21.28	16-Apr-11	05.54	Over Voltage.
400KV	Chakan-Talegaon(PG)	15-Apr-11	16.40	15-Apr-11	16.43	LILo arrangement of 400 KV Chakan-Padghe.
400KV	Talegaon(PG)-Padgha	15-Apr-11	18.20	15-Apr-11	18.25	LILo arrangement of 400 KV Chakan-Padghe.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	15-Apr-11	22.20	15-Apr-11	23.50	ICT LV side H/T to observe performance of ICT on no load.
400KV	Chandrapur - Parly - III	15-Apr-11	23.57	16-Apr-11	03.24	Occurrence at 400KV Chandrapur.
400KV	Chandrapur-Bhadravati II	15-Apr-11	23.57	16-Apr-11	03.00	Occurrence at 400KV Chandrapur
400KV	Chandrapur - Bhadravati-IV	15-Apr-11	23.57	16-Apr-11	03.09	Occurrence at 400KV Chandrapur
400KV	400KV C'PUR-HVDC AC Ckt.I	15-Apr-11	23.57	16-Apr-11	02.35	Occurrence at 400KV Chandrapur

400KV	400/220KV 315MVA ICT- I @ Chandrapur	15-Apr-11	23.45	16-Apr-11	02.17	Occurrence at 400KV Chandrapur
400KV	400/220 KV 315 MVA ICT-II @ Chandrapur	15-Apr-11	23.45	16-Apr-11	01.42	Occurrence at 400KV Chandrapur
400KV	400 KV Bus Coupler @ Chandrapur	15-Apr-11	23.55	16-Apr-11	01.37	Occurrence at 400KV Chandrapur
400KV	Main Bus - II @ Chandrapur	15-Apr-11	23.45	16-Apr-11	01.37	Occurrence at 400KV Chandrapur
400KV	400/220 KV 300 MVA ICT-I @ Koradi	16-Apr-11	02.05	16-Apr-11	17.07	ICT LV side H/T to observe performance of ICT on no load.
400KV	400/220 KV 315 MVA ICT - II @ Parli	16-Apr-11	09.31	16-Apr-11	13.18	Attending hot spot on 29A Bus isolator.
400KV	Bhusawal- Aurangabad	16-Apr-11	21.02	16-Apr-11	06.20	Over Voltage.
400KV	Dhule-S'Sarovar I	16-Apr-11	17.40	17-Apr-11	07.29	Over Voltage.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	16-Apr-11	22.46	17-Apr-11	14.04	LV side to observe performance of ICT-I on no load.
400KV	Dhule-Sar'Sarovar - II	16-Apr-11	23.27		Continued.	Over Voltage.
400KV	400/220KV 315MVA ICT-III at Karad.	17-Apr-11	19.18	17-Apr-11	22.12	Trip,CB pole discrepancy.
400KV	Bhusawal- Aurangabad	17-Apr-11	20.27		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - II	17-Apr-11	21.53		Continued.	Over Voltage.
220KV	Babaleshwar - Bhenda	5-Mar-11	20.47	15-Apr-11	11.11	To control BBLSR ICT Load
220KV	Wardha-Abhijeet II	5-Mar-11	07.49	13-Apr-11	09.48	To control 220KV A'zari-AEPL loading.
220KV	Chandrapur-Warora - I	8-Apr-11	08.00	17-Apr-11	10.15	To control Warora-Hinganghat L/L
220KV	220/132KV,50 MVA T/F-I at Chakan	10-Apr-11	07.03	12-Apr-11	12.17	Differential protection.
220KV	220/33 KV 100 MVA T/F - I @ Ghodbandar	10-Apr-11	06.10	11-Apr-11	12.59	Annual maintenance work.
220KV	Babaleshwar - Nagar - I	11-Apr-11	10.31	11-Apr-11	10.35	Load Trimming Scheme operated at BBLSR
220KV	Babaleshwar - Nagar - II	11-Apr-11	10.31	11-Apr-11	11.19	Load Trimming Scheme operated at BBLSR
220KV	Karad-Pophali	11-Apr-11	12.56	12-Apr-11	00.30	Distance protection
220KV	Chinchwad-Urse	11-Apr-11	13.27	11-Apr-11	13.35	Tripped at C'wad end only without Indication
220KV	Main Bus at Sawantwadi	11-Apr-11	09.20	11-Apr-11	17.22	Main Bus Isolator Alignment
220KV	Badnera-Amravati	11-Apr-11	18.45	11-Apr-11	19.10	Distance protection
220KV	220/132 KV 200 MVA ICT- I @ Jalna	11-Apr-11	10.10	11-Apr-11	17.27	Q.M.Work
220KV	Aurangabad-Shendra	11-Apr-11	11.40	11-Apr-11	17.44	Q.M.work
220KV	Main Bus at Dhamangaon	11-Apr-11	10.50	11-Apr-11	14.40	Jumpering work
220KV	220/132 KV 100 MVA ICT-I @ Chikhli.	11-Apr-11	11.54	11-Apr-11	14.42	Half Bus section-I outage at Chikhali
220KV	New Paras TPS - Chikhali - I	11-Apr-11	11.56	11-Apr-11	14.50	Half Bus section-I outage at Chikhali
220KV	Kalwa - Airol - Knowledge Park.	12-Apr-11	07.32	12-Apr-11	13.40	CT Leakage
220KV	Mudshingi-Chikodi	12-Apr-11	11.45	12-Apr-11	17.35	Breaker Overhauling
220KV	Karad - Ogalewadi - II	12-Apr-11	10.11	12-Apr-11	16.28	Q.M.Work
220KV	Mudshingi-Wathar	12-Apr-11	10.25	12-Apr-11	18.45	Insulator replacement
220KV	Vita - Miraj	12-Apr-11	10.10	12-Apr-11	15.13	Q.M.Work
220KV	Nasik - Ghatghar	12-Apr-11	12.50	12-Apr-11	13.05	Distance protection
220KV	Karad-Kolhapur - II	12-Apr-11	17.33	12-Apr-11	18.34	Distance Protection
220KV	220/100 KV,100 MVA ICT-I @ Tambati	12-Apr-11	15.35	12-Apr-11	20.11	PRV replacement
220KV	220/132 KV 100 MVA ICT @ Parli - I	12-Apr-11	09.19	12-Apr-11	16.05	To attend Hot Spot
220KV	Chandrapur-MIDC	13-Apr-11	10.40	13-Apr-11	14.21	Quarterly Maintainance Work.
220KV	220/33 KV 50 MVA T/F-II @ Butibori	13-Apr-11	11.30	13-Apr-11	16.03	Measurment of Tan Delta of C T.
220KV	220/132KV 200MVA ICT-II at Dhule	13-Apr-11	11.33	13-Apr-11	13.21	Attending Oil Leakage of L V Side B Ph C T.
220KV	Apta-Nagothane	13-Apr-11	08.58	13-Apr-11	19.41	To Attend Hot Spot.
220KV	Mudshingi - Peth	13-Apr-11	12.10	13-Apr-11	12.50	Distance Protection.
220KV	Versova-Arey-II	13-Apr-11	22.40	13-Apr-11	22.56	New GIS Bay Charging @ Arey.
220KV	Main Bus- I @ Kaparkheda	13-Apr-11	11.22	13-Apr-11	16.12	ABB Make Bus Bar Protection Scheme Testing Work.
220KV	Bus Coupler @ WPCL	13-Apr-11	15.37		Continued.	At Warora-WPCL - I Y Ph P T Humming Sound.
220KV	Main Bus - I @ Arrey	13-Apr-11	21.35	13-Apr-11	22.56	New GIS Bay Charging @ Arey.
220KV	Bale-Murud	13-Apr-11	09.33	13-Apr-11	15.49	To Control Girvali-Murud L/L.
220KV	Bale-Osmanbad	13-Apr-11	09.33	13-Apr-11	15.49	Mird Span Joint Work @ Loc No. 102.
220KV	Halkarni -Tillary	13-Apr-11	19.20	14-Apr-11	12.13	Distannce Protection.

220KV	Bale-Murud	14-Apr-11	01.52	14-Apr-11	12.27	Distance Protection R Ph Z-2.Declared Faulty.
220KV	Bale-Osmanbad	14-Apr-11	02.08	14-Apr-11	12.27	To Control Girvali-Osmanabad L/L.
220KV	Main Bus - I @ Arrey	14-Apr-11	06.10	14-Apr-11	09.38	Chrging of 220KV Aarey Saki Cable Circuit for Soak Test.
220KV	Chinchwad-Bhosari	14-Apr-11	09.07	14-Apr-11	17.23	LILO Work Chinchwad-Bhosari @ 400 KV Chakan S/S.
220KV	Karad-Wathar	14-Apr-11	09.53	14-Apr-11	16.46	Replacement of Insulator.
220KV	Bus Sectionliser @ Pophali	14-Apr-11	09.30	14-Apr-11	12.25	Red Hot.
220KV	Kandalgaon-Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Backup O/C.
220KV	Jejuri - Baramati	14-Apr-11	09.55	14-Apr-11	10.48	Due to Occurenace @ 400KV Jejuri.
220KV	Jejuri-Phursungi	14-Apr-11	09.55	14-Apr-11	10.52	Due to Occurenace @ 400KV Jejuri.
220KV	Jejuri-Jejuri I	14-Apr-11	09.55	14-Apr-11	10.54	Due to Occurenace @ 400KV Jejuri.
220KV	Jejuri-Jejuri-II	14-Apr-11	09.55	14-Apr-11	10.54	Due to Occurenace @ 400KV Jejuri.
220KV	Jejury - Lonand	14-Apr-11	09.55	14-Apr-11	10.50	Due to Occurenace @ 400KV Jejuri.
220KV	Lonand - Baramati	14-Apr-11	09.55	14-Apr-11	11.50	Due to Occurenace @ 400KV Jejuri.
220KV	Lonand - Satara Road	14-Apr-11	09.55	14-Apr-11	10.17	Due to Occurenace @ 400KV Jejuri.
220KV	Talangade - Mumewadi	14-Apr-11	14.19	14-Apr-11	19.33	Distance Protection.
220KV	220/66 KV 50 MVA T/F @ Chandrapur	14-Apr-11	20.20	14-Apr-11	20.26	Over Current Earthfault.
220KV	220/132 KV 125 MVA T/F @ Saki	14-Apr-11	09.20	14-Apr-11	09.38	Chrging of 220KV Aarey Saki Cable Circuit for Soak Test.
220KV	220/132 KV 200MVA T/F-II at Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri.
220KV	220/132KV,200MVA T/F-I at Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
220KV	Bhosari - Chakan	14-Apr-11	17.23	14-Apr-11	19.22	LILO of Chinchwad-Bhosari @ 400 KV Chakan.
220KV	Chinchwad - Chakan	14-Apr-11	17.23	14-Apr-11	19.05	LILO of Chinchwad-Bhosari @ 400 KV Chakan.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	15-Apr-11	06.50	15-Apr-11	17.25	Replacement of PRV and maintenance work.
220KV	Karad-Mudsingi-IV	15-Apr-11	09.55	15-Apr-11	17.50	Fixing of WT,CC
220KV	Kalwa - Tifil	15-Apr-11	09.42		Continued.	Stringing of 4th ckt. between Mahape S/S and TIFIL LILO Tower.
220KV	Pedambe - Pophali - II	15-Apr-11	08.00	15-Apr-11	17.18	Bay maintenance work.
220KV	220/22 KV, 50 MVA T/F-II @ Kalwa	15-Apr-11	08.30	15-Apr-11	18.20	R.M.Work
220KV	Halkarni-Amona I	15-Apr-11	10.52	15-Apr-11	16.32	Replacement of insulator.
220KV	220/132KV 200MVA ICT-I at Lonand	15-Apr-11	12.15	15-Apr-11	16.30	Replacement of Y ph.HV bushing.
220KV	220/132 KV,100 MVA T/F- I @ Malegaon	15-Apr-11	10.25	15-Apr-11	11.05	OLTC oil leakage.
220KV	Uran -Apta-III	15-Apr-11	16.41	15-Apr-11	19.05	Attending hot spot.
220KV	Khaperkheda-Purti	15-Apr-11	08.11	15-Apr-11	15.23	Alignment Of Main Bus II isolator and attending problem of Main CB.
220KV	Parly - Harangul - I	15-Apr-11	09.34	15-Apr-11	12.13	Attending Hot Spot detected in thermo vision scanning.
220KV	220/66 KV 50 MVA ICT- II @ Pusad	15-Apr-11	09.49	15-Apr-11	19.48	Relay retrofitting work.
220KV	Hingoli-Pusad	15-Apr-11	12.17	17-Apr-11	23.58	To control Wardha-Y'mal loading.
220KV	Pusad - Bhugaon	15-Apr-11	12.24	15-Apr-11	12.36	Dist.Prot.operated B-Ph.
220KV	Gangapur - Valve - I	15-Apr-11	13.23	15-Apr-11	15.39	Feeder Fault.
220KV	C'pur-Sicom-I	15-Apr-11	23.45	16-Apr-11	03.13	Occurrence at 400KV Chandrapur
220KV	C'pur-Sicom-II	15-Apr-11	23.45	16-Apr-11	03.16	Occurrence at 400KV Chandrapur
220KV	Chandrapur-Gadchandur	15-Apr-11	23.45	16-Apr-11	13.02	Occurrence at 400KV Chandrapur
220KV	Bus Coupler at 400KV C'pur	15-Apr-11	23.45	16-Apr-11	01.45	Occurrence at 400KV Chandrapur
220KV	BUS -I at Chandpur	15-Apr-11	23.45	16-Apr-11	01.43	Occurrence at 400KV Chandrapur
220KV	Bus-II at Chandrapur	15-Apr-11	23.45	16-Apr-11	01.45	Occurrence at 400KV Chandrapur
220KV	Chandrapur-Wani	15-Apr-11	23.45	16-Apr-11	02.27	Occurrence at 400KV Chandrapur
220KV	Chandrapur - Chandrapur MIDC	15-Apr-11	23.45	16-Apr-11	02.03	Occurrence at 400KV Chandrapur
220KV	Chandrapur - Rly TSS - I	15-Apr-11	23.45	16-Apr-11	01.46	Occurrence at 400KV Chandrapur
220KV	Chandrapur - Rly TSS - II	15-Apr-11	23.45	16-Apr-11	01.46	Occurrence at 400KV Chandrapur
220KV	Pusad - Bhugaon	16-Apr-11	02.53	16-Apr-11	03.44	Distance protection
220KV	220/132 KV 100 MVA ICT-II @ Parbhani	16-Apr-11	11.38		Continued.	Augmentation by 200MVA ICT.
220KV	Bhira-Kandalgaon	16-Apr-11	10.05	16-Apr-11	18.45	Earth wire replacement work.
220KV	220/132 KV 200MVA T/F II at Lonand	16-Apr-11	12.02	16-Apr-11	16.37	Phasing in out of 200MVA T/F and 100MVA T/F.
220KV	Mumewadi-Mudshingi	16-Apr-11	09.10	16-Apr-11	11.53	To attend leakage of Y ph.C.T.
220KV	Pedambe-Kharepatan	16-Apr-11	12.07	16-Apr-11	12.40	Distance protection Y-B ph.
220KV	Talangade - Mumewadi	16-Apr-11	17.02	16-Apr-11	22.42	Distance protection Zone 21.
220KV	Warora-Wardha	16-Apr-11	06.29	16-Apr-11	14.50	Maintenance work.
220KV	Kandalgaon - Dasturi	17-Apr-11	09.01	17-Apr-11	18.02	Replacement of CC,WT and LA.
220KV	Trombay - Tata Tie - II	17-Apr-11	06.33	17-Apr-11	21.25	Bay maintenance.
220KV	Karad Mudsingi-II	17-Apr-11	19.45	17-Apr-11	21.39	Distance protection.

220KV	Talangade - Mumewadi	17-Apr-11	17.49	18-Apr-11	00.49	Distance protection.Declared faulty.
220KV	220/33KV,100MVA T/F-IV at Aarey	17-Apr-11	07.00	17-Apr-11	20.43	Annual maintenance.
220KV	Parbhani-Parli	17-Apr-11	23.53		Continued.	Distance Protection, Declared Faulty
220KV	Chandrapur-Wani	17-Apr-11	10.19	17-Apr-11	14.43	Testing of distance protection scheme.
220KV	Chandrapur-Warora - I	17-Apr-11	15.00		Continued.	To control Warora-Hinganghat line loading.
220KV	New Paras TPS-Alola-II	17-Apr-11	18.25	17-Apr-11	18.46	Distance protection.
220KV	Bhoisor - Bhoisor PGCIL-II	17-Apr-11	09.28	17-Apr-11	17.20	Replacement of damaged conductor.
132KV	Gangakhed - Kandhar	13-Apr-11	01.40	13-Apr-11	09.06	Distance Protection
132KV	Kanhan-Pardi	13-Apr-11	10.30	13-Apr-11	15.07	Q.M.Work.
132KV	Malkapur - Khamgaon	13-Apr-11	10.45	13-Apr-11	15.56	Replacement of Line Matching Unit.
132KV	Jalgaon - Dhrangaon	13-Apr-11	13.20	13-Apr-11	13.50	Distance Protection.
132KV	Pusad-Umarkhed	13-Apr-11	15.04	13-Apr-11	19.28	Stringing Work of 400KV Double Circuit Bhadrawati-Parli Line.
132KV	Talegaon-Arvi	13-Apr-11	10.10	13-Apr-11	12.25	For Attending Hot Spot on Line Isolator of Above Ckt.
132KV	Tiwsa-Talegaon Ckt.	13-Apr-11	12.45	13-Apr-11	14.20	For Attending Hot Spot on Line Isolator of Above Ckt.
132KV	Mankapur - Uppalwadi	13-Apr-11	10.15	13-Apr-11	15.39	Bus Section-I Maintainance Work @ Uppalwadi
132KV	Lonand - Phaltan - I	14-Apr-11	09.55	14-Apr-11	10.42	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Phaltan - II	14-Apr-11	09.55	14-Apr-11	10.15	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Veer	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Vai	14-Apr-11	09.55	14-Apr-11	10.13	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Polochem	14-Apr-11	09.54	14-Apr-11	10.14	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Chavanoffwar	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/22 KV 50 MVA T/F - I @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/22 KV 50 MVA T/F - II @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/11 KV 25 MVA T/F - I @ Loanad	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/11 KV 25 MVA T/F - II @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	Bus Section -II at Boiser	15-Apr-11	07.20	15-Apr-11	17.00	132KV bus section-I insulator replacement.
132KV	Bus Section -I at Boiser	15-Apr-11	07.20	15-Apr-11	17.00	132KV bus insulator replacement work.
132KV	Butibori-MIDC Khapri	15-Apr-11	19.04	15-Apr-11	22.51	Dist.Prot.operated Z-I,B-Ph.
132KV	Beed - Beed	15-Apr-11	13.27	15-Apr-11	13.48	Dist.Prot.operated B-Ph.
132KV	Ujani-Umarga	17-Apr-11	17.55	17-Apr-11	18.55	Distance protection.
132KV	Chakur - Udgir	17-Apr-11	17.05	17-Apr-11	17.22	Distance protection.
132KV	Purna-Basmat	17-Apr-11	14.35	17-Apr-11	20.40	Distance protection.
132KV	Lalkhedi - Durgwada	17-Apr-11	09.07	17-Apr-11	09.15	Distance protection.
132KV	Harangul-Chakur	17-Apr-11	17.05	17-Apr-11	17.22	Distance protection
100KV	Chinchwad - Talegaon	11-Apr-11	16.37	11-Apr-11	19.15	Distance protection