

LINE OUTAGES FOR THE WEEK

FROM 7-Jun-10 TO 13-Jun-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	400/220 KV,315 MVA ICT-I at Parly.	29-May-10	22.22	11-Jun-10	17.20	ICT Charged with LV Side on TBC due to PDR Problem.
400KV	Dhule-SarSarovar - I	3-Jun-10	18.08	8-Jun-10	12.15	Over Voltage
400KV	Akola - Aurangabad - I	5-Jun-10	09.38	7-Jun-10	17.04	Sparking in Line Reactor
400KV	Bhusawal- Aurangabad	5-Jun-10	17.35	11-Jun-10	17.02	To control Waluj ICT Loading
400KV	Dhule-SarSarovar - II	6-Jun-10	23.44	7-Jun-10	09.15	Over Voltage
400KV	400/220kv, 315 MVA ICT-II @ Nagothane.	7-Jun-10	03.42	7-Jun-10	06.42	NDR trip
400KV	Padgha - Nagothane - I	7-Jun-10	03.55	7-Jun-10	04.11	Transient Fault
400KV	Chandrapur - Parly - 3	7-Jun-10	07.17	7-Jun-10	22.07	Disc Insulator Repl.Line on TBC.
400KV	Koradi - Kaparkheda	7-Jun-10	07.03	8-Jun-10	00.18	CVT Replacement.
400KV	Parli-Lonikand -I	7-Jun-10	10.10	7-Jun-10	19.32	Replacement of Disc Insulator.
400KV	Karad-Kolhapur CKT I	7-Jun-10	09.00	7-Jun-10	19.06	Replacement of Disc Insulator.
400KV	Chandrapur-Khaparkheda	7-Jun-10	07.03	7-Jun-10	11.26	Trip on Over Voltage,Charged From C'pur end only.
400KV	Karad-Lonikand.	7-Jun-10	12.40	7-Jun-10	13.10	Distance Protection.
400KV	400/220 Kv ICT 2 at Nagothane	7-Jun-10	11.05	7-Jun-10	15.25	NDR Operated.
400KV	400/220 KV,315 MVA ICT-IAT NAGOTHANE	7-Jun-10	11.27	7-Jun-10	11.35	Back up Protection Operated.
400KV	Chandrapur-Khaparkheda	7-Jun-10	18.06	8-Jun-10	00.18	Tripped on Over Voltage @ Khaparkheda.
400KV	Own Breaker of Chandrapur - Parly - III	7-Jun-10	22.07	11-Jun-10	08.48	Hydrolic Pressure Problem of Own CB.Line on TBC @ Chdpr.
400KV	Akola - Aurangabad - I	7-Jun-10	17.04	12-Jun-10	10.11	For Over Voltage.
400KV	Chandrapur - Parly - 3	8-Jun-10	08.13	8-Jun-10	19.25	Replacement of Faulty Disc Insulator.
400KV	Lonikand-Parli-I	8-Jun-10	09.02	8-Jun-10	18.35	Replacement of Insulator.
400KV	Karad-Kolhapur CKT I	8-Jun-10	09.12	8-Jun-10	17.12	Replacement of Faulty Disc Insulator.
400KV	Dhule-Khandwa I	8-Jun-10	12.19	8-Jun-10	12.43	For Reactor Work.
400KV	400/220 KV 315 MVA ICT - I @ Chakan	8-Jun-10	07.41	8-Jun-10	12.39	Bird Fault,Y Ph L A Replaced.
400KV	Dhule-SarSarovar - II	8-Jun-10	12.16	9-Jun-10	07.43	For Vover Voltage.
400KV	Chandrapur-parli - III	9-Jun-10	07.29	9-Jun-10	18.31	Insulator replacement work.
400KV	Dhule-SarSarovar - I	9-Jun-10	01.40	9-Jun-10	12.20	H.T. For Over Voltage.
400KV	Karad-Kolhapur CKT I	9-Jun-10	08.46	9-Jun-10	17.55	Replacement of faulty disc insulator.
400KV	400/220KV, 315MVA ICT-I @ New Koyna.	9-Jun-10	16.26	9-Jun-10	17.38	E/F LV side.
400KV	Jejuri-Koyna STG-IV	9-Jun-10	17.08	9-Jun-10	17.22	Distance protection.
400KV	Dhule-SarSarovar - I	9-Jun-10	23.10	11-Jun-10	18.54	H/T for over voltage.
400KV	Kolhapur-Mapusa Ckt I	10-Jun-10	00.46	10-Jun-10	08.34	H/T for over voltage.
400KV	400/220 KV 500 MVA ICT-I at Jejuri	10-Jun-10	00.16	10-Jun-10	08.10	Premansoon maintenance work.
400KV	Karad-Kolhapur CKT I	10-Jun-10	08.48	10-Jun-10	16.55	Replacement of Faulty Disc Insulator
400KV	Chandrapur-parli - III	10-Jun-10	09.13	10-Jun-10	18.55	Insulator Replacement,Permit cancelled,ready for charging
400KV	Dabhol-New Koyna-I	10-Jun-10	19.36	11-Jun-10	00.21	Y Phase C.T.Clamp replacement
400KV	400/220KV,315MVA ICT-I at Karad	10-Jun-10	17.12	10-Jun-10	18.15	Directional E/F
400KV	Koradi - Kaparkheda	10-Jun-10	07.38	13-Jun-10	12.09	Retrofitting work,Ready for charging at 23.05Hrs 12/6/10
400KV	Kolhapur-Mapusa-II	10-Jun-10	23.03	12-Jun-10	17.45	H/T for O/V,B-Phase CT replacement work.
400KV	Chandrapur-Khaparkheda	10-Jun-10	07.38	13-Jun-10	12.09	Tripped on Over Voltage,ready for charging 23.05Hrs/12-6-10
400KV	Chandrapur-Bhadravti - I	11-Jun-10	01.40	11-Jun-10	13.31	H/T for O/V
400KV	Dhule-SarSarovar - II	11-Jun-10	04.34		Continued.	Over Voltage
400KV	Chandrapur-Parli -I	11-Jun-10	09.30		Continued.	Replacement of Faulty Insulator,ready for charging at 18.53Hrs
400KV	400/220KV,315MVA ICT-II at Kharghar	11-Jun-10	09.00	11-Jun-10	18.50	Premansoon Maint.work
400KV	400/220KV,315MVA ICT-II at N.Koyna	11-Jun-10	10.17	11-Jun-10	14.30	Plastic covering work
400KV	Bableswhar-Aurangabad	11-Jun-10	18.03	12-Jun-10	08.03	Bus Bar Protection operated

400KV	Padgha - BBLSWR - II	11-Jun-10	18.03	12-Jun-10	07.46	Y phase CVT Jumper Snap
400KV	Babaleshwar-Dhule CKT - I	11-Jun-10	18.03	12-Jun-10	03.25	Bus-II Isolator fallen
400KV	400/220 kV,315 MVA ICT-I at BBLR	11-Jun-10	18.03	12-Jun-10	03.11	Bus Bar Protection operated
400KV	Dhule-Sar'Sarovar - I	11-Jun-10	19.28		Continued.	Over Voltage
400KV	Akola - Aurangabad - II	11-Jun-10	16.48	12-Jun-10	12.11	Distance Protection
400KV	Main Bus-II at BBLSR	11-Jun-10	18.03	12-Jun-10	03.10	Bus Bar Protection Operated
400KV	400/220KV,315MVA ICT-I at Karad	11-Jun-10	23.38	12-Jun-10	11.41	Y phase Buchholz Trip
400KV	Kalwa-Padgha II	12-Jun-10	08.08	12-Jun-10	17.32	Replacement of Faulty Disc Insulator
400KV	Bablsrw-Aurangabad	12-Jun-10	08.15	12-Jun-10	13.05	Due to sparking CVT Jumper
400KV	Kalwa-Kharghar	12-Jun-10	17.58	12-Jun-10	19.30	B phase Twin Conductor at CVT replaced
400KV	400/220 KV 315 MVA ICT - I @ Chakan	12-Jun-10	13.13	12-Jun-10	14.12	Buchhlz Trip
400KV	Kolhapur-Mapusa Ckt I	12-Jun-10	23.16		Continued.	Over Voltage
400KV	400/220 KV 315 MVA ICT II AT CHAKAN	12-Jun-10	13:04		Continued.	'R' phase unit replacement.
400KV	Akola - Aurangabad - II	12-Jun-10	23.02		Continued.	Main Breaker Problem at A,Bad end
400KV	Akola - Aurangabad - I	12-Jun-10	10.24	12-Jun-10	22.56	Heavy sparking on Reactor Isolator B phase Jaw at Akola
400KV	Padgha - Nagothane - I	13-Jun-10	01.05	13-Jun-10	13.40	Distance protection
400KV	Babaleshwar-Dhule CKT - I	13-Jun-10	09.25	13-Jun-10	12.52	Replacement of Corona Ring of Ins.Tube.
400KV	Kalwa-Padgha CKT I	13-Jun-10	08.13	13-Jun-10	16.44	Replacement of Faulty Disc Insulator.
220KV	Nasik-Navsari -II	6-Jun-10	17.35	7-Jun-10	06.00	Location no.204,Y phase suspension string replace
220KV	Apta-Nagothane	7-Jun-10	03.53	7-Jun-10	13.32	Y Ph Insulator String Decapping on Loc. No.34.
220KV	220/100 KV,125 MVA ICT-III at Trombay S/S	7-Jun-10	00.55	8-Jun-10	18.57	Diff.Protection operated
220KV	Apta-Uran-III	7-Jun-10	03.55	7-Jun-10	04.58	LBB Prot.operated, Tripped from APTA end only
220KV	Apta-Uran-IV	7-Jun-10	03.55	7-Jun-10	05.02	LBB Prot.operated, tripped from APTA end only
220KV	Apta - Taloja	7-Jun-10	03.55	7-Jun-10	05.05	LBB Prot.operated, tripped from APTA end only.
220KV	Apta - Tambati.	7-Jun-10	03.55	7-Jun-10	05.05	LBB Prot.operated, tripped from APTA end only
220KV	220/100 KV,200 MVA ICT-II at Apta	7-Jun-10	03.55	7-Jun-10	05.01	LBB Prot.operated
220KV	220KV Bus Section - I at Apta	7-Jun-10	03.55	7-Jun-10	04.58	LBB Prot.operated
220KV	Bussectionlizer at Apta	7-Jun-10	03.55	7-Jun-10	04.54	LBB Prot.operated
220KV	Padgha-Boiser(PGCIL)	7-Jun-10	02.45	7-Jun-10	11.54	PDR Operated phase to phase fault
220KV	Apta-Kalwa	7-Jun-10	08.30	7-Jun-10	18.32	Insulator String Replacement.
220KV	Karad - Nigade	7-Jun-10	10.02	7-Jun-10	19.37	L A Replacement.
220KV	Momewadi -Halkarni	7-Jun-10	07.00	10-Jun-10	13.30	Breaker Problem @ Halkarni.At 14.03 Hrs Charge from Mumewadi.
220KV	Halkarni-Tillari	7-Jun-10	06.59	7-Jun-10	21.33	Bay Shifting Work.
220KV	Uran-Kharghar-II	7-Jun-10	19.15	7-Jun-10	19.36	Distance Protection.
220KV	Pedambe - Pophali - II	7-Jun-10	08.15	7-Jun-10	11.05	Attending B Ph Unwound Strands of Conductor.
220KV	Kalwa I-Taloja	8-Jun-10	07.48	8-Jun-10	19.39	Replacement of Insulator.
220KV	Nasik - Ghatghar	8-Jun-10	15.25	8-Jun-10	16.02	Distanace Protection.
220KV	220 KV Main Bus at Ogalewadi S/S.	8-Jun-10	10.15	8-Jun-10	17.45	Q.M.Work.
220KV	Karad - Miraj	8-Jun-10	09.52	8-Jun-10	18.34	Q.M.Work.
220KV	Akola-Paras-II	8-Jun-10	09.46	8-Jun-10	12.16	C T Ten Delta Measurment.
220KV	Wardha-RLY TSS I	8-Jun-10	14.08	8-Jun-10	18.33	C T Ten Delta.
220KV	Main Bus @ Usmanabad	8-Jun-10	07.00	8-Jun-10	15.52	Q.M.Work.
220KV	Borivali-Mulund	9-Jun-10	11.12	9-Jun-10	17.23	R.M.Work.
220KV	Kalwa - Ghatghar	9-Jun-10	09.15	9-Jun-10	18.30	Insulator replacement work.
220KV	Vita - Pandharpur	9-Jun-10	10.00	9-Jun-10	18.30	R.M.Work.
220KV	M.B.-I at Solapur	9-Jun-10	11.01	9-Jun-10	14.10	Jumpering work of New ICT.
220KV	Karad-Vita-II	9-Jun-10	11.25	9-Jun-10	18.33	Errection of New LA.
220KV	Uran-Kharghar-II	9-Jun-10	10.20	9-Jun-10	16.52	Insulator replacement.
220KV	Talangade-Mudshingi	9-Jun-10	13.53	9-Jun-10	17.42	Earth wire replacement work.
220KV	Kharepatan-Pawas	9-Jun-10	18.35	10-Jun-10	12.40	Distance protection.

220KV	N.Koyna-Phinolex	9-Jun-10	18.10	10-Jun-10	10.18	Distance protection.
220KV	Padgha-Jambhul II	9-Jun-10	18.21	10-Jun-10	14.04	Distance protection.
220KV	Talangde - Chikodi	9-Jun-10	21.20	10-Jun-10	16.05	Distance protection.
220KV	Parbhani-Pusad	9-Jun-10	07.24	9-Jun-10	18.15	Replacement of Insulator.
220KV	Chandrapur - Warora - II.	9-Jun-10	14.22	9-Jun-10	21.11	Attending hot spot.
220KV	MUDSHINGI-CHIKODI	9-Jun-10	13.58	9-Jun-10	17.56	Charged at Mudshingi end only.
220KV	Kalwa - Ghatghar	10-Jun-10	08.59	10-Jun-10	17.47	Insulator replacement
220KV	Jejuri-Phursungi	10-Jun-10	00.40	10-Jun-10	01.15	Distance protection.
220KV	Bablsr-Ranjanagaon	10-Jun-10	08.40	10-Jun-10	19.03	Replacement of Disc Insulator
220KV	K'gaon-Lonand	10-Jun-10	09.42	11-Jun-10	21.34	Erection of Tower
220KV	Chinchwad-Parvati	10-Jun-10	10.51	10-Jun-10	15.22	Q.M.Work
220KV	Trombay-Kalwa	10-Jun-10	11.17	10-Jun-10	17.51	Red Hot Spot
220KV	K'gaon-Pirangut	10-Jun-10	14.50	10-Jun-10	15.17	Distance Protection
220KV	Nasik-Bablsr Ckt I	10-Jun-10	22.01	10-Jun-10	23.24	Distance protection
220KV	Nasik-Bablsr Ckt II	10-Jun-10	22.16	10-Jun-10	23.22	Distance Protection
220KV	Nasik - Ghatghar	10-Jun-10	22.24	10-Jun-10	23.19	Distance Protection
220KV	New Parly - Beed - I	10-Jun-10	17.20	10-Jun-10	19.07	Distance Protection
220KV	Bhusawal-Chalisgaon-II	10-Jun-10	17.19	10-Jun-10	17.33	Distance protection
220KV	220/132KV 200MVA ICT-II at Chikhali	10-Jun-10	10.32	10-Jun-10	11.58	To attend oil leakage
220KV	Pusad-Parbhani	10-Jun-10	07.40	10-Jun-10	18.53	Replacement of Earth Wire
220KV	Chandrapur - Warora - II.	10-Jun-10	11.58	10-Jun-10	20.29	Measurement of Tan Delta of CT LILLO at 220 kv Wani.
220KV	Khaparkheda-Kawlewada-I	10-Jun-10	16.05	10-Jun-10	17.59	Testing Work
220KV	220/132KV 100MVA ICT-II at Parli-II	10-Jun-10	10.09	10-Jun-10	13.09	SF6 Gas Filling
220KV	M.B.@ Urse	10-Jun-10	06.39	10-Jun-10	18.28	Stringing work
220KV	Wada-Kolshet	11-Jun-10	00.28	11-Jun-10	00.48	Distance protection
220KV	B'dying-Sahara	11-Jun-10	01.45	11-Jun-10	05.40	Distance Protection
220KV	ONGC-TSS	11-Jun-10	01.50	11-Jun-10	03.40	Distance Protection
220KV	Kalwa - Ghatghar	11-Jun-10	08.47	11-Jun-10	17.48	Insulator replacement
220KV	Dhule - Malegaon	11-Jun-10	09.20	11-Jun-10	12.52	Q.M.Work
220KV	Trombay - Tifil	11-Jun-10	09.45	11-Jun-10	16.14	Red Hot Spot
220KV	220/33 KV 50 MVA ICT-II @ Boisar	11-Jun-10	14.39	11-Jun-10	15.44	Removal of pipes connected for Regeneration
220KV	220/33KV,50 MVA T/F-I At Boiser.	11-Jun-10	15.52	11-Jun-10	18.44	Hot Spot
220KV	220/100 KV 200 MVA ICT-I at Kolshet	11-Jun-10	10.07	11-Jun-10	10.58	Plastic covering work
220KV	220/100KV 200MVA ICT-II at Kolshet	11-Jun-10	11.25	11-Jun-10	12.02	Plastic covering work
220KV	Pophali-K'gaon -I	11-Jun-10	22.40	11-Jun-10	23.00	Distance Protection
220KV	Karad-Pedambe	11-Jun-10	22.01	12-Jun-10	11.41	Distance Protection
220KV	Babaleshwar - Alephata	11-Jun-10	18.42	12-Jun-10	03.41	Distance protection
220KV	Babaleshwar - Nagar - II	11-Jun-10	18.03	12-Jun-10	03.37	Distance protection
220KV	Apta-Bombay Dyeing	11-Jun-10	16.25	11-Jun-10	18.15	Distance Protection
220KV	Halkarni-Tillari	11-Jun-10	17.55	12-Jun-10	10.53	Distance Protection
220KV	Mudsungi-Amona	11-Jun-10	17.36	12-Jun-10	14.30	Distance Protection
220KV	Pusad -Parbhani	11-Jun-10	07.34	11-Jun-10	18.27	Replacement of Faulty Disc Insulator
220KV	Aurangabad - Padegaon - I.	11-Jun-10	15.32	11-Jun-10	15.39	Distance protection
220KV	Aurangabad-Padegaon CKT-II	11-Jun-10	15.32	11-Jun-10	18.13	Distance Protection
220KV	Aurangabad - Bhenda	11-Jun-10	16.52	12-Jun-10	15:00	Distance protection
220KV	New Parli -Beed ckt-II	11-Jun-10	17.57	11-Jun-10	18.47	Distance Protection
220KV	Uran-Kharghar-II	12-Jun-10	00.31	12-Jun-10	00.58	Distance Protection
220KV	220/132 KV,100 MVA ICT At Parli I	12-Jun-10	00.53		Continued.	Differential protection
220KV	Kalwa-Ghatghar	12-Jun-10	08.52	12-Jun-10	20.06	Insulator replacement
220KV	K'gaon-Pirangut	12-Jun-10	12.45	12-Jun-10	14.10	E/W removing work

220KV	Wada-Kolshet	12-Jun-10	16.35	12-Jun-10	19.30	Replacement of Faulty Insulator
220KV	Karad Mudsingi-II	12-Jun-10	14.23	12-Jun-10	16.25	E/W removing work
220KV	Peth-Mudsingi-I	12-Jun-10	13.00	12-Jun-10	16.05	E/W removing work
220KV	Dhule-Dondaicha-II	12-Jun-10	16.35	12-Jun-10	19.14	Y phase LA broken Clamp replace
220KV	220/132 KV 150 MVA ICT-I at Dhule	12-Jun-10	09.30	12-Jun-10	13.45	Premansoon maint.work
220KV	Vita - Ghatnandre	13-Jun-10	08.20	13-Jun-10	14.45	Replacement of Faulty Disc Insulator.
220KV	Bhoisor-Bhoisor(PGCIL)-I	13-Jun-10	09.20	13-Jun-10	16.00	Hot Spot Attending Work.
220KV	Kalwa - Salshet - III	13-Jun-10	16.48	13-Jun-10	18.23	Premansoon Maintenance Work.
220KV	Kalwa - Salshet - IV	13-Jun-10	14.02	13-Jun-10	16.00	Premansoon Maintenance Wrok.
220KV	220/100KV 200MVA ICT-II at Padgha	13-Jun-10	17.28	13-Jun-10	17.38	B Ph PT(220KV) B Bus Burst Bus Bar Protection Operated.
220KV	Nasik-Padgha	13-Jun-10	17.28	13-Jun-10	18.00	B PH PT(220KV) B Bus Burst,Bus Bar Protection Operated.
220KV	Padgha - Kalwa	13-Jun-10	17.28	13-Jun-10	18.06	B PH PT(220KV) B Bus Burst,Bus Bar Protection Operated.
220KV	Padgha-Wada	13-Jun-10	17.28	13-Jun-10	18.06	B Ph PT(220KV) B Bus Burst Bus Bar Protection Operated.
220KV	Padgha-Temghar	13-Jun-10	17.28	13-Jun-10	18.07	B Ph PT(220KV) B Bus Burst,Bus Bar Protection Operated.
220KV	Padgha - Boisar (PGCIL)	13-Jun-10	17.28	13-Jun-10	18.10	B Ph PT(220KV) B Bus Burst,Bus Bar Protection Operated.
220KV	Chalisgaon - Malegaon	13-Jun-10	18.30	13-Jun-10	23.45	Distanace Protection,Line Faulty.
220KV	Tillary-Amona	13-Jun-10	15.52		Continued.	Distanance Protection,Declare Faulty.
220KV	220 KV Bus @ Padgha	13-Jun-10	17.28	13-Jun-10	18.00	B Ph PT(220KV) B Bus Burst,Bus Bar Protection Operated.
220KV	Padgha - Colorchem	13-Jun-10	17.28	13-Jun-10	18.09	B Ph PT (220KV) B Bus Burst,Bus Bar Protection Operated.
220KV	220/132 KV.200 MVA ICT-II at Boiser.	13-Jun-10	13.36	13-Jun-10	15.15	Bus Fault While Removing Bird Nest by Hot Line.
220KV	220/132KV 150MVA ICT at Boisor	13-Jun-10	13.36	13-Jun-10	19.23	Bus Fault While Removing Bird Nest by Hot Line.
220KV	220/132KV, 200MVA ICT-1@Boiser	13-Jun-10	13.36	13-Jun-10	15.22	Bus Fault While Removing Bird Nest by Hot Line.
220KV	220/132 KV,100 MVA ICT At Parli I	13-Jun-10	00.53	13-Jun-10	19.56	Differential Protection Operated.
220KV	Chandrapur-Warora - I	13-Jun-10	00.00	13-Jun-10	07.40	To Control ICT Loading @ C'PUR.
220KV	Aurangabad-Jalna-II	13-Jun-10	02.10	13-Jun-10	02.42	Distance Protection.
220KV	Aurangabad-Chitegaon-II	13-Jun-10	02.00	13-Jun-10	02.59	Distance Protection.
220KV	220/132 KV 200 MVA ICT - I @ Nanded	13-Jun-10	21.05		Continued.	To Attend Red Hot Spot on LV Bus side Isolator.
220KV	Momewadi-Halkarni	13-Jun-10	19.15	13-Jun-10	23.43	Distance Protection,Declared Faulty.
132KV	Kalmeshwar - Katol	7-Jun-10	14.53	7-Jun-10	17.50	Shifted on TBC - 132 kv Bus Free -for Loading New 200 MVA ICT.
132KV	Bhusawal - Pachora	7-Jun-10	11.15	7-Jun-10	11.50	To Attend Red Hot on C T Clamp @ Pachora.
132KV	Dhule-Nardhane	8-Jun-10	08.35	8-Jun-10	09.17	Backup Protection.
132KV	Kannad - Kagzipura	10-Jun-10	19.45	11-Jun-10	04.00	Distance protection
132KV	Chikhali - Khamgaon	10-Jun-10	10.28	10-Jun-10	12.08	H/T In view of Chikhali ICT outage
132KV	Mehkar - Malegaon	10-Jun-10	10.23	10-Jun-10	12.10	H/T in view of Chikhali ICT outage
132KV	Buldhana-Motala	10-Jun-10	10.16	10-Jun-10	16.52	H/T in view of Chikhali ICT outage
132KV	Pusad - Gunj	11-Jun-10	15.28	11-Jun-10	15.34	Tripped on Backup Protection
132KV	Harangul - Udgir	12-Jun-10	05.05	12-Jun-10	10.35	Distance protection
132KV	Chalisgaon - Kannad	12-Jun-10	09.40	12-Jun-10	14.35	LA replacement
132KV	Ujani-Umarga	12-Jun-10	16.30	12-Jun-10	17.30	Distance Protection
132KV	Ambazari - Mankapur	12-Jun-10	23.12	13-Jun-10	00.21	Distance protection
132KV	Hingna-Mankapur-I	12-Jun-10	23.12	13-Jun-10	00.42	Distance protection
132KV	Mankapur - Uppalwadi	12-Jun-10	23.12	13-Jun-10	01.05	Distance protection
132KV	132/11KV 25MVA T/F-I at Mankapur	12-Jun-10	23.12		Continued.	R phase CT Burst
132KV	Boiser - Palghar - I	13-Jun-10	13.36	13-Jun-10	15.27	Bus Fault While Removing Bird Nest by Hot Line.
132KV	Boiser - Viraj	13-Jun-10	13.36	13-Jun-10	15.26	Bus Fault While Removing Bird Nest by Hot Line.
132KV	Boiser - Palghar - II	13-Jun-10	13.36	13-Jun-10	15.16	Bus Fault While Remiving Bird Nest by Hot Line.
132KV	Boiser - MIDC	13-Jun-10	13.36	13-Jun-10	15.23	Bus Fault While Removing Bird Nest by Hot Line.
132KV	132 KV A Bus @ Boiser	13-Jun-10	13.36	13-Jun-10	15.15	Bus Fault While Removing Bird Nest by Hot Line.
132KV	132 KV B Bus @ Boiser	13-Jun-10	13.36	13-Jun-10	15.21	Bus Fault While Removing Bird Nest by Hot Line.
110KV	110 KV Main Bus @ Ogalewadi	8-Jun-10	10.15	8-Jun-10	18.00	Q.M.Work.
100KV	Kandalgaon-Roha-I	10-Jun-10	20.08	10-Jun-10	20.46	Distance Protection
100KV	Borivali-Tata-I	11-Jun-10	15.05	11-Jun-10	15.52	Tree Trimming work
100KV	Borivali-Tata-I	12-Jun-10	20.55	12-Jun-10	21.23	Trinned