

LINE OUTAGES FOR THE WEEK

FROM 12-Jul-10 TO 18-Jul-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole-I	12-Jul-10	23.53	13-Jul-10	02.25	Faulty Capacitor Replacement @ Padgha.
500KV	HVDC Pole II Padgha	17-Jul-10	06.03	17-Jul-10	09.38	Replacement of Faulty Capacitor
400KV	400/11.5/6.6 KV 70 MVA Stn.T/F 5B @ 400kV	25-Apr-10	03.59	17-Jul-10	17.59	B-Ph,HV Bushing Burst and Caught Fire.
400KV	50 MVAR Line Reactor of LN @ Parli	13-May-10	07.58	13-Jul-10	11.54	Overhauling of Line Reactor of Lonikand -I at Parli.
400KV	Akola - Aurangabad - I	25-Jun-10	14.10	15-Jul-10	10.45	To control Aurangabad ICT loading
400KV	Koradi - Kaparkheda	2-Jul-10	20.12	14-Jul-10	17.11	Over Voltage
400KV	Dhule-Sar'Sarovar - II	2-Jul-10	22.19	12-Jul-10	19.45	Over Voltage
400KV	Chandrapur - Khaparkheda	2-Jul-10	20.11	20-Jul-10	08:55	Over Voltage
400KV	Akola - Wardha - I	7-Jul-10	11.00	20-Jul-10	10:31	Changeover.
400KV	Dhule-Khandwa I	10-Jul-10	10.09	12-Jul-10	07.39	Over Voltage
400KV	Dhule-Sar'Sarovar - I	10-Jul-10	23.00	12-Jul-10	12:10	Over Voltage
400KV	Kolhapur-Mapusa-II	10-Jul-10	23.49	13-Jul-10	15.54	Over Voltage
400KV	Karad - Kolhapur - I	11-Jul-10	10.22	19-Jul-10	08.57	Relay retrofitting work
400KV	Dhule-S'Sarovar I	11-Jul-10	23.18	12-Jul-10	12.10	Over Voltage
400KV	Chandrapur - Parli - II	11-Jul-10	23.28	12-Jul-10	04.48	Replacement of Line Matching Units
400KV	Dhule-Sar'Sarovar - II	12-Jul-10	23.37	17-Jul-10	10.19	Over Voltage.
400KV	Karad-Lamboti	13-Jul-10	00.02	13-Jul-10	06:36	Over Voltage.
400KV	Parli - Lamboti	13-Jul-10	00.02	13-Jul-10	05.22	Over Voltage.
400KV	New Koyna - Karad - I	13-Jul-10	09.55	13-Jul-10	18.10	Attending Red Hot Work.
400KV	Parli-Lonikand -I	13-Jul-10	11.30	13-Jul-10	11.54	For Taking Reactor in Service.
400KV	Dhule-Khandwa-I	13-Jul-10	20.42	15-Jul-10	14.19	Over Voltage.
400KV	Kolhapur-Mapusa Ckt I	13-Jul-10	21.50	14-Jul-10	13.58	Over voltage.
400KV	Newkoyna - Jaigad - I	14-Jul-10	12.37	14-Jul-10	13.03	Dist.Protection.
400KV	Karad-New Koyna II	14-Jul-10	09.04	14-Jul-10	17.22	Repl.of jumper at Loc.no.197
400KV	400 KV Main Bus - II @ Lamboti	14-Jul-10	11.44	14-Jul-10	14.58	B-Ph insulator stringing work.
400KV	Kolhapur-Mapusa-II	14-Jul-10	22.15	15-Jul-10	14.25	Over Voltage.
400KV	Akola - Aurangabad- II	15-Jul-10	10.15	21-Jul-10	13.04	To control Aurangbad ICT loading
400KV	Padgha - Chakan	15-Jul-10	08.02	15-Jul-10	19.01	Repl.of disc.insulator.
400KV	400/220 KV 315 MVA ICT-II @ Lonikand	15-Jul-10	08.51	15-Jul-10	19.49	R.M.Work
400KV	Koyna IV - Jejuri	15-Jul-10	09.06	16-Jul-10	08.57	Rectification on E/W bet. Loc.no.254-255
400KV	New Koyna - StageIV - I	15-Jul-10	23.50	16-Jul-10	09.55	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	15-Jul-10	23.50	16-Jul-10	10.21	Over Voltage.
400KV	Karad-Kolhapur CKT II	15-Jul-10	23.59	17-Jul-10	08.46	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	15-Jul-10	22.39	18-Jul-10	19.16	Over Voltage.
400KV	Kolhapur-Mapusa Ckt I	15-Jul-10	22.55	16-Jul-10	07.34	Over Voltage.
400KV	C'pur-Parli II	16-Jul-10	01.41	16-Jul-10	05.05	Over Voltage.
400KV	400/220KV 315 MVA ICT-I @ Padgha	16-Jul-10	09.21	16-Jul-10	18.03	Maintenance work
400KV	Lonikand- Koyna Stage IV	16-Jul-10	10.52		Continued.	E/W replacement work (Ready)
400KV	Padgha -Tarapur - I	16-Jul-10	10.18	16-Jul-10	19.46	Maintenance work
400KV	Kolhapur-Mapusa Ckt I	16-Jul-10	18.43	28-Jul-10	19.45	Over Voltage
400KV	400/220 KV 315 MVA ICT @ Khadka	16-Jul-10	21.29	16-Jul-10	22.55	Tripped on NDR
400KV	Chandrapur - Parli - II	16-Jul-10	21.57	17-Jul-10	06.02	Over Voltage
400KV	Jejuri-Koyna STG-IV	16-Jul-10	22.58	17-Jul-10	09.36	Over Voltage
400KV	New Koyna - Koyna Stage IV - II	16-Jul-10	22.58	23-Jul-10	12.34	Over Voltage
400KV	Karad-Kolhapur-II	16-Jul-10	23.48	17-Jul-10	08.46	Over Voltage
400KV	New Koyna - StageIV - I	16-Jul-10	23.44	17-Jul-10	08.29	Over Voltage
400KV	Bableshtar-Aurangabad	16-Jul-10	01.45	17-Jul-10	10.10	Over Voltage
400KV	Chandrapur-Parli -I	17-Jul-10	11.20	18-Jul-10	11.41	Testing of R&Y phase CVT
400KV	400/220KV 315MVA ICT-II @ New Koyna	17-Jul-10	15.43	17-Jul-10	16.16	SF6 Gas Filling in CB

400KV	Dhule-Khandwa I	17-Jul-10	12.55	17-Jul-10	13.33	Over Voltage
400KV	Dhule-Sar'Sarovar - II	17-Jul-10	22.56	19-Jul-10	17.19	Over Voltage
400KV	400/220 KV315 MVA ICT-I @ BBLR	17-Jul-10	12.17	17-Jul-10	19.41	Q.M.Work
400KV	Jejuri-Koyna STG-IV	17-Jul-10	13.06	17-Jul-10	13.44	Over Voltage
400KV	Karad - Lonikand	17-Jul-10	21.44	18-Jul-10	09.23	Over Voltage
400KV	Karad-Kolhapur-II	18-Jul-10	00.56	18-Jul-10	08.33	Over Voltage
400KV	Jejuri-Koyna STG-IV	18-Jul-10	00.56	18-Jul-10	09.35	Over Voltage
400KV	Karad-Lamboti	18-Jul-10	09.46	20-Jul-10	08:09	Relay retrofitting work
400KV	Karad-Kolhapur-II	18-Jul-10	22.26	19-Jul-10	07:13	For control Voltage
220KV	220/132KV 200 MVA ICT- II @ Amravati	5-Jul-10	10.24	16-Jul-10	17.28	Replacement of CT's & L A'S.
220KV	Parli-Usmanabad	6-Jul-10	12.22	17-Jul-10	14:13	CKT on TBC for main BKR Repl.work.
220KV	220/33 KV 100 MVA ICT- II @ Versova	10-Jul-10	22.00	12-Jul-10	08.10	To attend Y phase Bushing oil leakage
220KV	Padgha-Temghar	12-Jul-10	09.05	12-Jul-10	18.00	Bay Maintenance.
220KV	Badnera - Deoli (PGCIL)	12-Jul-10	10.20	12-Jul-10	16.29	Oil Leakage on R Ph. C T.
220KV	Apta-Uran-IV	12-Jul-10	18.52	13-Jul-10	10.12	D/P,R Ph W/T Burnt Out.
220KV	Kanhan - Bhandara - I	12-Jul-10	10.50	12-Jul-10	11.25	Bus Bar Protection.
220KV	Kanhan - Bhandara - II	12-Jul-10	10.50	12-Jul-10	13.32	Bus Bar Protection.
220KV	Bhandara - RLY TSS - I	12-Jul-10	10.50	12-Jul-10	11.30	Bus Bar Protection.
220KV	Bhandara - Rly TSS - II	12-Jul-10	10.50	12-Jul-10	11.42	Bus Bar Protection.
220KV	220/132 KV 100 MVA ICT @ Bhandara	12-Jul-10	10.50	12-Jul-10	11.45	Bus Bar Protection.
220KV	220/132 KV 150 MVA ICT @ Bhandara	12-Jul-10	10.50	12-Jul-10	11.41	Bus Bar Protection.
220KV	Bhandara - Sunflag - I	12-Jul-10	10.50	12-Jul-10	11.28	Bus Bar Protection.
220KV	Wardha - Badnera - I	12-Jul-10	18.07	13-Jul-10	11.33	CVT Testing Work.
220KV	Bus Section @ Mahad	13-Jul-10	09.20	13-Jul-10	18.20	R.M.Work.
220KV	Pedambe-Mahad	13-Jul-10	09.20	13-Jul-10	18.20	R.M.Work.
220KV	Nagothane-MSL	13-Jul-10	10.12	13-Jul-10	13.03	Q.M.Work.
220KV	Uran - Apta (HOC)	13-Jul-10	11.37	13-Jul-10	13.03	Attending Hot Spot Work/Q.M.
220KV	Karad - Ogalewadi - II	13-Jul-10	10.26	13-Jul-10	13.20	Relay Testing @ Ogalewadi.
220KV	Karad-Oglewadi-I	13-Jul-10	15.30	13-Jul-10	19.20	Replacement of Own Bkr.,Taken on TBC.
220KV	220 KV Main Bus Section - I @ Vita	13-Jul-10	10.00	13-Jul-10	16.00	String Insulator Replacement of Main Bus Section - I
220KV	Badnera - Deoli (PGCIL)	13-Jul-10	18.07	13-Jul-10	11.33	Over Voltage @ Deoli,R Ph CVT Testing Work is in Prog.@ Deoli.
220KV	Karad-Oglewadi-I	13-Jul-10	19.20	20-Jul-10	20.00	Replacement of own Brekaer, Line on TBC
220KV	Bale-Osmanbad	14-Jul-10	14.25	14-Jul-10	16.11	Bay maintenance work.
220KV	Pophali-K'gaon	14-Jul-10	18.30	14-Jul-10	18.50	Dist.Protection.
220KV	Kandalgaon - Dasturi	14-Jul-10	18.30	14-Jul-10	19.37	Dist.Protection.
220KV	Padghe - Nashik - II	14-Jul-10	09.17	14-Jul-10	17.26	Repl.of damaged control cable from Bkr to C.P.
220KV	Bale-Murud	14-Jul-10	10.30	14-Jul-10	12.25	Q.M.Work
220KV	Butibori - Wardha	14-Jul-10	09.43	14-Jul-10	15.54	Q.M.Work
220KV	220 KV Main Bus-I @ Koradi	14-Jul-10	11.57	14-Jul-10	14.56	Repl.of B-Ph jumper of M.B.I to 220KV bus coupler isolator.
220KV	Main Bus II @ Aarey	15-Jul-10	00.48	15-Jul-10	03.58	Double isolator scheme work.
220KV	Lonikand-Kathapur	15-Jul-10	08.42	15-Jul-10	16.12	Breaker Problem.
220KV	Uran-Kharghar	15-Jul-10	09.28	15-Jul-10	18.54	To attend Hot Spot.
220KV	Jejuri I-Jejuri II	15-Jul-10	09.57	15-Jul-10	12.42	Maint.work.
220KV	Chinchwad - Telco	15-Jul-10	10.01	15-Jul-10	15.56	Q.M.Work
220KV	Kalyani-Bhigwan	15-Jul-10	10.50	15-Jul-10	15.25	Q.M.work
220KV	220/132 KV 200 MVA ICT @ Kurkumb	15-Jul-10	11.10	15-Jul-10	11.50	Maint.work
220KV	Butibori - Wardha	15-Jul-10	04.27	15-Jul-10	08.43	Dist.Protection.Z-1.
220KV	Virur - Gadchiroli	15-Jul-10	14.14	15-Jul-10	17.08	Retrofitting of distance relay.
220KV	Yavatmal-Pusad	15-Jul-10	10.01	15-Jul-10	14.47	Repl.of B-Ph 220KV Yavatmal-Pusad FDR coupling condenser.
220KV	Ambazari-Wardha	15-Jul-10	09.02	15-Jul-10	19.24	Work of CT replacement B-Ph.

220KV	Padgha-Wada	16-Jul-10	09.51	16-Jul-10	19.10	Maintenance work
220KV	Nasik-Bablsr - II	16-Jul-10	08.42	16-Jul-10	20.10	Replacement of Wave Trap
220KV	220/100KV 125 MVA ICT-II @ Kalwa	16-Jul-10	08.50	16-Jul-10	15.38	Maintenance work
220KV	220KV TBC @ Yavatmal	16-Jul-10	10.45	17-Jul-10	13:25	Replacement of Interrupter due to SF6 Gas leakage
220KV	220/132KV 200 MVA ICT- III @ Padegaon	16-Jul-10	11.00	16-Jul-10	16.02	Q.M.Work
220KV	220/132KV 100 MVA ICT- II @ Peth	17-Jul-10	03.00	17-Jul-10	03.15	Backup Protection
220KV	Main Bus II @ Aarey	17-Jul-10	00.50	17-Jul-10	05.35	Double Isolator Scheme Work
220KV	220/132KV 200MVA ICT-I @ Raymond	17-Jul-10	10.30	17-Jul-10	15.00	To find out DC Earth Leakage
220KV	Aurangabad - Babaleshwar	17-Jul-10	12.04	17-Jul-10	19.39	H/T due to BBLSR ICT Outage
220KV	Khaparkheda-Kawlewada-I	17-Jul-10	02.21	18-Jul-10	17.00	Conductor Snapped Loc.No.21,22
220KV	Parli-Usmanabad	17-Jul-10	13.51	17-Jul-10	16.13	Protection trial of Main Breaker
220KV	Warora-Hinganghat	17-Jul-10	14.12	17-Jul-10	15.30	Supervision Relay testing work
220KV	220/132KV 100 MVA ICT- III @ Parli-II	17-Jul-10	11.00	17-Jul-10	17.54	ICT OLTC checking work
220KV	Bableskhar-Bhenda	18-Jul-10	01.37	18-Jul-10	12.30	Distance Protection
220KV	Main Bus II @ Aarey	18-Jul-10	07.04	18-Jul-10	10.11	Double Isolator scheme work
220KV	Borivali-Boisar	18-Jul-10	12.02	18-Jul-10	17.12	To control line loading
220KV	Mudsungi - Chikodi	18-Jul-10	17.10	18-Jul-10	21.50	Distance protection
220KV	Tarapur-Boisor-II	18-Jul-10	09.00	18-Jul-10	15.06	Urgent Civil work
220KV	220/132KV 200 MVA ICT- II @ Raymond	18-Jul-10	19.55	21-Jul-10	15.40	H/T due to oil leakage of R phase CT
220KV	Aarey-Borivali-II	18-Jul-10	07.24	18-Jul-10	10.11	Double Isolator Scheme work
220KV	Murud-Bale	18-Jul-10	09.45	20-Jul-10	12:00	Main Breaker replacement work, Ckt on TBC
220KV	Butibori - Wardha	18-Jul-10	21.33	18-Jul-10	21.54	Distance Protection
132KV	Bhandara-Kardha	12-Jul-10	19.06	12-Jul-10	19.55	Distance Protection.
132KV	Nanded - Umri	15-Jul-10	10.48	15-Jul-10	11.06	HV back up protection operated.
132KV	132 KV Bus Coupler @ Boiser- II	16-Jul-10	09.30	16-Jul-10	16.00	Breaker work
132KV	Beed-Gevrai	16-Jul-10	00.00	16-Jul-10	00.14	Backup Protection operated
132KV	Girwali - Gangakhed	16-Jul-10	05.30	16-Jul-10	07.56	Distance Protection
132KV	Peth-Sirla	17-Jul-10	03.00	17-Jul-10	17.15	Backup Protection
132KV	Kalmeshwar-Katol	17-Jul-10	13.27	17-Jul-10	13.43	Tripped on PDR at Katol
132KV	Ambazari - Hingna - I	17-Jul-10	22.23	18-Jul-10	10.28	To attend Hot Glow on R Phase Wave-Trap Top
132KV	Kanhan - Bhandara	17-Jul-10	23.19	18-Jul-10	00.03	Distance protection
132KV	Bhandara - Madgi -I	18-Jul-10	00.58	18-Jul-10	01.26	Tripped on Backup Protection
132KV	Bhandara - Madgi - II	18-Jul-10	00.58	18-Jul-10	01.25	Distance Protection