

LINE OUTAGES FOR THE WEEK

FROM 9-Aug-10 TO 15-Aug-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	Chandrapur - Padgha Pole-I	5-Aug-10	08.23	9-Aug-10	20.36	Annual maintenance work.
500KV	HVDC POLE II - CHDPR	13-Aug-10	23.28	14-Aug-10	04.41	A C Conductor Ground Fault Protection Operated While Making Flow to 0 MW.
500KV	Chandrapur - Padgha Pole-I	14-Aug-10	18:03	14-Aug-10	20:58	Colling water valve pressure low.
400KV	Lonikand- Koyna Stage IV	16-Jul-10	10.52	19-Aug-10	17.08	E/W Replacement Work (Ready)
400KV	New Koyna - Karad - I	23-Jul-10	23.47	9-Aug-10	11.20	Over Voltage
400KV	Bhusawal- Aurangabad	31-Jul-10	23.25	21-Aug-10	09.22	Hand Tripped.
400KV	New Koyna - Koyna Stage IV - II	1-Aug-10	16.38	12-Aug-10	08.52	Over Voltage.
400KV	Dhule - S'Sarovar- II	6-Aug-10	01.53	11-Aug-10	10.39	Over Voltage.
400KV	Akola - Aurangabad - I	6-Aug-10	10.56	20-Aug-10	09.36	Changeover.
400KV	Lonikand-Karad	7-Aug-10	03.54	9-Aug-10	12.17	Bus Fault.
400KV	Kolhapur - Mapusa - II	7-Aug-10	23.38	11-Aug-10	11.13	Over Voltage.
400KV	Koradi - Kaparkheda	9-Aug-10	02.44	9-Aug-10	11.22	Over Voltage
400KV	Dhule-Sar'Sarovar - I	9-Aug-10	00.01	9-Aug-10	08.41	Over Voltage
400KV	Dhule-Khandwa-II	9-Aug-10	01.22	10-Aug-10	21.35	Over Voltage
400KV	Karad - Kolhapur - II	9-Aug-10	00.24	9-Aug-10	08.41	Over Voltage
400KV	New Koyna - Dabhol - II	9-Aug-10	10.40	9-Aug-10	12.57	For filling of SF6 Gas in CB
400KV	400/220 KV 315 MVA ICT @ Akola	9-Aug-10	22.15	10-Aug-10	09.00	Due to Fire to Y phase CT of Tie Breaker
400KV	Dhule - Babhaleshwar - I	9-Aug-10	21.41	10-Aug-10	11.35	Over Voltage
400KV	80 MVAR Reactor of 400 KV Dhule- Khand	9-Aug-10	01.22	10-Aug-10	21.35	Over Voltage.
400KV	Karad-Lamboti	10-Aug-10	01.14	10-Aug-10	06.30	Over Voltage
400KV	Dhule-Sar'Sarovar - I	10-Aug-10	01.18	10-Aug-10	12.32	Over voltage
400KV	Jejuri-Koyna STG-IV	10-Aug-10	06.04	10-Aug-10	09.10	Over Voltage
400KV	Karad - Kolhapur - II	10-Aug-10	06.05	10-Aug-10	06.41	Over Voltage
400KV	Kalwa-Kharghar	10-Aug-10	08.53	10-Aug-10	18.19	Testing Work,C T Tandelta & R M Work.
400KV	Dhule - Babhaleshwar - I	10-Aug-10	14.56	10-Aug-10	20.13	B Ph L A Burst & Dist.Prot.
400KV	400/220KV,315MVA ICT-I at Karad	10-Aug-10	15.00	10-Aug-10	15.14	Isolator Sparking Y Ph Main Bus-II.,Transferred to Main Bus-I.
400KV	Dhule-S'Sarovar I	11-Aug-10	01.37	12-Aug-10	13.12	Over Voltage.
400KV	Karad - Solapur(Lamboti)	11-Aug-10	01.37	11-Aug-10	09.08	Over Voltage.
400KV	Koradi - Kaparkheda	11-Aug-10	06.02	11-Aug-10	08.00	Over Voltage.
400KV	Dhule-Khandwa-II	11-Aug-10	06.04	11-Aug-10	08.45	Over Voltage.
400KV	Main Bus - I @ Lamboti.	11-Aug-10	10.01	20-Aug-10	19.27	Removing Existing Jumper & Main Bus-I to Top Bus for ICT-II.
400KV	Koradi-Akola	11-Aug-10	08.57	12-Aug-10	06.17	Retrofitting Work.
400KV	Kolhapur - Mapusa - I	11-Aug-10	23.08	12-Aug-10	14.00	Over Voltage.
400KV	Dhule - S'Sarovar- II	12-Aug-10	00.15	12-Aug-10	13.40	Over Voltage.
400KV	Jejuri 406 Breaker	12-Aug-10	09.43	12-Aug-10	18.20	29 B isolator work.
400KV	400 KV TBC AT BBLSR	12-Aug-10	09.45	12-Aug-10	16.32	Q.M.Work.
400KV	400/220KV 315MVA ICT at Akola.	12-Aug-10	12.47	12-Aug-10	20.43	Testing Work.
400KV	New Koyna - StageIV - I	12-Aug-10	09.00	12-Aug-10	09.10	H/T for change over bus(on bus-II)
400KV	Jejuri-Koyna STG-IV	12-Aug-10	15.15	12-Aug-10	18.20	29 B,isolator work.
400KV	Dhule - S'Sarovar- II	12-Aug-10	18.18	12-Aug-10	18:19	H/T for O/V.
400KV	Kolhapur - Mapusa - II	12-Aug-10	21.27		Continued.	Over Voltage.
400KV	Dhule - Babhaleshwar - I	12-Aug-10	23.01	13-Aug-10	08.58	H/T for O/V
400KV	Karad-Lamboti	12-Aug-10	23.36	13-Aug-10	09.40	H/T for O/V
400KV	Main Bus-I At Stage-4 Koyna.	12-Aug-10	11.50		Continued.	Routine Maintainance Work.
400KV	Dhule-Sar'Sarovar - II	12-Aug-10	18.18	16-Aug-10	10.07	Over Voltage

400KV	Jejuri-Koyna STG-IV	13-Aug-10	01.09	13-Aug-10	09.13	Tripped on O/V
400KV	Padgha-Nagothane	13-Aug-10	08.38	13-Aug-10	17.54	Bay maintenance
400KV	400/220KV 315MVA ICT-II @ Aurangabad	13-Aug-10	09.26	13-Aug-10	16.23	Overhauling work
400KV	Koradi - Bhusawal	13-Aug-10	09.49	14-Aug-10	07:58	CB problem,Ready for Charging from 01.40 Hrs on 14.08/2010.
400KV	400/220 KV 315 MVA ICT - II @ Parli	13-Aug-10	10.15	13-Aug-10	11.30	Pole descriptance on LV side.
400KV	Karad-Lamboti	13-Aug-10	18.26	13-Aug-10	18.56	Direct trip at Karad end.
400KV	Dhule-Khandwa-I	13-Aug-10	15.08	15-Aug-10	06.33	Trip on O/V.
400KV	Jejuri-Koyna STG-IV	14-Aug-10	01.32	14-Aug-10	07:57	Tripped on O/V.
400KV	Main Bus I at 400KV BBLSR	14-Aug-10	11:30	14-Aug-10	20:20	P.G. Isolator replacement.
400KV	Koradi - Kaparkheda	14-Aug-10	08:43	14-Aug-10	21:03	O/V.
400KV	Dhule - Babhaleshwar - I	14-Aug-10	08:17	14-Aug-10	08:29	Changeover Bus.
400KV	Bablsr-Padgha Ckt I	14-Aug-10	08:36	14-Aug-10	09:40	Changeover Bus.
400KV	Padgha - Kalwa - I	14-Aug-10	16:13	14-Aug-10	18:41	E/O To attend R Ph CT leakage.
400KV	Padgha - Kalwa - I	15-Aug-10	14.44	15-Aug-10	19.36	CT Replacement work
400KV	Wardha - Akola - I	15-Aug-10	16.03	16-Aug-10	12.40	Over Voltage
400KV	Dhule-SarSarovar - I	15-Aug-10	00.13	16-Aug-10	08.30	Over Voltage
400KV	Karad-Kolhapur-II	15-Aug-10	18.09	16-Aug-10	08.27	Over Voltage.
220KV	220/132 KV 100 MVA ICT - I @ Ranjangao	18-May-10	13.48	9-Aug-10	14.10	Transformer Augmentation work.
220KV	220/132KV 100 MVA ICT- I @ Parly-II	29-Jul-10	10.11	13-Aug-10	22.35	LV BKR Replacement Work.
220KV	TBC @ 220 KV Parli - I	6-Aug-10	14.30	12-Aug-10	16.00	Isolator replacement work.
220KV	Kalmeshwar - Pandurna	7-Aug-10	20.48	18-Aug-10	13.35	Main Breaker Trip Ckt Faulty Indication.Ckt on TBC.
220KV	Khaparkheda-Kawlewada-I	9-Aug-10	00.52	9-Aug-10	01.26	Distance protection
220KV	Raymond-Washala	9-Aug-10	09.20	9-Aug-10	18.50	Replacement of damaged Insulator at Loc.No.9
220KV	Apta-Uran-II	9-Aug-10	09.25	9-Aug-10	18.25	Attending Hot Spot and R.M.Work
220KV	Talangade - Mumewadi	9-Aug-10	12.41	9-Aug-10	16.36	R.M.work and Relay Testing work
220KV	Main Bus- II @ Aarey	10-Aug-10	00.18	10-Aug-10	04.40	Double Isolator Scheme work
220KV	Borivali - Aarey - I	10-Aug-10	00.15	10-Aug-10	04.46	For Crimping and connection of Jumpers
220KV	Chandrapur-Warora - I	10-Aug-10	09.06	10-Aug-10	15.44	Maintainance Work.
220KV	220/100 KV 100 MVA T/F - IV @ Kandalgaon	10-Aug-10	08.50	10-Aug-10	10.20	To Attend Red Hot.
220KV	Apta - Taloja	10-Aug-10	10.28	10-Aug-10	20.46	To Attend Red Hot on C T @ Taloja.
220KV	220 KV Main Bus @ Miraj	10-Aug-10	09.45	10-Aug-10	16.41	Quarterly Maintainance Work.
220KV	Miraj -Ichalkarajini	10-Aug-10	10.45	10-Aug-10	16.41	Quarterly Maintainance Work.
220KV	Miraj-Karad	10-Aug-10	10.42	10-Aug-10	16.41	Replacement of Faulty Disc.Insulator.
220KV	Babaleshwar - Nagar - I	10-Aug-10	10.30	10-Aug-10	14.50	C T Oil Leakage.
220KV	Tifil-Trombay	10-Aug-10	12.20	10-Aug-10	14.51	Line Maint.Work.
220KV	Dondaicha - Sahada	10-Aug-10	10.30	10-Aug-10	17.15	Attending Red Hot on Y Ph Jumper.
220KV	Khaparkheda - Kanhan - I	10-Aug-10	20.27	11-Aug-10	14.31	Distance Protection Operated,Z-I R Y B Ph.Dist-8.2 KMS.
220KV	Kandalgaon-Khargar	11-Aug-10	08.18	14-Aug-10	22:57	Erection of Towers LILO Work.
220KV	Kandalgaon - ONGC	11-Aug-10	08.41	14-Aug-10	16:30	Erection of Towers LILO Work.
220KV	Talandge - Sawantwadi	11-Aug-10	08.24	11-Aug-10	15.09	Attending Hot Spot.
220KV	Karad - Miraj	11-Aug-10	09.31	11-Aug-10	18.35	Replacement of Faulty Insulator.
220KV	Apta - Tambati	11-Aug-10	11.00	11-Aug-10	13.50	C B Maint. Work.
220KV	Lamboti-Bale-II	11-Aug-10	11.52	11-Aug-10	15.30	Q.M.Work.
220KV	Circuit Breaker - III @ Mulund	11-Aug-10	12.30	12-Aug-10	13:30	Pole Discripancy problem in breaker.
220KV	Main Bus II @ Aarey	11-Aug-10	07.14	11-Aug-10	18.52	Isolator Work.
220KV	Kalwa - Nasik III	12-Aug-10	04.30	12-Aug-10	04.53	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	Nasik - Ghatghar	12-Aug-10	04.31	12-Aug-10	04.06	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	Bus Section - I @ Nasik GCR	12-Aug-10	04.31	12-Aug-10	05.31	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	Nasik-Bablsr - I	12-Aug-10	04.30	12-Aug-10	05.25	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	Nasik-Bablsr - II	12-Aug-10	04.30	12-Aug-10	05.26	220KV Y Ph Bus P T Burst @ Nasik OCR.

220KV	Nasik-Navsari-I	12-Aug-10	04.30	12-Aug-10	15.27	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	Nasik - Navasari - II	12-Aug-10	04.30	12-Aug-10	17.50	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	200 MVA ICT- IV @ Nasik OCR	12-Aug-10	04.30	12-Aug-10	05.35	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	220 KV Bus P T @ Nasik OCR	12-Aug-10	04.30	12-Aug-10	15.20	Y Ph Burst.
220KV	220/132 KV 200 MVA ICT - V @ Nasik (OC	12-Aug-10	04.30	12-Aug-10	06.00	220KV Y Ph Bus P T Burst @ Nasik OCR.
220KV	Aarey-Borivali-I	12-Aug-10	06.17	12-Aug-10	08.06	To safty work on 33KV overhead line under it.
220KV	Babaleshwar - Ranjangaon	12-Aug-10	08.14	12-Aug-10	20.14	Replacement of faulty insulator.
220KV	220/22 KV,50 MVA T/F - I @ Lonikand	12-Aug-10	08.31	12-Aug-10	18.44	Q.M.Work
220KV	Chinchwad - Hinjewadi	12-Aug-10	08.20	12-Aug-10	13.29	Errection of bus gantry for new T/F work.
220KV	Karad - Miraj	12-Aug-10	09.12	12-Aug-10	18.20	Replacement of faulty insulator
220KV	Bus Coupler @ Boiser	12-Aug-10	09.32	12-Aug-10	17.41	Replacement of C.T.
220KV	Kalwa - Borivali	12-Aug-10	10.06	12-Aug-10	18.26	Wave trap burst.
220KV	Uran -Apta-III	12-Aug-10	09.30	12-Aug-10	20.17	To attend attend spot.
220KV	Lonikand-Khadki	12-Aug-10	10.00	12-Aug-10	14.30	Q.M.Work.
220KV	Borivali-Mulund	12-Aug-10	10.07	12-Aug-10	10.38	Distance protection.
220KV	Borivali-Kalwa	12-Aug-10	10.07	12-Aug-10	18.20	R Ph. CT burst.
220KV	Bablsr-Ranjangaon	13-Aug-10	03.27	13-Aug-10	18.29	Distance protection.
220KV	Padgha-Jambhul-I	13-Aug-10	14.58	13-Aug-10	17.18	R.M.Work.
220KV	Karad - Miraj	13-Aug-10	11.00	13-Aug-10	19.38	Line maintenance.
220KV	KHARGHAR--ONGC	13-Aug-10	11.38	14-Aug-10	16.19	Renewal of bunching and connecting to Kharghar line.Bunching Removed.
220KV	KDPH-Wankuswadi	13-Aug-10	11.55	13-Aug-10	16.15	Replacement of flash insulator string.
220KV	Nerul-Kharghar	13-Aug-10	06.30	13-Aug-10	07.42	Trip Y ph.on pole discrepancy.
220KV	Nerul -Sonkhar	13-Aug-10	06.30	13-Aug-10	06.45	Trip on pole discrepancy
220KV	Vita-Maisal	13-Aug-10	01.43	13-Aug-10	11.20	Decaping at Loc.91
220KV	Dhamangaon - Badnera	13-Aug-10	18.50	13-Aug-10	19.23	Distance protection.
220KV	NASIK-NAVSARI-II	13-Aug-10	08.06	13-Aug-10	18.00	Y Ph.insulator replaced.
220KV	Karad - Miraj	14-Aug-10	09:30	14-Aug-10	17:06	Insulator replacement.
220KV	Kalwa - Borivali	14-Aug-10	09:34	14-Aug-10	20:30	Replacement of Y Ph CT Jumper.
220KV	M'Peth -Vankuswade	14-Aug-10	09:42	14-Aug-10	10:03	Distence Prot.
220KV	Vankuswadi-KDPH	14-Aug-10	09:45	14-Aug-10	11:15	Distance Prot.
220KV	Kalwa-Mahape	14-Aug-10	15:56	14-Aug-10	16:45	Distance Prot.
220KV	MUDSHINGI-CHIKODI	14-Aug-10	15:05	14-Aug-10	17:05	Distance Prot.
220KV	Lote - N.Koyna	15-Aug-10	13.06	15-Aug-10	13.55	Distance Protection
220KV	Bale-Murud	15-Aug-10	13.16	15-Aug-10	19.12	Dist.Prot.Loc.no.24,R phase Disc Insulator replaced
220KV	Apta-Nagothane	15-Aug-10	21.10	16-Aug-10	07.50	R phase LA Flashover and Wave Trap fallen.
220KV	220/100 KV 200 MVA ICT-II @ Apta	15-Aug-10	21.10		Continued.	Tripped on Diff.prot.CTR system operated
220KV	220/132 KV 150 MVA ICT - I @ NSK.	15-Aug-10	15.22	15-Aug-10	16.30	Oil Leakage from Neutral Bushing
220KV	Khaparkheda-Kawlewada-II	15-Aug-10	15.00	15-Aug-10	20.23	Dist.Prot.,Loc.no.19,Disc Insulator replaced
132KV	Hinganghat-RLY TSS-II	9-Aug-10	02.44	9-Aug-10	16.34	C.B.Lockout
132KV	Parbhani-Parthur	9-Aug-10	18.10	9-Aug-10	18.43	Dir.Over current relay operated
132KV	Kawlewada-Madgi-I	10-Aug-10	11.01	10-Aug-10	14.20	Quarterly Maintainance Work.
132KV	Kawlewada-Madgi-I	10-Aug-10	14.55	10-Aug-10	18.20	Y Ph Coupling Condenser Burst.
132KV	Bhandara - Madgi -I	10-Aug-10	20.25	11-Aug-10	00.40	R Ph Line Isolator Problem.
132KV	Bhandara - Ambhora - I	11-Aug-10	15.05	12-Aug-10	12.00	distance protection
132KV	Harangul-Chakur	12-Aug-10	14.05	12-Aug-10	16.25	To make LILO line from 33 Kv S/S chakur.
132KV	Lalkhedi - Durgwada	12-Aug-10	08.50	12-Aug-10	09.00	Distance protection
132KV	Amravati - Achalpur	12-Aug-10	09.46	12-Aug-10	09.51	Distance protection
132KV	Amravati - Achalpur	12-Aug-10	11.12	12-Aug-10	20.55	Distance protection
132KV	Muktainagar-Bodwad	15-Aug-10	07.09	15-Aug-10	09.40	Distance Protection
132KV	Kanhan - Mansar.	15-Aug-10	18.45	16-Aug-10	17.48	B phase CT Oil Leakage at Mansar
132KV	Pachora - Chalisgaon - I	15-Aug-10	19.19	16-Aug-10	07.35	B phase CVT Burnt