

LINE OUTAGES FOR THE WEEK

FROM 6-Sep-10 TO 12-Sep-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE - II	8-Sep-10	12.30	8-Sep-10	15.49	Inspection of Smoothing Reactor.
500KV	HVDC POLE I -CHDPR	9-Sep-10	13.11	9-Sep-10	16.21	Y-Ph converter T/F work at Chdpr,Ready for charging from 16.21 Hrs.
400KV	Kolhapur - Mapusa - II	12-Aug-10	21.27	6-Sep-10	17.32	Over Voltage.
400KV	Bhusawal- Aurangabad	21-Aug-10	17.58	6-Sep-10	09.09	Over Voltage
400KV	Dhule - S'Sarovar- II	26-Aug-10	22.08	13-Sep-10	10.47	Over Voltage.
400KV	Karad - Kolhapur - II	27-Aug-10	23.01	15-Sep-10	13.01	Over Voltage.
400KV	Wardha - Akola - I	28-Aug-10	12.25	12-Sep-10	22.19	Change Over
400KV	STG IV-N.Koyna -I	1-Sep-10	09.40	8-Sep-10	13.50	Bay Maintenance
400KV	Chandrapur - Khaparkheda	4-Sep-10	19.10	10-Sep-10	16.37	Over Voltage,Ready for charging @ 19.30 Hrs.dt 5'th Sept.
400KV	Dhule-Sar'Sarovar - I	4-Sep-10	23.17	6-Sep-10	09.28	H/T for O/V.
400KV	Jejuri-Koyna STG-IV	6-Sep-10	01.16	6-Sep-10	08.34	Trip on O/V.
400KV	Karad-Lamboti	5-Sep-10	22.06	6-Sep-10	11.40	H/T For O/V.
400KV	Parli - Lamboti	6-Sep-10	04.25	6-Sep-10	11.43	Tripped on Dist.Protection.
400KV	Bableshwar-Aurangabad	6-Sep-10	09.13	6-Sep-10	23.03	Measurement of CT Tan Delta
400KV	Main Bus - I @ Lamboti.	6-Sep-10	15.05	6-Sep-10	20.23	Alignment of Isolator
400KV	Kolhapur - Mapusa - I	6-Sep-10	17.51		Continued.	Over Voltage
400KV	Karad-Lamboti	6-Sep-10	22.40	7-Sep-10	14.33	Over Voltage
400KV	Dhule - Babhaleshwar - I	6-Sep-10	22.54	7-Sep-10	06.06	Over Voltage
400KV	Bhusawal- Aurangabad	6-Sep-10	22.45		Continued.	Over Voltage
400KV	Dhule - Babaleshwar - II	7-Sep-10	03.25	7-Sep-10	06.24	Over Voltage
400KV	Parli - Solapur	6-Sep-10	11.52	6-Sep-10	12.39	Over Voltage at Solapur
400KV	400/220KV 315 MVA ICT-II at Korady	6-Sep-10	10.01	6-Sep-10	22.19	B/B Prot.operated of 220KV Bus-II,ICT HV side was on TBC
400KV	Dhule - Babhaleshwar - I	7-Sep-10	06.34	7-Sep-10	09.59	Over Voltage
400KV	Dhule - Babhaleshwar - I	8-Sep-10	00.40	8-Sep-10	08.16	Over Voltage
400KV	Karad-Lamboti	7-Sep-10	22.38	8-Sep-10	13.55	Over Voltage
400KV	Lonikand- Koyna Stage IV	7-Sep-10	22.42	8-Sep-10	09.10	Over Voltage
400KV	Dhule-Khandwa I	8-Sep-10	00.11	8-Sep-10	09.11	Over Voltage
400KV	Jejuri-Koyna STG-IV	8-Sep-10	03.44	8-Sep-10	08.39	Over Voltage
400KV	Main Bus - I @ Lamboti.	8-Sep-10	10.31	8-Sep-10	19.13	Alignment of 404-29A & 404-29B Isolator
400KV	Padgha - Nagothane - I	8-Sep-10	12.46	8-Sep-10	15.45	Replacement of Faulty N.T.Switch.
400KV	New Koyna - Karad - I	8-Sep-10	09.35	8-Sep-10	11.42	Bus Changeover.
400KV	Dhule - Babhaleshwar - I	8-Sep-10	18.56	9-Sep-10	09.35	Over Voltage.
400KV	80 MVAR Bus Reactor @ Nagothane	8-Sep-10	14.11	8-Sep-10	16.40	'A'Bus Isolator Allignment.
400KV	Lonikand - Parli - II	8-Sep-10	23.00	9-Sep-10	10.59	Over Voltage,Distance Protection,R Ph-E.
400KV	Lonikand-Karad	8-Sep-10	23.00	9-Sep-10	08.49	Over Voltage.
400KV	Karad-Lamboti	8-Sep-10	23.43	9-Sep-10	09.15	Over Voltage.
400KV	STG IV-New Koyna-II	8-Sep-10	23.36	9-Sep-10	15.12	Over Voltage.
400KV	Dhule-Khandwa-II	9-Sep-10	01.40	9-Sep-10	14.18	Over Voltage.
400KV	Lonikand - Jejuri	9-Sep-10	11.14	9-Sep-10	17.23	Relay testing and maint.work.
400KV	Dhule-Khandwa-I	9-Sep-10	13.25	12-Sep-10	07.39	Over Voltage.
400KV	Karad-New Koyna II	9-Sep-10	13.05	12-Sep-10	10.00	DC leakage problem 29 B Isolator open.
400KV	400/220 KV 600 MVA ICT- I @ Kalwa	9-Sep-10	06.36	9-Sep-10	10.41	Attending Red Hot on clamp of R-Ph LV side bushing.
400KV	400KV M.Bus-I at Lamboti	9-Sep-10	11.35	9-Sep-10	18.35	Alignment Of Isolator.
400KV	Karad-Lamboti	9-Sep-10	22.30	10-Sep-10	09.54	Over Voltage.
400KV	Chandrapur - Parli - II	9-Sep-10	00.55	12-Sep-10	07.29	Over Voltage.

400KV	Dhule - Babhaleshwar - I	9-Sep-10	23.50	10-Sep-10	17.28	Over Voltage.
400KV	Dhule-Khandwa-II	10-Sep-10	03.04	10-Sep-10	04.18	Over Voltage.
400KV	Lamboti-Parli (Tie CB)	10-Sep-10	13.58	10-Sep-10	16.15	Measurement of capacitance and tan delta.
400KV	Karad-Lamboti	10-Sep-10	21.11	13-Sep-10	08.11	Over Voltage.
400KV	STG IV-N.Koyna -I	10-Sep-10	15.23	10-Sep-10	17.07	PDR At Stg.IV.
400KV	STG IV-N.Koyna -I	10-Sep-10	19.33	13-Sep-10	08.30	PDR At Stg.IV.
400KV	400/220 KV 315 MVA ICT-II @ Nagothane.	10-Sep-10	11.30	10-Sep-10	15.25	Hot Spot.
400KV	Akola - Bhusawal	10-Sep-10	12.06	10-Sep-10	14.53	Testing work.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	10-Sep-10	06.36	10-Sep-10	15.33	Replacement of 220 KV Y Ph.bus jumper.
400KV	Babaleshwar - Dhule - I	11-Sep-10	00.44	11-Sep-10	08.39	Over Voltage.
400KV	Dhule - Babhaleshwar - I	11-Sep-10	22.54	12-Sep-10	07.35	Over Voltage.
400KV	Babeshwar-Aurangabad	12-Sep-10	03.10	12-Sep-10	06.48	Over Voltage
400KV	Karad - Kolhapur - I	12-Sep-10	00.44	12-Sep-10	07.20	Over Voltage
400KV	400/132KV 200 MVA ICT-II @ Bhusawal	12-Sep-10	22.16	13-Sep-10	04.50	Bus fault at 400KV Khadka.
220KV	Pedambe-Tambati	6-Sep-10	14.27	6-Sep-10	16.33	Line Maint.work
220KV	Pedambe - Mahad	6-Sep-10	08.48	6-Sep-10	14.00	To attend damaged overhead Conductor
220KV	Dhule - Malegaon	7-Sep-10	05.55	7-Sep-10	06.17	Backup protection
220KV	Nasik - Ghatghar	6-Sep-10	15.33	6-Sep-10	18.22	Distance Protection
220KV	Karad - Peth	7-Sep-10	11.13	7-Sep-10	15.55	Red Hot Y phase Isolator
220KV	Koradi - Ambazari - II	6-Sep-10	10.01	6-Sep-10	11.25	Tripped on B/B Prot.of 220KV Bus-II
220KV	Dhule-Chalisgaon	7-Sep-10	05.55	7-Sep-10	06.16	Backup Protection
220KV	Aurangabad - Padegaon - II	6-Sep-10	11.47	6-Sep-10	12.30	To attend Y Phase CT Oil Leakage
220KV	Murud - Girawli.	6-Sep-10	12.30	6-Sep-10	17.09	Tripped on PDR
220KV	Main Bus-II at Koradi	6-Sep-10	10.01	6-Sep-10	11.25	Bus Bar Prot.operated
220KV	Bus Coupler @ Koradi	6-Sep-10	09.50	6-Sep-10	11.35	Q.M.Work
220KV	220/6.6 KV Stn Tr - II @ K'Kheda	6-Sep-10	08.58		Continued.	Annual Maint.of Bay
220KV	220/7 KV 20 MVA Stn.T/F-II at Korady	6-Sep-10	10.01	6-Sep-10	11.48	Tripped on B/B Prot.of 220KV Bus-II
220KV	220/7 KV 20 MVA Stn.T/F-IV at Korady	6-Sep-10	10.01	6-Sep-10	11.44	Tripped on B/B Prot.of 220KV Bus-II
220KV	220/33 KV 50 MVA T/F-I @ Kharghar	6-Sep-10	09.14	6-Sep-10	19.00	Tan Delta measurement of CT
220KV	Koradi-Khaperkheda	6-Sep-10	10.01	6-Sep-10	13.14	Tripped on B/B Prot.of 220KV Bus-II
220KV	Karad-Sada Waghapur	7-Sep-10	12.44	7-Sep-10	17.40	Red Hot
220KV	Tilary-Amona	7-Sep-10	07.55	7-Sep-10	09.04	Distance Protection
220KV	Talagade - Mumewadi	7-Sep-10	08.02	7-Sep-10	08.34	Distance Protection
220KV	Kalwa-Colourchem	7-Sep-10	14.32	7-Sep-10	16.47	Red Hot
220KV	Kalwa-Nasik	7-Sep-10	14.40	7-Sep-10	17.10	For Kalwa-Colourchem outage
220KV	Karad-Wathar	7-Sep-10	23.01	8-Sep-10	11.53	Distance Protection
220KV	Bus Section -III @ Trombay	8-Sep-10	07.19	8-Sep-10	10.42	Attending Red Hot on 220KV Sonkar Line & ICT - III.
220KV	Bus-Section - II @ Trombay	8-Sep-10	07.19	8-Sep-10	10.42	Attending Red Hot on 220KV Sonkar Line & ICT - III.
220KV	Tata-Tie-2 @ Trombay.	8-Sep-10	06.15	8-Sep-10	11.30	Attending Red Hot on 220KV Sonkar Line & ICT - III.
220KV	Trombay-Kalwa	8-Sep-10	07.07	8-Sep-10	10.59	Attending Red Hot on 220KV Sonkar Line & ICT - III.
220KV	Tifli-Trombay	8-Sep-10	07.16	8-Sep-10	11.05	Attending Red Hot on 220KV Sonkar Line & ICT - III.
220KV	Trombay - Sonkar	8-Sep-10	07.08	8-Sep-10	11.31	Attending Red Hot on 220KV Sonkar Line & ICT - III.
220KV	220/100 125 MVA ICT - II @ Trombay	8-Sep-10	07.18	8-Sep-10	11.50	Attending Red Hot on 220KV Sonkar Line & ICT - III.
220KV	Karad - Miraj	8-Sep-10	08.07	8-Sep-10	18.22	For LILO Arrangement & Making Cut Point for 220 KV Wangi Tap.
220KV	220/132 KV,200 MVA ICT @ Bale	8-Sep-10	10.00	8-Sep-10	17.20	Q.M.
220KV	Bale - Lamboti I	8-Sep-10	14.18	8-Sep-10	18.55	Insulator Cleaning.
220KV	Kalwa-Nasik	8-Sep-10	12.49	8-Sep-10	15.42	LILO Work @ Airoli Knowledge Park.
220KV	Lote-Dasturi	8-Sep-10	13.31	8-Sep-10	16.05	C C Replacement.
220KV	220/132 200 MVA ICT - I @ Harangul	8-Sep-10	14.15	8-Sep-10	16.30	Testing Work.(OSR Relay Replacement)
220KV	New Paras TPS - Akola - I	8-Sep-10	12.16	8-Sep-10	13.05	During Testing Work of Bus PT.

220KV	New Paras TPS - Chikhali - I	8-Sep-10	12.16	8-Sep-10	15.37	During Testing Work of Bus PT.
220KV	Bhugaon-Wardha	8-Sep-10	16.07	8-Sep-10	17.41	Trip Relay 186 Operated.
220KV	New Parly - Beed - I	8-Sep-10	22.42	8-Sep-10	23.12	Distance Protection Operated.
220KV	Babaleshwar - Bhenda	9-Sep-10	05.28	9-Sep-10	06.19	Distance Protection.
220KV	Babaleshwar - Ranjangaon	9-Sep-10	06.55	9-Sep-10	20.42	Replacement of CT's.
220KV	Pirangut - Kandalgaon	9-Sep-10	08.19	10-Sep-10	17.40	E/W replacement.(2days Outage)
220KV	Karad - Miraj	9-Sep-10	08.54	9-Sep-10	15.27	For making cutpoint for 220 KV Wangi tap.
220KV	Uran - Apta (HOC)	9-Sep-10	10.27	9-Sep-10	22.32	Attending Hot Spot on R-Ph line side CT.
220KV	220/100 KV,200 MVA ICT-I @ Apta	9-Sep-10	14.38	9-Sep-10	17.09	Inspection of PRV and OSR.
220KV	ONGC-TSS	9-Sep-10	11.00	9-Sep-10	17.55	Attending Hot Spot.
220KV	Chinchwad-Parvati	9-Sep-10	11.25	9-Sep-10	16.35	Q.M.Work
220KV	Lonkand-Theur - I	9-Sep-10	15.09	9-Sep-10	18.18	Taurus measurements.
220KV	Kurkumb-Bhigwan	8-Sep-10	04.00	9-Sep-10	15.00	Dist.protection.
220KV	220/132,200 MVA Tr.-I @ Theur.	9-Sep-10	10.05	9-Sep-10	19.30	Q.M.Work
220KV	Bhandara - Sunflag - II	9-Sep-10	13.05	9-Sep-10	16.54	R-Ph CT replacement work.
220KV	220/132KV 200 MVA ICT-II @ Harangul	9-Sep-10	12.15	9-Sep-10	14.33	Q.M.Work
220KV	Padgha-Temghar	11-Sep-10	08.53	11-Sep-10	11.17	To attend Red hot on B Ph.wave trap jumper.
220KV	Girwali - Parbhani	9-Sep-10	09.35	9-Sep-10	14.27	Q/M.Work
220KV	Mulund-Kalwa-II	11-Sep-10	15.10	11-Sep-10	16.10	To attend red hot on M.B.II jumper.
220KV	Karad-Sada Waghapur	10-Sep-10	12.09	10-Sep-10	15.16	Distance Protection.
220KV	Wadkhal-IPCL I	10-Sep-10	09.40	10-Sep-10	15.10	Hot Spot.
220KV	220 KV Main Bus - II @ 400 KV Kalwa	10-Sep-10	06.36	10-Sep-10	15.12	Replacement of 220 KV Y-Ph Bus Jumper.
220KV	Main Bus II at New Paras	9-Sep-10	16.25	10-Sep-10	14.15	Bus PT Testing work.
220KV	Mudsungi-Amona	11-Sep-10	22.38	14-Sep-10	08.20	Over Voltage at Amona end.
220KV	Bhusawal-Chalisgaon-I	11-Sep-10	23.06	13-Sep-10	11.37	Ckt.on TBC.Due to red hot on isolator near main C.B.
220KV	Pophali - Pedambe - I	12-Sep-10	13.55	12-Sep-10	14.20	Distance protection.
220KV	220/132 KV 100 MVA ICT- II @ Bhusawal	12-Sep-10	22.16	13-Sep-10	01.15	Bus fault at 400KV Khadka
220KV	Khaparkheda - Kanhan - II	12-Sep-10	15.44	13-Sep-10	09.46	R Ph.string broken at Loc.151.
132KV	Bhusawal - Pachora	6-Sep-10	19.01	7-Sep-10	08.43	Dist.Prot,B/DN Declared(ckt is on no Load)
132KV	Bhusawal - Pachora	6-Sep-10	18.34	6-Sep-10	18.57	Distance Protection
132KV	Harangul - Nilanga	6-Sep-10	15.40	6-Sep-10	16.05	Distance Protection
132KV	Harangul - Latur - I	6-Sep-10	13.05	6-Sep-10	15.00	Maintenance work
132KV	Harangul - Latur - I	7-Sep-10	16.55	7-Sep-10	17.15	Attending Oil Leakage of CT
132KV	Pusad - Gunj	7-Sep-10	17.00	7-Sep-10	18.00	Testing work
132KV	Parbhani - Parbhani - II	9-Sep-10	23.52	10-Sep-10	00.01	Dist.Protection operated,Z-2.
132KV	Amravati - Morshi	10-Sep-10	09.27	10-Sep-10	09.34	Dist.Protection operated Z-1.
132KV	Parbhani - Parbhani - I	10-Sep-10	11.20	10-Sep-10	11.45	Dist.Protection operated Z-2.
132KV	Amravati - Achalpur	11-Sep-10	08.50	11-Sep-10	16.39	Distance protection.
132KV	Khadka-Deepnagar-II	12-Sep-10	22.16	12-Sep-10	23.24	Bus fault at 400KV Khadka
132KV	132 KV Bus Coupler at 400KV Khadka	12-Sep-10	22.16	13-Sep-10	04.22	Bus fault at 400KV Khadka
132KV	Bhusawal - Nimbhora	12-Sep-10	22.20	12-Sep-10	22.38	Bus fault at 400KV Khadka
132KV	Bhusawal - Jalgaon - I	12-Sep-10	22.20	12-Sep-10	22.38	Bus fault at 400KV Khadka
132KV	Bhusawal - Jalgaon - II	12-Sep-10	22.20	12-Sep-10	22.38	Bus fault at 400KV Khadka
132KV	Bhusawal - Yawal	12-Sep-10	22.20	12-Sep-10	22.30	Bus fault at 400KV Khadka
132KV	Theur-Sanaswadi	12-Sep-10	21.30	12-Sep-10	21.52	Transient fault.