

LINE OUTAGES FOR THE WEEK

FROM 10-Oct-11 TO 16-Oct-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Chandrapur-Bhadravti - I	26-Sep-11	17.52	12-Oct-11	15.25	Over Voltage.
400KV	Akola - Wardha - II	6-Oct-11	23.08	13-Oct-11	15:40	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	7-Oct-11	23.43	11-Oct-11	10.18	Over Voltage.
400KV	Parli-Solapur (PGCIL)-II	8-Oct-11	15.30	13-Oct-11	15.33	Newly commissioned on 08.10.2011 at 15.33 hrs.
400KV	Parli (PG)-Bhadravati I	8-Oct-11	19.50	15-Oct-11	12.03	Tripped.
400KV	Parli (PGCIL)-Bhadravati-II	8-Oct-11	22.14	15-Oct-11	14.32	Over Voltage.
400KV	Karad - Solapur (PGCIL)	9-Oct-11	19.35	10-Oct-11	13.13	Over Voltage
400KV	Kolhapur - Mapusa - I	9-Oct-11	22.07	10-Oct-11	13.36	Over Voltage
400KV	Bableshwar-Aurangabad	10-Oct-11	19.07	11-Oct-11	05.23	Over Voltage
400KV	Karad - Solapur (PGCIL)	10-Oct-11	19.59	11-Oct-11	11.57	Over Voltage
400KV	Kolhapur-Mapusa-II	10-Oct-11	20.33	11-Oct-11	09.19	Over Voltage
400KV	Karad-Jaigad II	10-Oct-11	23.03	11-Oct-11	09.28	To attend Hot Spot
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	11-Oct-11	08.40	11-Oct-11	17.54	Allinment of Isolator.
400KV	Dabhol - New Koyna - I	11-Oct-11	10.07	11-Oct-11	20.12	Insulator Replacement Work.
400KV	400/220KV, 315MVA ICT-I @ New Koyna.	11-Oct-11	20.23	11-Oct-11	23.00	OLTC Bucholz Operated.
400KV	Dhule-Sar'Sarovar - I	11-Oct-11	16.45	13-Oct-11	11:30	Over Voltage.
400KV	Karad - Solapur (PGCIL)	11-Oct-11	19.24	15-Oct-11	14.20	Over Voltage.
400KV	Kolhapur - Mapusa - I	11-Oct-11	19.35	12-Oct-11	09.39	Over Voltage.
400KV	Parli-Solapur (PGCIL) Ckt.II	11-Oct-11	23.22	12-Oct-11	08.27	Over Voltage.
400KV	400/220 KV 315 MVA ICT-I @ Koradi.	12-Oct-11	09.17	13-Oct-11	14:51	220KV Scada Commissioning.
400KV	400/220KV, 315MVA ICT-I @ New Koyna.	12-Oct-11	12.19	12-Oct-11	14.09	Replacement of plastic Cover OLTC.
400KV	400/220KV 315MVA ICT-II @ New Koyna	12-Oct-11	15.22	12-Oct-11	18.07	Replacement of Plastic Cover OLTC.
400KV	Bhusawal- Aurangabad	12-Oct-11	23.05	13-Oct-11	04.04	Over Voltage.
400KV	Jejuri-Koyna STG-IV	12-Oct-11	07.30	12-Oct-11	08.51	Over Voltage.
400KV	Dabhol-Nagothane - II	12-Oct-11	17.58	12-Oct-11	18.35	Distance Protection.
400KV	Newkoyna - Jaigad - I	12-Oct-11	18.25	13-Oct-11	10:54	Distance Protection.
400KV	400/220 KV 500 MVA ICT - I @ Solapur	12-Oct-11	10.21	14-Oct-11	13.54	Scada Commissining & Isolator Replacement Work.
400KV	400/220KV 500MVA ICT-III at Bableshwar	12-Oct-11	22.32	13-Oct-11	01.20	400KV Main Bus-I P G Isolator Problem.
400KV	Kolhapur - Mapusa - II	12-Oct-11	23.35	15-Oct-11	09.39	Over Voltage.
400KV	Koradi - Bhusawal	13-Oct-11	01.17	16-Oct-11	12.30	Taken on TBC Due to Trip Ckt Supervision Problem.
400KV	Karad-Jaigad II	13-Oct-11	07:34	13-Oct-11	08:36	Over Voltage.
400KV	Dhule - Babhaleshwar - I	13-Oct-11	16:39	13-Oct-11	17:24	Over Voltage.
400KV	Lonikand- Koyna Stage IV	13-Oct-11	17:45	13-Oct-11	18:30	Over Voltage.
400KV	Koradi-Bhilai	13-Oct-11	01:17	15-Oct-11	17.40	CKT on TBC continuos indication of trip CKT faulty.
400KV	Dhule - Babhaleshwar - I	13-Oct-11	18:01	13-Oct-11	20:58	Over Voltage.
400KV	400/220 KV 315 MVA ICT - I @ Chakan	13-Oct-11	09:56	13-Oct-11	18:26	Attend Oil Leakage.
400KV	Bhusawal- Aurangabad	13-Oct-11	23:22	14-Oct-11	04:05	Over Voltage.
400KV	Dhule - S'Sarovar- II	13-Oct-11	23:37	16-Oct-11	10.19	Over Voltage.
400KV	400/220KV 315 MVA ICT-I @ Padgha	14-Oct-11	08.29	14-Oct-11	18.42	Oil top up in servator tank,bay maint.work.
400KV	Bablswr-Aurangabad	14-Oct-11	07.56	14-Oct-11	08.46	Tripped on Over Voltage.
400KV	Bablswr-Padgha Ckt I	14-Oct-11	18.44	14-Oct-11	19.04	Tripped on Transient fault.
400KV	Karad - Newkoyna - I	14-Oct-11	14.45	14-Oct-11	15.38	Tripped on R ph. to earth.
400KV	Karad-New Koyna II	14-Oct-11	14.44	14-Oct-11	17.50	Tripped on B ph. to earth.
400KV	New Koyna - Dabhol - II	14-Oct-11	15.35	14-Oct-11	16.27	Distance protection,R ph. to earth.
400KV	Karad - Newkoyna - I	14-Oct-11	16.23	14-Oct-11	16.41	Due to sparking in 29A isolator at New Koyna end.
400KV	400/132KV 200MVA ICT-I @ Bhusawal	14-Oct-11	22.14	14-Oct-11	23.39	Main buchholz protection operated.
400KV	Lonikand-Karad	15-Oct-11	09.10	15-Oct-11	12.03	To attend hot spot.
400KV	400/220KV 315MVA ICT-II @ BBLSR	15-Oct-11	09.23	15-Oct-11	19.47	Retrofitting backup relay.

400KV	Karad-Jaigad II	15-Oct-11	07.33	15-Oct-11	09.07	Over Voltage.
400KV	400/132KV 200 MVA ICT- I @ Bhusawal	15-Oct-11	06.48	15-Oct-11	13.10	Buchholz alarm.
400KV	Lonikand- Koyna Stage IV	15-Oct-11	14.09	15-Oct-11	18.43	E/W retrofitting work.
400KV	400/220KV 315 MVA ICT-I @ Padgha	15-Oct-11	15.36	15-Oct-11	17.19	Heavy oil leakage R ph.LV bushing.
400KV	Bablsr-Padgha Ckt I	15-Oct-11	20.42	15-Oct-11	21.30	Test charging of BBLR auxiliary bus.
400KV	Bhusawal- Aurangabad	15-Oct-11	19.59	16-Oct-11	04.55	For Over Voltage.
400KV	400/220 KV 315 MVA ICT @ Bhusawal	15-Oct-11	06.48	15-Oct-11	07.48	Tripped.
400KV	400/132KV 200MVA ICT-I @ Bhusawal	15-Oct-11	14.33	15-Oct-11	17.57	Due to control cable fault.
400KV	400/132 KV 200 MVA ICT - II @ Bhusawal	15-Oct-11	06.48	15-Oct-11	07.12	Buchholz alarm
400KV	Kolhapur - Mapusa - I	16-Oct-11	00.27	16-Oct-11	14.07	Over Voltage
400KV	Karad-Jaigad II	16-Oct-11	03.28	16-Oct-11	09.22	Hot spot attending work.
400KV	Karad - Solapur (PGCIL)	16-Oct-11	07.26		Continued.	Over Voltage
400KV	Akola - Wardha - I	16-Oct-11	22.10		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - II	16-Oct-11	22.38		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	16-Oct-11	21.09		Continued.	Over Voltage
400KV	Dabhol - NewKoyna - II	16-Oct-11	16.09	16-Oct-11	16.41	Transient Fault
400KV	Bableswhar-Aurangabad	16-Oct-11	08.00	16-Oct-11	09.50	Over Voltage
220KV	Bale-Osmanbad	22-Sep-11	06.38	15-Oct-11	15.40	Parli ICT loading.
220KV	Chandrapur - Warora	30-Sep-11	23.40	12-Oct-11	12.38	H/T for system stability.
220KV	Vita - Lamboti	8-Oct-11	16.43	10-Oct-11	08.40	H/T Vita end for control Over Voltage.
220KV	Kalwa - Siemens	10-Oct-11	15.39	10-Oct-11	17.21	To attend Hot Spot
220KV	Pedambe - Pophali - II	10-Oct-11	05.08	10-Oct-11	06.40	B phase Conductor snapped of Pedambe-Karad line
220KV	Pedambe - Karad	10-Oct-11	05.08	10-Oct-11	16.49	B phase Conductor snapped of Pedambe-Karad line
220KV	Pedambe-Newkoyna	10-Oct-11	05.08	10-Oct-11	05.52	B phase Conductor snapped of Pedambe-Karad line
220KV	Pedambe - Tambati	10-Oct-11	05.08	10-Oct-11	06.33	B phase Conductor snapped of Pedambe-Karad line
220KV	Pedambe-Kharepatan	10-Oct-11	05.08	10-Oct-11	05.50	B phase Conductor snapped of Pedambe-Karad line
220KV	220/110KV,50 MVA T/F-I At Pedambe	10-Oct-11	05.08	10-Oct-11	06.05	B phase Conductor snapped of Pedambe-Karad line
220KV	220/110KV,50 MVA T/F-II At Pedambe	10-Oct-11	05.08	10-Oct-11	06.05	B phase Conductor snapped of Pedambe-Karad line
220KV	Bus Coupler Breaker @ New Koyna	10-Oct-11	05.08	10-Oct-11	05.33	B phase Conductor snapped of Pedambe-Karad line
220KV	Bus Section Breaker at Pedambe	10-Oct-11	05.08	10-Oct-11	05.35	B phase Conductor snapped of Pedambe-Karad line
220KV	Vita - Lamboti	10-Oct-11	19.57	16-Oct-11	06.10	H/T from Vita end To control voltage
220KV	Khapakheda - Koulawada - II	10-Oct-11	10.01	10-Oct-11	16.40	Attending Hot Spot
220KV	Warora - Wani	10-Oct-11	13.13	10-Oct-11	18.32	Commissioning of Bus Bar Prot.Scheme
220KV	Babaleshwar - Bhenda	11-Oct-11	01.25	11-Oct-11	04.09	Dist.Prot.(Taken on TBC)
220KV	Vita - Ghatnandare	11-Oct-11	09.47	11-Oct-11	11.23	L A & C C Criming Work.
220KV	Borivali -Tarapur	11-Oct-11	10.40	11-Oct-11	18.10	Distance Protection.
220KV	Miraj -Vita	11-Oct-11	10.22	11-Oct-11	16.07	Q.M.Work.
220KV	Phursungi - Theur	11-Oct-11	10.30	11-Oct-11	13.58	Q.M.Work.
220KV	220/100 KV 200 MVA ICT - IV @ Apta	11-Oct-11	11.11	11-Oct-11	18.34	Measurment of Fan 8 SFRA Test.
220KV	Nasik-Navsari-I	11-Oct-11	12.52	11-Oct-11	13.35	Distance Protection.
220KV	Jejuri-Phursungi	11-Oct-11	14.41	11-Oct-11	17.08	Y Ph. C T Red Hot.
220KV	Momewadi -Halkarni	11-Oct-11	14.43	11-Oct-11	15.14	Distance Protection.
220KV	Halkarni -Tillary	11-Oct-11	14.43	11-Oct-11	15.15	Distance Protection Zone- I.
220KV	Vita - Pandharpur	11-Oct-11	20.31	11-Oct-11	20.57	Distance Protection
220KV	Tillary-Amona	11-Oct-11	14.43	11-Oct-11	16.59	Tripped.
220KV	220/132 KV 200 MVA ICT- II @ Harangul	11-Oct-11	12.05	11-Oct-11	16.17	Quarterly Maintainance Work.
220KV	Chandrapur-Gadchandur	11-Oct-11	14.36	11-Oct-11	18.16	Retrofitting of Relay.
220KV	Aarey-Borivali-II	12-Oct-11	05.40	12-Oct-11	08.12	To Attend Hot Spot.
220KV	Babaleshwar - Ranjangaon	12-Oct-11	00.44	12-Oct-11	00.58	Distance Protection.

220KV	Boiser-Versova	12-Oct-11	03.15	12-Oct-11	03.30	Distance Protection.
220KV	Mumewadi-Mudshingi	12-Oct-11	10.05	12-Oct-11	13.05	Q.M.Work.
220KV	Reymond-OCR Nasik	12-Oct-11	10.11	12-Oct-11	17.32	Tandelta Measurment.
220KV	Pophali - Pedambe	12-Oct-11	12.00	12-Oct-11	13.26	Display Card Replacement.
220KV	Halkarni-Amona I	12-Oct-11	12.21	13-Oct-11	12:30	Distance Protection.
220KV	Uran-Kharghar-II	12-Oct-11	17.49	12-Oct-11	18.18	Distance Protection.
220KV	220/33 KV 100 MVA T/F - I @ Ghanthandre	12-Oct-11	12.10	12-Oct-11	14.00	CRM Measurment.
220KV	220/33 KV 100 MVA T/F - II @ Ghodbandar	12-Oct-11	14.05	12-Oct-11	15.10	CRM Measurment
220KV	220/33 KV 100 MVA T/F - III @ Ghanthandr	12-Oct-11	15.50	12-Oct-11	16.42	CRM Measurment
220KV	Babaleshwar - Alephata	12-Oct-11	21.21	13-Oct-11	03.31	Due to Outage on ICT - III.
220KV	Babaleshwar - Ranjangaon	12-Oct-11	22.22	13-Oct-11	03.25	Due to Outage on ICT - III.
220KV	Abhijeet - Wardha ckt - II	12-Oct-11	09.55	12-Oct-11	16.35	Quarterly Maintainance Work.
220KV	Chandrapur - Chandrapur MIDC	12-Oct-11	11.03	12-Oct-11	18.09	To Attend Hot Spot on M B Isolator.
220KV	Khaperkheda - Wardha.	12-Oct-11	07.56	12-Oct-11	17.42	Quarterly Maintainance Work.
220KV	220/66KV 50 MVA ICT- II @ Warora	12-Oct-11	12.40	12-Oct-11	19.35	Quarterly Maintainance Work of ICT.
220KV	Chandrapur - Warora	12-Oct-11	19.56		Continued.	For System Stability.
220KV	TBC @ Khaparkheda	12-Oct-11	10.00	12-Oct-11	17.30	Quarterly Maintainance Work.
220KV	Main Bus Section - II @ Virur	12-Oct-11	11.00	12-Oct-11	16.30	Quarterly Maintainance Work.
220KV	Girawli-Parli-III	12-Oct-11	16:30	13-Oct-11	19:00	B ph L.A. Burst.
220KV	Pophali-K'gaon	13-Oct-11	04.01	13-Oct-11	04.42	Distance Protection.
220KV	Kalmeshwar-Ambazari	13-Oct-11	11:03	13-Oct-11	15:10	To control Koradi ICT loading.
220KV	Bhosari-C'enka	13-Oct-11	12:05	13-Oct-11	18:50	Realy Replacement work.
220KV	220/132 KV 200 MVA ICT-III @ Phursungi	13-Oct-11	10:27	13-Oct-11	16:45	Q. M. Work.
220KV	Chinchwad-Urse	13-Oct-11	10:18	13-Oct-11	16:20	Q. M. Work.
220KV	MUDSHINGI-CHIKODI	13-Oct-11	11:25	14-Oct-11	17.40	Replacement of Isolator.
220KV	Babaleshwar - Ranjangaon	13-Oct-11	14:18	13-Oct-11	19:53	Testing Work.
220KV	Pedambe-Newkoyna	13-Oct-11	13:35	13-Oct-11	16:35	Maintenance Work.
220KV	Chinchwad-Theur	13-Oct-11	18:10	13-Oct-11	18:57	Jumper replacement.
220KV	Apta-Nagothane	13-Oct-11	14:34	13-Oct-11	15:03	A/R operated at Nagothane.
220KV	Padgha - Jindal	13-Oct-11	15:54	13-Oct-11	16:23	Distance Protection.
220KV	Kalwa - Ghatghar	13-Oct-11	15:53	13-Oct-11	18:14	Distance Protection.
220KV	Ghatghar - Washala	13-Oct-11	15:53	13-Oct-11	17:30	Bus fault at Ghatghar end.
220KV	Ghatghar-Nasik	13-Oct-11	15:54	13-Oct-11	17:29	Bus fault at Ghatghar.
220KV	Ghatghar-Jindal	13-Oct-11	15:54	13-Oct-11	17:25	Bus fault at Ghatghar end.
220KV	Raymond-Washala	13-Oct-11	15:55	13-Oct-11	16:30	Bus fault at Ghatghar end.
220KV	Pedambe-Mahad	13-Oct-11	18:15	14-Oct-11	18.55	R ph Distance Protection.
220KV	Tambati-Pedambe	13-Oct-11	18:15	15-Oct-11	04.10	Distance Protection.
220KV	Aurangabad-Chitegaon-I	13-Oct-11	12:09	13-Oct-11	15:14	Quarterly Maintainance Work.
220KV	220/132KV 100MVA ICT-II at Dondaicha	13-Oct-11	10:40	13-Oct-11	17:49	Measurement of Tan Delta of ICT Bushings SFRA test of ICT.
220KV	Khaperkheda - Wardha.	13-Oct-11	09:25	13-Oct-11	18:33	Tightening of nut bolts of jumpers PF cut point LOC from 1 to 335.
220KV	Bhugaon-Pusad	13-Oct-11	10:02	13-Oct-11	12:17	To attend hot spot on B ph W.T. jumper.
220KV	Hingoli-Pusad	13-Oct-11	09:13	13-Oct-11	15:08	To control WRRRA-WRDHA line loading.
220KV	Abhijeet-Wardha-I	13-Oct-11	13:30	13-Oct-11	22:36	To control Koradi ICT loading.
220KV	Abhijeet - Wardha ckt - II	13-Oct-11	13:30	13-Oct-11	22:37	To control Koradi ICT loading.
220KV	Parbhani-Girawali	13-Oct-11	17:41	13-Oct-11	18:56	D/P,B ph, Z-1.
220KV	Badnera-Akola-II	13-Oct-11	17:52	14-Oct-11	08.24	To control Koradi ICT loading.
220KV	Aarey-Versova	14-Oct-11	06.12	14-Oct-11	08.06	Maintenance work.
220KV	Bhigwan-Kurkum	14-Oct-11	09.15	14-Oct-11	17.20	Replacement of faulty insulators.
220KV	Peth-Mudsingi-I	14-Oct-11	11.30	14-Oct-11	14.13	Taurus measurement of line.

220KV	Uran-Kharghar-II	14-Oct-11	09.22	14-Oct-11	17.04	Insulator replacement at Loc.No.9
220KV	Kalwa-Mulund II	14-Oct-11	09.32	14-Oct-11	14.52	Hot spot attending work,Jumper replacement at Mulund s/s.
220KV	Dhule-Chalisgaon	14-Oct-11	09.51	14-Oct-11	09.59	H/T to give outage on Malegaon-Chalisgaon line.
220KV	Chalisgaon - Malegaon	14-Oct-11	09.51	14-Oct-11	17.50	Insulator replacement work.
220KV	Nasik-Navsari-I	14-Oct-11	08.31	14-Oct-11	18.26	To attend red hot at Navasari end.
220KV	Jambhul - Anandnagar	14-Oct-11	09.04	14-Oct-11	18.43	R.M.Work.
220KV	Bhoisor - Bhoisor PGCIL-II	14-Oct-11	07.17	14-Oct-11	12.11	To attend hot spot.
220KV	Kalwa-Colourchem	14-Oct-11	08.11	14-Oct-11	17.12	Measurement of tan delta of CT.
220KV	C' Enka - Khadki	14-Oct-11	8.15	14-Oct-11	17.59	Stringing of earth wire between Loc.No.14-22.
220KV	Kalwa-Mulund-I	14-Oct-11	16.07		Continued.	Taken on TBC for replacement of 29A isolator.
220KV	Kalwa - Ghatghar	14-Oct-11	17.00	14-Oct-11	21.00	Relay setting work.
220KV	Nivali-N'koyna	14-Oct-11	14.59	14-Oct-11	20.16	Tripped on distance protection.
220KV	Apta - Taloja	14-Oct-11	17.26	14-Oct-11	22.24	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	Apta-Bombay Dyeing	14-Oct-11	17.26	14-Oct-11	19.15	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	Apta-Kalwa	14-Oct-11	17.26	14-Oct-11	22.13	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	Apta-Tambati	14-Oct-11	17.26	14-Oct-11	19.35	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	Apta-Uran-II	14-Oct-11	17.26	14-Oct-11	19.47	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	Apta-HOC	14-Oct-11	17.26	14-Oct-11	21.37	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	220/100 KV 200 MVA ICT- IV @ Apta	14-Oct-11	17.26	14-Oct-11	18.30	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	220/100 KV 200 MVA ICT-II @ Apta	14-Oct-11	17.26	14-Oct-11	20.04	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	220/100 KV,200 MVA ICT-I @ Apta	14-Oct-11	17.26	14-Oct-11	22.28	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	Bus Section - II @ Apta.	14-Oct-11	17.26	14-Oct-11	18.30	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
220KV	Temghar-Colourchem	14-Oct-11	18.10	14-Oct-11	23.55	H/T due to heavy isolator sparking.
220KV	Bus Section at Kalwa	14-Oct-11	09.35	14-Oct-11	22.46	Jaw replacement work.
220KV	Dhule - Malegaon	14-Oct-11	09.51	14-Oct-11	17.50	Replacement of faulty insulator.
220KV	220/132 KV 200 MVA ICT -IV. at Padegaon	14-Oct-11	11.00	14-Oct-11	17.10	Q.M.Work
220KV	220/132 KV 200 MVA ICT - II @ Nanded	14-Oct-11	05.50	14-Oct-11	18.24	Diff.protection operated.
220KV	Abhijeet-Wardha-I	14-Oct-11	19.59	15-Oct-11	00.04	H/T to control over loading of 400KV Koradi ICTs.
220KV	Abhijeet - Wardha ckt - II	14-Oct-11	19.59	15-Oct-11	00.04	H/T to control over loading of 400KV Koradi ICTs.
220KV	Khaperkheda - Wardha.	14-Oct-11	20.55	14-Oct-11	23.33	H/T to control over loading of 400KV Koradi ICTs.
220KV	220/132KV 100 MVA ICT- II @ Padegaon	14-Oct-11	15.55	14-Oct-11	16.07	132KV Bus Bar protection operated at 220KV Padegaon.
220KV	220/132KV 100 MVA ICT-I @Padegaon	14-Oct-11	15.55	14-Oct-11	16.06	132KV Bus Bar protection operated at 220KV Padegaon.
220KV	220/132KV 200 MVA ICT- III @ Padegaon	14-Oct-11	15.55	14-Oct-11	16.09	132KV Bus Bar protection operated at 220KV Padegaon.
220KV	Raymond-Washala	15-Oct-11	10.10	15-Oct-11	19.20	Q.M.Work
220KV	220/132 KV 200 MVA ICT - II @ Raymand	15-Oct-11	10.31	15-Oct-11	17.16	Tan delta measurement.HV/LV CTs.
220KV	Bhusawal-Chalisgaon-I	15-Oct-11	06.48	15-Oct-11	07.12	220KV Bus at Khadka dead.
220KV	Borivali -Tarapur	15-Oct-11	11.55	15-Oct-11	16.55	To take TBC for attending C.B.problem.
220KV	Jejuri - Parvati	15-Oct-11	14.32	15-Oct-11	16.32	To avail outage on 400KV Lonikand-Stage IV line.
220KV	Khadka-Bhadli-I	15-Oct-11	06.48	15-Oct-11	07.12	220KV Bus at Khadka dead.
220KV	Khadka-Bhadli-II	15-Oct-11	06.48	15-Oct-11	07.12	220KV Bus at Khadka dead.
220KV	Bhusawal-Chalisgaon-II	15-Oct-11	06.48	15-Oct-11	08.00	220KV Bus at Khadka dead.
220KV	Nasik-Navsari-I	15-Oct-11	20.45		Continued.	Distance protection.Declared faulty.
220KV	Pedambe-Pophali I	15-Oct-11	14.50	15-Oct-11	15.25	Distance protection.
220KV	Pedambe-Mahad	15-Oct-11	15.45	15-Oct-11	16.12	Distance protection.
220KV	Pedambe - Tambati	15-Oct-11	15.52	15-Oct-11	17.00	Distance protection.
220KV	Uran-Apta-II	15-Oct-11	16.25	15-Oct-11	22.12	Distance protection.
220KV	Uran-Apta-I	15-Oct-11	16.53	16-Oct-11	00.15	Distance protection.
220KV	Wada-Kolshet	15-Oct-11	16.48	15-Oct-11	18.14	Transent fault.
220KV	Abhijeet-Wardha-I	15-Oct-11	17.47	16-Oct-11	07.38	To control Koradi ICT loading.

220KV	Abhijeet - Wardha ckt - II	15-Oct-11	17.48	16-Oct-11	07.38	To control Koradi ICT loading.
220KV	Wardha Power - Warora - II	16-Oct-11	03.02	16-Oct-11	05.25	Distance protection.
220KV	Bale-Murud	16-Oct-11	05.08		Continued.	To control Parli ICT loading.
220KV	Bale-Osmanbad	16-Oct-11	05.08		Continued.	To control Parli ICT loading
220KV	Lonikand-Bhosari	16-Oct-11	14.12	16-Oct-11	14.46	Distance Protection
220KV	Pedambe-Mahad	16-Oct-11	16.37		Continued.	Distance Protection
220KV	Nasik-Bablsr - I	16-Oct-11	17.27	16-Oct-11	17.47	Distance Protection
220KV	Phinolex-Kharepatan	16-Oct-11	18.08	16-Oct-11	19.42	Distance Protection
220KV	Karad-Wathar	16-Oct-11	11.36	16-Oct-11	16.52	Y Phase LA Burst
220KV	Trombay - Tifil	16-Oct-11	11.34	16-Oct-11	19.06	Relay testing
220KV	Kharghar-Nerul	16-Oct-11	08.19	16-Oct-11	11.10	Hot Spot
220KV	Nivali-Pawas	16-Oct-11	17.42	16-Oct-11	18.14	Distance Protection
220KV	Badnera-Akola Ckt.I	16-Oct-11	09.41	16-Oct-11	09.58	Distance Protection
220KV	Aurangabad - Padegaon - II	16-Oct-11	18.58		Continued.	R Phase Conductor Snapped
220KV	Badnera-Akola Ckt.I	16-Oct-11	20.07		Continued.	Y Phase Insulator String Broken
220KV	Trombay - Tata Tie - I	16-Oct-11	09.36	16-Oct-11	18.31	CVT Testing work
220KV	Jambhul - Anandnagar	16-Oct-11	19.55	16-Oct-11	21.28	Distance Protection
220KV	Jambul - Pal	16-Oct-11	19.55		Continued.	R Phase CC Burst
220KV	Anandnagar-Pal	16-Oct-11	19.55	16-Oct-11	21.39	R Phase CC Burst at Jambhul
220KV	220/22KV 50 MVA T/F-I @ Kolshet	16-Oct-11	20.00	16-Oct-11	21.23	Due to Wada-Kolshet and Kamba-Kolshet Tripped
220KV	220/100 KV 200 MVA ICT- I @ Kolshet	16-Oct-11	20.00	16-Oct-11	21.06	Due to Wada-Kolshet and Kamba-Kolshet Tripped
220KV	220/100KV 200 MVA ICT- II @ Kolshet	16-Oct-11	20.00	16-Oct-11	21.07	Due to Wada-Kolshet and Kamba-Kolshet Tripped
220KV	Kolshet-Khamba	16-Oct-11	20.00	16-Oct-11	21.07	Tripped at Kolshet end only
220KV	Wada-Kolshet	16-Oct-11	20.00	16-Oct-11	21.06	Distance Protection
220KV	Bus Section Breaker @ Kolshet	16-Oct-11	20.00	16-Oct-11	21.24	Due to Wada-Kolshet and Kamba-Kolshet Tripped
220KV	220/22KV 200MVA ICT -III at Pal	16-Oct-11	19.55	16-Oct-11	21.39	R Phase CC Burst at Jambhul
220KV	220/22KV 200MVA ICT -IV at Pal	16-Oct-11	19.55	16-Oct-11	21.39	R Phase CC Burst at Jambhul
220KV	220/22KV 50MVA ICT-I at Pal	16-Oct-11	19.55	16-Oct-11	21.39	R Phase CC Burst at Jambhul
220KV	220/22KV 50MVA ICT-II at Pal	16-Oct-11	19.55	16-Oct-11	21.39	R Phase CC Burst at Jambhul
220KV	220/22KV 50 MVA ICT -I at Jambhul	16-Oct-11	19.55	16-Oct-11	21.38	R Phase CC Burst at Jambhul
220KV	220/22KV 50 MVA ICT -II at Jambhul	16-Oct-11	19.55	16-Oct-11	21.38	R Phase CC Burst at Jambhul
132KV	Beed-Gevrai	10-Oct-11	02.35	10-Oct-11	03.00	Distance Protection
132KV	Giravali-Gangakhed	10-Oct-11	10.03	11-Oct-11	00.10	B phase Conductor Broken
132KV	Bhandara-Tekepar	10-Oct-11	14.10	10-Oct-11	15.16	Distance Protection
132KV	Kardha - Tekepar	10-Oct-11	14.10	10-Oct-11	15.15	Distance Protection
132KV	Parbhani-Parthur	10-Oct-11	12.43	10-Oct-11	15.07	To attend Hot Spot
132KV	Jangamwadi - Kandhar	10-Oct-11	07.00	10-Oct-11	23.30	Dist.Prot.B phase Conductor Broken
132KV	Kanhan-Uppalwadi	10-Oct-11	12.14	10-Oct-11	16.45	A/R testing work
132KV	Bale - Nuldurg	11-Oct-11	18.34	11-Oct-11	18.48	Transient Fault.
132KV	Anudh - Dahiwadi	11-Oct-11	18.45	11-Oct-11	19.15	Distance Protection.
132KV	Bhandara - Madgi - II	11-Oct-11	05.23	11-Oct-11	05.37	Distance Protection Operated.
132KV	Bhandara - Madgi - II	11-Oct-11	18.46	11-Oct-11	19.05	Distance Protection Operated Z-I R Ph.
132KV	Pusad - Digras	11-Oct-11	19.10	11-Oct-11	19.21	Distance Protection Operated Z-I R Ph.
132KV	Beed-Gevrai	11-Oct-11	22.24	11-Oct-11	22.50	Distance Protection Operated Z-I R Ph.
132KV	Bhoom-Kherda	12-Oct-11	13.58	12-Oct-11	14.32	B Ph. L A Burst @ Bhoom S/S.
132KV	Girawali-Parli	13-Oct-11	01:08	13-Oct-11	01:55	D/P,R ph, Z-1.
132KV	Lalkhedi - Durgwada	13-Oct-11	11:55	13-Oct-11	15:08	To control Koradi ICT loading.
132KV	Mankapur - Uppalwadi	13-Oct-11	13:02	13-Oct-11	13:18	Tripped D/P.
132KV	Bhandara - Madgi - II	14-Oct-11	11.31	14-Oct-11	15.40	Breaker overhaul.

132KV	Padegaon - Paithan	14-Oct-11	10.25	14-Oct-11	17.30	Q.M.Work
132KV	Padegaon-Sawangi	14-Oct-11	13.40	14-Oct-11	17.40	Q.M.Work
132KV	Bhandara - Madgi - II	14-Oct-11	19.05	14-Oct-11	19.20	Distance protection
132KV	Padegaon-Garware	14-Oct-11	15.55	14-Oct-11	16.10	132KV Bus Bar protection operated at 220KV Padegaon.
132KV	Padegaon-Pishor	14-Oct-11	15.55	14-Oct-11	16.09	132KV Bus Bar protection operated at 220KV Padegaon.
132KV	Padegaon-Harsul-I	14-Oct-11	15.55	14-Oct-11	16.09	132KV Bus Bar protection operated at 220KV Padegaon.
132KV	Padegaon-Harsul-II	14-Oct-11	15.55	14-Oct-11	16.10	132KV Bus Bar protection operated at 220KV Padegaon.
132KV	Padegaon - Gangapur	14-Oct-11	15.55	14-Oct-11	16.10	132KV Bus Bar protection operated at 220KV Padegaon.
132KV	Padegaon - Sat	14-Oct-11	15.55	14-Oct-11	16.08	132KV Bus Bar protection operated at 220KV Padegaon.
132KV	Akola - Paras-II	15-Oct-11	06.48	15-Oct-11	07.01	Tripped on O/C.
132KV	Bhusawal-Sawda	15-Oct-11	06.48	15-Oct-11	08.15	132KV Bus at Khadka dead.
132KV	Khadka-Malkapur	15-Oct-11	06.48	15-Oct-11	07.32	132KV Bus at Khadka dead.
132KV	Khadka-Deepnagar-II	15-Oct-11	06.48	15-Oct-11	07.12	132KV Bus at Khadka dead.
132KV	Khadka-Deepnagar ckt.III	15-Oct-11	06.48	15-Oct-11	07.12	132KV Bus at Khadka dead.
132KV	Akola - Paras - I	15-Oct-11	06.48	15-Oct-11	07.01	Tripped on O/C.
132KV	Paras-Malkapur	15-Oct-11	06.48	15-Oct-11	07.03	Tripped on O/C.
132KV	Paras - Warwat Bakal	15-Oct-11	06.48	15-Oct-11	07.32	Tripped on O/C.
132KV	Chikali - Mehkar	15-Oct-11	06.48	15-Oct-11	07.33	Tripped on O/C.
132KV	Chikhali - Khamgaon	15-Oct-11	06.48	15-Oct-11	07.34	Tripped on O/C.
132KV	Chikhali - Buldana	15-Oct-11	06.48	15-Oct-11	07.32	Tripped on O/C.
132KV	Khapri - Besa	16-Oct-11	12.50	16-Oct-11	13.30	Distance Protection
132KV	Dhule-Nardhane	16-Oct-11	17.06	16-Oct-11	17.18	Distance Protection
132KV	Dhule-Nardhane	16-Oct-11	17.21	16-Oct-11	22.31	Y Phase Conductor Snapped
100KV	Ganeshkhanda-Chinchwad	11-Oct-11	19.43	11-Oct-11	20.17	Distance Protection.
100KV	Kandalgaon-Roha-I	11-Oct-11	21.26	11-Oct-11	21.48	Distance Protection.
100KV	100/22KV,20 MVA T/F-II at Apta	14-Oct-11	17.26	14-Oct-11	18.32	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
100KV	100/22KV,50 MVA T/F-I at Apta	14-Oct-11	17.26	14-Oct-11	18.31	Earth wire of 220KV Apta-Taloja-Kalwa fallen on all 100KV lines.
100KV	Kalwa - Salshet - I	14-Oct-11	08.00	14-Oct-11	08.20	Tripped Y Phase.
100KV	K'gaon-Roha-II	15-Oct-11	14.37	15-Oct-11	15.00	Tripped R ph. from Kandalgaon end.
100KV	Kandalgaon - Mhasale	15-Oct-11	15.20	15-Oct-11	15.33	Distance protection.
100KV	Borivali-TATA-I	15-Oct-11	17.28	15-Oct-11	19.23	Distance protection.