

LINE OUTAGES FOR THE WEEK

FROM 8-Nov-10 TO 14-Nov-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Wardha - Akola - II	8-Oct-10	17.55	13-Nov-10	10.57	Normal Changeover.
400KV	Kolhapur-Mapusa-II	1-Nov-10	22.45	11-Nov-10	10.31	Over Voltage.
400KV	Padgha - Babaleshwar - II	5-Nov-10	14.04	8-Nov-10	11.56	Over Voltage
400KV	New Koyna - Koyna Stage IV - II	5-Nov-10	23.25	8-Nov-10	08.41	Over Voltage
400KV	Dhule-Sar'Sarovar - I	6-Nov-10	22.11	10-Nov-10	09.30	Over Voltage.
400KV	400/220KV,315MVA ICT-I at Karad	7-Nov-10	20.06	8-Nov-10	17.03	To Attend Red Hot on H V Side Neutral C T Clamp.
400KV	Bhusawal- Aurangabad	7-Nov-10	21.26	8-Nov-10	08.48	Over Voltage.
400KV	Karad-Lamboti	7-Nov-10	23.25	8-Nov-10	08.16	Over Voltage.
400KV	Karad - Kolhapur - II	7-Nov-10	23.25	8-Nov-10	08.41	Over Voltage.
400KV	Akola-Aurangabad-II	8-Nov-10	19.49	8-Nov-10	20.21	Triped from akole end only.
400KV	Bableswhar-Aurangabad	8-Nov-10	23.45	9-Nov-10	08.59	Over Voltage.
400KV	Karad-Kolhapur-II	8-Nov-10	22.52	9-Nov-10	08.26	Over Voltage.
400KV	Dhule - Babhaleshwar - I	9-Nov-10	00.45	9-Nov-10	08.47	Over Voltage
400KV	Lonikand- Koyna Stage IV	9-Nov-10	00.47	9-Nov-10	09.05	Over Voltage
400KV	Kalwa-Kharghar	9-Nov-10	08.46	9-Nov-10	17.30	Attending Oil leakage of Y phase CT
400KV	400/220 KV 315 MVA ICT- I @ Nagothane	9-Nov-10	11.58	9-Nov-10	17.10	To attend Hot Spot on 29C Isolator
400KV	Dhule-Sar'Sarovar - II	9-Nov-10	23.04	10-Nov-10	09.30	Over Voltage
400KV	Bhusawal- Aurangabad	9-Nov-10	23.13	10-Nov-10	08.57	Over Voltage
400KV	Karad - Kolhapur - II	9-Nov-10	23:45	10-Nov-10	07.51	Over Voltage.
400KV	Dhule - S'Sarovar- II	9-Nov-10	23:04	11-Nov-10	08.43	Over Voltage.
400KV	220/132 KV 100 MVA ICT - I @ Bhusawal	9-Nov-10	08:55	9-Nov-10	15:59	To attend Hot Spot on 220 KV Main Bus-I Isolator and HV CT Clamp.
400KV	220 KV Main Bus I at Bhusawal II	9-Nov-10	10:11	9-Nov-10	15:50	To attend Hot Spot on 220 KV Main Bus-I Isolator and HV CT Clamp.
400KV	400 KV TBC- I @ Chandrapur	9-Nov-10	11:30	9-Nov-10	17:10	Routine Maintainance Work.
400KV	Lonikand- Koyna Stage IV	10-Nov-10	00:49	10-Nov-10	08.00	Over Voltage.
400KV	Karad-Lamboti	10-Nov-10	06.38	13-Nov-10	09.03	LILo work of 400KV Karad-Lamboti at 400KV south Solapur(PG)
400KV	Main Bus- II @ Kalwa	10-Nov-10	08.45	10-Nov-10	18.32	For connecting New ICT to main B bus at KLV S/Stn.by jumpering
400KV	Dhule-S'Sarovar I	10-Nov-10	23.22	12-Nov-10	16.59	Over Voltage.
400KV	Kalwa-Kharghar	10-Nov-10	08.51	10-Nov-10	18.57	For connecting New ICT to main B bus at Kalwa s/stn.by jumpering.
400KV	Bhusawal- Aurangabad	11-Nov-10	00.25	11-Nov-10	07.55	Over Voltage.
400KV	Main Bus - I @ Kalwa	11-Nov-10	08.59	11-Nov-10	21.14	Connecting New ICT-II Bus to Main Bus-I @ Kalwa by Jumpering.
400KV	400/220 KV 315 MVA ICT-II @ Lonikand	11-Nov-10	08.35	11-Nov-10	17.51	Replacement of L V Side Y & B Ph C T's.
400KV	Koradi-Bhilai	11-Nov-10	10.35	11-Nov-10	19.21	Maintenance Work.
400KV	Kolhapur - Mapusa - I	11-Nov-10	22.30		Continued.	Over Voltage.
400KV	Akola - Wardha - I	11-Nov-10	23.47		Continued.	Over Voltage.
400KV	Seoni - Wardha	11-Nov-10	23.43	12-Nov-10	17.28	Over Voltage.

400KV	Lonikand- Koyna Stage IV	11-Nov-10	23.16	12-Nov-10	08.32	Over Voltage.
400KV	400/220 KV 105 MVA Spare ICT Unit @ Bhusa	11-Nov-10	13.55	11-Nov-10	17.35	Replacement of Buchholz Relay.
400KV	Dhule-Sar'Sarovar - II	11-Nov-10	23.19	14-Nov-10	08.24	Over Voltage.
400KV	400/220KV,500MVA ICT-III At Kalwa.	12-Nov-10	09.07	12-Nov-10	22.11	Testing Work.
400KV	Lonikand- Koyna Stage IV	13-Nov-10	00.15	13-Nov-10	08.14	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	13-Nov-10	00.21	13-Nov-10	17.38	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	13-Nov-10	23.05		Continued.	Over Voltage.
400KV	400/220 KV,105 MVA Spare ICT @ Dhule	13-Nov-10	12.20	13-Nov-10	17.03	Attending Oil Leakage & Buchloz Relay Testing.
400KV	Lonikand- Koyna Stage IV	14-Nov-10	01.06	14-Nov-10	08.19	Over Voltage.
400KV	Parli - Chandrapur - III	14-Nov-10	10.26		Continued.	Breaker Maintenance,Line on TBC.
400KV	Karad-Lamboti	14-Nov-10	15.50		Continued.	Dist.Prot. Z-I B Ph - Earth.
400KV	Bhusawal- Aurangabad	14-Nov-10	23.50	15-Nov-10	06.12	Over Voltage.
400KV	Karad-New Koyna II	14-Nov-10	20.30		Continued.	Dist.Prot.B Ph,Ready for Charging from 02.06 on dt 15.11.10.
220KV	Padgha - Boisar (PGCIL)	21-Oct-10	13.24	12-Nov-10	21.03	Hand Tripped at padgha end (To Transfer Load to PGCIL)
220KV	220/132 KV 200 MVA ICT - V @ Nasik (OCR) N	7-Nov-10	21.50	9-Nov-10	09.50	L V Side Control Ckt Problem.
220KV	SPCL - IPCL	8-Nov-10	15.47	8-Nov-10	18.22	To attend Hot spot on Y Ph. isolator.
220KV	Halkarni -Tillary	8-Nov-10	12.35	8-Nov-10	17.27	Jumpering on newly constructed bay.
220KV	Momewadi-Halkarni	8-Nov-10	12.37	8-Nov-10	17.50	Jumpering of newly constructed bay.
220KV	Lonand - Jejuri	8-Nov-10	08.58	8-Nov-10	17.04	Replacement of isolator jaw.
220KV	Pusad - Parbhani	8-Nov-10	22.28	9-Nov-10	12.24	Dist.Prot.R Ph.earth.Declared faulty.
220KV	220/132KV 100MVA ICT-II @ Chalisgaon	8-Nov-10	11.10		Continued.	Commissioning of new 200MVA ICT by replacing 100MVA ICT.
220KV	Khaparkheda-Kawlewada-I	8-Nov-10	15.43	10-Nov-10	14.06	Distance prot.B Ph E/F deleared faulty.
220KV	Bhosari - Lonikand	9-Nov-10	02.45	9-Nov-10	6:40	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari.
220KV	Bhosari-C'enka	9-Nov-10	02.45	9-Nov-10	03.22	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari
220KV	Bhosari-Chinchwad	9-Nov-10	02.45	9-Nov-10	03.27	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari
220KV	Bhosari-Telco	9-Nov-10	02.45	9-Nov-10	03.31	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari
220KV	220/22KV,50 MVA ICT-I At Bhosari..	9-Nov-10	02.45	9-Nov-10	03.29	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari
220KV	220/22KV,50MVA ICT-II At Bhosari.	9-Nov-10	02.45	9-Nov-10	03.23	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari
220KV	220/22KV,75 MVA ICT-III At Bhosari	9-Nov-10	02.45	9-Nov-10	03.30	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari
220KV	BBLSR-A"Nagar II	9-Nov-10	03.35	9-Nov-10	05.10	Dist.Prot.Z1,R Ph.-E
220KV	Lonikand - Bhosari	9-Nov-10	02.45	9-Nov-10	06.25	B Ph LA burst at Lonikand.Bus bar protection Operated at Bhosari
220KV	Mahad-Nagothane	9-Nov-10	09.13	9-Nov-10	17.32	Replacement of Disc Insulator
220KV	Nagothane-IPCL	9-Nov-10	10.41	9-Nov-10	17.40	To attend Red Hot
220KV	Mudshingi - Peth	9-Nov-10	10.15	9-Nov-10	17.20	R.M.Work
220KV	Wadkhali-IPCL-II	9-Nov-10	12.03	9-Nov-10	17.54	Red Hot on R phase Bus side Isolator
220KV	Bhusawal - Chalisgaon - II	9-Nov-10	16.22	9-Nov-10	16.25	Distance Protection
220KV	Badnera-Amravati	9-Nov-10	18.25	9-Nov-10	18.36	Distance Protection
220KV	Wadkhali-IPCL I	10-Nov-10	10.38	10-Nov-10	16.00	Relay retrofitting.
220KV	220/132 KV 150 MVA ICT - I @ NSK.	10-Nov-10	09.40		Continued.	Augmentation of existing 150 MVA ICT by new 200MVA ICT
220KV	Kolshet- 220KV Bus sectionaliser	10-Nov-10	11.35	10-Nov-10	14.05	CT tan delta measurement.

220KV	TBC @ Babaleshwar	10-Nov-10	11.30	10-Nov-10	12.35	Breaker timing work.
220KV	Mudshingi-Talangade - I	10-Nov-10	10.07	10-Nov-10	12.53	Q.M.Work.
220KV	Tarapur - Borivali	10-Nov-10	08.35	14-Nov-10	18.00	Bus section-II outage at Tarapur(Up to 15.11.2010.)
220KV	Kandalgaon - Dasturi	10-Nov-10	12.03	11-Nov-10	13.35	Distance protection.
220KV	Abhijeet-Wardha Ckt.	10-Nov-10	09.25	10-Nov-10	19.14	Replacement of CVTs and jumper connection of bus sectionaliser.
220KV	Butibori-Abhijeet ckt.	10-Nov-10	09.30	10-Nov-10	19.08	Replacement of CVTs and jumper connection of bus sectionaliser.
220KV	Khadka-Badli Ckt.II	10-Nov-10	10.12	10-Nov-10	16.40	Repl.of Y Ph.M.B.II isolator.
220KV	Main Bus-II At Bhusawal-II	10-Nov-10	10.23	10-Nov-10	16.44	Repl.of Y Ph.M.B.II isolator
220KV	220/33 KV 50 MVA T/F-II @ Butibori	10-Nov-10	11.35	10-Nov-10	15.35	Q.M.Work
220KV	220/33KV 50 MVA T/F - I @ Harangul	10-Nov-10	12.30	10-Nov-10	14.25	Attending air leakage problem of main breaker.
220KV	Warora-Hinganghat	10-Nov-10	11.35	10-Nov-10	14.13	R.M.Work
220KV	220/33 KV 100 MVA ICT - II @ Jamde	10-Nov-10	09.35	10-Nov-10	11.35	Q.M.Work
220KV	220/132 KV 100 MVA ICT- II @ Kanhan	10-Nov-10	10.17	10-Nov-10	15.34	Q.M.Work
220KV	220/132KV 150MVA ICT @ Boisor	11-Nov-10	07.10	11-Nov-10	10.14	C Bus Isolator Maintenance.
220KV	Bus coupler @ Bableshtar	11-Nov-10	08.15		Continued.	Replacement of Breaker.
220KV	Mudshini - Talangade - II	11-Nov-10	09.30	11-Nov-10	14.44	Q.M.Work.
220KV	Kandalgaon - Pirangut	11-Nov-10	09.26	11-Nov-10	18.28	Replacement of Earthwire.
220KV	Nagothane-IPCL	11-Nov-10	15.28	12-Nov-10	01.00	Relay Retrofitting Work.
220KV	Ghatghar-Jindal	11-Nov-10	19.46	11-Nov-10	20.24	Distance Protection.
220KV	Butibori-Abhijeet ckt.	11-Nov-10	10.13	11-Nov-10	19.51	Replacement of CVT'S by P T.
220KV	Abhijeet-Wardha Ckt.	11-Nov-10	10.09	11-Nov-10	20.00	Replacement of CVT'S by P T.
220KV	220/132KV 150 MVA ICT @ Ambazari.	11-Nov-10	09.32	11-Nov-10	14.37	Q.M. & Attending Oil Leakages.
220KV	220/132KV,200MVA ICT-III At Nanded.	11-Nov-10	10.50	11-Nov-10	14.55	ICT Painting Work.
220KV	Khaparkheda - Kanhan - I	11-Nov-10	08.03	11-Nov-10	15.03	At Loc.No.131 B Ph Faulty Disc Insulator String Replaced.
220KV	Badnera-Akola Ckt.I	11-Nov-10	20.01	11-Nov-10	20.20	Distance Protection R Ph.
220KV	Aurangabad - Bhenda	11-Nov-10	23.00	11-Nov-10	23.57	Distance Protection.
220KV	Padgha-Kamba	12-Nov-10	08.25	12-Nov-10	08.58	Replacement of Faulty Insulator.
220KV	Padgha-Kamba	12-Nov-10	11.45	12-Nov-10	19.08	Replacement of Faulty Insulator.
220KV	Talangade-Ichalkaranji I	12-Nov-10	11.06	12-Nov-10	16.45	Q.M.Work.
220KV	220/132KV,200MVA ICT-I at Malegaon	12-Nov-10	10.05	12-Nov-10	13.50	To Attend OLTC Oil Leakage.
220KV	220/132 KV 150 MVA ICT - I @ NSK.	12-Nov-10	10.52	12-Nov-10	12.08	Red Hot.Taken on TBC.
220KV	220/33 KV 50 MVA T/F I @ Boisar II	12-Nov-10	12.11	12-Nov-10	12.51	B Bus Isolator Alignment.
220KV	Padgha-Wada	12-Nov-10	08.38	12-Nov-10	11.13	Heavy Sparking on Isolator.
220KV	Lote - Dasturi	12-Nov-10	18.03	13-Nov-10	04.38	R Ph Jumper of Wave Trap Broken @Dasturi
220KV	Aurangabad - Padegaon - I.	12-Nov-10	09.57	12-Nov-10	17.20	Quarterly Maintainance Work.
220KV	Kalmeshwar-Nippon	12-Nov-10	09.06	12-Nov-10	18.25	Relay Testing Work.
220KV	Abhijeet-Wardha Ckt.	12-Nov-10	00.15	12-Nov-10	00.55	Distance Protection.
220KV	Pedambe - Karad	13-Nov-10	08.05	13-Nov-10	17.09	Preventive Maint. of 220 KV Bay.
220KV	Talangade-Ichalkaranji I	13-Nov-10	12.05	13-Nov-10	13.27	To Attend Hot Spot R Ph Bus Isolator.
220KV	Vita - Pandharpur	13-Nov-10	10.41	13-Nov-10	15.46	To Attend Oil Leakage.

220KV	SPCL - IPCL	13-Nov-10	12.41		Continued.	C B Overhalling Work @ IPCL End.
220KV	Nasik - Ghatghar	13-Nov-10	15.00	13-Nov-10	15.55	Distance Protection, R-E.
220KV	Airoli-Knowledge park-Nasik	13-Nov-10	15.00	13-Nov-10	15.40	Distance Protection.
220KV	220/132 KV 200 MVA ICT - II @ Kandalgaon	13-Nov-10	10.45	13-Nov-10	17.25	Q.M.Work.
220KV	220/132 KV,100MVA ICT-II At Padegaon.	13-Nov-10	09.18	13-Nov-10	18.00	Replacement of L A.
220KV	Abhijeet-Wardha Ckt.	13-Nov-10	12.12	13-Nov-10	15.45	Testing of PDR,Relay & Ckt Bkr @ Wardha.
220KV	Babaleshwar - Chalisgaon	14-Nov-10	05.35	14-Nov-10	05.58	Distance Protection.
220KV	Wadkhal-IPCL-II	14-Nov-10	09.20		Continued.	Overhauling Work.
220KV	Mudsungi-Amona	14-Nov-10	14.27		Continued.	Dist.Prot.R Ph - E142.5KM FROM Mudsungi.
220KV	Kandalgaon-Khargar	14-Nov-10	17.43	14-Nov-10	19.00	Dist.Prot. Z-2 R Ph to Earth.
220KV	Karad-Pedambe	14-Nov-10	19.39		Continued.	Dist.Prot. R Ph -E Ckt Tripped Both end,Declared Faulty.
220KV	Kandalgaon - ONGC	14-Nov-10	19.00	14-Nov-10	19.50	Tripped Due to R Ph P T Burst of ONGC-TSS Line.
220KV	ONGC-TSS	14-Nov-10	19.00	14-Nov-10	22.18	Tripped Due to R Ph P T Burst of ONGC- TSS Line.
220KV	Tillary-Amona	14-Nov-10	17.32	14-Nov-10	22.53	Hand Tripped.
220KV	Parly (Ext.) - Beed - II	14-Nov-10	06.01	14-Nov-10	06.08	Dist.Prot. R Ph,Zone-I.
132KV	Nanded - Tamsa	8-Nov-10	04.38	8-Nov-10	04.57	Distance protection B PH.E/F.
132KV	Nanded - Tamsa	8-Nov-10	06.43	8-Nov-10	16.15	Distance protection, remove broeken E/W.
132KV	Butibori MIDC-Khapri Cky.	8-Nov-10	10.10		Continued.	Dist.Prot.Y Ph.and B Ph.B/D deleared.
132KV	Boiser - Palghar - I	10-Nov-10	10.55	10-Nov-10	18.35	CT Replacement.
132KV	Dhule - Dhule	10-Nov-10	12.45	10-Nov-10	23.09	Distance protection.
132KV	Gondia - Amgaon Railway	10-Nov-10	11.35	10-Nov-10	15.35	Q.M.Work
132KV	TBC At 220 KV Kalmeshwar	10-Nov-10	10.23	10-Nov-10	16.44	Q.M.Work
132KV	Kalmeshwar-Saoner	10-Nov-10	12.30	10-Nov-10	13.28	Cutting of kateri bamboo
132KV	Kardha-Sakoli	10-Nov-10	10.12	10-Nov-10	16.40	Q.M.Work
132KV	Giravali-Gangakhed	11-Nov-10	13.54	12-Nov-10	16.24	Dist.Prot.R Ph Z-I@ Loc 49 Disc Insulator Broken,B/Dn Decleared,
132KV	132 KV Bus Coupler @ Boiser- II	12-Nov-10	07.37	12-Nov-10	11.43	Replacement of R Ph. C T.
132KV	Giravali-Latur	12-Nov-10	03.13	12-Nov-10	11.18	R Ph C T Burst.
132KV	Renapur - Latur	12-Nov-10	04.05	12-Nov-10	16.24	R Ph C T Burst.
132KV	Kalmeshwar - Katol	12-Nov-10	05.02	12-Nov-10	05.11	Distance Protection.
132KV	Latur (Koyna)-Latur MIDC	12-Nov-10	12.02	12-Nov-10	16.23	Distance Protection.
132KV	Bhusawal - Nimbhora	12-Nov-10	16.00	12-Nov-10	16.02	Due to Bhusawal Unit-3 Tripped.
132KV	Bhusawal - Jalgaon - I	12-Nov-10	16.00	12-Nov-10	16.01	Due to Bhusawal Unit - 3 Tripped.
132KV	Bhusawal - Jalgaon - II	12-Nov-10	16.00	12-Nov-10	16.02	Due to Bhusawal Unit - 3 Tripped
132KV	Bhusawal -Yawal	12-Nov-10	16.00	12-Nov-10	16.01	Due to Bhusawal Unit - 3 Tripped.
132KV	Pusad-Jambazar	12-Nov-10	17.25	12-Nov-10	17.43	Distance Protection.
132KV	Paras-Akot	12-Nov-10	18.00	12-Nov-10	18.15	Distance Protection.
132KV	Kallam - Bhoom - Kharda	12-Nov-10	17.50	13-Nov-10	16.00	Collapase of Tower @ Loc. No.81.
100KV	Chinchwad - Talegaon	11-Nov-10	23.56	12-Nov-10	00.05	Distance Protection.