

LINE OUTAGES FOR THE WEEK

FROM 7-Nov-11 TO 13-Nov-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Karad-New Koyna II	3-Nov-11	11.28	7-Nov-11	11.04	Taken on TBC to attend hot spot.
400KV	Parli (PG)-Bhadravati I	3-Nov-11	22.23	7-Nov-11	19:11	Over voltage.
400KV	Parli (PG)-Bhadravati I	3-Nov-11	10.26	10-Nov-11	14.00	Over Voltage
400KV	Parli (PGCIL)-Bhadravati-II	5-Nov-11	08.02	7-Nov-11	11:10	Control Koradi-Bhilai load.
400KV	Dhule-Sar'Sarovar - II	6-Nov-11	16.36	8-Nov-11	10.10	Over Voltage.
400KV	Karad - Kolhapur - I	6-Nov-11	16.22	12-Nov-11	09.56	Over Voltage.
400KV	Bhusawal- Aurangabad	6-Nov-11	22.37	8-Nov-11	10.04	Over Voltage.
400KV	Parly - Solapur (PGCIL) - I	6-Nov-11	10:00	7-Nov-11	09:02	Over Voltage.
400KV	400/220 KV 315 MVA ICT @ Akola	7-Nov-11	08:23	7-Nov-11	17:27	Q.M. Work.
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	7-Nov-11	10:50	7-Nov-11	17:02	Hot Spot attending work.
400KV	New Koyna - Karad - I	7-Nov-11	14:58	7-Nov-11	19:19	Attending Hot Spot, taken on TBC.
400KV	Karad - Solapur (PGCIL)	7-Nov-11	22:13	11-Nov-11	11.47	Over Voltage.
400KV	Kolhapur - Mapusa - I	7-Nov-11	22:54	8-Nov-11	10.01	Over Voltage.
400KV	Parli-Solapur (PGCIL) Ckt.II	7-Nov-11	09:10	8-Nov-11	07.35	Over Voltage.
400KV	Parli (PGCIL)-Bhadravati-II	7-Nov-11	16:42	10-Nov-11	10.39	R ph E fault.
400KV	Parli (PGCIL)-Bhadravati-II	7-Nov-11	17.00		Continued.	Over Voltage.
400KV	Dabhol - Nagothane - I	8-Nov-11	13.20	8-Nov-11	14.08	Distance Protection
400KV	400/132KV 200 MVA ICT-II @ Bhusawal	8-Nov-11	08.38	13-Nov-11	16.01	Filteration of Oil upto 13/11/2011
400KV	Dhule-Sar'Sarovar - I	8-Nov-11	22.56	9-Nov-11	11.03	Over Voltage
400KV	Kolhapur-Mapusa-II	8-Nov-11	22.58	9-Nov-11	09.51	Over Voltage
400KV	80 MVAR Reactor @ Kharghar	8-Nov-11	09.56	8-Nov-11	18.42	For attending Oil Leakage
400KV	400/220KV,315MVA ICT-I at Karad	9-Nov-11	10.58	11-Nov-11	12.20	Main Bus - I Outage.
400KV	Main Bus - I @ Karad	9-Nov-11	13.10	11-Nov-11	17:09	For extending Existing 400KV M.B.-I to 400KV Karad-Jaigad Line.
400KV	Dabhol - Nagothane - I	9-Nov-11	13.09	9-Nov-11	18.31	Hot Spot @ Dabhol End.
400KV	Bhusawal- Aurangabad	9-Nov-11	21.57	10-Nov-11	09.45	Over Voltage.
400KV	Dhule - S'Sarovar- II	9-Nov-11	22.36	10-Nov-11	12.07	Over Voltage.
400KV	Kolhapur - Mapusa - I	9-Nov-11	22.36	10-Nov-11	09.07	Over Voltage.
400KV	Dabhol-Nagothane - II	10-Nov-11	15.06	10-Nov-11	18.19	Testing Work.
400KV	400/220KV,315 MVA ICT-I At Lonikand.	10-Nov-11	07.44	10-Nov-11	19.07	Relay Testing Work.
400KV	Parli-Lonikand -I	10-Nov-11	09.18	10-Nov-11	19.00	Replacement of Disc Insulator.
400KV	400/220 KV,315 MVA ICT-I At Jejuri	10-Nov-11	10.31	10-Nov-11	15.13	L V Side Taken on TBC Testing Work.
400KV	Chandrapur - Parli - II	10-Nov-11	10.49	10-Nov-11	17.50	Maintenance of Damaged Conductor.
400KV	Dhule-Sar'Sarovar - I	10-Nov-11	22.41	11-Nov-11	10.57	Over Voltage.
400KV	Kolhapur-Mapusa-II	10-Nov-11	22.41	11-Nov-11	09.20	Over Voltage.
400KV	Bhusawal- Aurangabad	10-Nov-11	21.43	11-Nov-11	04.59	Over Voltage.
400KV	400/220KV,500MVA ICT-III At Kalwa.	11-Nov-11	10.27	11-Nov-11	19.31	To attend DC fail of relay.
400KV	Lonikand-Kalwa	11-Nov-11	07.45	11-Nov-11	15.36	Replacement of flashover insulators.
400KV	Kalwa - Padgha - I	11-Nov-11	09.58		Continued.	Taken on TBC for Hot Spot.
400KV	New Koyna - Karad - I	11-Nov-11	08.02	11-Nov-11	15.10	To attend 29A isolator damaged blades.
400KV	Bblswr - Padgha - II	11-Nov-11	09.03	11-Nov-11	18.58	Bay maintenance work.
400KV	Akola - Bhusawal	11-Nov-11	08.48	11-Nov-11	18.56	Q.M. Work.
400KV	400/220 KV 315 MVA ICT- I @ Nagothane	11-Nov-11	09.19	12-Nov-11	01.11	SFRA Work.
400KV	Kolhapur - Mapusa - I	11-Nov-11	22.57	12-Nov-11	09.01	Over Voltage.
400KV	Karad - Solapur (PGCIL)	11-Nov-11	16.18	13-Nov-11	11.12	Over Voltage.
400KV	Bhusawal- Aurangabad	11-Nov-11	21.32	12-Nov-11	04.28	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	12-Nov-11	08.23		Continued.	Over Voltage.
400KV	Dabhol-Nagothane - II	12-Nov-11	14.22	12-Nov-11	14.36	While carrying testing work.
400KV	Kolhapur - Mapusa - I	12-Nov-11	21.51		Continued.	Over Voltage.

400KV	Bhusawal- Aurangabad	12-Nov-11	22.41	13-Nov-11	05.04	Over Voltage.
220KV	Chandrapur - Warora	12-Oct-11	19.56	12-Nov-11	14.49	For System Stability.
220KV	Karad - Ogalewadi - II	7-Nov-11	04.30	7-Nov-11	05.27	Tripped at Ogalewadi end .
220KV	Karad-Oglewadi-I	7-Nov-11	04.30	7-Nov-11	09:13	Distance protection.Declared faulty.
220KV	Pedambe - Tambati	7-Nov-11	09:23	7-Nov-11	13:05	To replace Wave Trap Conductor.
220KV	Mudshingi - Karad - II	7-Nov-11	10:51	7-Nov-11	12:56	Q.M. Work.
220KV	Osmanabad - Solapur	7-Nov-11	16:13	7-Nov-11	23:19	To attend Y-ph CT leakage.
220KV	220/100 KV 200 MVA T/F IV @ Apta	8-Nov-11	07.37	8-Nov-11	20.05	CTR Commissioning work
220KV	Peth-Nigde	8-Nov-11	09.35	9-Nov-11	15.08	LA Replacement
220KV	P'pur-Malinagar	8-Nov-11	12.15	8-Nov-11	17.40	R.M.Work
220KV	Karad - Ogalewadi - II	8-Nov-11	12.43	8-Nov-11	17.02	Testing of Relay Panel
220KV	Murud-Bale	8-Nov-11	07.35	10-Nov-11	11.35	Loading Problem
220KV	Wadkhal-IPCL I	8-Nov-11	11.27	8-Nov-11	17.45	Replacement of New CT
220KV	220/132 KV 100 MVA T/F - I @ Oglewadi	8-Nov-11	14.11	8-Nov-11	17.26	Annual Maint.work
220KV	220/100KV,125 MVA T/F-II at Jambhul	8-Nov-11	13.50		Continued.	Inspection and Rectification of Gasformation upto 29/11/2011
220KV	Parli-Usmanabad	8-Nov-11	10.35	8-Nov-11	18.36	Distance Relay Card Replacement
220KV	Koradi-Ambazari-I	8-Nov-11	09.30	9-Nov-11	17.03	Main Bkr O/H work(Ckt on TBC for 2 Days)
220KV	Main Bus @ Usmanabad	8-Nov-11	15.11	8-Nov-11	16.39	To connect the Jumper of Main Bus for 220/33KV 50MVA T/F-I
220KV	Dondaicha - Jamde - II.	8-Nov-11	17.28	8-Nov-11	19.45	Tan Delta Measurement
220KV	Wadkhal - Ndil - 2	8-Nov-11	12.40	12-Nov-11	00.40	CT & PT Replaced at NDIL end.
220KV	Wadkhal-NDIL-3	8-Nov-11	09.55	12-Nov-11	00.45	CT & PT Replaced at NDIL end.
220KV	Wadkhal-IPCL-II	9-Nov-11	08.35	9-Nov-11	17.35	Replacement of C T P T (Metering).
220KV	Wadkhal - Ndil - I	9-Nov-11	10.15	9-Nov-11	18.35	Replacement of C T P T (Metering).
220KV	Main Bus - II @ Wadkhal	9-Nov-11	10.15	9-Nov-11	17.00	Maintenance Work.
220KV	Uran-Kharghar-II	9-Nov-11	11.01	9-Nov-11	15.37	Hot Spot.
220KV	Mudshingi - Talandage - I	9-Nov-11	12.02	9-Nov-11	18.33	Hot Spot.
220KV	Wardha - Deoli (PGCIL)	9-Nov-11	07.55	9-Nov-11	19.01	For Carrying out Stringing Work of 400KV D/C Chandrapur Line.
220KV	Badnera - Deoli (PGCIL)	9-Nov-11	07.53	9-Nov-11	19.24	For Carrying out Stringing Work of 400KV D/C Chandrapur Line.
220KV	Mudsinghi - Mumewadi - I	9-Nov-11	09.54	9-Nov-11	19.40	Outage.
220KV	Talangade-Mumewadi-II	9-Nov-11	09.51	9-Nov-11	19.50	Outage.
220KV	220/132KV 200 MVA ICT- II @ Amravati	9-Nov-11	10.00	9-Nov-11	14.55	Repairing of Gear Box of M.B.Isolator.
220KV	220/132 KV 200 MVA ICT @ Ambazari	9-Nov-11	11.02	9-Nov-11	11.24	Tripped From L V Side Only.No Indication.
220KV	Miraj-Maisal	10-Nov-11	05.15	10-Nov-11	05.55	Bus Bar Protection Operated.
220KV	Miraj-Karad	10-Nov-11	05.15	10-Nov-11	05.55	Bus Bar Protection Operated.
220KV	Miraj -Vita	10-Nov-11	05.15	10-Nov-11	05.55	Bus Bar Protection Operated.
220KV	Miraj -Ichalkarajni	10-Nov-11	05.15	10-Nov-11	05.55	Bus Bar Protection Operated.
220KV	220/33 KV 50 MVA T/F - I @ Miraj	10-Nov-11	05.15	10-Nov-11	20.45	R Ph. C T Burst.
220KV	220/33 KV T/F II AT Miraj	10-Nov-11	05.15	10-Nov-11	05.55	Bus Bar Protection Operated.
220KV	220/100 KV,200MVA ICT-I at Miraj	10-Nov-11	05.15	10-Nov-11	05.55	Bus Bar Protection Operated.
220KV	220/110KV 100 MVA ICT-II @ Miraj.	10-Nov-11	05.15	10-Nov-11	05.55	Bus Bar Protection Operated.
220KV	Phursungi -Theur - II	10-Nov-11	09.48	10-Nov-11	18.32	Replacement of Disc Insulator.
220KV	SPCL - IPCL	10-Nov-11	10.12	10-Nov-11	17.06	Testing Work.
220KV	Wadkhal-IPCL I	10-Nov-11	09.41	10-Nov-11	18.17	Ten Delta Measurment.
220KV	Chinchwad - Hinjewadi	10-Nov-11	10.31	10-Nov-11	18.35	Q.M.
220KV	Bhosari-Telco	10-Nov-11	09.30	10-Nov-11	15.01	Bus P T Connection Work.
220KV	Karad-Pophali	10-Nov-11	14.30	10-Nov-11	15.00	Distance Protection.
220KV	Pedambe-Pophali I	10-Nov-11	16.25	11-Nov-11	17.03	B Ph. L A Burst @ Pedambe.
220KV	Talangade - Mumewadi	10-Nov-11	16.58	10-Nov-11	17.16	Trip.
220KV	Mumewadi-Mudshingi	10-Nov-11	16.58	10-Nov-11	21.00	R Ph. L A Burst.

220KV	Bus Coupler @ Ghodbandar	10-Nov-11	09.06	10-Nov-11	14.56	Annual Maintenance.
220KV	220 KV TBC @ Koradi	10-Nov-11	09.30		Continued.	Breaker O/H Work.
220KV	220/132 KV 100 MVA ICT @ Shahada	10-Nov-11	13.10	10-Nov-11	18.25	Tan Delta of Bushing & Windings of 220/132KV,100 MVA ICT.
220KV	Wardha - Deoli (PGCIL)	11-Nov-11	06.22	11-Nov-11	18.22	Stringing Work of 400KV D/C C'pur-Wardha.
220KV	Bus Section - I @ Pedambe	11-Nov-11	07.22	11-Nov-11	17.00	Replacement of damaged wave trap work.
220KV	Pedambe - Mahad	11-Nov-11	06.50	11-Nov-11	17.11	Bus section outage.
220KV	Pedambe-Newkoyna	11-Nov-11	07.11	11-Nov-11	17.28	Bus section outage.
220KV	Versova - Goregaon	11-Nov-11	10.24	11-Nov-11	18.56	Civil work of GIS Building.
220KV	Badnera - Deoli (PGCIL)	11-Nov-11	06.28	11-Nov-11	18.17	Stringing work.
220KV	Jambul - Pal	11-Nov-11	09.15	11-Nov-11	18.20	R.M.Work
220KV	Padgha-Wada	11-Nov-11	08.28	11-Nov-11	18.21	Insulator replacement work.
220KV	Pophali-New Koyna	11-Nov-11	08.16	11-Nov-11	17.56	Conductor snapped at Pophali
220KV	Pedambe - Oni	11-Nov-11	08.10	11-Nov-11	08.50	Without indication.
220KV	Oni - Kharepatan	11-Nov-11	08.10	11-Nov-11	08.50	Without indication.
220KV	Kharepatan-Pawas	11-Nov-11	08.10	11-Nov-11	08.50	Without indication.
220KV	Mudshingi-Chikodi	11-Nov-11	11.40	11-Nov-11	12.48	R-Ph,E/F.
220KV	Nasik-Navsari -II	11-Nov-11	08.50	11-Nov-11	22.41	CT replacement.
220KV	Pedambe - Mahad	11-Nov-11	18.02	11-Nov-11	22.15	Distance Protection.
220KV	Hinganghat - Rly TSS - I	11-Nov-11	16.27	11-Nov-11	18.24	Main Bkr Problem(Ckt.is on TBC).
220KV	Wadkhal - Ndil - I	12-Nov-11	02.12		Continued.	Maintenance work(CT,PT replacement at Wadkhal end.)
220KV	Nagothane-Mahad	12-Nov-11	09.22	12-Nov-11	18.20	Making LILO arrangement for M/S POSCO.
220KV	Kalwa-Mulund II	12-Nov-11	09.43		Continued.	Replacement of breaker isolator .Line taken on TBC.
220KV	Versova - Goregaon	12-Nov-11	09.22	12-Nov-11	18.19	Civil works of GIS building near LILO Tower.
220KV	Karad-Pedambe	12-Nov-11	10.02	12-Nov-11	18.23	Preventive maintenance work.
220KV	Bus coupler at Lonikand.	12-Nov-11	10.44	12-Nov-11	17.57	To attend hot spot.
220KV	Wardha Power - Warora-I	12-Nov-11	11.08	12-Nov-11	15.20	To attend hot spot on B ph.isolator
220KV	Magarpatta-Sirum	12-Nov-11	10.20	12-Nov-11	12.30	Tan delta measurement work.
220KV	Wardha Power -Warora -II	12-Nov-11	15.45	12-Nov-11	18.38	To attend hot spot on CT jumper.
220KV	Versova-Boiser	12-Nov-11	16.10	12-Nov-11	18.29	Distance protection .
220KV	Nasik-Navsari-I	12-Nov-11	14.40	12-Nov-11	15.09	Distance protection Z-1.
220KV	Bus Section - I & II @ Trombay	12-Nov-11	22.58	13-Nov-11	06.20	Permanent jumpering to 220KV terminal of proposed Chembur line.
220KV	Kalwa-Trombay	12-Nov-11	22.32	13-Nov-11	06.48	Bus section outage I and II.
220KV	Tifil-Trombay	12-Nov-11	22.40	13-Nov-11	07.03	Bus section outage I and II.
220KV	Sonkhar-Trombay	12-Nov-11	22.44	13-Nov-11	06.58	Bus section outage I and II.
220KV	220/100KV 200MVA ICT-III at Trombay	12-Nov-11	22.48	13-Nov-11	07.23	Bus section outage I and II.
220KV	220/100KV,200 MVA ICT-II at Trombay.	12-Nov-11	22.36	13-Nov-11	07.15	Bus section outage I and II.
220KV	Trombay - Tata Tie - II	12-Nov-11	22.55	13-Nov-11	06.41	Bus section outage I and II.
220KV	Girwali - Parbhani	12-Nov-11	14.59	12-Nov-11	18.09	To attend oil leakage on R ph CT.
220KV	Chandrapur - Warora	12-Nov-11	22.49	13-Nov-11	16.25	For system stability.
220KV	220/100KV,200MVA ICT-I at Borivali.	13-Nov-11	09.05	13-Nov-11	13.20	Alignment of isolator and R.M.Work
220KV	Bhoisor-Bhoisor(PGCIL)-I	13-Nov-11	07.14	13-Nov-11	16.15	For stringing of Boiser PG-Padgha line through new draft tower.
220KV	Vita - Pandharpur	13-Nov-11	19.29	13-Nov-11	19.43	Distance protection.
132KV	Malegaon-Patur	7-Nov-11	11.22	7-Nov-11	12.03	Distance Protection.
132KV	Chikali - Mehkar	7-Nov-11	11.22	7-Nov-11	11.40	Tripped on Backup Protection.
132KV	Paras-Patur	7-Nov-11	11.11	7-Nov-11	12.03	Distance protection operated Zone-2 R ph and Y ph.
132KV	Pusad - Umarkhed	8-Nov-11	17.03	8-Nov-11	17.08	Backup Over Current
132KV	Degaon - Mandrup	8-Nov-11	06.15	8-Nov-11	06.25	Transient Fault
132KV	Bhandara - Madgi -I	8-Nov-11	00.05	8-Nov-11	00.22	Distance Protecion
132KV	Kallamb - Bhoom	8-Nov-11	09.55	8-Nov-11	14.50	Stringing work for Paranda Line

132KV	Pardi- Besa	8-Nov-11	10.20	8-Nov-11	12.32	To attend Hot Spot
132KV	Chikhali - Dhad	9-Nov-11	08.37	9-Nov-11	10.56	Distance Protection Operated Z-I B Ph.
132KV	Harangul-Chakur	9-Nov-11	12.55	9-Nov-11	13.05	Tripped on O/C E/F.
132KV	Padegaon-Sawangi	9-Nov-11	15.05	9-Nov-11	18.14	Dist.Prot.Operated Z-I R Y Ph.
132KV	Chalisgaon - Kannad	10-Nov-11	12.41	10-Nov-11	12.49	FTR Freq. 49.7 (Ckt was on no Load)
132KV	Paras-Malkapur	10-Nov-11	14.25	10-Nov-11	14.43	Distance Protection Operated Z-I Y Ph.
132KV	Pench - Kanhan	10-Nov-11	18.54	11-Nov-11	02.07	To control Kanhan ICT loading .
132KV	Khapri - Besa	10-Nov-11	09.10		Continued.	Height Raising of 132 KV Ambazari-Pardi
132KV	Ambazari-Pardi	10-Nov-11	08.49		Continued.	Height Raising of 132 KV Ambazari-Pardi
132KV	Butibori MIDC - Khapri - II	11-Nov-11	11.21	11-Nov-11	13.27	To attend Hot Glow at Loc.no 2.
132KV	Pench - Kanhan	12-Nov-11	00.01	12-Nov-11	16.55	H/T.
132KV	Pench - Kanhan	12-Nov-11	23.04	13-Nov-11	17.10	To control generation.
132KV	Paras-Patur	13-Nov-11	05.57	13-Nov-11	06.14	Tripped O/C.
132KV	Malegaon - Mehekar	13-Nov-11	05.57	13-Nov-11	06.29	Tripped.
132KV	Malegaon-Resod	13-Nov-11	05.57	13-Nov-11	06.30	Tripped.
132KV	Pench - Kanhan	13-Nov-11	23.54		Continued.	Hand Tripped.
110KV	Borivali(T)-Borivali(M)-I	13-Nov-11	07.28	13-Nov-11	19.00	To facilitate Stringing of conductor of 220KV 220KV Bo-B0-5 line.
100KV	Kalwa - Salsette - II	9-Nov-11	14.48	9-Nov-11	14.54	Earth Fault.
100KV	Borivali-Tata-II	13-Nov-11	15.20	13-Nov-11	16.05	To facilitate stringing of conductor of 220KV Bo-Bo line.