

LINE OUTAGES FOR THE WEEK

FROM 6-Dec-10 TO 12-Dec-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE II - CHDPR	8-Dec-10	23:38	9-Dec-10	01:51	Opportunity outage availed to replace MCB in control cabinet of T/F.
400KV	400/220 KV315 MVA ICT-I @ BBLR	2-Dec-10	10.46	10-Dec-10	22.15	For repl.of 33 KV bushing of R,Y,and B ph.
400KV	Dhule - S'Sarovar- II	2-Dec-10	17.11	10-Dec-10	17.38	Over Voltage.
400KV	Kolhapur - Mapusa - II	4-Dec-10	23.14	6-Dec-10	09.08	Over Voltage.
400KV	Bhusawal- Aurangabad	5-Dec-10	23.46	6-Dec-10	07.49	Over Voltage.
400KV	Karad - Kolhapur - II	5-Dec-10	23.42	6-Dec-10	13.05	Over Voltage.
400KV	Bblswr - Padgha - II	6-Dec-10	03.02	6-Dec-10	07.54	Over Voltage.
400KV	Karad - Kolhapur - II	6-Dec-10	22.40	7-Dec-10	08.46	Over Voltage.
400KV	Kolhapur - Mapusa - I	6-Dec-10	09.14	13-Dec-10	16.06	Over Voltage.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	6-Dec-10	22.40	7-Dec-10	00.40	Oil Top Up work.
400KV	Wardha - Akola - I	6-Dec-10	23.13	15-Dec-10	16.31	Over Voltage.
400KV	Bhusawal- Aurangabad	6-Dec-10	21.55	7-Dec-10	05.54	Over Voltage.
400KV	Babaleshwar - Dhule - I	7-Dec-10	00.29	7-Dec-10	05.26	Over Voltage.
400KV	Karad-Lamboti	7-Dec-10	06.55	7-Dec-10	19.59	Erection of Tower for 400KV Jaigad-Karad D/C line.
400KV	Bablswr-Padgha Ckt I	7-Dec-10	10.47	7-Dec-10	12.03	Taken on TBC.
400KV	Padgha - Nagothane- II	7-Dec-10	15.02	7-Dec-10	18.50	To attend hot spot.
400KV	Bhusawal- Aurangabad	7-Dec-10	22.20	8-Dec-10	05.39	Over Voltage.
400KV	Karad - Kolhapur - I	7-Dec-10	21.57	8-Dec-10	07.44	Over Voltage.
400KV	Akola - Aurangabad - II	7-Dec-10	10.52	7-Dec-10	18.00	For repl of oil pressure switch of Tie Bkr ; ckt was in service.
400KV	Dhule-S'Sarovar I	7-Dec-10	23.53	11-Dec-10	10.32	Over Voltage.
400KV	Karad-Lamboti	8-Dec-10	07.01	8-Dec-10	18.10	Erection of tower for 400KV Jaigad-karad D/C line.
400KV	Bhusawal- Aurangabad	8-Dec-10	22.16	9-Dec-10	05.46	Over Voltage.
400KV	Karad - Kolhapur - II	8-Dec-10	22.39	9-Dec-10	06.50	Over Voltage.
400KV	Nagothane-Dabhol-I	8-Dec-10	09.15	8-Dec-10	19.14	Cold washing of line insulator.
400KV	Karad-Lamboti	9-Dec-10	07.07	9-Dec-10	20.39	Insulator replacement work.
400KV	Nagothane-Dabhol-I	9-Dec-10	08.28	9-Dec-10	18.02	Cold washing of line insulator.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	9-Dec-10	15.15	9-Dec-10	17.23	Tightening of nut bolt of Y ph.33 KV PT.
400KV	Bhusawal- Aurangabad	9-Dec-10	21.54	10-Dec-10	05.16	Over Voltage.
400KV	Karad - Kolhapur - I	9-Dec-10	22.00	10-Dec-10	07.22	Over Voltage
400KV	400/220KV,500MVA ICT-III At Kalwa.	10-Dec-10	06.22	10-Dec-10	11.43	Attending Hot Spot on L V Side Jumper.
400KV	Dhule-Sar'Sarovar - II	10-Dec-10	22.44	13-Dec-10	10.31	Over Voltage.
400KV	Dabhol - Nagothane - I	10-Dec-10	08.15	11-Dec-10	07.55	Cold Washing of Insulator.
400KV	400/220 KV ICT - II @ Nagothane	10-Dec-10	08.11	10-Dec-10	20.03	Bay Maint. & Hot Spot Attending.
400KV	400/220KV 315MVA ICT- I @ Kharghar	10-Dec-10	10.51	12-Dec-10	22.12	Maintenance Work.
400KV	400/220KV 315 MVA ICT-I @ Padgha	10-Dec-10	17.13	10-Dec-10	19.00	Attending Hot Spot of L V Side Bushing.
400KV	Bhusawal- Aurangabad	10-Dec-10	20.29	11-Dec-10	05.36	Over Voltage.
400KV	Karad-Kolhapur-II	10-Dec-10	20.41	11-Dec-10	06.52	Over Voltage.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	11-Dec-10	00.08	11-Dec-10	01.34	Checking Oil Level.
400KV	Karad-Lamboti	11-Dec-10	07.12	11-Dec-10	19.03	Erection of Tower.
400KV	Nagothane-Dabhol-I	11-Dec-10	08.08	11-Dec-10	17.36	Cold Washing of Line Insulator.
400KV	Padgha - Nagothane- II	11-Dec-10	09.17	11-Dec-10	16.49	Bay Maint.Work.
400KV	Bhusawal- Aurangabad	11-Dec-10	21.20	12-Dec-10	05.42	Over Voltage.
400KV	Karad - Kolhapur - I	11-Dec-10	23.02	12-Dec-10	06.36	Over Voltage.
400KV	Karad-Lamboti	12-Dec-10	00.55	12-Dec-10	05.44	Over Voltage.
400KV	Lonikand- Koyna Stage IV	12-Dec-10	01.48	12-Dec-10	06.35	Over Voltage.
400KV	Dhule - Babhaleshwar - I	12-Dec-10	02.02	12-Dec-10	05.21	Over Voltage.
400KV	Lonikand - Parli - I	12-Dec-10	11.22	12-Dec-10	13.10	For Taking Recoctor I/S @ Parli End.
400KV	Dabhol - Nagothane - I	12-Dec-10	09.03	12-Dec-10	17.05	Cold Washing of Line Insulator.
400KV	Bhusawal- Aurangabad	12-Dec-10	20.00	13-Dec-10	05.59	Over Voltage.
400KV	Karad - Kolhapur - II	12-Dec-10	23.47	13-Dec-10	10.02	Over Voltage.

400KV	400/11.5KV 90 MVA STN T/F- V @ 400 KV	12-Dec-10	08.00		Continued.	To Attend Oil Leakage
220KV	220/100 125 MVA ICT - II @ Trombay	23-Aug-10	12.17	14-Dec-10	15.10	Dismantling of old ICT & commissioning of New 200MVA ICT
220KV	220/132KV 100MVA ICT-II @ Chalisgaon	8-Nov-10	11.10	8-Dec-10	17.45	Commissioning of new 200MVA ICT by replacing 100MVA ICT.
220KV	Main Bus - I @ Dahanu	3-Dec-10	09.03	6-Dec-10	23.05	Bus Maint.Work.
220KV	Kalmeshwar - Pandurna	5-Dec-10	19.01	6-Dec-10	13.47	Main Bkr PDR Problem.(Ckt is on TBC)
220KV	Main Bus - II Talangde	6-Dec-10	10.35	13-Dec-10	09.47	Alignment of isolator and testing work of equip.for 400 KV Solapur.
220KV	Kalwa-Colourchem	6-Dec-10	11.15	6-Dec-10	13.52	Distance Protection.
220KV	Temghar-Colourchem	6-Dec-10	11.15	6-Dec-10	13.52	Distance Protection.
220KV	Bus Section I at Kharepatan	6-Dec-10	13.20	6-Dec-10	17.10	Replacement of 220 KV PT.
220KV	Main Bus at Tilwani	6-Dec-10	11.25	6-Dec-10	17.53	Maintenance work.
220KV	Tilwani-Ichalkaranji	6-Dec-10	11.25	6-Dec-10	17.53	Stringing of conductor at Tilwani end.
220KV	Aurangabad-Chitegaon-I	6-Dec-10	07.15	6-Dec-10	13.19	Overhead stringing bet.Loc. 519 & 520 of 400 Kv D/C BSL-Waluj line.
220KV	Aurangabad-Chitegaon-II	6-Dec-10	07.16	6-Dec-10	13.19	Overhead stringing bet.Loc. 519 & 520 of 400 Kv D/C BSL-Waluj line.
220KV	Usmanabad-Barshi	6-Dec-10	19.55	6-Dec-10	21.15	Distance Protection Operated.
220KV	Nasik - Navasari - II	7-Dec-10	05.39	7-Dec-10	06.47	Dist.Prot.Z-I,B-Ph.
220KV	220/22KV,25 MVA T/F-II At Nagothane	7-Dec-10	09.00	7-Dec-10	17.30	Tan delta and bay maintenance work.
220KV	220/132 KV 50 MVA T/F @ Peth	7-Dec-10	09.40	7-Dec-10	17.30	Q.M.Work.
220KV	220/132KV 200 MVA ICT- II @ Amravati	7-Dec-10	09.20	7-Dec-10	11.00	To attend X'mer HV side B-Ph isolator problems.
220KV	Lonand - Jejuri	7-Dec-10	12.12	7-Dec-10	12.41	Distance protection.
220KV	220/132KV 100 MVA ICT II at Amalner	7-Dec-10	14.40	7-Dec-10	17.00	R & Y-Ph Testing work.
220KV	NASIK-NAVSARI-II	7-Dec-10	13.12	7-Dec-10	14.31	Distance protection.
220KV	Chandrapur-Chandrapur MIDC	7-Dec-10	15.25	7-Dec-10	17.35	To attend main Bkr gas flow pressure problem ckt.on TBC.
220KV	220/132KV 150 MVA ICT II @ Nasik	7-Dec-10	12.00	7-Dec-10	17.40	CTR testing work.
220KV	220/132KV,200 MVA T/F-I At Apta	7-Dec-10	11.28	7-Dec-10	17.20	Attending oil leakage B ph.of HV bushing.
220KV	220/132KV,200 MVA T/F-I At Nagar	7-Dec-10	14.50	9-Dec-10	11:59	Augmentation of 100 MVA ICT by 200 MVA ICT.
220KV	Malinagar-Temburni	7-Dec-10	19.35	7-Dec-10	20.27	Distance protection.
220KV	Apta-Nagothane	8-Dec-10	09.40	8-Dec-10	18.28	Replacement of Disc insulator.
220KV	220/132 KV 200 MVA ICT- I @ Bale	8-Dec-10	10.00	8-Dec-10	17.57	Repl.of R and Y Ph.of CT.
220KV	Kalwa - Salsket - IV	8-Dec-10	11.05	8-Dec-10	13.50	Taken on TBC to attend hot spot on 29A line insulator.
220KV	Main Bus II @ Versova	8-Dec-10	13.06	8-Dec-10	15.58	SF6 pressure low in isolator.
220KV	220 KV Interconnector @ Kalwa	8-Dec-10	15.12	8-Dec-10	16.55	Attending hot spot of isolaor.
220KV	Padgha - Boisar (PGCIL)	8-Dec-10	16.50	8-Dec-10	20.02	Distance protection.
220KV	MUDSHINGI-CHIKODI	8-Dec-10	14.07	8-Dec-10	18.35	Distance protection.
220KV	Talangde - Chikodi	8-Dec-10	14.15	8-Dec-10	15.20	Distance protection.
220KV	220 KV TBC @ Akola	8-Dec-10	09.35	9-Dec-10	11.10	Breaker overhaul.
220KV	220/132 KV,100 MVA ICT At Hinganghat	8-Dec-10	15.05	8-Dec-10	16.10	To attend oil leakage of CT.
220KV	Chandrapur-Wani	9-Dec-10	01.07	9-Dec-10	01.40	Distance protection.
220KV	Bhigwan-Kalyani	9-Dec-10	03.20	9-Dec-10	04.00	Distance protection.
220KV	Lonikand-Theur - I	9-Dec-10	08.08	9-Dec-10	13.35	Tan delta and 'C' measurement of CT.
220KV	Bhosari-Telco	9-Dec-10	10.11	9-Dec-10	13.57	Q.M.Work.
220KV	220/100KV,100 MVA T/F 4At K'gaon	9-Dec-10	10.50	11-Dec-10	13.22	LV side CB overhauling work.
220KV	Lonikand -Theur - II	9-Dec-10	13.37	9-Dec-10	17.00	Tan delta and C measurement work.
220KV	Kandalgaon - Dasturi	9-Dec-10	08.26	9-Dec-10	17.57	Replacement of disc insulator.
220KV	Kalwa-Mulund-I	9-Dec-10	18.20	10-Dec-10	02.01	Distance protection.(Y'Ph. LA burnt)
220KV	Kalwa - Borivali	9-Dec-10	18.20	9-Dec-10	18.41	Distance protection
220KV	Kalwa-Colourchem	9-Dec-10	18.20	9-Dec-10	18.44	Distance protection
220KV	Kalwa I-Kalwa II Inter connector	9-Dec-10	18.20	9-Dec-10	18.46	Distance protection
220KV	Borivali-Mulund	9-Dec-10	18.20	9-Dec-10	19.00	Distance protection
220KV	Pusad -Parbhani	9-Dec-10	11.07	9-Dec-10	17.34	Replacement of isolator rod of B ph.
220KV	Girivali - Parli - III	9-Dec-10	09.11	9-Dec-10	17.30	Replacement of LA.
220KV	220/132 KV 150 MVA ICT-I @ Akola.	9-Dec-10	13.38	10-Dec-10	12.55	Main Ckt.Breaker O/H work.
220KV	220/132 KV 50 MVA ICT @ Gadchiroli	9-Dec-10	13.14	9-Dec-10	15.14	To attend red hot spot.
220KV	220/132 KV,200 MVA T/F At Tilwani	9-Dec-10	13.25	9-Dec-10	17.23	Oil leakage work.
220KV	Karad - Miraj	10-Dec-10	01.50	10-Dec-10	09.54	Distance protection.

220KV	220/132KV,200MVA ICT-I at Malegaon	10-Dec-10	06.55	10-Dec-10	14.25	Conductor Replacement Work.
220KV	Pedambe-Tambati	10-Dec-10	08.27	10-Dec-10	18.15	Replacement of Insulators Conductors.
220KV	220/132 200 MVA ICT @ Boiser	10-Dec-10	09.13	10-Dec-10	17.42	Q.M.Work.
220KV	Babaleshwar - Ranjangaon	10-Dec-10	10.14	10-Dec-10	15.50	Replacement of Insulators.
220KV	Wada-Kolshet	10-Dec-10	09.45	10-Dec-10	19.11	Tend Measurment C B Overhauling Work.
220KV	Babhaleshwar-Nasik-II	10-Dec-10	10.40	11-Dec-10	19.22	Replacement of 20 C Isolator Under LB's.
220KV	Jambul - Pal	10-Dec-10	10.37	10-Dec-10	20.15	Relay Retrofitting Work @ Pal.
220KV	Padgha-Wada	10-Dec-10	14.30	10-Dec-10	14.58	Distenace Protection,V T Supply Fail.
220KV	Kalwa - Salshet - III	10-Dec-10	23.10	11-Dec-10	02.11	Replacement of B Ph C T Jumper.
220KV	Kalwa - Salshet - IV	11-Dec-10	02.11	11-Dec-10	05.06	Attending Hot Spot on 29D Isolators C T Clamp.
220KV	Kalwa - Ghatghar	11-Dec-10	09.51	11-Dec-10	16.50	Replacement of Insulator.
220KV	Babaleshwar - Babaleshwar - II	11-Dec-10	10.10	11-Dec-10	10.50	Replacement of Bus Isolator.
220KV	220/132 KV 200 MVA ICT - V @ Nasik (OC	11-Dec-10	09.20	11-Dec-10	17.20	Testing Work.
220KV	Pophali-K'gaon	11-Dec-10	08.40	11-Dec-10	17.30	Replacement of Insulator Strings.
220KV	Karad-Pedambe	11-Dec-10	12.54	11-Dec-10	13.25	Distanese Protection.
220KV	Main Breaker of 220/132KV 150MVA ICT-II	12-Dec-10	10.15	12-Dec-10	16.15	Breaker Overhaul (ICT HV side on TBC)
220KV	Kalwa-Mulund-I	12-Dec-10	06.11	12-Dec-10	12.01	To Attend Red Hot on Loc.No.38.
220KV	Pedambe-Pophali I	12-Dec-10	08.55	12-Dec-10	17.50	C T Meggering Work.
220KV	Kandalgaon - Topworth	12-Dec-10	09.18	12-Dec-10	19.36	Replacement of Insulator String.
220KV	220/100 KV 125MVA ICT-II @ Borivali	12-Dec-10	09.12	12-Dec-10	10.47	Attending Red Hot Spot.
220KV	220/100 KV ICT- III @ Borivali	12-Dec-10	10.52	12-Dec-10	13.11	Attending Red Hot Spot.
220KV	Trombay Sonkhar	12-Dec-10	12.10	12-Dec-10	19.19	Replacement of Insulator.
220KV	Bhugaon-Pusad	12-Dec-10	05.34	12-Dec-10	06.20	Distenace Protection.
220KV	Purti - Bhugaon	12-Dec-10	07.10	12-Dec-10	08.01	Distenace Protection.
220KV	Boiser PGCIL-Boiser II	12-Dec-10	11.19	12-Dec-10	14.50	Attending Hot Spot.
220KV	Babaleshwar - Ranjangaon	12-Dec-10	23.01	13-Dec-10	01.25	Distance Protection.
220KV	Badnera - Akola - I	12-Dec-10	16.25	12-Dec-10	18.35	Main CB SF6 Gas Pressure Switch Setting Work.
220KV	Purti - Bhugaon	12-Dec-10	08.01	12-Dec-10	14.20	To Attend Main CB PDR Problem.Ckt Was on TBC.
132KV	Harangul - Ujani - I	7-Dec-10	08.55	7-Dec-10	22.05	Replacement of CC.
132KV	Harangul-Ujani-II	8-Dec-10	10.45	8-Dec-10	18.35	Replacement of CC and WT balance work.
132KV	Parbhani-Jintur	9-Dec-10	02.47	9-Dec-10	03.12	Distance protection.
132KV	132 K V Bus @ Malegaon	10-Dec-10	11.15	10-Dec-10	14.25	Connecting Jumpers.
132KV	Kurkumbh - Daund	10-Dec-10	17.00	10-Dec-10	18.00	B Ph C T TO Isolator Jumper Opened @ Kurkumbh.
110KV	Miraj-Vishrambag.	7-Dec-10	11.07	7-Dec-10	13.55	Double string insulator repl.work.
110KV	Ogalewadi - Pandharpur	12-Dec-10	23.03	12-Dec-10	23.10	Distenance Protection.
100KV	Kalwa - Salshet - I	4-Dec-10	10.50	11-Dec-10	09.28	CB Opened @ Salset End,For Outage of Salset Bay.
100KV	Kandalgaon-Roha-I	7-Dec-10	09.15	8-Dec-10	23.11	Ckt.Breaker overhauling work.
100KV	Chinchwad - Talegaon	9-Dec-10	08.47	9-Dec-10	17.14	Tower errection work.
100KV	100 KV Bus @ Kalwa - I	10-Dec-10	09.00	10-Dec-10	17.37	Isolator Replacement Work.
100KV	Kalwa - Salshet - I	11-Dec-10	17.59	12-Dec-10	08.45	H/T From Kalwa end
100KV	Chinchwad - Talegaon	12-Dec-10	09.22	12-Dec-10	09.32	Distenace Protection.
100KV	Kalwa - Salshet - I	12-Dec-10	16.30		Continued.	Hand Tripped,From Kalwa End.