

LINE OUTAGES FOR THE WEEK

FROM 12-Dec-11 TO 18-Dec-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Parli-Parli (PGCIL) I	19-Oct-11	21.40	13-Dec-11	13.03	Over Voltage.
400KV	Karad-Kolhapur-II	11-Dec-11	16.03	13-Dec-11	10.38	Over Voltage.
400KV	Dhule - S'Sarovar- II	11-Dec-11	16.22	12-Dec-11	14.36	Over Voltage.
400KV	Bhusawal- Aurangabad	11-Dec-11	20.08	12-Dec-11	07.50	Over Voltage.
400KV	Kolhapur - Mapusa - I	11-Dec-11	21.34	12-Dec-11	10.11	Over Voltage.
400KV	Bhusawal- Aurangabad	12-Dec-11	20.28	13-Dec-11	07.21	Over Voltage.
400KV	Koradi-Bhilai	12-Dec-11	14.43	12-Dec-11	19.52	Due to own breaker problem, Line on TBC. NO INTERRUPTION.
400KV	Dhule-Sar'Sarovar - I	12-Dec-11	16.51	14-Dec-11	07.33	Over Voltage.
400KV	Kolhapur - Mapusa - I	12-Dec-11	16.49	13-Dec-11	09.35	Over Voltage.
400KV	400/220,105MVA Spare ICT at Kharghar	12-Dec-11	15.50	12-Dec-11	15.58	Charged from HV side only.
400KV	400/220KV 315 MVA ICT-I @ Padgha	13-Dec-11	00.09	13-Dec-11	01.57	Attend oil leakage OLTC pipe line in B bus unit.
400KV	400/220 KV 315 MVA ICT-III @ Padgha	13-Dec-11	20.12	14-Dec-11	09.25	R Phase Stubbus Jumper of 220KV B Bus Open
400KV	400/220KV 315 MVA ICT- II @ Padgha	13-Dec-11	20.12	13-Dec-11	21.13	Bus Fault
400KV	400/220KV 315 MVA ICT-I @ Padgha	13-Dec-11	20.12	13-Dec-11	21.07	Bus Fault
400KV	Bhusawal- Aurangabad	13-Dec-11	20.26	14-Dec-11	09.52	Over Voltage
400KV	Dabhol - New Koyna - I	13-Dec-11	21.33	13-Dec-11	22.16	Tie Breaker Lockout at Dabhol end
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	13-Dec-11	08.00	13-Dec-11	12.56	For Thermo Scanning of ICT-I and III
400KV	400/220KV 315MVA ICT-III at Karad.	13-Dec-11	09.07	13-Dec-11	22.08	HV side LA replace
400KV	Padgha - Nagothane- II	13-Dec-11	09.30	13-Dec-11	19.05	CB Preasure not Builing(taken on TBC)
400KV	80 MVAR Reactor @ Kharghar	13-Dec-11	09.45		Continued.	Replacement of Bushing(upto 17/12/2011)
400KV	400/220 KV 315 MVA ICT- I @ Nagothane	13-Dec-11	12.56	13-Dec-11	20.32	Testing and R.M.Work
400KV	Karad - Newkoyna - I	13-Dec-11	07.56	13-Dec-11	08.04	Transient Fault
400KV	400/220KV,315MVA ICT-I at Karad	13-Dec-11	07.56	13-Dec-11	08.38	Tripped on PDR
400KV	Koradi-Bhilai	13-Dec-11	11.35	13-Dec-11	12.32	Taken on TBC
400KV	Kolhapur - Mapusa - II	13-Dec-11	17.08	14-Dec-11	09.35	Over Voltage
400KV	400/132KV,200MVA ICT-I at Khadka.	13-Dec-11	20.28	14-Dec-11	13.25	Trip Ckt Faulty Ind.(ICT is on TBC)
400KV	Karad - Kolhapur - I	14-Dec-11	00.07	14-Dec-11	09.23	Over Voltage
400KV	Dhule - S'Sarovar- II	14-Dec-11	10.08	16-Dec-11	10.40	Over Voltage
400KV	Karad - Kolhapur - II	14-Dec-11	16.24	15-Dec-11	09.03	Over Voltage
400KV	400/220 KV 315 MVA ICT- I @ Nagothane	14-Dec-11	16.28	14-Dec-11	18.52	Repl.of Numerical Relay replacement
400KV	Bhusawal- Aurangabad	14-Dec-11	21.26	15-Dec-11	05.56	Over Voltage
400KV	Lonikand - Jejuri	15-Dec-11	08.06	15-Dec-11	17.14	Attending Hot Spot.
400KV	Kolhapur - Mapusa - I	15-Dec-11	00.07	15-Dec-11	09.13	Over Voltage
400KV	400/220 KV 315 MVA ICT- II @ Chakan	15-Dec-11	10.06	15-Dec-11	16.34	To Attend Red Hot.
400KV	400/220KV,200MVA Spare ICT at Kalwa.	15-Dec-11	14.59		Continued.	For Replacement of Y Ph. C T of ICT-I by 400KV C T of Spare ICT.
400KV	Bhusawal- Aurangabad	15-Dec-11	20.30	16-Dec-11	07.22	Over Voltage.
400KV	Kolhapur-Mapusa-II	15-Dec-11	21.00	16-Dec-11	19.23	Over Voltage
400KV	400/220KV 315 MVA ICT- II @ Padgha	15-Dec-11	09.45	15-Dec-11	18.13	B Ph.Tershary L A Burst.
400KV	New Koyna - Stage IV	15-Dec-11	16.20	15-Dec-11	18.52	Over Voltage.
400KV	400/220KV,315MVA ICT-I at Karad	15-Dec-11	18.00	15-Dec-11	18.24	No Indication.
400KV	Karad - Newkoyna - I	15-Dec-11	18.00	15-Dec-11	18.16	No Indication.
400KV	Karad - Kolhapur - II	16-Dec-11	16.24	18-Dec-11	09.00	Over Voltage.
400KV	Karad - Kolhapur - I	16-Dec-11	00.52	16-Dec-11	09.45	Over Voltage.
400KV	Dhule - S'Sarovar- II	16-Dec-11	16.52		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	16-Dec-11	20.18	17-Dec-11	04.52	Over Voltage.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	16-Dec-11	07.58	16-Dec-11	19.19	Replacement of 400KV Y-Ph CT and 33KV PT of tertiary delta.
400KV	400 KV Main Bus - I @ Aurangabad	16-Dec-11	10.39	16-Dec-11	21.17	Dismantling of Y-Ph W/T of Deepnagar II.
400KV	Kolhapur - Mapusa - I	16-Dec-11	21.57	17-Dec-11	09.30	Over Voltage.

400KV	Padgha-Tarapur - II	16-Dec-11	09.18	16-Dec-11	19.24	Q.M.Work
400KV	Koradi -Bhusawal	16-Dec-11	11.19	16-Dec-11	15.22	Repl of broken springs of seizer of B-Ph PG isolator of Aux.Bus.
400KV	400/220KV 500MVA ICT- I at Khaperkheda	16-Dec-11	11.57		Continued.	Due to CTR low nitrogen pressure alarm received.
400KV	Parly(PG) - Wardha (PG) - I	16-Dec-11	22.06		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	17-Dec-11	20.03	18-Dec-11	07.11	Over Voltage.
400KV	Kolhapur - Mapusa - II	17-Dec-11	19.43		Continued.	Over Voltage.
400KV	Babaleshwar - Dhule - II	17-Dec-11	11.06	17-Dec-11	18.38	Providing 5 No.of Missing Spacers Between Loc no. 219-227.
400KV	400/220 KV 100 MVA Spare Unit @ Koradi	17-Dec-11	20.32		Continued.	Buccolz Alarm.
400KV	Karad - Kolhapur - I	18-Dec-11	09.23	18-Dec-11	11.40	To attend red hot.
400KV	Karad - Kolhapur - I	18-Dec-11	16.08		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	18-Dec-11	20.07		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	18-Dec-11	23.17		Continued.	Over Voltage.
220KV	Hinganghat - Rly TSS - I	9-Dec-11	02.03	14-Dec-11	17.05	CKT on TBC, CKT breaker timing problem.
220KV	Chandrapur - Warora	9-Dec-11	01.44	18-Dec-11	12.44	Hand trip.
220KV	Mudsinghi - Mumewadi - I	12-Dec-11	09.45	12-Dec-11	15.20	Making cut point for Kolhapur-phonda line LILO at Hamidwada.
220KV	Versova-Gorai	12-Dec-11	09.04	12-Dec-11	17.05	Annual maintenance.
220KV	220/100 KV,200 MVA ICT-I @ Apta	12-Dec-11	12.01	12-Dec-11	17.38	Differential and B/U relay replacement work.
220KV	220/100KV 200MVA ICT-I at Kalwa	12-Dec-11	13.51	12-Dec-11	16.40	Testing work and taken on own breaker.
220KV	Mudshingi-Wathar	12-Dec-11	14.05	12-Dec-11	21.05	Q.M.Work.Isolator problem at Wathar end.
220KV	Talandge-Halkarni	12-Dec-11	09.45	12-Dec-11	15.20	Making cut point for Kolhapur-phonda line LILO at Hamidwada.
220KV	Padgha - Boisar (PGCIL)	13-Dec-11	20.12	13-Dec-11	22.42	Bus Fault
220KV	Padgha-Wada	13-Dec-11	20.12	13-Dec-11	21.29	Bus Fault
220KV	Padgha-Kamba	13-Dec-11	20.12	13-Dec-11	21.30	Bus Fault
220KV	Padgha-Jambhul II	13-Dec-11	20.12	13-Dec-11	21.14	Bus Fault
220KV	Padgha - Nalasopara	13-Dec-11	20.12	13-Dec-11	22.40	Bus Fault
220KV	Padgha-Jambhul	13-Dec-11	20.12	13-Dec-11	21.12	Bus Fault
220KV	Padgha - Temghar - II	13-Dec-11	20.35	15-Dec-11	09.27	H/T due to Bus Fault
220KV	Padgha-Temghar I	13-Dec-11	20.35	14-Dec-11	09.44	H/T due to Bus Fault
220KV	Padgha-Jambhul-I	13-Dec-11	20.12	13-Dec-11	21.56	Bus Fault
220KV	220KV A Bus at Padgha	13-Dec-11	20.12	13-Dec-11	21.07	Bus Fault
220KV	220KV B Bus at Padgha	13-Dec-11	20.12	14-Dec-11	11.40	Bus Fault
220KV	Gadchandur-Virur-II	13-Dec-11	11.44	13-Dec-11	16.18	Tan Delta Measurement
220KV	Apta - Taloja	13-Dec-11	16.56	13-Dec-11	19.56	R phase L.A.Burst
220KV	220/22KV 50 MVA T/F -I at Padgha	13-Dec-11	20.12	13-Dec-11	21.16	Bus Fault
220KV	220/22KV 50 MVA T/F -II at Padgha	13-Dec-11	20.12	13-Dec-11	21.17	Bus Fault
220KV	Karad - Ogalewadi - II	13-Dec-11	12.35	13-Dec-11	17.42	Replacement of Insulator
220KV	Apta - Tambati	13-Dec-11	10.43	13-Dec-11	18.25	Tan Delta measurement
220KV	Padghe - Nashik - II	13-Dec-11	20.12	13-Dec-11	21.23	Bus Fault
220KV	Aarey - Goregaon	13-Dec-11	09.27	14-Dec-11	00.44	Annual Maint.Work
220KV	220/100KV 200 MVA ICT III at Borivali	13-Dec-11	12.30	17-Dec-11	22.30	Air Leakage problem of Breaker(Taken on TBC)
220KV	220/100KV 200 MVA ICT- II @ Padgha	13-Dec-11	20.12	13-Dec-11	21.19	Bus Fault
220KV	220/100KV 200 MVA ICT- III @ Padgha	13-Dec-11	20.12	13-Dec-11	21.17	Bus Fault
220KV	220/100KV 200 MVA ICT-I at Padgha	13-Dec-11	20.12	13-Dec-11	21.21	Bus Fault
220KV	220/100KV 200 MVA ICT-IV at Padgha	13-Dec-11	20.12	13-Dec-11	21.36	Bus Fault
220KV	Talangade - Mumewadi	14-Dec-11	08.29	14-Dec-11	17.28	LILO Work
220KV	Ghodbhundur - Gorai	14-Dec-11	09.47	14-Dec-11	16.04	To attend heavy oil leakage from R phase CVT
220KV	Pawas-Kharepatan	14-Dec-11	12.45	14-Dec-11	13.48	To attend Red Hot on B phase C.B.
220KV	220/132 KV 100 MVA ICT - I @ Bale	14-Dec-11	09.25	14-Dec-11	19.56	C.T.Upgradation
220KV	Chinchwad - Parvati	14-Dec-11	17.56	14-Dec-11	18.01	No Indication

220KV	Jejuri - Parvati	14-Dec-11	17.56	14-Dec-11	18.28	Overload
220KV	Bus Sectionlizer Breaker at C'Wad	14-Dec-11	17.56	14-Dec-11	18.01	Breaker Tripped No Indication
220KV	Lonikand-Khadki	15-Dec-11	08.48	15-Dec-11	16.40	Making LILO Arrangment.
220KV	Bus Coupler @ Varsoa	15-Dec-11	09.08	15-Dec-11	13.57	Annual Maint.Work.
220KV	Padgha-Temghar I	15-Dec-11	09.32	15-Dec-11	19.06	Red Hot Y Ph. C T Clamp.
220KV	Bus Section at Maggerpatta	15-Dec-11	10.25	15-Dec-11	13.31	Isolator Maintenance.
220KV	220 KV Bus @ Tillary	15-Dec-11	08.57	15-Dec-11	19.10	Replacement of Air Blast C B by SF6 Breaker.
220KV	Halkarni -Tillary	15-Dec-11	08.55	15-Dec-11	19.10	Bus Maintenance Work @ Tillary.
220KV	Tillary-Amona	15-Dec-11	08.57	15-Dec-11	19.19	Bus Maintenance Work @ Tillary.
220KV	Theur - Magarpatta	15-Dec-11	10.15	15-Dec-11	13.55	Bus Outage @ Magarpatta Shifted on TBC.
220KV	Bus section at 220KV Chinchwad.	15-Dec-11	06.40	15-Dec-11	17.56	Commissioning 220KV Hybrid Pass Bus Sectionlizer.
220KV	220/132KV 200 MVA ICT I at Chalisgaon	15-Dec-11	12.33	15-Dec-11	18.41	Tandelta Mesurment of Bushing, C T SFRA Testing & Maint.Work.
220KV	Wardha-Badnera	15-Dec-11	18.10	15-Dec-11	19.07	To Attend Oil Leakage of C V T.
220KV	BBLSR-Chalisgaon	15-Dec-11	13.39	17-Dec-11	14.03	Converting S/C to D/C.
220KV	220/132 KV,100 MVA ICT At Hinganghat	15-Dec-11	11.30	15-Dec-11	16.42	Measurment of Tan Delta of C T.
220KV	Virur - Gadchiroli	15-Dec-11	10.30	15-Dec-11	15.05	Measurment of Tan Delta of C T.
220KV	Amalner-Deepnagar	15-Dec-11	05.55	15-Dec-11	08.25	Distance Protection Operated Z-I Y Ph.
220KV	220 KV Road side Bus @ Kalwa	16-Dec-11	06.56	16-Dec-11	16.32	Repl of single core conductor by twin core conductor in B-Ph bus.
220KV	Kalwa-Temghar	16-Dec-11	05.40	16-Dec-11	18.05	Due to bus outage at 220KV Kalwa.
220KV	Kalwa-Taloja	16-Dec-11	05.42	16-Dec-11	17.42	Due to bus outage at 220KV Kalwa.
220KV	220/22 KV, 50 MVA T/F-II @ Kalwa	16-Dec-11	05.48	16-Dec-11	17.10	Due to bus outage at 220KV Kalwa.
220KV	220/100KV 200MVA ICT-IV at Kalwa	16-Dec-11	05.54	16-Dec-11	16.53	Due to bus outage at 220KV Kalwa.
220KV	Dhule-Chalisgaon	16-Dec-11	09.22	16-Dec-11	16.36	Erection of W/T.
220KV	Wada-Kolshet	16-Dec-11	09.27	16-Dec-11	20.08	Replacement Of B & R Ph CT's.
220KV	KDPH-Wankuswadi	16-Dec-11	10.50	16-Dec-11	18.15	Maintenance work.
220KV	Tillari-Amona-II	16-Dec-11	13.30	16-Dec-11	15.25	Air leakage problem at Amona.
220KV	220/132 KV 200 MVA ICT -IV. at Padegaon	16-Dec-11	10.10	16-Dec-11	17.14	Minor oil leakage from turret and Q.M.Work.
220KV	220/132KV 100MVA ICT-II at Virur	16-Dec-11	16.15	16-Dec-11	18.28	Measurement of tan delta of ICT bushings.
220KV	220/132KV 200MVA ICT-II at Dhule	17-Dec-11	15.01	17-Dec-11	18.26	Attending Oil Leakages of ICT, Testing of Tan Delta of ICT Bushing.
220KV	220/132KV 100 MVA ICT- II @ Peth	17-Dec-11	09.26	17-Dec-11	14.10	R.M.Work.
220KV	Borivali-Mulund	17-Dec-11	10.12	17-Dec-11	20.12	Through Fault Stability of Cable & Removing of LILO Jumper.
220KV	Apta - Taloja	17-Dec-11	11.07	17-Dec-11	13.35	L A Replacement Work.
220KV	Malegaon - Satana - II	17-Dec-11	09.23	17-Dec-11	14.47	Replacement of Faulty Disc.
220KV	220/132KV 200MVA ICT-I @ Raymond	17-Dec-11	10.08	17-Dec-11	17.29	Q.M.Work.
220KV	Babaleshwar - Babaleshwar - II	17-Dec-11	12.21	17-Dec-11	15.11	Tan Delta Measurment.
220KV	220/132KV,200 MVA ICT-I at Dhule	17-Dec-11	09.44	17-Dec-11	14.24	Attending Oil Leakages of ICT, Testing of Tan Delta of ICT Bushing.
220KV	BBLSR-Chalisgaon	17-Dec-11	14.03	17-Dec-11	22.46	Distance Protection Operated Z-3 B Ph.
220KV	220/100KV,200MVA ICT-I at Borivali.	17-Dec-11	23.14	18-Dec-11	02.40	Insulator Fixing for 6 No's of 220KV Cable Termination.
220KV	Borivali-Tata Borivali 4	17-Dec-11	23.18	18-Dec-11	02.54	Insulator Fixing for 6 No's of 220KV Cable Termination.
220KV	Mulund - Bhandup (GIC)	17-Dec-11	10.12	17-Dec-11	20.07	Mulund-Borivali Made LILO @ Bhandup GIC
220KV	Borivali - Bhandup (GIC)	17-Dec-11	10.12	17-Dec-11	20.10	Mulund-Borivali Made LILO @ Bhandup GIC
220KV	Borivali - Bhandup (GIC)	17-Dec-11	23.20	18-Dec-11	02.48	Insulator Fixing for 6 No's of 220KV Cable Termination.
220KV	Borivali-Tarapur	18-Dec-11	00.05	18-Dec-11	02.37	Insulator Fixing for 6 No's of 220KV Cable Termination.
220KV	Bus section-I At Borivali.	18-Dec-11	00.15	18-Dec-11	02.37	Insulator Fixing for 6 No's of 220KV Cable Termination.
220KV	220/33 KV 100 MVA T/F - III @ Ghanthandur	18-Dec-11	08.20	18-Dec-11	17.41	R.M.Work.
220KV	Dahanu-Versova	18-Dec-11	08.56	18-Dec-11	15.55	R.M.Work
220KV	220/33KV,125MVA T/F-V at Aarey.	18-Dec-11	08.45	18-Dec-11	13.13	R.M.Work.
220KV	Trombay - Salsett - I	18-Dec-11	06.11	18-Dec-11	21.48	Conductor diversion work.
220KV	Chandrapur - Warora	18-Dec-11	16.06		Continued.	To control Warora-Wardha and Warora-Hinghat line loading.

132KV	Girwali - Kej	6-Dec-11	18.30	14-Dec-11	10.00	Replacement of 132KV Breaker @ Girwali.Ckt on TBC.
132KV	Bus Section -II at Boiser	16-Dec-11	09.07	16-Dec-11	18.55	Replacement of 132KV line and bus isolator.
132KV	Ujani-Umarga	16-Dec-11	22.30	16-Dec-11	22.45	Distance protection.
132KV	Boisar(MIDC)-Dahanu - I	17-Dec-11	11.25	17-Dec-11	12.12	Hot Spot Attending Work.
132KV	Dhule-Sakri	17-Dec-11	09.00	17-Dec-11	17.23	Armouring of Y & B Ph. Conductor & Repl of Disc Insulator@Loc.35.
110KV	Borivali(T)-Borivali(M)-II	18-Dec-11	08.32	18-Dec-11	19.51	To facillitate work on DF of 220KV Bo-Bo-V.
100KV	Bus section @ Kolshet	16-Dec-11	11.11	16-Dec-11	16.36	Hot Spot.