

LINE OUTAGES FOR THE WEEK

FROM 17-Jan-11 TO 23-Jan-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole II Padgha	19-Jan-11	20.28	20-Jan-11	00.56	Attending Oil leakage of B-Ph convertor transformer.
500KV	HVDC Pole II Padgha	20-Jan-11	18.02	20-Jan-11	20.06	Converter Transformer Tripped At Padghe end.
400KV	50 MVAR Reactor 400 KV Koradi Ckt-I @ E	14-Jan-11	18.48	17-Jan-11	21.36	Oil Filtration work
400KV	Karad - Kolhapur - II	16-Jan-11	21.47	17-Jan-11	06.19	Over Voltage.
400KV	Kolhapur - Mapusa - I	16-Jan-11	21.44	17-Jan-11	07.20	Over Voltage.Taken on TBC @ 03.52 Due to Bkr Problem @ Kolhapur
400KV	Dhule-Sar'Sarovar - I	16-Jan-11	21.46	17-Jan-11	12.19	Over Voltage.
400KV	Bhusawal- Aurangabad	16-Jan-11	20.35	17-Jan-11	07.28	Over Voltage.
400KV	Akola - Wardha - II	16-Jan-11	21.46	18-Jan-11	12.38	Over Voltage.
400KV	Dabhol - New Koyna - I	17-Jan-11	08.17	17-Jan-11	18.06	Cold Line Washing of Insulators.
400KV	Karad - Kolhapur - II	17-Jan-11	11.05	17-Jan-11	17.45	Faulty Insulator Replacement.
400KV	Bhusawal- Aurangabad	17-Jan-11	14.34	17-Jan-11	14.49	Direct Trip Received @ Bhusawal.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	17-Jan-11	16.28	17-Jan-11	16.55	To Attend Buchholz Alaram Indication.
400KV	Bhusawal- Aurangabad	17-Jan-11	20.42	18-Jan-11	05.25	Over Voltage.
400KV	Koradi - Bhusawal	17-Jan-11	21.17	17-Jan-11	21.36	To Take Reactor in Service.
400KV	Kolhapur - Mapusa - II	17-Jan-11	23.14	18-Jan-11	00.14	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	17-Jan-11	22.38	19-Jan-11	12.41	Over Voltage.
400KV	Karad-Kolhapur-II	17-Jan-11	17.45	19-Jan-11	06.23	Over Voltage.
400KV	Own Brekar @ Kolhapur-Mapusa-I	18-Jan-11	03.52	19-Jan-11	15.35	Low Air Pressure of Main C B.On TBC.
400KV	Dabhol - New Koyna - I	18-Jan-11	08.00	18-Jan-11	18.45	Cold line washing of insulators.
400KV	Chandrapur-B' vati II	18-Jan-11	10.04	18-Jan-11	16.04	Maintenance work.
400KV	Bhusawal- Aurangabad	18-Jan-11	21.28	19-Jan-11	04.46	Over Voltage.
400KV	Dabhol-Nagothane - II	18-Jan-11	16.50	20-Jan-11	17.33	Taken on TBC, For attending SF-6 gas leakage at Dabhol end.
400KV	Karad - Solapur(Lamboti)	18-Jan-11	23.50	21-Jan-11	17.12	Lilo of 400 KV Kard-Solapur line.
400KV	Jejuri 406 Breaker	18-Jan-11	11.15	18-Jan-11	13.54	Demo & CT analyser kit.
400KV	400/220 KV 315 MVA ICT-II @ Lonikand	18-Jan-11	18.03	19-Jan-11	20.00	LV side taken on TBC due to sparking at 29B isolator.
400KV	Karad - Lonikand	19-Jan-11	06.33	19-Jan-11	19.45	Making insulator histing & conductor stringing for Jaigad-Karad D/C line
400KV	Chandrapur-Bhadravti - I	19-Jan-11	09.50	19-Jan-11	19.30	Maintenance work.
400KV	Dhule - S'Sarovar- II	19-Jan-11	18.03	23-Jan-11	11.40	Over Voltage.
400KV	Kalwa - Padgha - II	19-Jan-11	20.52	19-Jan-11	21.02	Direct Trip received at Padgha end.
400KV	Bhusawal- Aurangabad	19-Jan-11	22.56	20-Jan-11	05.04	Over Voltage.
400KV	Karad - Kolhapur - I	19-Jan-11	23.00	20-Jan-11	06.45	Over Voltage.
400KV	Kolhapur - Mapusa - I	19-Jan-11	23.46	20-Jan-11	19.16	Over Voltage.
400KV	Bhusawal- Aurangabad	20-Jan-11	21.34	21-Jan-11	05.36	Over Voltage.
400KV	Padgha-Tarapur - II	20-Jan-11	09.29	21-Jan-11	07.06	Preventative maint.work.Ready for charging 20.32 Hrs.
400KV	Karad - Lonikand	20-Jan-11	06.33	21-Jan-11	06.15	For Jaigad line stringing work.Ready for charging 20.12 Hrs.
400KV	Karad - Kolhapur - II	20-Jan-11	23.13	21-Jan-11	07.52	Over Voltage.
400KV	400 KV TBC - II @ Chandrapur	20-Jan-11	13.02	20-Jan-11	17.40	Tan delta measurement work.
400KV	Bableshwar-Aurangabad	20-Jan-11	11.33	21-Jan-11	19.46	H/T at BBLR end to control 400 KV BBLR ICT loading.
400KV	Dabhol - New Koyna - I	20-Jan-11	16.59	20-Jan-11	17.33	To attend Hot Spot,Taken on TBC
400KV	Lamboti - Solapur (PGCIL)	21-Jan-11	22.00	22-Jan-11	05.34	Over Voltage
400KV	Kolhapur - Mapusa - I	21-Jan-11	03.41	21-Jan-11	08.48	R'Ph. air leakage.
400KV	Padgha-Tarapur - II	21-Jan-11	08.54	21-Jan-11	20.16	Preventive maint.work
400KV	Kolhapur - Mapusa - I	21-Jan-11	08.48	22-Jan-11	14.12	R phase air leakage,Line taken on TBC.
400KV	Lamboti - Solapur (PGCIL)	21-Jan-11	17.51	21-Jan-11	17.52	New Line Commissioned
400KV	Karad - Solapur (PGCIL)	21-Jan-11	18.14	21-Jan-11	18.15	New Line Commissioned

400KV	Dhule - Babhaleshwar - I	21-Jan-11	08.40	21-Jan-11	18.17	Restraining of broken E/W
400KV	400/220KV 315MVA ICT- I @ Kharghar	21-Jan-11	08.20	21-Jan-11	18.30	Retrofitting Differential Relay
400KV	Bhusawal- Aurangabad	21-Jan-11	20.58	22-Jan-11	05.24	Over Voltage
400KV	Karad - Kolhapur - II	21-Jan-11	23.10	22-Jan-11	17:39	Over Voltage.
400KV	Lonikand- Koyna Stage IV	21-Jan-11	23.17	22-Jan-11	05.43	Over Voltage
400KV	Nagothane-Dabhol-I	22-Jan-11	07.49	22-Jan-11	22.03	Cold Line washing of Insulator
400KV	Padgha -Tarapur - I	22-Jan-11	10.43	22-Jan-11	13.20	To attend Hot Spot
400KV	Bablsr-Padgha Ckt I	22-Jan-11	14.16	22-Jan-11	15.02	Heavy Sparking at BBLSR end
400KV	Karad - Kolhapur - I	22-Jan-11	20.12	23-Jan-11	08.02	Over Voltage
400KV	Lamboti - Solapur (PGCIL)	22-Jan-11	14.18	22-Jan-11	20.25	Pole Discrepancy
400KV	Bhusawal- Aurangabad	23-Jan-11	21.42	24-Jan-11	05.44	Over Voltage.
400KV	Kolhapur - Mapusa - II	23-Jan-11	02.03	23-Jan-11	08.30	Over Voltage
400KV	Dhule-Sar Sarovar - II	23-Jan-11	18.01		Continued.	Over Voltage.
400KV	Karad - Kolhapur - II	23-Jan-11	18.04		Continued.	Over Voltage.
400KV	Solapur - Solapur (PG)	23-Jan-11	20.17		Continued.	Over Voltage.
400KV	Dabhol - New Koyna - I	23-Jan-11	07.54	23-Jan-11	18.37	Cold Line Washing of Insulator.
400KV	Kolhapur - Mapusa - I	23-Jan-11	22.48		Continued.	Over Voltage.
220KV	Kalwa-Mahape	28-Nov-10	15.17	19-Jan-11	16.45	For Strengthening of mumbai system network.
220KV	Chandrapur-Warora - I	13-Jan-11	08.25	23-Jan-11	17.45	To control Warora-Hinganghat line load
220KV	Parly - New Parly TPS - I	13-Jan-11	11.47	18-Jan-11	16.44	Line isolator replacement work.
220KV	Dhule-Chalisgaon	15-Jan-11	07.18	18-Jan-11	13.37	To control load on Dhule ICT
220KV	Aurangabad - Babhaleshwar	16-Jan-11	08.13	17-Jan-11	07.37	To Control Bblsr ICT Loading.
220KV	Bus Section - II @ Pedambe	17-Jan-11	08.16	17-Jan-11	17.10	Replacement of Insulator.
220KV	Bus Section @ Tilwani	17-Jan-11	10.12	17-Jan-11	18.35	Conductor Restraining of 220 KV Main Bus in Section - II.
220KV	220/132 KV,200 MVA T/F AT Tilwani	17-Jan-11	11.30	18-Jan-11	02.35	For Attending Oil Leakage.
220KV	Aurangabad - Babhaleshwar	17-Jan-11	07.55	19-Jan-11	11.07	Due to ICT Over Loading.
220KV	Tillawni-Talangade-I	17-Jan-11	10.08	17-Jan-11	18.32	Main Bus Outage.
220KV	Tilwani - Talangde - II	17-Jan-11	10.07	17-Jan-11	18.33	Main Bus Outage.
220KV	Tilawani-Miraj	17-Jan-11	10.00	17-Jan-11	18.32	Main Bus Outage.
220KV	220 KV Main Bus @ Tilwani	17-Jan-11	10.12	17-Jan-11	18.35	Main Bus Outage.
220KV	Talangade - Mumewadi	17-Jan-11	10.28	17-Jan-11	13.43	Q.M.Work.
220KV	Pedambe - Tambati	17-Jan-11	06.48	17-Jan-11	19.15	For Bus Outage @ Pedambe.
220KV	Karad-Pedambe	17-Jan-11	06.50	17-Jan-11	17.27	For Bus Outage @ Pedambe.
220KV	Pedambe - Pophali - II	17-Jan-11	06.44	17-Jan-11	17.55	For Bus Outage @ Pedambe.
220KV	220/132 KV 100 MVA ICT @ Shahada	17-Jan-11	10.00	17-Jan-11	14.00	Attending Oil Leakage in ICT & y Ph.CT.
220KV	Ambazari-Wardha	17-Jan-11	16.24	17-Jan-11	17.04	To Control Load on 400KV Koradi ICT-2.
220KV	Vita - Lamboti	18-Jan-11	00.19	19-Jan-11	01:16	Distance Protection.
220KV	Borivali-Mulund	18-Jan-11	07.15	18-Jan-11	15.36	Taking trial of TBC.
220KV	Apta-Kalwa	18-Jan-11	08.50	18-Jan-11	20.20	Replacement of damaged & bent tower at Loc.No.675.
220KV	Kalwa I-Taloja	18-Jan-11	07.05	18-Jan-11	19.33	Replacement of damaged & bent tower at Loc.No.675.
220KV	220/132KV,200MVA ICT-I at Malegaon	18-Jan-11	13.16	18-Jan-11	15.04	For adjusting CT Clamp at 132KV Incomer I.
220KV	Dhule - Malegaon	18-Jan-11	13.26	18-Jan-11	13.43	Distance Protection.
220KV	Vankushwadi - MIDC Satara - I	18-Jan-11	14.30	18-Jan-11	17.46	Replacement of Y-Ph LA at Satara.
220KV	Apta-Nagothane	18-Jan-11	14.50	18-Jan-11	20.03	Taken on TBC due to bus outage.
220KV	Karad-Sada Waghapur	18-Jan-11	13.00	18-Jan-11	16.08	Maintenance work.
220KV	220/100KV 100 MVA ICT- I @ Tambati	18-Jan-11	17.50	18-Jan-11	19.15	To attend LV side CB problem.
220KV	Dhule-Chalisgaon	18-Jan-11	15.53		Continued.	To control O/L of 400KV Dhule ICT,From 22/01/11 Repl of Line Insulat
220KV	220KV B Bus at Nagothane	18-Jan-11	14.52	18-Jan-11	19.47	Maintenance and Testing Work.
220KV	220/132 KV, 100 MVA ICT - II @ Beed.	18-Jan-11	16.37	18-Jan-11	17.09	O/L,O/C.
220KV	Yavatmal-Pusad	18-Jan-11	11.03	18-Jan-11	15.33	Attending B-Ph CT leakage.

220KV	220/132KV 200MVA ICT @ Beed	18-Jan-11	16.37	18-Jan-11	17.09	O/L,O/C.
220KV	Kalwa - Borivali	19-Jan-11	07.32	19-Jan-11	13.52	Taking Trials of TBC.
220KV	Ghodbandar-Versova-I	19-Jan-11	08.56	19-Jan-11	21.30	Annual Maintenance work.
220KV	220/132 KV,100 MVA T/F- II @ Malegaon	19-Jan-11	08.55		Continued.	Replacement of 100MVA ICT by 200MVA.
220KV	Mahape-Tifil	19-Jan-11	10.07		Continued.	Dismantalling and erection of MC tower and stringing of conductor.
220KV	Mudsungi - Chikodi	19-Jan-11	12.25	19-Jan-11	18.45	Bay Maintenance work.
220KV	Karad-Kolhapur - II	19-Jan-11	13.42	19-Jan-11	18.33	Distance Protection,Z-I.
220KV	Aurangabad - Babaleshwar	19-Jan-11	11.34	21-Jan-11	19.43	H/T from BBSLR end.To control 400KV BBSLR ICT loading.
220KV	New Parli-Nanded	19-Jan-11	13.06	19-Jan-11	20.33	Distance Protection, R-PH Z-I.
220KV	Khaperkheda - Koradi	19-Jan-11	08.37	19-Jan-11	14.14	Q.M.Work
220KV	Bhandara - RLY TSS - I	19-Jan-11	08.45	19-Jan-11	13.50	Q.M.Work
220KV	220/7 KV 35 MVA Stn.T/F- II @ Parly	19-Jan-11	16.10		Continued.	LV side E/F fire in Aux.Dist.box due to burning of 2 No.feeder.
220KV	New Paras TPS-Alola-II	20-Jan-11	12.00	20-Jan-11	14.20	DCRM measurement work.Ckt was on TBC.
220KV	Sahara-B'dying	20-Jan-11	09.17	20-Jan-11	19.10	Q.M.Work.
220KV	Nagothane-MSL	20-Jan-11	09.29	20-Jan-11	18.22	Testing work.
220KV	Borivali-Boisar	20-Jan-11	08.57	20-Jan-11	14.14	For TBC Trial
220KV	Chinchwad - Parvati	20-Jan-11	08.50	20-Jan-11	18.45	Replacement of insulator.
220KV	Temghar-Colourchem	20-Jan-11	13.20	20-Jan-11	16.30	Attend Hot spot.
220KV	220 KV TBC At Parbhani.	20-Jan-11	09.20	20-Jan-11	10.15	Measurement of tan delta of CT.
220KV	220/66KV 50 MVA ICT- II @ Wardha	20-Jan-11	10.05	20-Jan-11	17.56	Replacement of winging and oil temp.meter.
220KV	220/132KV 100 MVA ICT @ Yavatmal	20-Jan-11	11.00	20-Jan-11	16.45	Attending oil leakages of ICT.
220KV	Borivali -Tarapur	21-Jan-11	10.05	21-Jan-11	13.07	For TBC trial
220KV	Wardha Power - Warora-I	21-Jan-11	11.10	21-Jan-11	12.12	Tripped at Warora end only
220KV	Apta-Nagothane	21-Jan-11	08.11	21-Jan-11	19.38	Replacement of E/W and Insulator
220KV	Tambati-Pedambe	21-Jan-11	08.15	21-Jan-11	19.33	Replacement of E/W and Insulator
220KV	Padgha - Nalasopara	21-Jan-11	12.49	21-Jan-11	20.31	Isolator work
220KV	Wardha-RLY TSS I	21-Jan-11	05.09	21-Jan-11	14.46	M.B.PDR problem, ckt on TBC
220KV	Badnera - Akola - I	21-Jan-11	11.55	21-Jan-11	14.25	DCRM of Main Breaker,ckt on TBC
220KV	Padegaon - Sawangi	21-Jan-11	10.12	21-Jan-11	16.28	Q.M.Work
220KV	Apta-Nagothane	22-Jan-11	07.50	22-Jan-11	18.42	Replacement of E/W and Insulator
220KV	Tambati-Pedambe	22-Jan-11	08.45	22-Jan-11	18.55	Replacement of E/W and Insulator
220KV	Karad-Sada Waghapur	22-Jan-11	13.18	22-Jan-11	13.40	Relay Testing
220KV	Vita - Lamboti	22-Jan-11	16.40		Continued.	CB replacement,line taken on TBC
220KV	Bus Sectionlizer @ Apta	22-Jan-11	11.39	22-Jan-11	13.00	Hot Spot
220KV	Kalyani-Baramati Agro	22-Jan-11	09.40	22-Jan-11	18.42	Replacement of Faulty Disc Insulator
220KV	220/100KV,100 MVA T/F-I at Jambhul	22-Jan-11	11.30		Continued.	For Dismantaling 100MVA T/F-I under JICA scheme
220KV	Kalmeshwar - Pandurna	22-Jan-11	10.37		Continued.	Main Breaker O/H work,Line on TBC
220KV	220/132 KV 150 MVA ICT-I @ Akola.	22-Jan-11	12.20	22-Jan-11	13.40	Measurement of Contact Resistances,HV side on TBC
220KV	Kandalgaon-Mhasale	23-Jan-11	05.46	23-Jan-11	06.05	Distance Protection
220KV	220/33 KV 100 MVA ICT- IV @ Versova	23-Jan-11	07.23		Continued.	Annual Maintenance Work.
220KV	Nerul -Sonkhar	23-Jan-11	07.10	23-Jan-11	10.28	To Attend Hot Spot.
220KV	Babaleshwar - Nagar - II	23-Jan-11	15.11	23-Jan-11	16.52	Distance Protection, B Ph to Earth,Z-I.
220KV	Babaleshwar - Nagar - I	23-Jan-11	15.55	23-Jan-11	18.43	Distance Protection,R & Y Ph, Z-I.
220KV	Babaleshwar - Nagar - II	23-Jan-11	17.38	23-Jan-11	18.28	Distance Protection,Y-B Ph,Z-I.
220KV	Baramati Agro - Bhigwan	23-Jan-11	09.30	23-Jan-11	18.40	Strings 22 Cut Points & 11 Suspensions.
220KV	Chandrapur-Warora - I	23-Jan-11	18.14		Continued.	To Control 220KV Warora-Hinganghat Loading.
132KV	Parbhani-Parthur	21-Jan-11	11.07	21-Jan-11	14.52	R Phase CT oil leakage
132KV	Kanhan - Bhandara	21-Jan-11	08.38	21-Jan-11	18.44	Replacement of E/W
132KV	Harsool - Kagzipura	21-Jan-11	11.50	21-Jan-11	16.28	Oil Leakage of CT
132KV	Dhule-Nardhane	22-Jan-11	12.05	22-Jan-11	15.20	Replacement of Line Isolator
132KV	Beed - Beed	23-Jan-11	11.50	23-Jan-11	11.55	Due to Overloading.
100KV	Kandalgaon - Mhasale	18-Jan-11	09.15	18-Jan-11	17.15	Maintenance work.
100KV	Mudshingi-Dudhganga	20-Jan-11	12.15	20-Jan-11	19.45	Distance protection.
100KV	Chinchwad - Talegaon	20-Jan-11	08.07	20-Jan-11	16.25	Errection of Tower.