

LINE OUTAGES FOR THE WEEK

FROM 14-Feb-11 TO 20-Feb-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE II - CHDPR	17-Feb-11	07.52	18-Feb-11	04.23	Stringing work of 400kV Bhadravati-Parli & Wardha-Parli by PGCIL
500KV	HVDC POLE I -CHDPR	17-Feb-11	07.52	17-Feb-11	23.29	Stringing work of 400kV Bhadravati-Parli & Wardha-Parli by PGCIL
400KV	Dhule-Sar'Sarovar - I	12-Feb-11	23.50	17-Feb-11	08.26	Over Voltage
400KV	Karad - Kolhapur - II	13-Feb-11	18.03	14-Feb-11	10.43	Over Voltage
400KV	Kolhapur - Mapusa - I	13-Feb-11	22.27	14-Feb-11	09.05	Over Voltage
400KV	Bhusawal- Aurangabad	13-Feb-11	22.44	14-Feb-11	04.30	Over Voltage
400KV	Karad - Kolhapur - II	14-Feb-11	18.02	15-Feb-11	08.49	Over Voltage
400KV	Bhusawal- Aurangabad	14-Feb-11	22.10	15-Feb-11	04.40	Over Voltage
400KV	Kolhapur - Mapusa - I	14-Feb-11	22.20	15-Feb-11	08.10	Over Voltage
400KV	Karad - Kolhapur - I	14-Feb-11	11.03	14-Feb-11	14.19	For Erection of 400KV Jaigad Ckt Tower near karad
400KV	Main Bus - II @ Koradi	14-Feb-11	09.16	16-Feb-11	22.27	Insulator String replacement
400KV	400/220 KV 300 MVA ICT-I @ Koradi	14-Feb-11	15.25	14-Feb-11	16.28	To attend Buchholz Alarm
400KV	400/220 KV 315 MVA ICT - II @ Koradi.	14-Feb-11	09.02	14-Feb-11	17.14	Main Bus-II outage,(ICT HV side is on TBC)
400KV	400/220 KV 300 MVA ICT-I @ Koradi	14-Feb-11	17.50	15-Feb-11	18.25	Main Bus-II outage (ICT HV side is on TBC)
400KV	Own Breaker of Lonikand-Kalwa line	14-Feb-11	12.05	15-Feb-11	19.22	O/H of own Breaker at Lonikand,Line on TBC
400KV	Karad - Kolhapur - II	15-Feb-11	09.20	16-Feb-11	08.05	Replacement of C V T.
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	15-Feb-11	09.40	15-Feb-11	19.56	Relay Testing & R.M.Work.
400KV	Main Bus - I @ Kolhapur	15-Feb-11	10.06	18-Feb-11	13.37	Alignment of Isolators.
400KV	Kolhapur - Mapusa - II	15-Feb-11	23.57	16-Feb-11	08.03	Over Voltage.
400KV	Kolhapur - Mapusa - I	16-Feb-11	22.08	17-Feb-11	09.44	Over Voltage.
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	16-Feb-11	16.44	16-Feb-11	18.31	Red Hot on R & B-Ph Bushing.
400KV	400/220 KV 315 MVA ICT - II @ Koradi.	16-Feb-11	09.07	16-Feb-11	12.27	Bucholz alarm problem.
400KV	Bableshtar-Aurangabad	16-Feb-11	10.18	16-Feb-11	13.45	Q.M.Work
400KV	Koradi - Bhusawal	16-Feb-11	14.33	16-Feb-11	20.18	In View of Main Bus-II outage,(ICT HV Side is on TBC.)
400KV	Parli - Solapur	16-Feb-11	09.14	16-Feb-11	09.28	Hot Spots Observed at 29D,29A,29B,521, CT.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	16-Feb-11	09.07	16-Feb-11	13.27	Bucholz relay checking.
400KV	Karad - Kolhapur - I	17-Feb-11	01.38	17-Feb-11	07.19	Over Voltage.
400KV	400/220 KV 315 MVA ICT-II @ Lonikand	17-Feb-11	09.50	17-Feb-11	18.02	Bay Maintenance Work.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	17-Feb-11	14.03	17-Feb-11	18.01	To check Bucholz alarm indication.
400KV	Dhule-Sar'Sarovar - II	17-Feb-11	22.27	19-Feb-11	08.22	Over Voltage.
400KV	Bhusawal- Aurangabad	17-Feb-11	22.49	18-Feb-11	05.14	Over Voltage.
400KV	Karad - Kolhapur - I	17-Feb-11	22.48	18-Feb-11	14.53	Over Voltage.
400KV	Kolhapur - Mapusa - II	17-Feb-11	23.46	18-Feb-11	07.32	Over Voltage.
400KV	400/132KV 200 MVA ICT- I @ Bhusawal	17-Feb-11	14.36	17-Feb-11	15.26	Attending Red Hot on line side R-Ph isolator.
400KV	Chandrapur - Parli - I	18-Feb-11	09.22	18-Feb-11	16.45	Replacement of damaged pilot,line on TBC
400KV	New Koyana - Dabhol - II	18-Feb-11	11.22	18-Feb-11	13.40	Checking of SF6 Gas Leakage and refilling of SF6 Gas
400KV	Bus Coupler @ Aurangabad	18-Feb-11	11.47	18-Feb-11	13.56	Retrofitting work
400KV	Kolhapur - Mapusa - I	18-Feb-11	20.45	19-Feb-11	09.28	Over Voltage
400KV	Bhusawal- Aurangabad	18-Feb-11	21.21	19-Feb-11	04.54	Over Voltage
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	18-Feb-11	14.58	18-Feb-11	15.04	Shifting of B Bus to A Bus
400KV	Karad-Kolhapur-II	18-Feb-11	23.00	19-Feb-11	06.28	Over Voltage
400KV	Dhule-Sar'Sarovar - I	18-Feb-11	23.27		Continued.	Over Voltage
400KV	Akola - Wardha - I	18-Feb-11	23.30	19-Feb-11	05.05	Over Voltage
400KV	400/220 KV 300 MVA ICT-I @ Koradi	18-Feb-11	23.28	19-Feb-11	02.26	For releasing Air from Air Plug Vent
400KV	Karad - Kolhapur - I	19-Feb-11	21.51	20-Feb-11	07.59	Over Voltage
400KV	Kolhapur - Mapusa - II	19-Feb-11	22.25	20-Feb-11	08.20	Over Voltage
400KV	Akola - Wardha - II	19-Feb-11	23.03	20-Feb-11	08.03	Over Voltage

400KV	Bhusawal- Aurangabad	19-Feb-11	22.00	20-Feb-11	04.09	Over Voltage
400KV	400/132KV 200 MVA ICT-II @ Bhusawal	19-Feb-11	13.21	19-Feb-11	15.14	Replacement of B phase Rotary (ICT is on TBC)
400KV	400/220 KV 300 MVA ICT-I @ Koradi	19-Feb-11	10.42		Continued.	For Releasing Air from Air Releasing Plugs of R Phase
400KV	Kolhapur-Mapusa-II	20-Feb-11	21.47		Continued.	Over Voltage
400KV	Wardha - Akola - I	20-Feb-11	21.58		Continued.	Over Voltage
400KV	Karad - Kolhapur - II	20-Feb-11	08.49		Continued.	Relay retrofitting work(ready for charging at 18.30Hrs)
400KV	Dabhol-Nagothane-II	20-Feb-11	16.52	20-Feb-11	17.48	Distance Protection
400KV	New Koyna - Koyna Stage IV - II	20-Feb-11	18.04	20-Feb-11	18.30	Over Voltage
220KV	Alephata-Kathapur	14-Jan-11	14.08	15-Feb-11	04.58	To Control LNKD ICT Load.
220KV	Wardha - Deoli (PGCIL)	10-Feb-11	15.18	19-Feb-11	15.40	220KV Wardha-Yavatmal line reoriented as Deoli-Yavatmal Ckt
220KV	Kharghar-Uran-I	13-Feb-11	18.16	14-Feb-11	01.17	B phase LA Burst
220KV	Nasik - Airoli - Knowledge Park	14-Feb-11	05.44	14-Feb-11	06.28	Distance Protection
220KV	Badnera-Amravati	14-Feb-11	14.56	14-Feb-11	16.51	DCRM of Main breaker(CKT on TBC)
220KV	Aurangabad-Chitegaon-II	14-Feb-11	10.26	14-Feb-11	16.06	Q.M.Work
220KV	220/132KV 200MVA ICT-II at Dhule	14-Feb-11	20.14	14-Feb-11	21.23	For Inspection of HV Bushing Oil Level
220KV	New Koyna - Pawas	14-Feb-11	09.11	14-Feb-11	17.44	Insulator replacement
220KV	Bhigwan-Kurkum	14-Feb-11	10.20	14-Feb-11	12.15	Earthing work
220KV	Baramati Agro - Bhigwan	14-Feb-11	15.20	14-Feb-11	17.25	Earthing work
220KV	Bale-Murud	14-Feb-11	14.50	15-Feb-11	06.50	To control load on Parli ICT
220KV	Bale-Usmanabad	14-Feb-11	15.23	15-Feb-11	20.55	To control load on Parli ICT
220KV	Kandalgaon - Lonand	14-Feb-11	14.30	14-Feb-11	16.45	To Facilitate Minister's Helicopter landing
220KV	Tilawani-Miraj	14-Feb-11	10.38	14-Feb-11	18.35	Replacement of Jumpers of 220KV bays
220KV	Tillawni-Talangade-I	14-Feb-11	10.35	14-Feb-11	18.32	Replacement of Jumpers of 220KV bays
220KV	Tilwani - Talandge - II	14-Feb-11	10.35	14-Feb-11	18.33	Replacement of Jumpers of 220KV Bays
220KV	Main Bus at Tilwani	14-Feb-11	10.40	14-Feb-11	18.40	To attend Hot Spot
220KV	Main Bus-I at Pawas	14-Feb-11	09.59	14-Feb-11	17.35	Cold Washing of Bus Insulator
220KV	220/110 KV 200 MVA ICT - I @ Kolhapur	14-Feb-11	09.15	14-Feb-11	19.15	To attend Oil Leakage
220KV	Main Bus @ Miraj	15-Feb-11	08.30	15-Feb-11	17.50	Q.M.Work & Hot Spot Attending.
220KV	Main Bus @ Usmanabad	15-Feb-11	09.16	15-Feb-11	18.30	Tand,LCM SFRA Test.
220KV	220/100KV 100MVA T/F @ K'gaon	15-Feb-11	08.02	15-Feb-11	19.40	R.M.Work.
220KV	Phursungi - Theur	15-Feb-11	09.05	15-Feb-11	16.55	Y Ph C T Replacement.
220KV	Uran - HOCL	15-Feb-11	10.20	15-Feb-11	18.28	Replacement of Insulator.
220KV	Mudshingi - Peth	15-Feb-11	10.19	15-Feb-11	14.15	Q.M.Work.
220KV	220/33 KV 50 MVA T/F - II @ Vita	15-Feb-11	13.20	15-Feb-11	17.03	Q.M.Work.
220KV	Dahanu-Ghodbunder	15-Feb-11	08.00	15-Feb-11	10.20	Damaged Conductor Work.
220KV	220/100KV 100 MVA T/F- I @ Tambati	15-Feb-11	11.03	15-Feb-11	18.58	R.M.Work.
220KV	Karad - Miraj	15-Feb-11	08.17	15-Feb-11	18.54	R.M.Work.
220KV	Lamboti - Pandharpur	15-Feb-11	13.49	15-Feb-11	17.05	Dist.Prot.
220KV	Hingoli-Pusad	15-Feb-11	12.46	20-Feb-11	12.14	To Control Pusad-Bhugaon Line Loading.
220KV	Mudsungi-Amona	15-Feb-11	13.35	15-Feb-11	14.20	Dist.Prot.
220KV	220/100 KV 200 MVA ICT- IV @ Apta	15-Feb-11	10.20	15-Feb-11	16.30	R M Work.
220KV	Main Bus @ Satara	15-Feb-11	10.58	15-Feb-11	16.50	Bus & L B B Prot. Work & Testing Work.
220KV	Karad-Vita-II	16-Feb-11	11.18	16-Feb-11	15.37	To attend Red Hot R-Ph CT line Isolator.
220KV	Vita - Pandharpur	16-Feb-11	09.55	16-Feb-11	16.19	To attend Red Hot R-Ph CT line Isolator.
220KV	220 KV Interconnector @ Kalwa	16-Feb-11	09.53	16-Feb-11	21.26	Y-Ph CT leakage.
220KV	Uran-Kharghar-I	16-Feb-11	13.16	16-Feb-11	17.35	LA Earthing,Maintenance work.
220KV	Varsova - Aarey - I	16-Feb-11	06.39	16-Feb-11	21.38	Errection of cable on tower for project work.
220KV	Vankuswadi-KDPH	16-Feb-11	13.50	16-Feb-11	17.00	Y-Ph Jumper snapped on Aux.Bus, Bus fault.
220KV						

220KV	Vankushwadi - MIDC Satara - I	16-Feb-11	13.50	16-Feb-11	14.45	Y-Ph Jumper snapped on Aux.Bus, Bus fault.
220KV	Vankuswadi - MIDC Satara- II	16-Feb-11	13.50	16-Feb-11	14.46	Y-Ph Jumper snapped on Aux.Bus, Bus fault.
220KV	Parli-Usmanabad	16-Feb-11	09.14	16-Feb-11	09.44	Backup Protection Operated,O/C,& E/F.
220KV	Murud - Girawli.	16-Feb-11	09.15	16-Feb-11	09.19	To Control Parli ICT Loading.
220KV	Chinchwad-Bhosari	17-Feb-11	05.40	17-Feb-11	21.01	Erection of 2 new towers @Loc No.147,149.
220KV	Bhosari-Telco	17-Feb-11	06.00	17-Feb-11	20.58	Erection of 2 new towers @Loc No.147,149.
220KV	220/100 KV 200 MVA T/F - IV @ Apta	17-Feb-11	11.16	17-Feb-11	16.32	SF-6 Gas Leakage attending work.
220KV	Chandrapur-Wani	17-Feb-11	07.41	17-Feb-11	16.58	Due to outage on HVDC Pole I & II outage.
220KV	Dhule-Dondaicha-II	17-Feb-11	12.27	17-Feb-11	21.32	Line isolator alignment work.
220KV	Versova - Arey- I	17-Feb-11	07.37	17-Feb-11	20.22	Cable work,Goregaon LILo work.
220KV	220/132KV,200MVA ICT-III At Nanded.	17-Feb-11	12.00	17-Feb-11	15.15	To attend oil leakages from OLTC chamber.
220KV	Uran-Kharghar-I	18-Feb-11	03.47	18-Feb-11	04.12	Tripped.
220KV	Pawas-Kharepatan	18-Feb-11	09.10	18-Feb-11	17.55	R.M.Work
220KV	Apta-Uran-IV	18-Feb-11	09.33	18-Feb-11	14.58	R.M.Work
220KV	Uran - Khargar - I	18-Feb-11	15.30	18-Feb-11	18.15	Attending Red Hot
220KV	220/100KV 200 MVA ICT- II @ Kolshet	18-Feb-11	10.38	18-Feb-11	16.40	R.M.Work
220KV	220/132KV 200 MVA ICT- II @ Amravati	18-Feb-11	09.51	18-Feb-11	12.55	Q.M.Work
220KV	Karad-Pedambe	19-Feb-11	06.28	19-Feb-11	14.10	Tripped on distance protection, "R" phase.
220KV	Kharepatan-Pawas	19-Feb-11	09.08	19-Feb-11	18.01	Insulator replacement work
220KV	Nasik-Padgha- II	19-Feb-11	09.35	19-Feb-11	14.56	Bay Maint.work
220KV	Pedambe-Tambati	19-Feb-11	09.05	19-Feb-11	20.20	Line Maintenance work
220KV	Mudshingi-Talangade - I	19-Feb-11	14.04	19-Feb-11	18.51	Insulator replacement work
220KV	Kolhapur-Karad-IV	19-Feb-11	06.46	19-Feb-11	12.38	B Phase E/F
220KV	Ghatghar-Jindal	19-Feb-11	14.29	19-Feb-11	15.45	Distance Protection
220KV	220 KV Interconnector @ Kalwa	19-Feb-11	06.36	19-Feb-11	15.04	Repl.of R and B phase CT under LES
220KV	Wardha--Dhamangaon	19-Feb-11	11.24	19-Feb-11	19.02	Testing work
220KV	New Paras TPS - Chikhali - II	19-Feb-11	13.09		Continued.	Breaker Overhaul work(Ckt is on TBC)
220KV	Bhugaon - IIPL	19-Feb-11	10.20	20-Feb-11	16.12	Breaker Overhaul work(Ckt is on TBC)
220KV	220/132KV 200MVA ICT-III at BBLSR	20-Feb-11	12.35	20-Feb-11	13.05	Bus Bar Prot.operated while charging ICT-II from LV side
220KV	220/66 KV 50 MVA T/F - I @ Warora	20-Feb-11	06.23	20-Feb-11	17.12	REF relay operated
220KV	Kalwa - Salshet - IV	20-Feb-11	08.15	20-Feb-11	16.15	For Thermoscanning
220KV	Pedambe - Tambati	20-Feb-11	09.15	20-Feb-11	19.50	Insulator replacement
220KV	220/132KV 200MVA ICT-II at BBLSR	20-Feb-11	11.15	20-Feb-11	12.30	To attend Red Hot
220KV	220/132KV 200MVA ICT-II at BBLSR	20-Feb-11	12.35	20-Feb-11	17.15	Bus Bar Prot.operated while charging ICT-II from LV side
220KV	220/132 KV 100 MVA ICT- I @ BBLSR.	20-Feb-11	12.35	20-Feb-11	13.10	Bus Bar Prot.operated while charging ICT-II from LV side
220KV	Koradi-Ambazari-I	20-Feb-11	18.43		Continued.	To Control Koradi ICT Loading
132KV	Bhandara - Madgi -I	14-Feb-11	11.10	17-Feb-11	13.56	Erection of Tower and Restraining work
132KV	Bhandara - Madgi - II	14-Feb-11	11.02	17-Feb-11	13.58	Erection of Tower and Restraining work
132KV	Bhusawal -Yawal	14-Feb-11	16.18	14-Feb-11	18.01	Rotary switch work,Ckt on TBC
132KV	Deepnagar - Jalgaon - I	16-Feb-11	13.47	16-Feb-11	13.48	Load Trimming operated,due to tripping of BSL-3.
132KV	Deepnagar - Yawal	16-Feb-11	13.47	16-Feb-11	13.49	Load Trimming operated,due to tripping of BSL-3.
132KV	Deepnagar-Nimbhora	16-Feb-11	13.47	16-Feb-11	13.49	Load Trimming operated,due to tripping of BSL-3.
132KV	Deepnagar-Jalgaon-II	16-Feb-11	13.47	16-Feb-11	13.48	Load Trimming operated,due to tripping of BSL-3.
132KV	Giravali-Latur	16-Feb-11	09.14	16-Feb-11	09.30	Load Trimming Scheme Operated at 400KV Parli S/S.
132KV	Girwali - Latur MIDC	16-Feb-11	09.14	16-Feb-11	09.29	Load Trimming Scheme Operated at 400KV Parli S/S.
132KV	Giravali-Gangakhed	16-Feb-11	09.14	16-Feb-11	09.35	Load Trimming Scheme Operated at 400KV Parli S/S.
132KV	Girwali - Kej	16-Feb-11	09.14	16-Feb-11	09.21	Load Trimming Scheme Operated at 400KV Parli S/S.
132KV	Beed - Talegaon	18-Feb-11	11.00	18-Feb-11	14.16	Distance Protection

132KV	Nasik-Ozar-I	19-Feb-11	10.52	19-Feb-11	11.52	B phase C.T.oil Leakage
132KV	Nasik - Ozar - II	19-Feb-11	11.53	19-Feb-11	14.16	Y Phase C.T. Oil Leakage
132KV	Babaleshwar - Kopargaon	20-Feb-11	12.35	20-Feb-11	13.02	Bus Bar Prot.operated while charging ICT-II from LV side
132KV	BBLSR - Rahuri	20-Feb-11	12.35	20-Feb-11	13.07	Bus Bar Prot.operated while charging ICT-II from LV side
132KV	BBLSR - Sangamner	20-Feb-11	12.35	20-Feb-11	13.06	Bus Bar Prot.operated while charging ICT-II from LV side
132KV	BBLSR -BBLSR	20-Feb-11	12.35	20-Feb-11	13.13	Bus Bar Prot.operated while charging ICT-II from LV side
132KV	BBLSR - Newasa	20-Feb-11	12.35	20-Feb-11	13.10	Bus Bar Prot.operated while charging ICT-II from LV side
100KV	Kalwa - Salsette - II	4-Feb-11	17.14	18-Feb-11	10.55	H/T From Kalwa end.
100KV	Kalwa - Salsette	14-Feb-11	09.33	14-Feb-11	14.53	To open A Phase Loop at Loc.86
100KV	Kalwa - Salshet - I	18-Feb-11	10.56		Continued.	From Kalwa End
100KV	Kalwa-Washi	18-Feb-11	07.57	18-Feb-11	18.00	Stringing work of multi Ckt 220KV Kharghar-Borivali line
100KV	Std.Alkali - washi	18-Feb-11	07.57	18-Feb-11	18.35	Stringing work of multi Ckt 220KV Kharghar-Borivali line.
100KV	Kalwa-Standard	18-Feb-11	09.34	18-Feb-11	16.58	C T Ratio changing.