

LINE OUTAGES FOR THE WEEK

FROM 14-Feb-11 TO 20-Feb-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Dhule-Sar'Sarovar - I	9-Mar-11	22.51	14-Mar-11	07.06	Over Voltage.
400KV	Kolhapur-Mapusa-II	12-Mar-11	23.03	15-Mar-11	07.43	Over Voltage.
400KV	Bhusawal- Aurangabad	13-Mar-11	22.13	14-Mar-11	06.13	Over Voltage
400KV	Karad - Kolhapur - II	13-Mar-11	23.16	14-Mar-11	08.00	Over Voltage
400KV	Newkoyna - Jaigad - I	14-Mar-11	12.09	14-Mar-11	12.21	For Transportation of ICT Unit-I
400KV	New Koyna-Jaigad II	14-Mar-11	12.01	14-Mar-11	12.08	For Transportation of ICT Unit-I
400KV	Dhule-Sar'Sarovar - II	14-Mar-11	00.05	15-Mar-11	06.51	Over Voltage
400KV	Akola - Wardha - I	14-Mar-11	00.01	15-Mar-11	07.24	Over Voltage
400KV	Dhule-Sar'Sarovar - I	14-Mar-11	23.35		Continued.	Over Voltage
400KV	Karad - Kolhapur - I	15-Mar-11	00.24	15-Mar-11	07.31	Over Voltage
400KV	Karad - Kolhapur - II	15-Mar-11	22.00	16-Mar-11	08.16	Over Voltage.
400KV	Kolhapur - Mapusa - I	15-Mar-11	22.12	16-Mar-11	08.30	Over Voltage.
400KV	Bhusawal- Aurangabad	15-Mar-11	20.01	16-Mar-11	04.52	Over Voltage.
400KV	Akola - Wardha - II	15-Mar-11	23.50	16-Mar-11	07.20	Over Voltage.
400KV	400/220 KV 315 MVA ICT @ Akola	15-Mar-11	08.15	17-Mar-11	21.13	Q.M.Work.
400KV	400/220 KV 315 MVA ICT - II @ Parli	15-Mar-11	11.12	16-Mar-11	16.08	Attending Hot Spot @ B Ph of 220 KV Side 29D Isolator.
400KV	Padgha - Kharghar	15-Mar-11	12.17	15-Mar-11	23.44	Dist.Prot. Y Ph E, Z-I.
400KV	400/220 KV 315 MVA ICT-III @ Padgha	16-Mar-11	20.25	17-Mar-11	00.09	To Attend Oil Leakage in R Ph L V Side Bushing.
400KV	Karad - Kolhapur - I	16-Mar-11	23.29	17-Mar-11	07.57	Over Voltage
400KV	Akola - Wardha - I	16-Mar-11	21.57	17-Mar-11	08.54	Over Voltage.
400KV	Kolhapur - Mapusa - II	16-Mar-11	22.02	17-Mar-11	08.49	Over Voltage.
400KV	Bhusawal- Aurangabad	17-Mar-11	01.30	17-Mar-11	03.50	Over Voltage.
400KV	400/220 KV 315 MVA ICT - II @ Koradi.	17-Mar-11	09.31	17-Mar-11	21.57	Replacement of Y-Ph CT of HV side.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	17-Mar-11	10.40	17-Mar-11	19.02	Replacement of 33KV Y-Ph PT and Installation of oil pump of Y-Ph
400KV	Lonikand - Parli - II	17-Mar-11	11.09	17-Mar-11	19.17	Replacement of defective insulator.
400KV	Chandrapur - Parli - III	17-Mar-11	10.05	17-Mar-11	16.31	Armoving the damaged conductor at Loc.No.875-876.
400KV	400/220 KV 315 MVA ICT-III @ Padgha	18-Mar-11	00.32	18-Mar-11	06.44	R-Ph LV Side bushing leakage.(06.14Hrs kept on humming)
400KV	Karad - Kolhapur - II	18-Mar-11	00.11	18-Mar-11	06.00	Over Voltage.
400KV	Kolhapur - Mapusa - I	18-Mar-11	00.46	18-Mar-11	09.27	Over Voltage.
400KV	Kolhapur - Mapusa - I	18-Mar-11	21.27	19-Mar-11	09.02	Over Voltage.
400KV	Bhusawal- Aurangabad	18-Mar-11	07.24	18-Mar-11	13.09	For Stringing work of 400KV D/C Deepnagar-Waluj line.
400KV	400 KV Bus Reactor @ Nagothane	18-Mar-11	09.08	18-Mar-11	18.22	R.M. and Testing work.
400KV	Kalwa-Kharghar	18-Mar-11	09.11	18-Mar-11	16.18	Replacement of R-Ph LA.
400KV	400/220 KV Spare ICT @ Babaleshwar	18-Mar-11	10.00	18-Mar-11	17.40	Q.M.Work
400KV	Karad - Newkoyna - I	18-Mar-11	23.13	19-Mar-11	07.15	Retrofitting work of Main II,distance protection relay.
400KV	400KV AUX BUS at Aurangbad	18-Mar-11	08.50	18-Mar-11	14.35	stringing work from existing 400KV beam to new BSL-I.
400KV	50 MVAR Line Reactor of BSL-KORDY at B	18-Mar-11	12.51		Continued.	O/H work
400KV	Koradi - Bhusawal	18-Mar-11	12.51	18-Mar-11	13.01	To take out 50MVAR Line Reactor at BSL for O/H work
400KV	Kolhapur - Mapusa - I	19-Mar-11	23.43		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	19-Mar-11	23.57	20-Mar-11	05.00	Over Voltage.
400KV	New Koyna-Karad-II	19-Mar-11	22.41	20-Mar-11	05.12	Relay Retrofitting Work.
400KV	Bhusawal- Aurangabad	20-Mar-11	10:00	21-Mar-11	04:38	H/T for O/V.
400KV	Dhule - S'Sarovar- II	20-Mar-11	13:55		Continued.	H/T For O/V.
400KV	Lonikand-Karad	20-Mar-11	07:45		Continued.	Errection of 2 Nos. of In line towers at Loc. No. 328 (for 7 days).
400KV	400/132KV 200 MVA ICT- I @ Bhusawal	20-Mar-11	13:42		Continued.	Repl of Main Bus Isolator (ICT LV side is on TBC)

220KV	220/100 KV125 MVA ICT-III @Trombay	6-Jan-11	12.03	17-Mar-11	18.26	Augmentation by New 200 MVA ICT,
220KV	Alephata-Kathapur	6-Mar-11	07.52	19-Mar-11	10.15	To control Load on BBLSR ICT
220KV	Dhule-Chalisgaon	9-Mar-11	10.40	18-Mar-11	07.15	To Control Dhule ICT Loading.
220KV	220 KV TBC At Parbhani.	9-Mar-11	10.30	17-Mar-11	17.05	Breaker Overhaul.
220KV	Raymond-Washala	11-Mar-11	09.31	16-Mar-11	19.20	Shifting of Towers at Talegaon.
220KV	Nasik-Padgha	11-Mar-11	09.16	16-Mar-11	19.13	Shifting of Towers at Talegaon
220KV	Salsett-Borivali-II	11-Mar-11	11.30	14-Mar-11	10.38	Maint.work on 100KV Kolshet-BMC
220KV	Salsett-Borivali-II	11-Mar-11	11.35	14-Mar-11	14.38	Re Routing of Line in BMC Area.
220KV	Aurangabad - Babaleshwar	13-Mar-11	17.10	18-Mar-11	10.44	To Control BBLSR ICT Load
220KV	Pophali - Pedambe - I	13-Mar-11	15.00	14-Mar-11	12.50	Distance protection,(Declared Faulty)
220KV	Tillawni-Talange-I	14-Mar-11	10.58	14-Mar-11	15.11	Attending Hot Spot and Maint.work
220KV	Tilwani - Talange - II	14-Mar-11	16.20	14-Mar-11	18.31	Attending Hot Spot and Maint.work
220KV	Apta-HOC	14-Mar-11	10.20	14-Mar-11	17.37	Conductor replacement
220KV	Mudshingi-Talange-II	14-Mar-11	09.35	14-Mar-11	18.55	Insulator replacement work
220KV	Bus Section-III @ Nasik GCR	14-Mar-11	10.20	14-Mar-11	17.18	CT and Tan delta measurement
220KV	Pedambe-Kharepatan	14-Mar-11	14.10	14-Mar-11	18.23	Isolator overhauling work
220KV	Kalmeshwar - Pandurna	14-Mar-11	11.18	17-Mar-11	18.37	Relay Retrofitting Work for 4 days Outage.
220KV	Tarapur Zone-I	14-Mar-11	09.37		Continued.	Maintenance work.
220KV	Khaparkheda - Kanhan - I	14-Mar-11	07.08	14-Mar-11	18.34	Replacement of Faulty Disc Insulator
220KV	Babaleshwar - Nagar - I	14-Mar-11	14.50	14-Mar-11	14.55	Load Trimming Scheme operated
220KV	Babaleshwar - Nagar - II	14-Mar-11	14.50	14-Mar-11	14.55	Load Trimming Scheme operated
220KV	Bus section- II @ Mahad	15-Mar-11	09.30	15-Mar-11	17.49	R.M.Work.
220KV	Pedambe - Mahad	15-Mar-11	09.19	15-Mar-11	18.06	For Mahad Bus Section-II Outage.(R M)
220KV	220/100 KV 200 MVA ICT-II @ Apta	15-Mar-11	11.05	15-Mar-11	15.55	H V Side C T Oil Leakage.
220KV	Mudshingi-Talange-II	15-Mar-11	09.47	15-Mar-11	13.40	Replacement of Insulator.
220KV	Bhugaon-Pusad	15-Mar-11	12.35	17-Mar-11	14.52	Breaker Overhaul Work (3 Days) Ckt is on TBC.
220KV	220/66 KV 150 MVA ICT- I @ Gadchander	15-Mar-11	09.17	15-Mar-11	18.40	Replacement of L V Side R,Y,B Ph C T's.
220KV	Khaparkheda - Kanhan - I	15-Mar-11	06.56	15-Mar-11	18.53	Replacement of Faulty Disc Insulator.
220KV	Borivali - Salset - I	15-Mar-11	09.00	19-Mar-11	00.58	Re Routing of Line in BMC Area
220KV	Kandalgaon - Pophali	15-Mar-11	13.45	15-Mar-11	22.16	Distance Protection.
220KV	Lote- Dasturi	15-Mar-11	13.45	15-Mar-11	14.50	Distance Protection.
220KV	Lote- Dasturi	15-Mar-11	15.10	15-Mar-11	18.10	Distance Protection.
220KV	Vita - Karkambh	16-Mar-11	10.17	16-Mar-11	16.14	Attending Hot Spot & Repairing Work of Isolator.
220KV	Padgha-Temghar	16-Mar-11	20.24	17-Mar-11	00.11	To Control ICT Loading @ Padgha.
220KV	Bale-Usmanabad	16-Mar-11	05.54	16-Mar-11	18.38	Joint Work on Loc. 125-126.Charge from Usmanabad end only.
220KV	220/110KV 100 MVA ICT-II @ Miraj.	16-Mar-11	18.10	16-Mar-11	21.05	Tandelta Measurment of H V & L V Side Bushing.
220KV	Main Bus @ Karkumbh	16-Mar-11	10.15	16-Mar-11	16.50	Q.M.Work.
220KV	Badnera - Akola - I	16-Mar-11	09.50	16-Mar-11	14.10	For Retrofitting of Backup Relay & Quarteely Maintenance Work.
220KV	Badnera-Akola-II	16-Mar-11	14.25	16-Mar-11	16.45	For Retrofitting of Backup Relay & Quartely Maintenance Work.
220KV	220/132KV 200MVA ICT @ Beed	16-Mar-11	10.00	16-Mar-11	16.05	Oil Indicator of Conservator & Aero Seal Commissioning
220KV	Dondaicha - Jamde - I	16-Mar-11	09.30	16-Mar-11	17.30	For Providing Missing Elements of Location No.37.
220KV	Dondaicha - Jamde - II.	16-Mar-11	09.30	16-Mar-11	17.45	For Providing Missing Elements of Location No.37.
220KV	Khaparkheda - Kanhan - I	16-Mar-11	06.57	16-Mar-11	19.27	Replacement of Faulty Disc Insulator.
220KV	Valve-Jamde	16-Mar-11	09.25	16-Mar-11	18.18	Annual Maintenance Work.
220KV	Gangapur - Valve - I	16-Mar-11	09.02	16-Mar-11	18.18	Annual Maintenance Work.
220KV	Nagothane-Mahad	16-Mar-11	13.33	16-Mar-11	13.57	Distance Protection Y-B.
220KV	Kandalgaon - Pirangut	16-Mar-11	14.15	16-Mar-11	14.39	Distance Protection Y-E.
220KV	Pedambe-Tambati	16-Mar-11	15.00	16-Mar-11	15.26	Distance Protection.
220KV	Nagothane-Mahad	16-Mar-11	15.06	16-Mar-11	19.49	Distance Protection.
220KV	Kandalgaon - Dasturi	16-Mar-11	16.12	16-Mar-11	16.39	Distance Protection.

220KV	Kandalgaon - Dasturi	16-Mar-11	17.40	16-Mar-11	18.15	Distance Protection.
220KV	Jambhul - Anandnagar	17-Mar-11	16.10	17-Mar-11	17.53	CT Oil leakage.
220KV	Kalwa - Borivali	17-Mar-11	22.35	18-Mar-11	04.21	B-Ph CT Bello Expended due to gas formation.
220KV	Padgha-Temghar	17-Mar-11	23.35	18-Mar-11	07:05	Due to outage on Padgha ICT-III.
220KV	Khaperkheda - Wardha.	17-Mar-11	19.00	17-Mar-11	21.00	To control Koradi ICT O/L.
220KV	Kalmeshwar - Pandurna	17-Mar-11	19:14	17-Mar-11	20:56	Relay Problem.
220KV	Apta-Bombay Dyeing	17-Mar-11	09.48	17-Mar-11	18.05	Replacement of faulty Insulator.
220KV	220KV Bus Section I at 220KV Kalwa	17-Mar-11	09.04	18-Mar-11	17.18	Replacement of CT's and commissioning of new CP & RP
220KV	220/100 KV 200 MVA T/F - IV @ Apta	17-Mar-11	09.02	17-Mar-11	14.50	LV Side R-Ph pole of CB Replacement.
220KV	Kandalgaon - Dasturi	17-Mar-11	09.15	17-Mar-11	18.15	Replacement of insulator and E/W.
220KV	220/66 KV 150 MVA ICT- I @ Gadchandur	17-Mar-11	12.11	17-Mar-11	18.18	Maintenance work.
220KV	Khaparkheda - Kanhan - I	17-Mar-11	06.48	17-Mar-11	18.56	Jumpering work.
220KV	Halkarni - Tillary	17-Mar-11	04.51	17-Mar-11	05.41	Distance Protection.
220KV	Pophali - KDPH	17-Mar-11	12.50	17-Mar-11	14.12	Distance Protection.
220KV	Apta-Kalwa	17-Mar-11	12.00	17-Mar-11	12.15	Distance Protection.
220KV	Tillari-Amona-II	17-Mar-11	04.51	17-Mar-11	15.20	Distance Protection.
220KV	Halkarni-Amona I	17-Mar-11	11.25	17-Mar-11	13.38	Distance Protection.
220KV	Mudshingi-Talandage-II	18-Mar-11	09.00	18-Mar-11	15.07	Replacement of Insulator.
220KV	Wada-Kolshet	18-Mar-11	09.22	18-Mar-11	21.50	R.M. and Testing work.
220KV	220/33 KV 50 MVA T/F I @ Boisar II	18-Mar-11	09.07	18-Mar-11	12.32	R.M.Work
220KV	Khargar-Topworth	18-Mar-11	08.55	18-Mar-11	20.07	Replacement of E/W.
220KV	Kandalgaon - ONGC	18-Mar-11	08.29	18-Mar-11	19.26	Replacement of E/W.
220KV	Karad Mudsingi-II	18-Mar-11	10.42	18-Mar-11	13.17	Q.M.Work
220KV	Kalwa - Ghatghar	18-Mar-11	10.27	18-Mar-11	18.32	Jumper Tighting work.
220KV	Nasik - Ghatghar	18-Mar-11	10.51	18-Mar-11	18.55	Jumper Tighting work.
220KV	220 KV TBC @ Aurangabad	18-Mar-11	12.15	18-Mar-11	14.40	Tan delta of CT.
220KV	220/6.6 KV 40 MVA Station T/F- I @ Kapar	18-Mar-11	09.25	18-Mar-11	15.39	Testing work.
220KV	220/132KV 200MVA ICT-III at Padegaon	18-Mar-11	09.00	18-Mar-11	16.14	Replacement of AIR CELL.
220KV	Virur - Railway TSS-II	18-Mar-11	10.30	18-Mar-11	17.04	Replacement of failed CVT.
220KV	Hingoli-Pusad	19-Mar-11	17.24		Continued.	To control Wardha-Y'mal ckt loading.
220KV	Khargar-Topworth	19-Mar-11	08.35	19-Mar-11	19.36	E/W Stringing Work.
220KV	Kandalgaon - ONGC	19-Mar-11	08.15	19-Mar-11	18.55	E/W Stringing Work.
220KV	220/100 KV 125MVA ICT-II @ Borivali	19-Mar-11	09.30		Continued.	Augmentation ny 200MVA.
220KV	220/132 KV100 MVA ICT-I @ Chalisgaon	19-Mar-11	14.26		Continued.	Augmentation from 100 to 200 MVA ICT (up to 31.03.2011)
220KV	220/100 KV 200 MVA ICT II at Trombay	19-Mar-11	15.10	19-Mar-11	17.32	To release air.
220KV	Kanhan - Bhandara - II	19-Mar-11	08.52	19-Mar-11	16.40	Replacement of Disc Insulator.
220KV	220/132 KV100 MVA ICT-I @ Chalisgaon	19-Mar-11	14:26		Continued.	Replacement by 200 MVA ICT upto 31/03/2011.
220KV	Boiser-Taps	19-Mar-11	06.32	19-Mar-11	12.42	Distance Protection.
220KV	Kolshet - Kamba	19-Mar-11	13.20	19-Mar-11	13.29	Distance Protection.
220KV	Wada-Kolshet	19-Mar-11	13.20	19-Mar-11	19.11	Distance Protection.
220KV	Kurkumb-Bhigwan	19-Mar-11	13.45	19-Mar-11	1410	Distance Protection.
220KV	Bhandara - Rly TSS - II	19-Mar-11	16.58	19-Mar-11	18.25	Distance Protection.
220KV	Bombay Dyeing - Sahara	20-Mar-11	03.18	20-Mar-11	03.55	Red Hot Y-Ph.
132KV	Boisar(MIDC)-Dahanu - I	14-Mar-11	10.55	14-Mar-11	20.25	Conductor replacement work
132KV	Mehkar - Malegaon	14-Mar-11	11.25	14-Mar-11	12.55	Replacement of B phase LA
132KV	Amravati - Morshi	14-Mar-11	04.49	14-Mar-11	05.07	Distance Protection
132KV	Malkapur - Khamgaon	14-Mar-11	12.00	14-Mar-11	12.10	Distance Protection
132KV	Bhusawal - Nimbhora	15-Mar-11	10.05	15-Mar-11	17.22	Replacement of Two No. C T's Due to Higher Value of Tandelta.
132KV	Nanded - Ardhapur	15-Mar-11	08.20	15-Mar-11	11.58	Due to Opening of B Ph Wave Trap Jumper.
132KV	Paras - Akot	16-Mar-11	11.15	16-Mar-11	14.25	To Attend Oil Leakage of Y Ph. C T.
132KV	Palghar-TSS II	19-Mar-11	10.25	19-Mar-11	14.22	Conductor replacement.
132KV	Kalmeshwar-Katol	19-Mar-11	13.34	19-Mar-11	13.46	D/P, R & Y-Ph.
132KV	Chalisgaon - Manmad	19-Mar-11	23.55		Continued.	R-Ph CT Burst.
132KV	Chalisgaon - Manmad - I	19-Mar-11	23:55	20-Mar-11	20:50	R. Ph CT Burst at Chalisgaon.