

LINE OUTAGES FOR THE WEEK

FROM 18-Apr-11 TO 24-Apr-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE II - CHDPR	24-Apr-11	10.02	24-Apr-11	13.05	Tripped on converter block at Padghe end.
400KV	50 MVAR Line Reactor of BSL-KORDY at B	18-Mar-11	12.51	22-Apr-11	09.35	O/H Work.
400KV	Dhule-Sar'Sarovar - II	16-Apr-11	23.27	19-Apr-11	06.33	Over Voltage.
400KV	Bhusawal- Aurangabad	17-Apr-11	20.27	18-Apr-11	06:35	Over Voltage
400KV	Kolhapur - Mapusa - II	17-Apr-11	21.53	18-Apr-11	08:52	Over Voltage.
400KV	Karad - Kolhapur - II	18-Apr-11	00.56	18-Apr-11	11:22	Distance Protection
400KV	Bhusawal- Aurangabad	18-Apr-11	22.42	19-Apr-11	07.58	Over Voltage
400KV	400/220 KV 300 MVA ICT-I @ Koradi	18-Apr-11	09.20	23-Apr-11	20.04	Kept on humming R-Ph unit replacement with spare ICT.
400KV	New Koyna-Karad-II	19-Apr-11	05.15	19-Apr-11	10.35	To attend Red Hot Spot
400KV	Bhusawal- Aurangabad	19-Apr-11	20.43	20-Apr-11	04.53	Over Voltage
400KV	Wardha - Akola - II	19-Apr-11	18.25	19-Apr-11	19.26	Distance Protection
400KV	Dhule-S'Sarovar I	19-Apr-11	23.11	20-Apr-11	07.57	Over Voltage
400KV	Newkoyna - Jaigad - I	20-Apr-11	09.27	20-Apr-11	20.11	Insulator Washing Work.
400KV	Auxiliary Bus At Aurangabad.	20-Apr-11	08.45	20-Apr-11	17.08	Stringing Work.
400KV	400/220KV 315MVA ICT- I @ Kharghar	20-Apr-11	13.28	20-Apr-11	16.11	To Attend Oil Leakage from Y Ph.H V Bushing.
400KV	Lamboti - Solapur (PGCIL)	20-Apr-11	11.19	20-Apr-11	21.48	Replacement of R Ph. C T.
400KV	Bhusawal- Aurangabad	20-Apr-11	20.27	21-Apr-11	05.49	Over Voltage.
400KV	Dhule - S'Sarovar- II	20-Apr-11	22.45	24-Apr-11	10.44	H/T ON OVERVOTAGE
400KV	Parli-Lonikand -I	21-Apr-11	05.46	21-Apr-11	23.25	Insulator Replacement Work.
400KV	Main Bus- I @ 400 KV Parli	21-Apr-11	06.20	21-Apr-11	23.03	New bay construction and Ext'n work by PGCIL.
400KV	Chandrapur - Parli - I	21-Apr-11	09.30	21-Apr-11	23.14	Replacement CVT and 29 A isolator.
400KV	Main Bus-II @ Kolhapur	21-Apr-11	14.11	22-Apr-11	14.25	Isolator allinment work.
400KV	Koradi -Bhusawal	21-Apr-11	16.55	21-Apr-11	17.00	R-E fault.
400KV	400 KV Bus Coupler @ Parli	21-Apr-11	06.20	24-Apr-11	12.15	Control wiring problem.
400KV	400/220 KV 315 MVA ICT- I @ Parly.	21-Apr-11	21.12	21-Apr-11	23.00	To charge Main Bus I through TBC.
400KV	Bhusawal- Aurangabad	21-Apr-11	23.32	22-Apr-11	05.58	Over Voltage.
400KV	400/220 KV 315 MVA ICT- II @ Parli	21-Apr-11	23.01		Continued.	To Attend L V Side Main Bkr.Problem.L V Side of ICT Taken on TB
400KV	Koradi - Bhusawal	22-Apr-11	08.53	22-Apr-11	09.35	To Take Reactor of Bhusawal in Service.
400KV	Kalwa - Padgha - I	22-Apr-11	10.05	22-Apr-11	17.24	Removal of Rusty E/W Between Loc. No.1129-1130.
400KV	Lonikand - Chakan	22-Apr-11	14.29	22-Apr-11	15.02	LBB Operated.
400KV	400/220 KV 315 MVA ICT- I @ Chakan	22-Apr-11	14.29	22-Apr-11	16.06	B Ph Buchholz Operated.
400KV	400/220 KV 315 MVA ICT- II @ Chakan	22-Apr-11	14.29	22-Apr-11	15.12	Tripped.
400KV	Chakan-Talegaon(PG)	22-Apr-11	14.29	22-Apr-11	15.06	LBB Operated @ Chakan.
400KV	Bhusawal- Aurangabad	22-Apr-11	21.11	23-Apr-11	05.15	Over Voltage.
400KV	Akola - Aurangabad - II	22-Apr-11	11.34	22-Apr-11	18.08	AMP Work by PGCIL Ckt Was in Service Through Tie Breraker.
400KV	Kalwa - Lonikand	23-Apr-11	03.55	23-Apr-11	13.35	Distance Protection.
400KV	Karad - Lonikand	23-Apr-11	04.07	23-Apr-11	05.43	Distance Protection Trip from Krarad End Only.
400KV	Talegaon(PG)-Padgha	23-Apr-11	04.28	23-Apr-11	14.33	Distance Protection.
400KV	Babaleshwar - Dhule - I	23-Apr-11	09.49	23-Apr-11	16.58	Q.M. & Hot Spot attending work.
400KV	Bhusawal- Aurangabad	23-Apr-11	21.32	24-Apr-11	06.33	Over Voltage.
400KV	Akola-Aurangbad Ckt-II Tie Bkr.	23-Apr-11	11.42	23-Apr-11	18.45	Tan-delta measurement.
400KV	Dabhol-Nagothane - II	24-Apr-11	07.29	24-Apr-11	16.48	To attend hotspot -R ph.isolator @Dabhol & repl of LA@Nagothane
400KV	Bhusawal- Aurangabad	24-Apr-11	21.02	25-Apr-11	05.32	Over Voltage.
400KV	Bablsr-Padgha Ckt I	24-Apr-11	17.54		Continued.	Distance protection.
400KV	Dhule-Sar'Sarovar - I	24-Apr-11	17.36		Continued.	Over Voltage.
220KV	Borivali -Tarapur	3-Apr-11	09.10	22-Apr-11	18.12	LILo work of 220KV Borivali-Boiser at 220KV Ghodbander.
220KV	Bus Coupler at WPCL	13-Apr-11	15.37	20-Apr-11	04.49	At Warora end WPCL CKT-I Y phase PT Noise
220KV	Talangade - Mumewadi	17-Apr-11	17.49	18-Apr-11	00.49	Distance protection.Declared faulty.

220KV	Parbhani-Parli	17-Apr-11	23.53	18-Apr-11	12.41	Distance Protection, Declared Faulty
220KV	Newkoyna -Lote-Parsuram	18-Apr-11	08.09	19-Apr-11	18.00	Total Overhauling of CB and Testing work
220KV	Karad-Kolhapur - II	18-Apr-11	08.51	18-Apr-11	15.18	B Phase damaged conductor replacement
220KV	ONGC-JNPT	18-Apr-11	12.02	18-Apr-11	16.56	Line and Bay maint.work
220KV	Pophali-K'gaon	18-Apr-11	11.40	18-Apr-11	16.30	Distance Protection
220KV	Pophali-K'gaon	18-Apr-11	10.25	18-Apr-11	11.10	Distance Protection
220KV	Bus Section - II at Khareptan	18-Apr-11	08.30	18-Apr-11	16.25	220KV PT replacement
220KV	Khaperkheda - Wardha.	18-Apr-11	18.54	19-Apr-11	07.58	To control Koradi ICT Load
220KV	Wardha-Abhijeet I	18-Apr-11	17.05		Continued.	To control Koradi ICT Load
220KV	Badnera - Akola - I	18-Apr-11	08.21	18-Apr-11	08.58	Distance Protection
220KV	Hingoli-Pusad	18-Apr-11	13.07		Continued.	To control Wardha-Yavatmal load
220KV	Wardha-Abhijeet II	18-Apr-11	13.09	24-Apr-11	17.08	To control Koradi ICT load
220KV	220/132 KV 100 MVA ICT- II @ Bhusawal	18-Apr-11	10.20	20-Apr-11	21.34	Replacement of Single Conductor to Double Conductor of Stub Bus
220KV	Karad-Kolhapur - II	19-Apr-11	05.48	19-Apr-11	06.10	Distance Protection
220KV	Kalwa-Mahape	19-Apr-11	10.02	19-Apr-11	20.01	Normalization of 220KV Mahape-Tifil line
220KV	Karad - Vita - I	19-Apr-11	10.58	19-Apr-11	14.30	Q.M.Work
220KV	Karad - Miraj	19-Apr-11	11.20	19-Apr-11	13.43	CT Tand delta measurement
220KV	Vankuswadi-KDPH	19-Apr-11	11.00	19-Apr-11	18.40	Q.M.Work
220KV	Vankuswadi - MIDC Satara- II	19-Apr-11	11.50	19-Apr-11	18.50	Q.M.Work
220KV	Karad-Kolhapur - II	19-Apr-11	08.33	19-Apr-11	08.55	Distance Protection
220KV	Mudshingi - Peth	19-Apr-11	08.32	19-Apr-11	09.02	Distance Protection
220KV	220/100 KV 200 MVA ICT- IV @ Apta	19-Apr-11	09.57	19-Apr-11	19.15	Maint.work
220KV	220/110 KV 100 MVA T/F @ Miraj.	19-Apr-11	12.55	19-Apr-11	14.50	Tan Delta measurement
220KV	Khaperkheda - Wardha.	19-Apr-11	19.36	20-Apr-11	06.09	To control Koradi ICT-II Loading
220KV	Badnera - Akola - I	19-Apr-11	08.05	19-Apr-11	14.52	Retrofitting of relays
220KV	Parli-I - Harangul - II	19-Apr-11	10.32	19-Apr-11	13.52	Replacement of repaired sleeve
220KV	220/132 KV 200 MVA ICT-I @ Harangul.	19-Apr-11	14.00	19-Apr-11	15.42	To attend Hot Spot
220KV	Lamboti-Bale-I	20-Apr-11	09.30	20-Apr-11	15.47	Q.M.Work.
220KV	Chandrapur-Wani	20-Apr-11	08.51	20-Apr-11	16.15	Replacement of Faulty Insulator.
220KV	Lamboti-Bale-II	20-Apr-11	15.50	20-Apr-11	18.18	Q.M.Work.
220KV	Babaleswar - Ranjangaon	20-Apr-11	13.00	20-Apr-11	13.18	Distance Protection.
220KV	Usmanabad-Barshi	20-Apr-11	10.02	20-Apr-11	14.58	Q.M.Work.
220KV	Pusad - Nanded	21-Apr-11	12.15	21-Apr-11	16.49	Retrofitting work.
220KV	Nanded - Parali	21-Apr-11	07.34	21-Apr-11	09.22	To attend Hot Spot.
220KV	Pedambe-Mahad	21-Apr-11	08.45	22-Apr-11	15.10	Replacement of old damage insulator.
220KV	Kandalgaon - Pophali	21-Apr-11	10.25	21-Apr-11	14.30	Y & B Ph. wave trap clamp replacement work.
220KV	Ambazari-Amravati	21-Apr-11	16.46	22-Apr-11	08.45	Distance protection.
220KV	220 KV Bus at Chinchwad	21-Apr-11	08.32	21-Apr-11	16.17	Removing BusSection isolator for providing Bus Section Breaker.
220KV	Chinchwad-Urse	21-Apr-11	08.32	21-Apr-11	16.26	Removing BusSection isolator for providing Bus Section Breaker.
220KV	Chinchwad-Parvati	21-Apr-11	08.31	21-Apr-11	15.39	Removing BusSection isolator for providing Bus Section Breaker.
220KV	Chinchwad-Theur	21-Apr-11	08.31	21-Apr-11	16.25	Removing BusSection isolator for providing Bus Section Breaker.
220KV	Chinchwad - Telco	21-Apr-11	08.31	21-Apr-11	18.30	Removing BusSection isolator for providing Bus Section Breaker.
220KV	Chinchwad - Chakan	21-Apr-11	08.31	21-Apr-11	18.28	Removing BusSection isolator for providing Bus Section Breaker.
220KV	Chinchwad - Hinjewadi	21-Apr-11	08.31	21-Apr-11	16.29	Removing BusSection isolator for providing Bus Section Breaker.
220KV	220/132 KV 200MVA T/F II at Chinchwad	21-Apr-11	08.30	21-Apr-11	16.49	Removing BusSection isolator for providing Bus Section Breaker.
220KV	220/100KV 100MVA ICT-IV at C'wad	21-Apr-11	08.30	21-Apr-11	18.43	Removing BusSection isolator for providing Bus Section Breaker.
220KV	220/132KV 50MVA T/F I at Chinchwad	21-Apr-11	08.30	21-Apr-11	20.37	Removing BusSection isolator for providing Bus Section Breaker.
220KV	220/100KV 50 MVA T/F V at Chinchwad	21-Apr-11	08.30	21-Apr-11	18.54	Removing BusSection isolator for providing Bus Section Breaker.
220KV	Khaparkheda-Kawlewada-I	21-Apr-11	04.16	21-Apr-11	04.31	R-Ph-E.

220KV	220/100 KV ICT- III @ Borivali	22-Apr-11	10.50	22-Apr-11	13.05	Erection of Radiator.
220KV	Kalwa I-Taloja	22-Apr-11	09.10	22-Apr-11	20.24	Replacement of C T .
220KV	Tarapur-Boisor-II	22-Apr-11	09.46	22-Apr-11	18.12	Removal of Cross Jumpering & Restoration of Tarapur-Borivali.
220KV	Nagothane-Mahad	22-Apr-11	13.55	22-Apr-11	14.13	Distance Protection.
220KV	Bhosari - Chakan	22-Apr-11	14.29	22-Apr-11	15.10	LBB Operated @ Chakan.
220KV	Chinchwad - Chakan	22-Apr-11	14.29	22-Apr-11	16.08	LBB Operated @ Chakan.
220KV	Bhosari - Chakan	22-Apr-11	16.07	22-Apr-11	16.17	Trip.
220KV	220/33 KV 25 MVA T/F @ Halkarni	22-Apr-11	06.47	22-Apr-11	09.56	H V C B Problem.
220KV	220/132KV 200 MVA ICT- II @ Amravati	22-Apr-11	14.53	22-Apr-11	15.29	L V Backup Protection Operated.
220KV	New Parli - Beed - II	22-Apr-11	21.29	22-Apr-11	23.45	Distance Protection B Ph.
220KV	Parly - Harangool - I	22-Apr-11	21.34	23-Apr-11	09.07	Distance Protection B Ph.
220KV	Bale-Osmanbad	23-Apr-11	06.19	23-Apr-11	15.10	To Control Parli ICT Loading.
220KV	Bale-Murud	23-Apr-11	06.19	23-Apr-11	15.10	To Control Parli ICT Loading.
220KV	Nasik-Navsari-I	23-Apr-11	15.47	23-Apr-11	19.28	Jumper replacement work.
220KV	Kalwa - Airoli - Knowledge Park.	23-Apr-11	17.28	23-Apr-11	17.50	To remove bird nest.
220KV	Temghar-Colourchem	23-Apr-11	15.30	23-Apr-11	16.35	To replace decapped bottom phase pilot.
220KV	Mahad-Nagothane	23-Apr-11	08.53	24-Apr-11	20.36	Replacement of old damaged insulator.
220KV	220 KV Bus Section-II @ Nasik GCR	23-Apr-11	09.07	23-Apr-11	14.55	Replacement of R & B Ph CT's.
220KV	220/100KV,200MVA ICT-I at Borivali.	23-Apr-11	11.10	23-Apr-11	17.00	To attend oil leakage.
220KV	220KV Bus Coupler at 400KV Kalwa	23-Apr-11	09.40	23-Apr-11	16.53	Red Hot attending.
220KV	220/132 KV 200 MVA ICT - II @ Raymand	23-Apr-11	09.32	23-Apr-11	18.35	Q.M.Work
220KV	Kandalgaon-Bhira	23-Apr-11	09.50	23-Apr-11	19.15	LA replacement work.
220KV	220/132KV 200MVA ICT-III at BBLSR	23-Apr-11	11.40	23-Apr-11	17.25	Q.M.Work.
220KV	Mudshingi-Talangade ckt- I	23-Apr-11	10.02	23-Apr-11	13.26	Q.M.Work
220KV	Khaparkheda-Kawlewada-I	23-Apr-11	11.33	23-Apr-11	18.14	Insulator string replacement.
220KV	Dhule-Chalisgaon	23-Apr-11	09.34	23-Apr-11	16.00	Q.M.Work
220KV	Khaperkheda - Wardha.	23-Apr-11	19.05	24-Apr-11	10.37	To control Koradi ICT-II loading.
220KV	Boisor - Dahanu	24-Apr-11	06.33	24-Apr-11	16.42	Maintenance work.
220KV	Kandalgaon-Bhira	24-Apr-11	09.45	24-Apr-11	17.34	Stringing of new 220KV Vile-Bagad line.
220KV	220/100 KV 200 MVA ICT II at Trombay	24-Apr-11	10.56	24-Apr-11	14.25	To attend red hot spot.
220KV	Vankuswade-Malharpath	24-Apr-11	14.48	24-Apr-11	15.50	V.T.Fuse fail
220KV	Karad-M'peth	24-Apr-11	14.48	24-Apr-11	15.50	V.T.fuse fail
220KV	Peth-Nigde	24-Apr-11	17.02	24-Apr-11	17.17	Distance protection.
220KV	220/33KV,50 MVA T/F-I at Malharpath.	24-Apr-11	14.48	24-Apr-11	15.55	V.T.fuse fail.
220KV	220/33KV,50 MVA T/F-II at Malharpath	24-Apr-11	14.48	24-Apr-11	15.55	V.T.fuse fail.
220KV	Karad - Nigade	24-Apr-11	17.51	24-Apr-11	18.11	Distance protection.
220KV	Chakan- Volkswageon	24-Apr-11	12.14	24-Apr-11	16.30	To attend R ph.C.T. leakage.
132KV	Pench - Kanhan	8-Apr-11	10.39	18-Apr-11	17.05	Replacement of relay & control pannel.
132KV	Kandhar-Mukhed	18-Apr-11	04.51	18-Apr-11	05.14	Tripped.
132KV	Main Bus - II @ Bhusawal	18-Apr-11	10.10	20-Apr-11	21.07	Replacement of Single Conductor to Duuble Conductor of Stub Bus
132KV	Khapri - Besa	19-Apr-11	08.55	19-Apr-11	12.10	To attend Red Hot Spot
132KV	Chalisgaon - Kannad	20-Apr-11	20.15	20-Apr-11	20.20	Tripped on FTR
132KV	Chikhali - Mehakar	20-Apr-11	00.16	20-Apr-11	01.10	Y phase PT Burst at Mehkar S/S
132KV	Malegaon - Mehekar	20-Apr-11	00.16	20-Apr-11	02.15	Y Phase PT Burst at Mehkar S/S
132KV	Chinchwad-Baja Auto	21-Apr-11	08.30	21-Apr-11	17.01	Removing BusSection isolator for providing Bus Section Breaker.
132KV	Chinchwad-Rahatri	21-Apr-11	08.30	21-Apr-11	17.01	Removing BusSection isolator for providing Bus Section Breaker.
132KV	Chinchwad-Chakan	21-Apr-11	08.30	21-Apr-11	17.21	Removing BusSection isolator for providing Bus Section Breaker.
132KV	Paras-Malkapur	21-Apr-11	15.35	21-Apr-11	15.55	B-Ph PT fuse blown up.
132KV	Malkapur - Khamgaon	21-Apr-11	15.35	21-Apr-11	15.54	B-Ph PT fuse blown up.

132KV	Malkapur-Motala	21-Apr-11	15.35	21-Apr-11	15.53	B-Ph PT fuse blown up.
132KV	Malkapur-Bodwad	21-Apr-11	15.35	21-Apr-11	15.56	B-Ph PT fuse blown up.
132KV	Khadka-Malkapur	21-Apr-11	15.35	21-Apr-11	15.55	B-Ph PT fuse blown up.
132KV	Girwali - Kej	22-Apr-11	17.04	22-Apr-11	17.22	Distance Protection.
132KV	Girwali-Parli	23-Apr-11	01.30	23-Apr-11	07.25	D/P,R-Ph.
132KV	Ambazari-Khaperkheda - II	23-Apr-11	15.09	23-Apr-11	15.40	D/P,B/U E/F.
132KV	Ambazari-Manakapur Ckt.II	23-Apr-11	15.09	23-Apr-11	15.40	D/P,B/U E/F.
110KV	Borivali-Borivali (Borivali-Borivali-II)	22-Apr-11	12.45	22-Apr-11	18.40	Attending Hot Spot @ MSETCL End.
110KV	Borivali-Borivali Tata-II	24-Apr-11	09.10	24-Apr-11	16.04	To attend hot spot.
100KV	Kalwa - Salsette - II	5-Apr-11	10.56	22-Apr-11	08.42	From Kalwa End
100KV	Kalwa-Mukund I	21-Apr-11	11.44	21-Apr-11	12.07	B/Up protection.
100KV	Kalwa-Kalyan	22-Apr-11	08.48	22-Apr-11	12.45	Line Will be Open @ Tata end Due to 110KV Bus Voltage @ Kalya
100KV	Kalwa-Nocil I	22-Apr-11	10.06	22-Apr-11	10.35	Tripped on Bird Fault.
100KV	Kalwa-Nocil I	22-Apr-11	11.35	22-Apr-11	13.40	Replacement of Line Side B Ph Jumper.
132KV	Gangakhed - Kandhar	13-Apr-11	01.40	13-Apr-11	09.06	Distance Protection
132KV	Kanhan-Pardi	13-Apr-11	10.30	13-Apr-11	15.07	Q.M.Work.
132KV	Malkapur - Khamgaon	13-Apr-11	10.45	13-Apr-11	15.56	Replacement of Line Matching Unit.
132KV	Jalgaon - Dhrangaon	13-Apr-11	13.20	13-Apr-11	13.50	Distance Protection.
132KV	Pusad-Umarkhed	13-Apr-11	15.04	13-Apr-11	19.28	Stringing Work of 400KV Double Circuit Bhadrawati-Parli Line.
132KV	Talegaon-Arvi	13-Apr-11	10.10	13-Apr-11	12.25	For Attending Hot Spot on Line Isolator of Above Ckt.
132KV	Tiwsa-Talegaon Ckt.	13-Apr-11	12.45	13-Apr-11	14.20	For Attending Hot Spot on Line Isolator of Above Ckt.
132KV	Mankapur - Uppalwadi	13-Apr-11	10.15	13-Apr-11	15.39	Bus Section-I Maintainance Work @ Uppalwadi
132KV	Lonand - Phaltan - I	14-Apr-11	09.55	14-Apr-11	10.42	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Phaltan - II	14-Apr-11	09.55	14-Apr-11	10.15	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Veer	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Vai	14-Apr-11	09.55	14-Apr-11	10.13	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Polochem	14-Apr-11	09.54	14-Apr-11	10.14	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Chavanoffwar	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/22 KV 50 MVA T/F - I @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/22 KV 50 MVA T/F - II @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/11 KV 25 MVA T/F - I @ Loanad	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/11 KV 25 MVA T/F - II @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	Bus Section -II at Boiser	15-Apr-11	07.20	15-Apr-11	17.00	132KV bus section-I insulator replacement.
132KV	Bus Section -I at Boiser	15-Apr-11	07.20	15-Apr-11	17.00	132KV bus insulator replacement work.
132KV	Butibori-MIDC Khapri	15-Apr-11	19.04	15-Apr-11	22.51	Dist.Prot.operated Z-I,B-Ph.
132KV	Beed - Beed	15-Apr-11	13.27	15-Apr-11	13.48	Dist.Prot.operated B-Ph.
132KV	Ujani-Umarga	17-Apr-11	17.55	17-Apr-11	18.55	Distance protection.
132KV	Chakur - Udgir	17-Apr-11	17.05	17-Apr-11	17.22	Distance protection.
132KV	Purna-Basmat	17-Apr-11	14.35	17-Apr-11	20.40	Distance protection.
132KV	Lalkhedi - Durgwada	17-Apr-11	09.07	17-Apr-11	09.15	Distance protection.
132KV	Harangul-Chakur	17-Apr-11	17.05	17-Apr-11	17.22	Distance protection
100KV	Chinchwad - Talegaon	11-Apr-11	16.37	11-Apr-11	19.15	Distance protection