

LINE OUTAGES FOR THE WEEK

FROM 16-Apr-12 TO 22-Apr-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE II - CHDPR	20-Apr-12	22.09	21-Apr-12	03.28	Convertor Transformer work at Padghe end.
400KV	400/220 KV,500MVA ICT-II at Deepnagar.	10-Jan-12	10.30	19-Apr-12	20.01	Connection of L V Side Jumpers of ICT-II and one Span Stringing Work.
400KV	Aux.Bus @ Kolhapur	27-Mar-12	12.51	29-Apr-12	19.15	Alignment and servicing of C bus pentograph isolator.
400KV	Dhule-S'Sarovar I	12-Apr-12	13.50	17-Apr-12	11.27	Over Voltage.
400KV	Kolhapur - Mapusa - I	14-Apr-12	18.06	17-Apr-12	10.52	Over Voltage.
400KV	Bhusawal- Aurangabad	15-Apr-12	17:01	16-Apr-12	08.45	Over Voltage.
400KV	Karad - Kolhapur - II	15-Apr-12	17:41	16-Apr-12	09.22	Over Voltage.
400KV	Newkoyna - Jaigad - I	16-Apr-12	09.59	16-Apr-12	14.55	Cold Line Washing of Insulators.
400KV	Karad-Jaigad II	16-Apr-12	15.30	17-Apr-12	07.55	Cold Line Insulator Washing.Ready for Charging @ 18.27 dt 16.04.2012.
400KV	Bhusawal- Aurangabad	16-Apr-12	17.32	17-Apr-12	08.29	Over Voltage.
400KV	Chandrapur - Parli - I	16-Apr-12	15.58	16-Apr-12	16.50	Line Reactor Oil Topping Work & Attending Oil Leakage.
400KV	50MVAR Reactor C'Pur - Parli - I at Parli end	16-Apr-12	16.50		Continued.	Filtration work
400KV	400/220KV 500MVA ICT- I at Khaperkheda	17-Apr-12	01.05	17-Apr-12	05.20	Due to D C Supply Problem.
400KV	80 MVAR Bus Reactor @ Nagothane	17-Apr-12	09.00	17-Apr-12	18.05	R.M.Work & Testing Work.
400KV	400/220KV 500MVA ICT- III at Dhule	17-Apr-12	18.00	17-Apr-12	18.59	Weather Proff Repair.
400KV	Bhusawal- Aurangabad	17-Apr-12	17.40	18-Apr-12	07.40	Over Voltage.
400KV	Koradi -Bhusawal	17-Apr-12	17.17	17-Apr-12	17.31	Distance Protection.
400KV	Solapur-Solapur(PGCIL)	17-Apr-12	16.24	17-Apr-12	16.51	Distance Protection.
400KV	400/220KV 315MVA ICT-III at Karad.	17-Apr-12	15.14	19-Apr-12	01.00	Changing of Bay and Stringing work
400KV	Dhule-Sar'Sarovar - II	18-Apr-12	03.02	21-Apr-12	08.12	Over Voltage.
400KV	Bhusawal- Aurangabad	18-Apr-12	17.41	19-Apr-12	08.49	Over Voltage.
400KV	Kolhapur - Mapusa - I	18-Apr-12	22.06	19-Apr-12	10.32	Over Voltage.
400KV	400 KV Tie Breaker @ Lamboti	18-Apr-12	10.58	18-Apr-12	18.53	DCRM Testing.
400KV	400/220 KV 500 MVA ICT-I @ Deepnagar	18-Apr-12	21.54	18-Apr-12	22.48	Oil Temp.High Indication.
400KV	Karad-Jaigad I	18-Apr-12	22.27	19-Apr-12	06.58	Dist.Protection.
400KV	Bhusawal- Aurangabad	19-Apr-12	17.01	21-Apr-12	08.47	Over Voltage.
400KV	400/220KV,315 MVA ICT-III at Lonikand.	19-Apr-12	07.09	19-Apr-12	16.55	Maintenance and testing work.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	19-Apr-12	16.17	19-Apr-12	17.20	NDR.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	19-Apr-12	16.17	19-Apr-12	17.17	NDR.
400KV	Padgha - Talegaon (PG)	19-Apr-12	09.21	19-Apr-12	18.19	Cold line washing of D/C line.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	19-Apr-12	08.52	20-Apr-12	01.44	Relay retrofitting work.
400KV	400/220 KV 315 MVA ICT- I @ Parly.	19-Apr-12	08.57	19-Apr-12	18.17	Measurement of tan delta of ICT bushing.
400KV	Kolhapur - Mapusa - I	20-Apr-12	03.38	20-Apr-12	09.18	Over Voltage.
400KV	Lonikand-Kalwa	20-Apr-12	07.58	20-Apr-12	19.10	R.M.Work,cold line washing of insulator.
400KV	400/220KV 315MVA ICT-I at Kharghar	20-Apr-12	08.32	20-Apr-12	18.07	R.M.Work and Testing work.
400KV	400/220KV 315 MVA ICT-I @ Padgha	20-Apr-12	08.48	20-Apr-12	18.37	Bay maintenance work.
400KV	New Koyna - Karad - I	20-Apr-12	17.05	21-Apr-12	07.55	Due to heavy rain.Trip at Karad end.
400KV	400/220KV,315MVA ICT-I at Karad	20-Apr-12	17.04	20-Apr-12	19.44	NDR
400KV	400/220 KV,500MVA ICT-II at Deepnagar.	20-Apr-12	07.20	20-Apr-12	10.15	ICT was charged on No load and H/T to release trapped air.Load taken.
400KV	400/220KV 500MVA ICT- III at Dhule	20-Apr-12	11.47	20-Apr-12	15.31	To attend heavy sparking on bus side isolator.
400KV	400/11.5/6.6 KV 70 MVA Stn.T/F 5B @ 400	20-Apr-12	08.23	20-Apr-12	16.53	Q.M.Work
400KV	Kolhapur - Mapusa - I	20-Apr-12	21.34	21-Apr-12	09.13	Over Voltage
400KV	400/220KV 315 MVA ICT III at Bhusawal	21-Apr-12	09.12	21-Apr-12	18.12	Replacement of NDR Relay
400KV	400/220 KV 315 MVA ICT - II @ Koradi.	21-Apr-12	09.29	22-Apr-12	00.12	Replacement of Relay
400KV	Karad-Jaigad I	21-Apr-12	10.26	21-Apr-12	23.31	TBC Wiring and Trials
400KV	Dhule-S'Sarovar I	21-Apr-12	08.19	21-Apr-12	19.07	Replacement of Insulator
400KV	Kolhapur - Mapusa - II	21-Apr-12	22.41	22-Apr-12	10.42	Over Voltage
400KV	Bhusawal- Aurangabad	21-Apr-12	17.06		Continued.	Over Voltage

400KV	Dhule-S'Sarovar I	22-Apr-12	02.19	22-Apr-12	10.02	Over Voltage
400KV	Koradi - Akola	22-Apr-12	08.23	22-Apr-12	13.05	Replacement of B Phase Jumper
400KV	Karad-Jaigad II	22-Apr-12	09.21	22-Apr-12	22.53	TBC Wiring and Trials
400KV	Dhule - S'Sarovar- II	22-Apr-12	16.18		Continued.	Over Voltage
220KV	Mulund - Bhandup (GIS)	12-Apr-12	08.24	16-Apr-12	15.30	Railway crossing stringing work.
220KV	Chandrapur - Warora	12-Apr-12	15.17	16-Apr-12	09.36	To control Wardha-Warora line loading.
220KV	Bhosari-C'enka	15-Apr-12	22:04	16-Apr-12	00:27	Jumpering Work.
220KV	220 KV Bus Section - II at Bhosari.	15-Apr-12	22:10	16-Apr-12	00:22	Jumpering Work.
220KV	Kalwa - Borivali	16-Apr-12	00:02	16-Apr-12	03:13	Railway Crossing Work.
220KV	Uran -Apta-III	16-Apr-12	02:57	16-Apr-12	03:27	Distance Protection.
220KV	ONGC-JNPT	16-Apr-12	10.15	16-Apr-12	20.15	Line Maintenance Work.
220KV	220/110KV, 200MVA T/F-III at Mudshingi	16-Apr-12	10.03	16-Apr-12	19.30	Q.M.Work.
220KV	Uran - Apta (HOC)	16-Apr-12	11.42	16-Apr-12	19.57	Testing Work.
220KV	Nivali-Pawas	16-Apr-12	09.55	16-Apr-12	16.02	For Attending Red Hot Spot.
220KV	Padgha-Temghar I	16-Apr-12	10.36		Continued.	To Control Padghe ICT Loading.
220KV	Padgha - Temghar - II	16-Apr-12	10.36	20-Apr-12	06.56	To Control Padghe ICT Loading.
220KV	Warora-Wardha	16-Apr-12	09.31	17-Apr-12	05.11	Distance Protection Operated Z-I R Ph.
220KV	Bus Coupler at Varsova	16-Apr-12	22.32	16-Apr-12	23.51	For attending air leakage from main compresor.
220KV	New Paras TPS - Chikhali - II	16-Apr-12	07.52	17-Apr-12	05.31	Erection Work.
220KV	Auxiliary Bus @ Chikhli	16-Apr-12	07.52	17-Apr-12	05.31	Erection Work.
220KV	Karad - Peth	17-Apr-12	09.10	17-Apr-12	13.23	Replacement of TNC Switch.
220KV	Chandrapur - Warora	17-Apr-12	05.25	17-Apr-12	09.18	To Control Wardha-Warora L/L.
220KV	Uran - JNPT	17-Apr-12	10.46	17-Apr-12	19.55	Replacement of Insulator.
220KV	Mahad - Century Enka	17-Apr-12	10.48	17-Apr-12	18.00	Maint. Work.
220KV	Uran -Apta-III	17-Apr-12	11.13	17-Apr-12	19.40	Replacement of Insulator.
220KV	Pedambe - Oni	17-Apr-12	14.25	17-Apr-12	14.50	Distance Protection.
220KV	Oni - Kharepatan	17-Apr-12	14.25	17-Apr-12	14.31	Back up Protection.
220KV	Parly - Harangool - II	17-Apr-12	08.50	17-Apr-12	11.51	Disc Replacement Work @ Loc.1,2.
220KV	Chandrapur - Warora	18-Apr-12	13.11	18-Apr-12	15.52	Dist.prot,B-Ph.
220KV	Tarapur - Borivali	18-Apr-12	08.17	18-Apr-12	19.32	Annual Maintenance work.
220KV	Bale-Lamboti II	18-Apr-12	08.25	18-Apr-12	18.28	Repl.of conductor.
220KV	Apta-Uran-IV	18-Apr-12	10.25	18-Apr-12	17.53	Testing work.
220KV	Kandalgaon-Lonand	19-Apr-12	16.17	19-Apr-12	16.40	Y-Ph LA burst at Lonand.
220KV	Lonand - Baramati	19-Apr-12	16.17	19-Apr-12	16.42	Y-Ph LA burst at Lonand.
220KV	Lonikand -Theur - II	19-Apr-12	08.01	19-Apr-12	14.19	Annual maintenance work.
220KV	Babaleshwar - Alephata	19-Apr-12	09.08	19-Apr-12	20.04	Maint.work.
220KV	Borivali-Tarapur	19-Apr-12	08.19	19-Apr-12	19.40	Hot spot attending.
220KV	220/110 KV 200 MVA T/F @ Ogalewadi	19-Apr-12	10.10	19-Apr-12	15.15	Fire detector work.
220KV	Main Bus @ Alephata	19-Apr-12	09.08	19-Apr-12	17.21	Q.M.Work
220KV	Jejuri-Jejuri I	19-Apr-12	09.22	19-Apr-12	18.33	Retrofitting of 29 D isolator.
220KV	Pophali - KDPH	19-Apr-12	10.05	19-Apr-12	17.50	Replacement of old disc insulator by New anti-fog insulator.
220KV	Chinchwad - Parvati	19-Apr-12	09.31	19-Apr-12	15.53	Bus sectionalisation work.
220KV	220/132KV 200 MVA ICT- I @ Amravati	19-Apr-12	08.38	19-Apr-12	15.53	Q.M.Work
220KV	Girwali - Parbhani	19-Apr-12	07.00	19-Apr-12	18.19	Replacement of guy piece at loc.No305 and 303.
220KV	Theur-Phursungi-I	19-Apr-12	16.25	19-Apr-12	18.12	H/T due to tripping of Jejuri ICT.
220KV	Chinchwad - Chakan	19-Apr-12	22.24	19-Apr-12	23.31	Hot spot attended.
220KV	Dhule-Chalisgaon	20-Apr-12	06.00	20-Apr-12	19.02	Taking Chalisgaon-Malegaon on own breaker at Chalisgaon.
220KV	Chalisgaon - Malegaon	20-Apr-12	06.00	20-Apr-12	10.06	Taking Chalisgaon-Malegaon on own breaker at Chalisgaon.
220KV	Pophali - KDPH	20-Apr-12	09.30	20-Apr-12	18.40	Replacement of insulator.

220KV	Apta-Nagothane	20-Apr-12	09.21	20-Apr-12	15.48	Replacement of insulator.
220KV	Mahape - Siemens	20-Apr-12	09.16	21-Apr-12	16.10	Breaker overhuling work.Line on TBC.
220KV	Nasik - Airoli - Knowledge Park	20-Apr-12	09.03	20-Apr-12	18.04	Bus isolator problem.
220KV	Bus Section-II at Airoli Knowledge Park.	20-Apr-12	09.05	20-Apr-12	18.03	Bus isolator problem.
220KV	Jambhul - Anandnagar	20-Apr-12	09.11	20-Apr-12	19.43	Maintenance work.
220KV	Bus Section III @ Temghar.	20-Apr-12	09.10	20-Apr-12	16.31	Hot Spot.
220KV	Borivali -Tarapur	20-Apr-12	08.18	20-Apr-12	18.19	Annual maintenance work.
220KV	Kandalgaon - Pirangut	20-Apr-12	11.35	20-Apr-12	11.48	Distance protection.
220KV	Babaleshwar - Ranjangaon	20-Apr-12	13.23	20-Apr-12	13.46	Distance protection.
220KV	Vankushwadi - MIDC Satara.	20-Apr-12	16.12	20-Apr-12	16.37	Distance protection.
220KV	Vankuswadi - MIDC Satara- II	20-Apr-12	16.12	20-Apr-12	17.05	Distance protection.
220KV	Karad-Pophali	20-Apr-12	17.54	20-Apr-12	18.30	Distance protection.
220KV	Miraj - Mhaisal	20-Apr-12	21.21	20-Apr-12	21.40	Distance protection.
220KV	220/132KV 100MVA ICT at Butibori	20-Apr-12	12.43	20-Apr-12	19.06	Oil leakage in HV side Y ph.CT.
220KV	Dhule - Amalner	20-Apr-12	10.30	20-Apr-12	18.48	Stringing of 220KV Dhule-Dondaicha reorientation line at Dhule S/S.
220KV	Dhule - Malegaon	20-Apr-12	11.04	20-Apr-12	18..36	Stringing of 220KV Dhule-Dondaicha reorientation line at Dhule S/S.
220KV	Aurangabad - Padegaon - I.	20-Apr-12	12.32	20-Apr-12	16.08	For auto reclosing taken in service.
220KV	Chalisgaon - Malegaon	20-Apr-12	10.16		Continued.	Own Bkr.Prob(Line on TBC)
220KV	Babaleshwar - Chalisgaon	21-Apr-12	08.26	21-Apr-12	19.12	Clipping of suspension clamps
220KV	Uran-ONGC	21-Apr-12	12.15	21-Apr-12	17.46	Testing work
220KV	Boisor - Dahanu	21-Apr-12	08.42	21-Apr-12	12.18	Hot Spot
220KV	220/132KV 200MVA ICT-III at BBLSR	21-Apr-12	09.05	21-Apr-12	13.45	Q.M.Work
220KV	Pophali - KDPH	21-Apr-12	09.30	21-Apr-12	18.40	Replacement of Disc Insulator
220KV	Raymond-Washala	21-Apr-12	10.02	21-Apr-12	13.50	Line maint.work
220KV	Trombay - Tifil	21-Apr-12	10.24	21-Apr-12	15.44	Jumper Nut Bolt tightening and R.M.Work
220KV	220/132 KV 200 MVA ICT - II @ Raymand	21-Apr-12	11.04	21-Apr-12	16.45	Testing work
220KV	Aarey-Versova	21-Apr-12	12.27	22-Apr-12	03.29	LILO Work
220KV	A Bus @ Boiser	21-Apr-12	08.20	22-Apr-12	19.58	P.T.maint.and Isolator maint.work
220KV	Halkarni - Amona	21-Apr-12	08.48	21-Apr-12	17.50	LILO Work
220KV	220/132 KV 150 MVA T/F @ Boiser	21-Apr-12	14.45	21-Apr-12	16.10	Maintenance work
220KV	Babaleshwar - Ranjangaon	22-Apr-12	02.57	22-Apr-12	03.05	Distance Protection
220KV	Boiser-Versova	22-Apr-12	07.35	22-Apr-12	12.10	Hot Spot
220KV	Jejuri - Parvati	22-Apr-12	10.06	22-Apr-12	12.22	To attend oil Leakage
220KV	Tillary-Amona	22-Apr-12	08.45	22-Apr-12	16.34	Distance protection
220KV	Paras - Akola - I	22-Apr-12	05.29	22-Apr-12	08.01	Bus Bar Prot.operated at Paras
220KV	Main Bus II at New Paras	22-Apr-12	05.29	22-Apr-12	08.00	Heavy sparking on Y Phase Isolator of GT-3
220KV	Chikali - Paras - I	22-Apr-12	05.29	22-Apr-12	08.02	Bus Bar Prot.operated at Paras
220KV	Bus Coupler at New Paras TPS	22-Apr-12	05.29	22-Apr-12	08.00	Heavy sparking on Y Phase Isolator on GT-3
132KV	Padegaon - Sat	17-Apr-12	06.17	17-Apr-12	14.22	B Ph. C T Burst @ Sat End.
132KV	Nanded - Vishnupuri	19-Apr-12	07.05	19-Apr-12	17.20	Stringing work of 220KV partly-Nanded line crossing at loc.No.286 and 28
132KV	Nanded - Vishnupuri - II	19-Apr-12	07.06	19-Apr-12	17.20	Stringing work of 220KV partly-Nanded line crossing at loc.No.286 and 28
132KV	Paranda-Bhoom	20-Apr-12	18.26	20-Apr-12	19.24	Distance protection.
132KV	Jalgaon - Bambhori	21-Apr-12	11.37	21-Apr-12	11.49	Distance Protection
110KV	Borivali(T)-Borivali(M)-I	19-Apr-12	07.34	19-Apr-12	09.33	For testing and charging of New Transformer NO.8 at Borivali.
100KV	Tata - Borivali - II	22-Apr-12	15.01	22-Apr-12	19.20	Premansoon maint.work
100KV	Borivali-Tata-I	22-Apr-12	09.24	22-Apr-12	14.00	Pre Mansoon maint work