

LINE OUTAGES FOR THE WEEK

FROM 16-May-11 TO 22-May-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE I -CHDPR	16-May-11	11.46	17-May-11	13.20	Attending sparking on R ph.isolator.Ckt on TBC-II.
400KV	Khadka-Deepnagar-I	11-May-11	08.23	16-May-11	17.28	Replacement of Bus I and II isolator.Ckt on TBC.
400KV	Dhule-Sar'Sarovar - I	15-May-11	00.01	17-May-11	17.55	Over Voltage.
400KV	Bhusawal- Aurangabad	15-May-11	18.36	17-May-11	11.02	Over Voltage.
400KV	Lonikand-Kalwa	16-May-11	15.25	16-May-11	17.21	To attend hot spot isolator.
400KV	Karad-Kolhapur-II	16-May-11	16.06	16-May-11	18.15	Trip PDR at Kolhapur end.
400KV	New Koyna - Jaigad - II	16-May-11	19.08	16-May-11	19.56	Distance protection.
400KV	Newkoyna - Jaigad - I	16-May-11	19.40	16-May-11	20.16	Distance protection.
400KV	Nagothane-Dabhol-I	16-May-11	19.47	17-May-11	13.16	Distance protection.
400KV	New Koyna-Jaigad II	16-May-11	20.57	17-May-11	00.40	Distance protection.
400KV	Newkoyna - Jaigad - I	16-May-11	20.15	17-May-11	00.36	Distance protection.
400KV	Newkoyna - Jaigad - I	17-May-11	01.10	17-May-11	08.31	Distance protection.
400KV	New Koyna - Jaigad - II	17-May-11	02.04	17-May-11	02.57	Distance protection.
400KV	New Koyna - Jaigad - II	17-May-11	03.15	17-May-11	12.09	Distance protection
400KV	Dhule-Sar'Sarovar - II	17-May-11	17.23	19-May-11	09.49	Trip command received from Thyristor monitoring relay
400KV	Bhusawal- Aurangabad	17-May-11	20.56	18-May-11	07.33	Over Voltage
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	17-May-11	08.27	17-May-11	22.13	Premansoon Maint.work
400KV	New Koyna - Jaigad - II	17-May-11	22.53	18-May-11	19.49	Distance Protection
400KV	Dabhol - Nagothane - I	17-May-11	19.15	17-May-11	21.33	Distance Protection
400KV	Dabhol - Nagothane - I	17-May-11	21.39	19-May-11	17.53	Distance Protection,(declared fauly)Charged from Nagothana End.
400KV	Newkoyna - Jaigad - I	17-May-11	15.06	18-May-11	16.43	Isolator work by JSW
400KV	New Koyna - Jaigad - II	17-May-11	20.31	17-May-11	22.27	Distance Protection
400KV	Chandrapur 400 KV HVDC-II	18-May-11	15.34	18-May-11	17.10	To attend PG-I Isolator Prob.(ckt is on TBC)
400KV	New Koyna - Jaigad - II	19-May-11	00.53	19-May-11	19.23	Distance Protection
400KV	Newkoyna - Jaigad - I	19-May-11	01.38	19-May-11	02.29	Distance Protection
400KV	Newkoyna - Jaigad - I	19-May-11	03.17	19-May-11	19.06	Distance Protection
400KV	Dabhol-Nagothne	19-May-11	19.56	19-May-11	20.17	To Close Isolator @ Dabhol End.
400KV	Bhusawal- Aurangabad	19-May-11	21.02	20-May-11	06.09	Over Voltage.
400KV	Koradi-Bhilai	19-May-11	06.43	19-May-11	18.30	Maint.Work.
400KV	Wardha - Akola - I	19-May-11	17.12	19-May-11	17.19	Tripped @ Wardha End Only.
400KV	Wardha - Akola - II	19-May-11	17.12	19-May-11	17.28	Tripped @ Wardha End Only.
400KV	Chandrapur - Parli - I	19-May-11	16.05	19-May-11	16.33	Distance Protection.R Ph.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	19-May-11	08.46	19-May-11	16.17	Testing Work.
400KV	Dhule-Sar'Sarovar - I	20-May-11	00.05		Continued.	Over Voltage.
400KV	New Koyna - Jaigad - II	20-May-11	04.41	20-May-11	05.08	Distance Protection.
400KV	Dabhol - Nagothane - I	20-May-11	05.16	20-May-11	07.12	Distance Protection.
400KV	Dabhol - New Koyna - I	20-May-11	06.00	21-May-11	15:00	Distance Protection.
400KV	Lonikand-Karad	20-May-11	15.11	20-May-11	15.34	Distance protection.
400KV	Bhusawal- Aurangabad	20-May-11	13.35	21-May-11	06.20	Over Voltage.
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	20-May-11	09.00	20-May-11	21.34	Commissioning of CTR system.
400KV	400/220KV 315 MVA ICT- II @ Padgha	20-May-11	09.53	20-May-11	19.21	Maintenance work.
400KV	New Koyna-Jaigad II	20-May-11	10.29	20-May-11	15.23	Insulator replacement
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	20-May-11	11.43	20-May-11	14.54	Premansoon maintenance work.
400KV	400/220KV,315MVA ICT-I at Karad	21-May-11	10.32	21-May-11	15.19	Attending Hot Spot.
400KV	Lonikand-Karad	21-May-11	15.36	21-May-11	15.40	Transient tripping.
400KV	Dabhol - New Koyna - I	21-May-11	19.53	21-May-11	20.44	Distance protection.
400KV	Bhusawal- Aurangabad	21-May-11	21.45	22-May-11	05.58	Over Voltage.

400KV	Dabhol - New Koyna - I	22-May-11	09.09	22-May-11	19.00	Insulator washing.
400KV	New Koyna-Jaigad II	22-May-11	10.20	22-May-11	19.28	Insulator cleaning
400KV	Bhusawal- Aurangabad	22-May-11	21.48	23-May-11	05.48	Over Voltage.
400KV	Padgha - Nagothane- II	22-May-11	14.35	23-May-11	01.45	Distance protection
220KV	Khaperkheda - Wardha.	2-May-11	19.15	19-May-11	16.11	To control Koradi ICT loading.
220KV	Ambazari - Abhijeet	2-May-11	19.52	16-May-11	11.37	To control Koradi ICT loading.
220KV	220/6.6 KV,40 MVA Stn.T/F-III at Khaparkhe	10-May-11	16.16	22-May-11	18.06	Overhauling Work.
220KV	Chandrapur-Warora - I	14-May-11	18.16	19-May-11	08.20	To Control 220KV Warora-Hinganghat ckt Loading
220KV	Bale-Murud	15-May-11	08.32	17-May-11	08.50	To control Parli ICT loading.
220KV	Bale-Usmanabad	15-May-11	08.32	17-May-11	08.50	To control Parli ICT loading
220KV	Dondaicha - Jamde - I	15-May-11	14.02	16-May-11	08.08	Distance protection.
220KV	Pedambe - Pophali - II	15-May-11	19.24	16-May-11	01.15	Single phasing.
220KV	Aurangabad-Jalna-II	15-May-11	19.37	16-May-11	00.01	220KV R ph.CT burst.
220KV	Talangade-Mumewadi-II	16-May-11	09.37	16-May-11	17.39	Insulator replacement.
220KV	Aurangabad-Jalna-I	16-May-11	09.25	16-May-11	12.34	R.M.Work
220KV	Talandge - Sawantwadi	16-May-11	09.54	16-May-11	17.06	Tree cutting work.
220KV	Kandalgaon - Topworth	16-May-11	12.45	16-May-11	17.40	Hot spot attending.
220KV	Pawas-Kharepatan	16-May-11	21.45	17-May-11	15.13	Distance protection.
220KV	220/132 KV 200 MVA ICT @ Ambazari	16-May-11	10.11	16-May-11	14.45	Tan delta measurement work of bushings and CTs.
220KV	220/132 KV,200 MVA ICT-II at Chikhli	16-May-11	10.02	16-May-11	15.45	Replacement of jumper.
220KV	Aurangabad-Jalna-II	16-May-11	09.26	16-May-11	12.35	Q.M.Work
220KV	Abhijeet-Wardha-I	16-May-11	11.38		Continued.	To control Koradi ICT loading.
220KV	New Koyna - Pawas	17-May-11	01.07	17-May-11	01.45	Distance protection.
220KV	Aurangabad-Shendra	17-May-11	10.36	17-May-11	12.51	To attend Hot Spot
220KV	Badnera - Akola - I	17-May-11	17.29	17-May-11	17.49	Distance Protection
220KV	New Parly - Beed - I	17-May-11	21.38	17-May-11	22.35	Distance Protection
220KV	Talangade-Mumewadi-II	17-May-11	09.08	17-May-11	18.22	Replacement of Old H/W by New
220KV	Kandalgaon-Lonand	17-May-11	10.07	17-May-11	18.15	Premansoon maint.work
220KV	Borivali-Mulund	17-May-11	12.28		Continued.	Cable Termination work of 220KV Bhandup GIS Up to 10-06-2011.
220KV	Babaleshwar - Ranjangaon	17-May-11	10.12	17-May-11	15.40	Charged from Ranjangaon end
220KV	Vankuswadi - MIDC Satara- II	17-May-11	11.30	17-May-11	16:30	Replacement of L.A.
220KV	NewKoyna - Pawas	17-May-11	15.56	17-May-11	18.00	Insulator washing work
220KV	Apta-Kalwa	17-May-11	12.26	17-May-11	16.05	Distance protection
220KV	Kalwa I-Taloja	17-May-11	12.31	17-May-11	20.12	Distance Protection
220KV	Chinchwad - Parvati	17-May-11	12.31	17-May-11	12.40	Distance Protection
220KV	220/22KV,50MVA T/F-I at Taloja	17-May-11	12.35	17-May-11	18.45	Differential Protection
220KV	Kalmeshwar - Pandurna	18-May-11	09.06	18-May-11	17.52	Testing & Commisioning of Dist.Prot.Relay.
220KV	220/132KV 150MVA ICT @ Boisor	18-May-11	14.54	18-May-11	16.30	Bushing Measurement.
220KV	220/132KV 150 MVA ICT @ Ambazari.	18-May-11	13.03	18-May-11	15.25	To attend Oil Leakage
220KV	Usmanabad-Barshi	18-May-11	09.40	18-May-11	19.20	Q.M.Work
220KV	220/132 KV 100 MVA ICT @ Kawlewada	18-May-11	09.50	18-May-11	16.30	Q.M.Work
220KV	Karad-Pedambe	19-May-11	15.42	19-May-11	16.02	Distance Protection.
220KV	Warora-Wardha	19-May-11	08.58	19-May-11	09.18	Distance Protection.
220KV	Talangade-Mumewadi-II	19-May-11	09.21	19-May-11	17.57	Replacement of Hardware.
220KV	Talangade-Mudshingi-II	19-May-11	09.45	19-May-11	13.50	Q.M.Work.
220KV	Main Bus @ Alephata	19-May-11	09.00	19-May-11	18.53	Maintenance Work.
220KV	Chandrapur - Rly TSS - II	19-May-11	09.35	19-May-11	15.21	Attending Hot Spot on 29A,20B Isolator .

220KV	Chandrapur-Wani	19-May-11	08.24	19-May-11	17.16	Replacement of Faulty Disc Insulator of B Ph.@ Loc No.104.
220KV	Girwali - Parbhani	19-May-11	08.12	19-May-11	17.12	400KV Stringing Work of PGCIL Wardha-Parly D/C Line Crossing
220KV	220/66KV 150 MVA ICT- II @ Gadchandur	19-May-11	21.40	19-May-11	21.43	Over Current B Ph Alongwith 66KV Sicom-I(Tripped on Backup E/F
220KV	Dondaicha - Jamde - I	20-May-11	11.53	20-May-11	12.10	Tripped
220KV	Pedambe-Newkoyna	20-May-11	10.20	20-May-11	11.19	At N.Koyna end,BKR problem taken on TBC.
220KV	Dahanu-Versova	20-May-11	13.13	20-May-11	14.52	Distance protection.
220KV	Versova - Goregaon	20-May-11	13.13	20-May-11	14.52	Distance protection.
220KV	Chinchwad - Parvati	20-May-11	08.27	20-May-11	14.23	Reconductoring at LOC.No.23 to increase road clearance.
220KV	Padghe - Boisar (PGCIL)	20-May-11	09.15	20-May-11	17.29	Insulator replacement.
220KV	Raymond-Washala	20-May-11	10.09	20-May-11	15.03	Premansoon Maintenance work.
220KV	Kolshet-Khamba	20-May-11	10.05	20-May-11	18.21	.Insulator replacement
220KV	220/132 KV 200 MVA ICT - II @ Malegaon	20-May-11	10.57	20-May-11	18.26	Oil leakage.
220KV	220/100KV, 200MVA T/F-IV at Kalwa	20-May-11	11.30	20-May-11	15.40	Premansoon maintenance work.
220KV	Bus Section I at Nalasopara	20-May-11	11.30	20-May-11	15.15	Premansoon maintenance work.
220KV	220/100KV 200 MVA ICT- II @ Kolshet	20-May-11	13.10	20-May-11	17.17	Maintenance work.
220KV	Talangade-Mumewadi-II	20-May-11	09.03	20-May-11	18.46	Replacement of insulator.
220KV	New Paras TPS - Akola - I	20-May-11	09.15	20-May-11	17.18	Retrofitting work.
220KV	Bhugaon - IIPL	20-May-11	11.32	20-May-11	12.05	Connecting of wire bet.LA bus To LA counter.
220KV	220/132KV 100MVA ICT-I @ Padegaon	20-May-11	10.00	20-May-11	17.44	Q.M.Work
220KV	Girwali - Parbhani	20-May-11	07.50	20-May-11	19.47	Repl.of faulty insulator strings detected in PID testing.
220KV	220/132 KV 100 MVA ICT-II @ Parbhani	20-May-11	15.25	20-May-11	16.49	To attend B-Ph.isolator heavy sparking.
220KV	Wardha - Yawatmal	20-May-11	18.2818.48	20-May-11	Continued.	Distance protection R-Ph to E.
220KV	220/132 KV 200MVA ICT-II at BSL II	20-May-11	09.43	20-May-11	10.45	Rapping of Plastic cover on Buchholz.
220KV	Bhoisor - Bhoisor PGCIL-II	21-May-11	03.55	21-May-11	07.11	Trip Ckt.faulty.
220KV	Uran - JNPT	21-May-11	11.11	21-May-11	17.14	R.M.Work.
220KV	220/100KV 125 MVA ICT-II @ Kalwa	21-May-11	08.20	21-May-11	12.10	To attend oil leakage.
220KV	220/132 KV,200MVA ICT-I at Nasik GCR	21-May-11	09.05	21-May-11	15.57	CT replacement.
220KV	Nasik-Raymond	21-May-11	12.50	21-May-11	16.33	Premonsoon maintenance work.
220KV	Talangade-Mumewadi-II	21-May-11	09.06	21-May-11	18.25	Hardware replacement.
220KV	Chinchwad - Chakan	21-May-11	13.05	21-May-11	15.59	.Distance protection
220KV	Bhosari - Chakan	21-May-11	13.05	21-May-11	13.35	.Distance protection
220KV	Main Bus at Hinjewadi	21-May-11	09.10	21-May-11	14.40	Isolator alignment CB wiring and testing work.
220KV	Hingoli-Pusad	21-May-11	16.26		Continued.	To control Wardha-Y'mal L/L.
220KV	220/132KV 100MVA ICT at Butibori	21-May-11	08.45	21-May-11	12.50	To replace R-Ph LV side LA.
220KV	220/132KV 100 MVA ICT- I @ Parbhani	21-May-11	09.10		Continued.	Replacement of 220/132 KV 100 MVA ICT by 200 MVA ICT
220KV	Padghe - Nashik - II	22-May-11	00.14	22-May-11	15:07	Distance Protection.
220KV	220/100KV 125 MVA ICT-I @ Kalwa	22-May-11	11.05	22-May-11	14.46	100 KV Bus R & Y Ph support insulator string flashover
220KV	220/100KV 125 MVA ICT-II @ Kalwa	22-May-11	11.05	22-May-11	14.47	101 KV Bus R & Y Ph support insulator string flashover
220KV	220/100KV, 200MVA T/F-IV at Kalwa	22-May-11	11.05	22-May-11	11.21	102 KV Bus R & Y Ph support insulator string flashover
220KV	Kalwa - Borivali	22-May-11	07.26	22-May-11	15.33	Removal of damage E/W.
220KV	220/100KV,200MVA ICT-I at Borivali.	22-May-11	09.00	22-May-11	18.53	Premonsoon maintenance work.
220KV	Versova - Goregaon	22-May-11	09.45	22-May-11	12.31	To attend hot spot.
220KV	Babaleswar - Ranjangaon	22-May-11	16.05		Continued.	To control BBLSR ICT loading.
220KV	Dondaicha - Shahada	22-May-11	14.22	22-May-11	15.37	132KV Bus,PT burst at Sahada.
220KV	220/132 KV 100 MVA ICT @ Shahada	22-May-11	14.22	22-May-11	15.19	132 KV Bus,PT burst at Shahada.
220KV	Main Bus at Shahada	22-May-11	14.22	22-May-11	15.25	132 KV Bus,PT burst at Shahada.
220KV	220/132 KV 150 MVA T/F @ Boiser	22-May-11	22.57		Continued.	Oil filtration work.

132KV	Chikhali - Khamgaon	16-May-11	09.53	16-May-11	20.52	Replacement of jumper.
132KV	Chikhali - Buldana	16-May-11	09.57	16-May-11	15.50	Replacement of jumper.
132KV	Kalmeshwar-Saoner Ckt.	16-May-11	18.22	16-May-11	19.27	Backup prot.operated.
132KV	Girwali - Renapur	17-May-11	17.03	18-May-11	00.38	Distance Protection
132KV	Khapri - Besa	17-May-11	22.35	17-May-11	23.25	Distance Protection
132KV	Hingna-Khapri II	17-May-11	22.45	17-May-11	23.05	Distance Protection
132KV	Mehkar - Malegaon	17-May-11	10.10	20-May-11	14.30	Repl.of LA OLD RCC Structure
132KV	Kalmeshwar - Katol	18-May-11	16.28	18-May-11	16.48	Distance Protection.
132KV	Ambazari-Kalmeshwar	18-May-11	08.27	18-May-11	13.55	Replacement of R Phase CT
132KV	Jalgaon - Dhrangaon	18-May-11	08.50	20-May-11	17.25	Replacement of Bus Isolator
132KV	Bhusawal - Jalgaon - I	18-May-11	07.32		Continued.	Replacement of Isolator(Ckt.on TBC)
132KV	Dahanu - MIDC - II	19-May-11	10.00	19-May-11	14.45	Replacement of E/W.
132KV	Boiser - Viraj	20-May-11	07.40	20-May-11	15.26	CB Overhauling.
132KV	Viraj-IOL	20-May-11	07.40	20-May-11	16.40	Oil Leakage.
132KV	Pachora-Chalisgaon Ckt.II.	21-May-11	09.06	21-May-11	11.59	Q.M.Work
132KV	Malkapur - Bhusawal	22-May-11	13.00		Continued.	Stringing work of 400 KV Deepnagar-Waluj D/C.
132KV	Dondaicha - Sahada	22-May-11	14.22	22-May-11	15.27	132 KV Bus,PT burst at Shahada.
132KV	Shahada-Taloda	22-May-11	14.22	22-May-11	15.45	132 KV Bus,PT burst at Shahada.
132KV	132 KV Main Bus at Shahada	22-May-11	14.22	22-May-11	15.25	132 KV Bus,PT burst at Shahada.
132KV	Khadka-Malkapur	22-May-11	10.18		Continued.	Stringing work of 400 KV Deepnagar-Waluj D/C.
100KV	Kalwa-Nocil II	30-Apr-11	17.17	30-May-11	17.50	B ph.Earth fault.
100KV	100 KV Bus Section @ Kalwa	22-May-11	11.05	22-May-11	14.38	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Reliable	22-May-11	11.05	22-May-11	12.22	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Standard	22-May-11	11.05	22-May-11	12.17	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Nocil I	22-May-11	11.05	22-May-11	11.48	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Washi	22-May-11	11.05	22-May-11	13.05	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Mukund I	22-May-11	11.05	22-May-11	12.23	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Kalyan	22-May-11	11.05	22-May-11	12.21	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Nocil II	22-May-11	11.05	22-May-11	15.02	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa - Salshet - I	22-May-11	11.05	22-May-11	15.00	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Mukund II	22-May-11	11.05	22-May-11	15.09	102 KV Bus R & Y Ph support insulator string flashover
100KV	Kalwa-Pal	22-May-11	11.05	22-May-11	14.54	102 KV Bus R & Y Ph support insulator string flashover