

# LINE OUTAGES FOR THE WEEK

FROM 14-Jun-10 TO 20-Jun-10

| Voltage | Name                                     | date_trip | time_trip | date_sync | time_sync  | reason                                                                |
|---------|------------------------------------------|-----------|-----------|-----------|------------|-----------------------------------------------------------------------|
| 500KV   | HVDC Pole-I                              | 20-Jun-10 | 16.53     | 20-Jun-10 | 19.31      | Due to High Pressure Tap Changer-1,Conv T/F Pole-1 Y Ph.              |
| 400KV   | Akola - Wardha - I                       | 5-Jun-10  | 15.51     | 16-Jun-10 | 14.47      | Due to line loading                                                   |
| 400KV   | Dhule-Sar'Sarovar - II                   | 11-Jun-10 | 04.34     | 19-Jun-10 | 13.26      | Over Voltage                                                          |
| 400KV   | Dhule-Sar'Sarovar - I                    | 11-Jun-10 | 19.28     | 16-Jun-10 | 18.46      | Over Voltage                                                          |
| 400KV   | Kolhapur-Mapusa Ckt I                    | 12-Jun-10 | 23.16     | 14-Jun-10 | 09.13      | Over Voltage                                                          |
| 400KV   | Bhusawal- Aurangabad                     | 12-Jun-10 | 13.02     | 18-Jun-10 | 17.43      | Hand Tripped at both end                                              |
| 400KV   | Karad-Kolhapur CKT I                     | 14-Jun-10 | 03.59     | 14-Jun-10 | 08.57      | For Over Voltage.                                                     |
| 400KV   | 400 KV Main Bus - II A'bad.              | 14-Jun-10 | 11.03     | 14-Jun-10 | 18.03      | Stringing of M.B.-II Conductor for Pune I&II Bay,400KV Erection Work. |
| 400KV   | Lonikand-Parli-I                         | 14-Jun-10 | 10.31     | 14-Jun-10 | 16.48      | Replacement of Defective Insulator String.                            |
| 400KV   | Kolhapur-Mapusa-II                       | 14-Jun-10 | 16.12     | 15-Jun-10 | 09.51      | For Over Voltage.                                                     |
| 400KV   | Padgha-Bhoisor (PGCIL)                   | 14-Jun-10 | 19.00     | 15-Jun-10 | 15.41      | Distenace Protection.                                                 |
| 400KV   | N.Koyna-jaigad-I                         | 14-Jun-10 | 19.40     | 15-Jun-10 | 00.25      | Erection of ABT Meter & Bus Bar Protection Pannel @ Jaigad End.       |
| 400KV   | Padgha 400 Kv HVDC AC Ckt-1 Bkr          | 14-Jun-10 | 16:33     | 14-Jun-10 | 22:40      | Taken on TBC.Lockout Problem.                                         |
| 400KV   | C'pur-Parli CKT .I                       | 14-Jun-10 | 08.03     |           | 19:00      | Insulator Replacement,Permit cancelled.Line is ready for charging.    |
| 400KV   | C'pur-Parli CKT .I                       | 14-Jun-10 | 8:03      | 14-Jun-10 | 19:00      | Insulator Replacement,Permit Cancelled.Line is ready for charging.    |
| 400KV   | Karad-Kolhapur CKT I                     | 15-Jun-10 | 00.35     | 15-Jun-10 | 09.17      | For Over Voltage.                                                     |
| 400KV   | Main Bus - I @ Lamboti.                  | 15-Jun-10 | 11.07     | 15-Jun-10 | 14.25      | New ICT bay synch.and CVT testing.                                    |
| 400KV   | Chandrapur-Parli-I                       | 15-Jun-10 | 07.48     |           | 19:49      | Repl.of faulty disc insulators.Ready to charge.                       |
| 400KV   | Kalwa - Lonikand                         | 15-Jun-10 | 08.02     | 15-Jun-10 | 17.30      | Repl.of faulty disc insulators.                                       |
| 400KV   | 400/220 KV 315 MVA ICT at Akola          | 15-Jun-10 | 14.10     | 15-Jun-10 | 16.06      | Tripped on NDR.                                                       |
| 400KV   | Karad-Kolhapur CKT II                    | 15-Jun-10 | 23.58     | 17-Jun-10 | 11.38      | H/T For O/V.                                                          |
| 400KV   | Kolhapur-Mapusa Ckt I                    | 15-Jun-10 | 22.36     |           | Continued. | H/T for O/V.                                                          |
| 400KV   | Koradi-Satpur                            | 16-Jun-10 | 09.28     | 16-Jun-10 | 18.23      | Q.M.work.                                                             |
| 400KV   | Akola - Wardha - II                      | 16-Jun-10 | 14.53     |           | Continued. | H/T due to line loading.                                              |
| 400KV   | Padgha - BBLSWR - II                     | 17-Jun-10 | 04.02     | 17-Jun-10 | 08.50      | Tripped on O/V                                                        |
| 400KV   | Bus coupler at Koradi                    | 17-Jun-10 | 00.32     | 17-Jun-10 | 11.20      | Attending sparking on post insulator of B ph.                         |
| 400KV   | Koradi - Kaparkheda                      | 17-Jun-10 | 00.32     | 17-Jun-10 | 10.49      | Tripped on O/V                                                        |
| 400KV   | Dhule-S'Sarovar I                        | 17-Jun-10 | 00.15     |           | Continued. | H/T for O/V                                                           |
| 400KV   | Khaparkheda-Chandrapur.                  | 17-Jun-10 | 00.32     | 17-Jun-10 | 10.49      | Tripped on O/V.                                                       |
| 400KV   | Main Bus - I @ 400 KV Jejuri             | 17-Jun-10 | 11.26     | 17-Jun-10 | 19.36      | Testing work of spare ICT bay.                                        |
| 400KV   | Nagothane-Dabhol-I                       | 17-Jun-10 | 11.49     | 19-Jun-10 | 13.41      | Attending hot spot.                                                   |
| 400KV   | Karad-Kolhapur CKT I                     | 17-Jun-10 | 23.28     | 20-Jun-10 | 11.49      | H/T for O/V                                                           |
| 400KV   | Padgha - Chakan                          | 18-Jun-10 | 09.21     | 18-Jun-10 | 18.57      | Bay Maintenance work                                                  |
| 400KV   | Chandrapur-Parli -I                      | 18-Jun-10 | 07.48     | 19-Jun-10 | 20.37      | Replacement of Insulator,ready for charging at 17.41.                 |
| 400KV   | M.B.I. at A'bad                          | 18-Jun-10 | 09.28     | 18-Jun-10 | 17.40      | Replacement of Main Bus-I Conductor for Pune-I Bay                    |
| 400KV   | 400 KV TBC-I at Chandrapur               | 18-Jun-10 | 07.33     | 19-Jun-10 | 10.27      | Replacement of B Phase CT                                             |
| 400KV   | Main Bus-II at Aurangabad                | 18-Jun-10 | 17.22     | 18-Jun-10 | 17.44      | Bus Bar protection operated while charging 400KV Bus-I                |
| 400KV   | Bableshtar-Aurangabad                    | 18-Jun-10 | 17.22     | 18-Jun-10 | 17.53      | Bus Fault at Aurangabad                                               |
| 400KV   | Akola - Aurangabad - I                   | 18-Jun-10 | 17.22     | 19-Jun-10 | 11.28      | Bus Fault at Aurangabad                                               |
| 400KV   | 400/220 KV 315 MVA ICT - I at Aurangabad | 18-Jun-10 | 17.22     | 18-Jun-10 | 17.40      | Bus Fault                                                             |
| 400KV   | 400/220KV, 315MVA ICT-II at Aurangabad.  | 18-Jun-10 | 17.22     | 18-Jun-10 | 17.45      | Bus Fault                                                             |
| 400KV   | Bablsr-Padgha Ckt I                      | 19-Jun-10 | 00.38     | 19-Jun-10 | 08.32      | Distance protection                                                   |
| 400KV   | Babaleshwar-Bhusawal                     | 19-Jun-10 | 08.47     | 19-Jun-10 | 19.16      | Replacement of Flashover Insulator                                    |
| 400KV   | Padgha - BBLSWR - II                     | 19-Jun-10 | 09.35     | 19-Jun-10 | 17.40      | Replacement of Flashover Disc Insulator                               |
| 400KV   | 400/220 KV 315 ICT-I DHULE               | 19-Jun-10 | 09.01     | 19-Jun-10 | 18.55      | Premansoon Maint.work                                                 |

|       |                                           |           |       |           |            |                                                         |
|-------|-------------------------------------------|-----------|-------|-----------|------------|---------------------------------------------------------|
| 400KV | Lonikand - Chakan                         | 19-Jun-10 | 20.37 |           | Continued. | Ready For Charging from dt 19/06/10.                    |
| 400KV | Karad-Lamboti                             | 19-Jun-10 | 11.29 | 19-Jun-10 | 12.22      | To take Reactor at Karad                                |
| 400KV | BBLSR - Dhule - II                        | 19-Jun-10 | 19.16 | 20-Jun-10 | 08.23      | Replacement of R phase CVT, ready for charging at 21.30 |
| 400KV | Chandrapur 400 KV HVDC-II                 | 19-Jun-10 | 01.53 | 19-Jun-10 | 03.06      | To attend Filter problem                                |
| 400KV | Bhusawal- Aurangabad                      | 19-Jun-10 | 22.51 |           | Continued. | Over Voltage                                            |
| 400KV | Karad-Lonikand.                           | 20-Jun-10 | 01.10 | 20-Jun-10 | 07.00      | Over Voltage.                                           |
| 400KV | Dhule-Sar'Sarovar - II                    | 20-Jun-10 | 00.01 |           | Continued. | Over Voltage                                            |
| 400KV | Lonikand-Karad                            | 20-Jun-10 | 20.32 |           | Continued. | For Over Voltage.                                       |
| 400KV | C'pur-Parli CKT .I                        | 20-Jun-10 | 07.42 | 20-Jun-10 | 18.50      | Replacement of Line Insulators. Ready for Charging.     |
| 400KV | Parli-Lonikand -I                         | 20-Jun-10 | 07.35 | 20-Jun-10 | 18.06      | Replacement of Spacers Cum Dumpers.                     |
| 400KV | Karad-Kolhapur CKT II                     | 20-Jun-10 | 20.36 |           | Continued. | For Over Voltage.                                       |
| 220KV | 220/132 KV,100 MVA T/F- II @ Malegaon     | 19-Mar-10 | 09:15 | 26-Jun-10 | 20:55      | ICT replaced by new 200 MVA ICT on 26/03/10.            |
| 220KV | Tillary-Amona                             | 13-Jun-10 | 15.52 | 15-Jun-10 | 13.45      | Distanance Protection,Declare Faulty.                   |
| 220KV | 220/132 KV 200 MVA ICT - I @ Nanded       | 13-Jun-10 | 21.05 | 14-Jun-10 | 12.05      | To Attend Red Hot Spot on LV Bus side Isolator.         |
| 220KV | HALKARNI-TILLARY                          | 13-Jun-10 | 19.15 | 14-Jun-10 | 10.43      | B Ph D caping.                                          |
| 220KV | B.S. II at Pedambe                        | 14-Jun-10 | 06.25 | 14-Jun-10 | 17.38      | Main Bus Isolator Replacement.                          |
| 220KV | Pedambe - Karad                           | 14-Jun-10 | 06.12 | 14-Jun-10 | 19.03      | Bus Section-II Outage @ Pedambe.                        |
| 220KV | Pedambe - Pophali - II                    | 14-Jun-10 | 06.23 | 14-Jun-10 | 18.05      | Bus Section-II Outage @ Pedambe.                        |
| 220KV | Pedambe - Tambati                         | 14-Jun-10 | 06.09 | 14-Jun-10 | 19.23      | Bus Section-II Outage @ Pedambe.                        |
| 220KV | Pedambe-Kharepatan                        | 14-Jun-10 | 06.13 | 14-Jun-10 | 18.40      | Bus Section-II Outage @ Pedambe.                        |
| 220KV | Vita - Ghatnandre                         | 14-Jun-10 | 08.25 | 14-Jun-10 | 15.06      | Insulator Replacement.                                  |
| 220KV | Kolhapur - Karad - II                     | 14-Jun-10 | 10.10 | 14-Jun-10 | 14.17      | Jumper Replacement.                                     |
| 220KV | Momewadi -Halkarni                        | 14-Jun-10 | 12.05 | 14-Jun-10 | 16.36      | LILO Work.                                              |
| 220KV | Nasik - Ghatghar                          | 14-Jun-10 | 16.14 | 14-Jun-10 | 16.32      | Dist.Prot.                                              |
| 220KV | Nasik - Ghatghar                          | 14-Jun-10 | 16.46 | 14-Jun-10 | 17.38      | Dist.Prot.                                              |
| 220KV | Kalwa-Nasik                               | 14-Jun-10 | 16.52 | 14-Jun-10 | 17.21      | Dist.Prot.                                              |
| 220KV | Ghatghar-Jindal                           | 14-Jun-10 | 16.36 | 14-Jun-10 | 17.30      | Dist.Prot.                                              |
| 220KV | Kalwa - Khargar                           | 14-Jun-10 | 18.35 | 14-Jun-10 | 18.58      | Trip.                                                   |
| 220KV | Kalwa I-Taloja                            | 14-Jun-10 | 18.35 | 14-Jun-10 | 19.18      | Dist.Prot.                                              |
| 220KV | Borivali-Kalwa                            | 14-Jun-10 | 18.33 | 14-Jun-10 | 19.07      | Dist.Prot.                                              |
| 220KV | Borivali-Mulund                           | 14-Jun-10 | 18.33 | 14-Jun-10 | 18.52      | Dist.Prot.                                              |
| 220KV | HALKARNI-TILLARY                          | 14-Jun-10 | 11.47 | 14-Jun-10 | 16.55      | Tower Erection Work @ Halkarni.                         |
| 220KV | Khaperkheda - Ambazari - II               | 14-Jun-10 | 10.40 | 14-Jun-10 | 12.00      | Quarterly Maintainance Work.                            |
| 220KV | Aurangabad-Jalna-I                        | 14-Jun-10 | 07.25 | 14-Jun-10 | 17.41      | LILO Arrangement Work for Shendra S/S.                  |
| 220KV | Dhamangaon - Badnera                      | 14-Jun-10 | 10.10 | 14-Jun-10 | 15.18      | Isolator Maintenance & Tighting of Jumper Clamp.        |
| 220KV | 220/132 KV 200 MVA ICT - I @ Nanded       | 14-Jun-10 | 12.05 | 16-Jun-10 | 16.37      | L V Side Taken on TBC.                                  |
| 220KV | Chandrapur MIDC - Gadchandur              | 14-Jun-10 | 03.25 | 14-Jun-10 | 03.54      | Dist.Prot.,Y Ph to E/F.                                 |
| 220KV | Chandrapur-Chandrapur MIDC                | 14-Jun-10 | 03.34 | 14-Jun-10 | 03.53      | Dist.Prot.,B Ph to E/F.                                 |
| 220KV | 250 MW Gen.Unit Breaker @ New Parly       | 14-Jun-10 | 14.55 | 15-Jun-10 | 16.25      | Main Breaker SF-6 Gas Leakage,GT-VII on TBC.            |
| 220KV | Mudsungi-Amona                            | 15-Jun-10 | 10.00 | 15-Jun-10 | 13.30      | Decapping at Loc no.378                                 |
| 220KV | Pusad - Parbhani                          | 15-Jun-10 | 07.00 | 15-Jun-10 | 18.24      | Repl.of Faulty disc Insulator.                          |
| 220KV | 220/66 KV, 50 MVA ICT-I At Warora         | 15-Jun-10 | 09.07 | 15-Jun-10 | 13.00      | For connecting pipe for oil filtration work.            |
| 220KV | 220/132 KV 200 MVA ICT-I at Harangul S/S. | 15-Jun-10 | 11.50 | 15-Jun-10 | 12.25      | Premonsoon maintenance work.                            |
| 220KV | 220/132 KV 200 MVA ICT-II at Harangul     | 15-Jun-10 | 09.55 | 15-Jun-10 | 11.45      | Premonsoon maintenance work.                            |
| 220KV | Ambazari-Wardha                           | 15-Jun-10 | 17.08 | 15-Jun-10 | 17.59      | Tripped at Wardha end only on tripping relay 186.       |
| 220KV | Butibori - Wardha                         | 15-Jun-10 | 17.40 | 15-Jun-10 | 17.59      | Tripped at Wardha end only, on tripping relay 186.      |
| 220KV | 220/66KV,50MVA T/F-II at Wardha           | 15-Jun-10 | 19.05 | 16-Jun-10 | 13:04      | Tripped on Buchholz.                                    |
| 220KV | 220/132KV200MVA ICT IV @Phursungi         | 16-Jun-10 | 01.11 | 16-Jun-10 | 02.40      | To attend Red Hot On R-Ph CT.                           |
| 220KV | Khapakheda - Koulawada - II               | 16-Jun-10 | 05.02 | 16-Jun-10 | 05.27      | Dist.protection.                                        |
| 220KV | Dhule - Dondaicha - I                     | 16-Jun-10 | 06.05 | 16-Jun-10 | 14.15      | Tripped on dist.prot.Z-2.                               |

|       |                                                |           |       |           |       |                                                             |
|-------|------------------------------------------------|-----------|-------|-----------|-------|-------------------------------------------------------------|
| 220KV | 220/132 KV 200 MVA ICT at Amravati             | 16-Jun-10 | 10.10 | 16-Jun-10 | 16.25 | To cover buchholz and PRV of ICT to avoid ingress of water. |
| 220KV | 220/132KV,200MVA ICT-II at Amravati            | 16-Jun-10 | 12.27 | 16-Jun-10 | 14.27 | To cover buchholz and PRV of ICT to avoid ingress of water. |
| 220KV | New Parli -Beed ckt-II                         | 16-Jun-10 | 10.00 | 16-Jun-10 | 14.00 | Q.M.Work.                                                   |
| 220KV | 220/132 KV, 100 MVA ICT - II @ Beed.           | 16-Jun-10 | 10.15 | 16-Jun-10 | 14.00 | Q.M.Work.                                                   |
| 220KV | Chandrapur MIDC - Gadchandur                   | 16-Jun-10 | 10.07 | 16-Jun-10 | 18.08 | Jumpering Work.                                             |
| 220KV | Dhule-Amalner Ckt.                             | 16-Jun-10 | 06.02 | 16-Jun-10 | 14.15 | Distance protection.                                        |
| 220KV | 220/66KV 50MVA T/F at Chandrapur               | 16-Jun-10 | 18.42 | 16-Jun-10 | 19.13 | Tripped on backup E/F.                                      |
| 220KV | Aurangabad-Padegaon CKT-II                     | 16-Jun-10 | 17.05 | 17-Jun-10 | 07.25 | D/P Y phase to Earth Fault.                                 |
| 220KV | K'gaon-Pirangut                                | 17-Jun-10 | 12.15 | 17-Jun-10 | 20.15 | Replacement of relay panel.                                 |
| 220KV | Bhosari-Telco                                  | 17-Jun-10 | 12.25 | 17-Jun-10 | 17.38 | Q.M.Work.                                                   |
| 220KV | Satara MIDC-Vankushwadi-I                      | 17-Jun-10 | 09.35 | 17-Jun-10 | 13.45 | Q.M.Work.                                                   |
| 220KV | Satara,MIDC-Wankuswadi 2                       | 17-Jun-10 | 14.25 | 17-Jun-10 | 17.40 | Q.M.Work.                                                   |
| 220KV | Lonikand - Bhosari                             | 17-Jun-10 | 10.19 | 17-Jun-10 | 12.04 | Attending hot spot.                                         |
| 220KV | Vita - Miraj                                   | 17-Jun-10 | 15.15 | 18-Jun-10 | 01.35 | Distance protection.                                        |
| 220KV | 220 KV junction breaker(B/C) at Koyna I and II | 17-Jun-10 | 08.40 | 17-Jun-10 | 11.00 | Replacement of Y Ph.jumper.                                 |
| 220KV | Padgha-Temghar                                 | 18-Jun-10 | 08.48 | 18-Jun-10 | 18.16 | Replacement of Insulator                                    |
| 220KV | Padgha - Nalasopara                            | 18-Jun-10 | 08.16 | 18-Jun-10 | 16.51 | Q.M.Work                                                    |
| 220KV | Lote - Dasturi                                 | 18-Jun-10 | 12.12 | 18-Jun-10 | 13.13 | Distance protection                                         |
| 220KV | Lote - N.Koyna                                 | 18-Jun-10 | 12.12 | 18-Jun-10 | 13.30 | Distance Protection                                         |
| 220KV | 220/100KV 125 MVA ICT-I at Kalwa               | 18-Jun-10 | 08.32 | 18-Jun-10 | 15.58 | Maintenance work                                            |
| 220KV | 220/132 KV,200 MVA ICT-II at Boiser.           | 18-Jun-10 | 09.03 | 18-Jun-10 | 12.50 | R.M.Work                                                    |
| 220KV | Aurangabad - Padegaon - I.                     | 18-Jun-10 | 10.20 | 18-Jun-10 | 12.21 | Dismantling of Earth Wire                                   |
| 220KV | Aurangabad-Padegaon CKT-II                     | 18-Jun-10 | 10.20 | 18-Jun-10 | 12.20 | Dismantling of Earth Wire                                   |
| 220KV | Main Bus Section- I at Chikhli                 | 18-Jun-10 | 12.12 | 18-Jun-10 | 17.18 | Maintenance work                                            |
| 220KV | Nasik - Ghatghar                               | 19-Jun-10 | 09.04 | 19-Jun-10 | 17.52 | Replacement of Flashover Disc Insulator                     |
| 220KV | Padga-Kalwa-I                                  | 19-Jun-10 | 09.08 | 19-Jun-10 | 18.01 | Replacement of old Insulator String                         |
| 220KV | 220/132,200MVA Tr.-2 @ A' Nager                | 19-Jun-10 | 10.10 | 19-Jun-10 | 13.50 | Maint.work                                                  |
| 220KV | Babaleshwar - Nagar - I                        | 19-Jun-10 | 09.28 | 19-Jun-10 | 17.03 | Tandelta measurement                                        |
| 220KV | Hinjawadi-I - Hinjawadi-II                     | 19-Jun-10 | 13.36 | 19-Jun-10 | 17.54 | Q.M.Wrok                                                    |
| 220KV | 220/132KV 200MVA ICT-I at Raymond              | 19-Jun-10 | 09.10 | 19-Jun-10 | 14.27 | Replacement of Flashover Disc Insulator                     |
| 220KV | Khaparkheda-Kawlewada-II                       | 19-Jun-10 | 19.07 | 19-Jun-10 | 19.57 | Removal of broken E/W                                       |
| 220KV | Wardha--Dhamangaon                             | 19-Jun-10 | 03.17 | 19-Jun-10 | 09.38 | H/T to Load AKOLA ICT                                       |
| 220KV | Khaparkheda-Kawlewada-II                       | 19-Jun-10 | 15.14 | 19-Jun-10 | 15.38 | Distance protection                                         |
| 220KV | 220/132KV,100MVA ICT-I at Kanhan               | 19-Jun-10 | 11.07 | 19-Jun-10 | 12.42 | Q.M.Work                                                    |
| 220KV | 220/132 KV 200 MVA ICT - I @ Nanded            | 19-Jun-10 | 13.55 | 19-Jun-10 | 14.53 | Q.M.Work                                                    |
| 220KV | 220/66KV 50 MVA ICT-II at Warora               | 19-Jun-10 | 13.00 | 19-Jun-10 | 13.36 | Q.M.Work                                                    |
| 220KV | 220/33KV 100MVA ICT - I at Valve               | 19-Jun-10 | 11.00 | 19-Jun-10 | 15.25 | Q.M.Work                                                    |
| 220KV | Kalwa-Padgha I                                 | 20-Jun-10 | 08.35 | 20-Jun-10 | 18.10 | Polymer Insulator Change Work.                              |
| 220KV | Kharghar - Panvel                              | 20-Jun-10 | 16.43 | 20-Jun-10 | 19.18 | Distanace Protection, Y Ph E/F.                             |
| 220KV | Lonikand-Ranjangaon                            | 20-Jun-10 | 19.18 | 20-Jun-10 | 19.37 | Distanace Protection.                                       |
| 132KV | 132 KV Main Bus @ Amravati                     | 14-Jun-10 | 07.08 | 14-Jun-10 | 11.38 | Attending Bus Isolator of 132KV Achalpur Line.              |
| 132KV | Amravati-Morshi                                | 14-Jun-10 | 23.05 | 15-Jun-10 | 13.55 | Main Breaker Air Preaure Low,Ckt on TBC                     |
| 132KV | A A Energy - Wadsa                             | 14-Jun-10 | 01.17 | 14-Jun-10 | 01.55 | Dist.Prot.                                                  |
| 132KV | A A Energy - Wadsa                             | 14-Jun-10 | 06.05 | 14-Jun-10 | 07.00 | Dist.Prot.                                                  |
| 132KV | Chikhali - Khamgaon                            | 14-Jun-10 | 11.25 | 14-Jun-10 | 11.36 | Transient Fault.                                            |
| 132KV | Mehkar - Malegaon                              | 15-Jun-10 | 20.10 | 16-Jun-10 | 17.45 | R-Ph LA burst at Mehkar.                                    |
| 132KV | Paras-Patur                                    | 15-Jun-10 | 20.10 | 15-Jun-10 | 20.32 | Dist.Protection                                             |
| 132KV | M.B.I at 132 KV Bale                           | 16-Jun-10 | 09.20 | 16-Jun-10 | 14.40 | Jumpering and Testing work                                  |
| 132KV | Bhandara-Mouda                                 | 17-Jun-10 | 06.52 | 17-Jun-10 | 07.16 | Tripped.                                                    |
| 132KV | Kanhan - Mouda                                 | 17-Jun-10 | 06.52 | 17-Jun-10 | 07.16 | Tripped.                                                    |
| 132KV | Khadka-Malkapur                                | 17-Jun-10 | 16.40 | 17-Jun-10 | 16.45 | Tripped at both end due to heavy lightning                  |
| 132KV | Kanhan-Pardi                                   | 17-Jun-10 | 17.07 | 18-Jun-10 | 12.50 | B PH.burst at Pardi end.                                    |
| 132KV | Dhule-Nardhane                                 | 19-Jun-10 | 13.05 | 19-Jun-10 | 15.25 | Q.M.Work                                                    |
| 132KV | Ambazari - Amravati                            | 19-Jun-10 | 15.53 | 19-Jun-10 | 16.03 | Distance protection                                         |
| 132KV | Bhandara-Ambhora                               | 19-Jun-10 | 20.17 | 20-Jun-10 | 02.14 | B phase CC Burst at Ambhora S/S                             |
| 100KV | Kandalgaon-Roha-I                              | 15-Jun-10 | 21.20 | 16-Jun-10 | 09.10 | Tripped on Dist.Protection                                  |
| 100KV | Kalwa-Kalyan                                   | 16-Jun-10 | 11.10 | 16-Jun-10 | 15.38 | Guard wire work.                                            |