

LINE OUTAGES FOR THE WEEK

FROM 19-Jul-10 TO 25-Jul-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Chandrapur - Khaparkheda	2-Jul-10	20.11	20-Jul-10	08:55	Over Voltage
400KV	Akola - Wardha - I	7-Jul-10	11.00	20-Jul-10	10:31	Changeover.
400KV	Karad - Kolhapur - I	11-Jul-10	10.22	19-Jul-10	08.57	Relay retrofitting work
400KV	Akola - Aurangabad- II	15-Jul-10	10.15	21-Jul-10	13.04	To control Aurangabad ICT loading
400KV	Kolhapur-Mapusa Ckt I	16-Jul-10	18.43	28-Jul-10	19.45	Over Voltage
400KV	New Koyna - Koyna Stage IV - II	16-Jul-10	22.58	23-Jul-10	12.34	Over Voltage
400KV	Dhule-Sar'Sarovar - II	17-Jul-10	22.56	19-Jul-10	17.19	Over Voltage
400KV	Karad-Lamboti	18-Jul-10	09.46	20-Jul-10	08:09	Relay retrofitting work
400KV	Karad-Kolhapur-II	18-Jul-10	22.26	19-Jul-10	07:13	For control Voltage
400KV	Jejuri-Koyna STG-IV	19-Jul-10	00.12	19-Jul-10	08.26	Over Voltage(Stg- IV-426KV,Jejuri-412KV)
400KV	Karad - Kolhapur - I	19-Jul-10	19.52	26-Jul-10	09.42	Over Voltage.
400KV	Jejuri-Koyna STG-IV	19-Jul-10	23:55	20-Jul-10	07:51	Over Voltage.
400KV	Karad-New Koyna II	20-Jul-10	00.13	20-Jul-10	09:08	Over Voltage.
400KV	Karad-Lamboti	20-Jul-10	18.55	21-Jul-10	08.54	Over Loading.
400KV	Karad - Newkoyna - I	20-Jul-10	23.10	21-Jul-10	09.35	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	20-Jul-10	23.24	26-Jul-10	12.50	Over Voltage.
400KV	Akola - Aurangabad - I	21-Jul-10	13.10		Continued.	Changeover.
400KV	400/132KV 200MVA ICT-I @ Bhusawal	21-Jul-10	09.30	21-Jul-10	11.30	Repl.of polyethylene papaer of Bucholz relay and R.M.work.
400KV	400/132 KV 200 MVA ICT - II @ Bhusawal	21-Jul-10	13.59	21-Jul-10	16.25	Repl.of polyethylene paper of Bucholz relay and R.M.Work.
400KV	Karad-New Koyna II	21-Jul-10	22.49	23-Jul-10	11.30	H/T For O/V.
400KV	Jejuri-Koyna STG-IV	22-Jul-10	05.26	22-Jul-10	09.17	Trip on O/V.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	22-Jul-10	07.38	22-Jul-10	15.21	Testing work.
400KV	Main Bus- II @ Jejuri	22-Jul-10	10.06	22-Jul-10	15.47	Overhauling and Serving of 29A isolator.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	22-Jul-10	15.27	22-Jul-10	18.30	Testing work.
400KV	Jejuri-Koyna STG-IV	22-Jul-10	23.54	23-Jul-10	08.31	Trip on O/V.
400KV	400/220 KV 315 MVA ICT - I @ Aurangabad	23-Jul-10	09.44	23-Jul-10	17.29	Testing work
400KV	Dabhol - Nagothane - I	23-Jul-10	06.43	23-Jul-10	17.50	Distance Protection
400KV	New Koyna - StageIV - I	23-Jul-10	12.36	27-Jul-10	08.09	Over Voltage
400KV	Dhule-Sar'Sarovar - II	23-Jul-10	15.17		Continued.	Over Voltage
400KV	Karad-Lamboti	23-Jul-10	19.33	27-Jul-10	09.23	Over Voltage
400KV	C'pur-Parli II	23-Jul-10	22.51	24-Jul-10	05.56	Over Voltage
400KV	Chandrapur - Bhadravati - III	23-Jul-10	10.51	23-Jul-10	12.46	To attend Y phase PG Isolator problem, Ckt was on TBC
400KV	New Koyna - Karad - I	23-Jul-10	23.47		Continued.	Over Voltage
400KV	Koyna IV - Jejuri	24-Jul-10	01.54	25-Jul-10	08.45	Over Voltage
400KV	Dhule-Khandwa I	24-Jul-10	19.48	25-Jul-10	07.27	Over Voltage
400KV	Koradi - Kaparkheda	24-Jul-10	19.54	26-Jul-10	10.38	Trip on O/V.
400KV	Chandrapur - Khaparkheda	24-Jul-10	19.54		Continued.	Over Voltage.
400KV	Koyna IV - Jejuri	25-Jul-10	23.26	27-Jul-10	09.35	Over Voltage
220KV	Karad-Oglewadi-I	13-Jul-10	19.20	20-Jul-10	20.00	Replacement of own Brekaer, Line on TBC
220KV	220/132KV 200 MVA ICT- II @ Raymond	18-Jul-10	19.55	21-Jul-10	15.40	H/T due to oil leakage of R phase CT
220KV	Murud-Bale	18-Jul-10	09.45	20-Jul-10	12:00	Main Breaker replacement work, Ckt on TBC
220KV	Kalwa-Mulund	19-Jul-10	12.05	19-Jul-10	13.48	To Attend Red Hot on 29D Isolator.
220KV	Pedambe-Kharepatan	19-Jul-10	08.25	19-Jul-10	17.40	Preventative Maint. Work.
220KV	Kalmeshwar - Pandurna	19-Jul-10	12.18	19-Jul-10	12.59	Dist.Prot.
220KV	Chandrapur-Chandrapur MIDC	19-Jul-10	14.30	19-Jul-10	17.22	Attending Air Leakage from Compressor.Ckt on TBC.
220KV	Kalmeshwar-Kaparkheda	19-Jul-10	08.28	19-Jul-10	14.16	Quarterly Maintainance.
220KV	220/100KV 125 MVA ICT-I @ Kalwa	20-Jul-10	08.30	20-Jul-10	12.07	L V Side R Ph Bushing Jumper Replacement
220KV	Main Bus II @ Aarey	20-Jul-10	01.18	20-Jul-10	03.45	Double Isolator Scheme Work.
220KV	Aarey-Borivali-II	20-Jul-10	00.22	20-Jul-10	03.36	Double Isolator Scheme Work.

220KV	220 KV Bus Coupler @ Kharghar	20-Jul-10	08.59	20-Jul-10	18.50	Commisioning of High Set Relay,R/M.
220KV	220/100 KV 200 MVA ICT-II @ Apta	20-Jul-10	11.55	20-Jul-10	18.32	SFRA,Inspection of PRV Leakage.
220KV	Pedambe-Mahad	20-Jul-10	14.55	20-Jul-10	17.03	To Attended Breaker Air Leakage.
220KV	Dondaicha - Suzlon - I	20-Jul-10	18.41	21-Jul-10	01.25	R Ph Wave Trap Jumper of Suzlon-I Open @ Dondaicha
220KV	Dondaicha - Suzlon - II	20-Jul-10	18.41	20-Jul-10	23.09	R Ph Wave Trap Jumper of Suzlon-I Open @ Dondaicha
220KV	Dondaicha - Walve	20-Jul-10	18.41	21-Jul-10	00.45	R Ph Wave Trap Jumper of Suzlon-I Open @ Dondaicha
220KV	Walve - Gangapur	20-Jul-10	18.41	21-Jul-10	00.50	R Ph Wave Trap Jumper of Suzlon-I Open @ Dondaicha
220KV	Nasik - Ghatghar	21-Jul-10	11.52	21-Jul-10	16.33	Insulator replacement.
220KV	N.Koyna-Phinolex	21-Jul-10	18.30	22-Jul-10	16.43	Control ckt.of 220KV Finolex is faulty,so line is on TBC.
220KV	Temghar-Colourchem	21-Jul-10	12.40	21-Jul-10	17.38	Auto reclose lock out at Colourchem.
220KV	220/100 125 MVA ICT - II @ Trombay	21-Jul-10	22.54	22-Jul-10	01.29	Diff.Protn.operated.
220KV	Khaperkheda-Purti	21-Jul-10	10.34	21-Jul-10	16.40	For attending Hot Spot at Loc.no 178.
220KV	220/132 KV 150 MVA ICT- I @ Dhule	21-Jul-10	20.25	21-Jul-10	21.43	To attend Red Hot Spot on HV Y-Ph Bushing.
220KV	Parly - New Parly TPS - I	21-Jul-10	10.12	21-Jul-10	20.25	Dist.Protn.operated,B-Ph to ground.
220KV	Main Bus - I @ Arrey	22-Jul-10	00.34	22-Jul-10	05.50	Double isolator scheme work.
220KV	New parly-Nanded	22-Jul-10	20.22	22-Jul-10	21.26	Dist.Prot.Operated Z-1,Y-Ph.
220KV	Wardha - Yawatmal	22-Jul-10	10.51	22-Jul-10	16.09	Repl.of B & Y-Ph wave trap.
220KV	220/132KV 200 MVA ICT- III @ Chinchwad	22-Jul-10	10.44	22-Jul-10	17.43	Q.M.Work
220KV	Babaleshwar - Alephata	22-Jul-10	09.43	22-Jul-10	18.10	Q.M.Work
220KV	Karad-Sada Waghapur	23-Jul-10	00.01	25-Jul-10	10.41	Trip on O/V.
220KV	Padgha-Kamba	23-Jul-10	09.15	23-Jul-10	18.57	Bay maintenance, line taken on TBC at Padgha end
220KV	Lote - N.Koyna	23-Jul-10	11.53	23-Jul-10	14.45	Distance Protection
220KV	Lote- Dasturi	23-Jul-10	11.28	23-Jul-10	12.25	Distance protection
220KV	Temghar-Colourchem	23-Jul-10	15.57	23-Jul-10	17.10	To replace A/R relay
220KV	220/132 KV 150MVA ICT-II @ Dhule	23-Jul-10	10.52	23-Jul-10	13.04	To attend Isolator problem
220KV	220/132KV 200MVA ICT-II at Amravati	23-Jul-10	17.05	23-Jul-10	22.30	Differential Protection operated
220KV	Bhandara - RLY TSS - I	23-Jul-10	20.01	23-Jul-10	20.15	Distance protection
220KV	Talangade - Mumewadi	24-Jul-10	06.03	24-Jul-10	13.08	Distance protection
220KV	Karad-Pophali	25-Jul-10	14.06	25-Jul-10	14.30	Distance protection
220KV	Momewadi-Halkarni	25-Jul-10	16.40	25-Jul-10	17.15	Distance Protection
220KV	Tillari-Halkarni.	25-Jul-10	16.40	25-Jul-10	17.45	Tripped at Tillari end
220KV	220 KV Bus @ Kandalgaon	25-Jul-10	11.10	25-Jul-10	11.56	Bus Fault due to fault on Lonand line
220KV	220/132 KV 100 MVA ICT-II @ Parbhani	25-Jul-10	11.05	25-Jul-10	11.20	Attending Red Hot
220KV	Kandalgaon - Lonand	25-Jul-10	11.10	25-Jul-10	13.50	Faulty declared
220KV	Kharghar - Kandalgaon	25-Jul-10	11.10	25-Jul-10	11.50	Bus Fault at K'gaon
220KV	Pophali-K'gaon	25-Jul-10	11.10	25-Jul-10	12.05	Bus Fault at K'gaon
220KV	Bhira-Kandalgaon	25-Jul-10	11.10	25-Jul-10	12.10	Bus Fault at K'gaon
220KV	Kandalgaon - Pirangut	25-Jul-10	11.10	25-Jul-10	12.14	Bus Fault
220KV	Kandalgaon - ONGC	25-Jul-10	11.10	25-Jul-10	12.13	Bus Fault
220KV	Kandalgaon - Dasturi	25-Jul-10	11.10	25-Jul-10	12.11	Bus Fault
220KV	220/100 KV 50 MVA ICT- II @ K'gaon	25-Jul-10	11.10	25-Jul-10	12.21	Bus Fault
220KV	220/100KV 100MVA ICT-III at K'gaon	25-Jul-10	11.10	25-Jul-10	12.24	Bus Fault
220KV	220KV Bus Coupler at Phursungi	25-Jul-10	13.15	25-Jul-10	14.00	To remove conductor strand on CT
220KV	220/100KV 50MVA ICT-I at K'gaon	25-Jul-10	11.10	25-Jul-10	12.21	Bus Fault
220KV	220/22KV 50MVA ICT-II at K'gaon	25-Jul-10	11.10	25-Jul-10	12.24	Bus Fault
132KV	Ambazari - Hingna - I	21-Jul-10	10.00	21-Jul-10	13.25	Repl.Of R-Ph wave trap.
132KV	Ambazari-Hingna-II	21-Jul-10	12.25	21-Jul-10	13.20	Installing trip ckt.supervision relay.
132KV	Girwali - Gangakhed	22-Jul-10	05.42	22-Jul-10	06.12	Dist.Prot.operated Y-Ph.
132KV	132 KV Bus @ Chinchwad	22-Jul-10	10.44	22-Jul-10	17.45	Q.M.Work
132KV	Boiser - Viraj	23-Jul-10	09.32	23-Jul-10	13.48	Conductor replacement

132KV	Girwali - Gangakhed	23-Jul-10	05.44	23-Jul-10	06.25	Distance protection
132KV	Amravati-Chandurbazar	23-Jul-10	17.05	23-Jul-10	18.20	Distance Protection
132KV	Bhandara-Mouda	23-Jul-10	20.01	23-Jul-10	20.34	Distance protection
100KV	Kandalgaon-Roha-I	25-Jul-10	11.10	25-Jul-10	12.32	Bus Fault
100KV	Kandalgaon-Roha-II	25-Jul-10	11.10	25-Jul-10	12.42	Bus Fault
220KV	220/132KV 100 MVA ICT- II @ Peth	17-Jul-10	03.00	17-Jul-10	03.15	Backup Protection
220KV	Main Bus II @ Aarey	17-Jul-10	00.50	17-Jul-10	05.35	Double Isolator Scheme Work
220KV	220/132KV 200MVA ICT-I @ Raymond	17-Jul-10	10.30	17-Jul-10	15.00	To find out DC Earth Leakage
220KV	Aurangabad - Babaleshwar	17-Jul-10	12.04	17-Jul-10	19.39	H/T due to BBLSR ICT Outage
220KV	Khaparkheda-Kawlewada-I	17-Jul-10	02.21	18-Jul-10	17.00	Conductor Snapped Loc.No.21,22
220KV	Parli-Usmanabad	17-Jul-10	13.51	17-Jul-10	16.13	Protection trial of Main Breaker
220KV	Warora-Hinganghat	17-Jul-10	14.12	17-Jul-10	15.30	Supervision Relay testing work
220KV	220/132KV 100 MVA ICT- III @ Parli-II	17-Jul-10	11.00	17-Jul-10	17.54	ICT OLTC checking work
220KV	Bableswhar-Bhenda	18-Jul-10	01.37	18-Jul-10	12.30	Distance Protection
220KV	Main Bus II @ Aarey	18-Jul-10	07.04	18-Jul-10	10.11	Double Isolator scheme work
220KV	Borivali-Boisar	18-Jul-10	12.02	18-Jul-10	17.12	To control line loading
220KV	Mudsungi - Chikodi	18-Jul-10	17.10	18-Jul-10	21.50	Distance protection
220KV	Tarapur-Boisor-II	18-Jul-10	09.00	18-Jul-10	15.06	Urgent Civil work
220KV	220/132KV 200 MVA ICT- II @ Raymond	18-Jul-10	19.55	21-Jul-10	15.40	H/T due to oil leakage of R phase CT
220KV	Aarey-Borivali-II	18-Jul-10	07.24	18-Jul-10	10.11	Double Isolator Scheme work
220KV	Murud-Bale	18-Jul-10	09.45	20-Jul-10	12:00	Main Breaker replacement work, Ckt on TBC
220KV	Butibori - Wardha	18-Jul-10	21.33	18-Jul-10	21.54	Distance Protection
132KV	Bhandara-Kardha	12-Jul-10	19.06	12-Jul-10	19.55	Distance Protection.
132KV	Nanded - Umri	15-Jul-10	10.48	15-Jul-10	11.06	HV back up protection operated.
132KV	132 KV Bus Coupler @ Boiser- II	16-Jul-10	09.30	16-Jul-10	16.00	Breaker work
132KV	Beed-Gevrai	16-Jul-10	00.00	16-Jul-10	00.14	Backup Protection operated
132KV	Girwali - Gangakhed	16-Jul-10	05.30	16-Jul-10	07.56	Distance Protection
132KV	Peth-Sirla	17-Jul-10	03.00	17-Jul-10	17.15	Backup Protection
132KV	Kalmeshwar-Katol	17-Jul-10	13.27	17-Jul-10	13.43	Tripped on PDR at Katol
132KV	Ambazari - Hingna - I	17-Jul-10	22.23	18-Jul-10	10.28	To attend Hot Glow on R Phase Wave-Trap Top
132KV	Kanhan - Bhandara	17-Jul-10	23.19	18-Jul-10	00.03	Distance protection
132KV	Bhandara - Madgi -I	18-Jul-10	00.58	18-Jul-10	01.26	Tripped on Backup Protection
132KV	Bhandara - Madgi - II	18-Jul-10	00.58	18-Jul-10	01.25	Distance Protection