

LINE OUTAGES FOR THE WEEK

FROM 16-Jul-12 TO 22-Jul-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Kolhapur - Mapusa - II	12-Jul-12	23.28	16-Jul-12	09.29	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	13-Jul-12	11.20	19-Jul-12	13.36	Over Voltage,Oppt. outage,availed on 14.07.2012 Jumper tightening work.
400KV	Karad - Kolhapur - II	15-Jul-12	16.14	16-Jul-12	08.59	Over Voltage.
400KV	Karad-Jaigad II	15-Jul-12	15.53	16-Jul-12	07.16	Distance protection .Ready for charging at 16.40Hrs.on 15.07.2012.
400KV	Akola - Wardha - I	16-Jul-12	00.06	18-Jul-12	11.13	Over Voltage.
400KV	New Koyna - Dabhol - I	16-Jul-12	09.23	16-Jul-12	18.25	CVT checking for VT fail problem main-II relay.
400KV	Karad - Kolhapur - I	16-Jul-12	16.13	17-Jul-12	09.11	Over Voltage.
400KV	Kolhapur - Mapusa - I	16-Jul-12	17.10	18-Jul-12	09.44	Over Voltage.
400KV	400/220KV,500 MVA ICT-III at Kolhapur	16-Jul-12	16.38	16-Jul-12	18.40	For taking load.
400KV	400/220 KV 315 MVA ICT - I @ Chakan	16-Jul-12	19.08	16-Jul-12	20.28	Hot spot attending work.
400KV	TBC at 400KV Aurangabad	16-Jul-12	15.25	16-Jul-12	17.23	Measurement of tan delta of CT.
400KV	400/220 KV 315 MVA ICT-II @ Chandrapur	17-Jul-12	08.28	17-Jul-12	22.28	Retrofitting of Relay
400KV	Parli-Lonikand - II	17-Jul-12	09.05	17-Jul-12	09.55	Removal of Snapped E/W
400KV	Dabhol - NewKoyna - II	17-Jul-12	18.55	17-Jul-12	19.50	Distance Protection
400KV	Dhule-Sar'Sarovar - I	17-Jul-12	08.07	17-Jul-12	18.02	R-ph LA burst.
400KV	Karad-Kolhapur-II	17-Jul-12	17.00	18-Jul-12	09.39	Over Voltage
400KV	Karad - Kolhapur - II	18-Jul-12	17.07	19-Jul-12	09.06	Over Voltage
400KV	Parli - Solapur	18-Jul-12	07.43	18-Jul-12	16.28	Hot Spot
400KV	400/220KV,315MVA ICT-I at Karad	18-Jul-12	10.53	18-Jul-12	15.36	Q.M.Work
400KV	Main Bus-I at Girwali	18-Jul-12	07.55	18-Jul-12	15.47	Hot Spot
400KV	400/220KV 315MVA ICT-II @ Kharghar	18-Jul-12	10.53	18-Jul-12	17.50	D.C.Leakage
400KV	New Koyna - Dabhol - I	18-Jul-12	11.14	18-Jul-12	16.06	Replacement of CVT Faulty cable
400KV	Padgha-Bhoisor (PGCIL)	18-Jul-12	11.10	19-Jul-12	17.58	Breaker Problem(Taken on TBC)
400KV	Kolhapur-Mapusa-II	18-Jul-12	22.46		Continued.	Over Voltage
400KV	Chandrapur - Parli - I	19-Jul-12	07.53	19-Jul-12	19.32	Realignment of corona ring of main bus-II.
400KV	Dhule-Sar'Sarovar - I	19-Jul-12	15.35		Continued.	Over Voltage.
400KV	Parli-Parli (PGCIL) I	19-Jul-12	08.00	19-Jul-12	21.51	Realignment of corona ring of main bus-ii.
400KV	M.B-II At 400KV Parli	19-Jul-12	08.19	19-Jul-12	19.24	Realignment of corona ring of B Ph of main bus-II
400KV	Karad-Jaigad II	19-Jul-12	08.31	19-Jul-12	09.56	Distance Protection.
400KV	Karad - Kolhapur - II	19-Jul-12	20.05	20-Jul-12	10.19	Over Voltage.
400KV	Jejuri-Koyna STG-IV	19-Jul-12	21.46	20-Jul-12	13.43	Distance Protection.
400KV	Karad-Jaigad II	19-Jul-12	23.14	20-Jul-12	07.25	Distance Protection.
400KV	Parli-Parli (PGCIL)-II	19-Jul-12	08:08		Continued.	Over Voltage.
400KV	TBC @ Kharghar	20-Jul-12	09.55	20-Jul-12	19.17	Repl.of rotary insulator for R-Ph & Y-Ph C-isolator alignment of C-isolator
400KV	Khaparkheda - Chandrapur	20-Jul-12	09.20	20-Jul-12	19.02	Measurement of C.T.tan delta and R.M.Work.
400KV	400/220KV,500 MVA ICT-III At A'bad.	20-Jul-12	10.17	20-Jul-12	18.08	Maintenance and PRS work.
400KV	Karad - Kolhapur - II	20-Jul-12	16.38	21-Jul-12	09.21	Over Voltage.
400KV	Akola - Wardha - I	20-Jul-12	12.51		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	21-Jul-12	04.04	21-Jul-12	06.53	Over Voltage.
400KV	Karad - Kolhapur - II	21-Jul-12	17.11		Continued.	Over Voltage.
400KV	Babaleswar - Dhule - I	21-Jul-12	15.58	21-Jul-12	16.12	R-Ph PT isolator sparking at Dhule end.
400KV	Babaleswar - Dhule - I	21-Jul-12	09.33	21-Jul-12	15.45	Maint.of PG mechanism box.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	21-Jul-12	12.38		Continued.	29 D isolator work (Taken on TBC).
400KV	TBC at 400KV Aurangabad	21-Jul-12	14.30	21-Jul-12	19.00	For DEMO DCRM Kit.
400KV	Bhusawal- Aurangabad	22-Jul-12	16.09		Continued.	Over Voltage.
400KV	C'pur-Parli II	22-Jul-12	02.00		Continued.	Distance Protection.
220KV	220/110KV 200MVA ICT-II at Mudshingi	9-Jul-12	09.12	16-Jul-12	14.40	Bus section II and III outage.
220KV	Bale-Osmanbad	9-Jul-12	12.30	18-Jul-12	18.07	To control Parli ICT loading.

220KV	Auxiliary Bus @ Babhleshwar	12-Jul-12	11.02	16-Jul-12	18.45	Balance work of conversion of single to Twin Conductor.
220KV	Main bus section I & III at Mudshingi.	16-Jul-12	09.20	16-Jul-12	14.35	Connecting jumper of bus isolator of 220KV Wathar,Karad T/F II.
220KV	Mudshingi-Wathar	16-Jul-12	09.05	16-Jul-12	14.41	220 KV Bus Section II & III outage at Mudshingi.
220KV	Mudshingi - Karad - II	16-Jul-12	09.05	16-Jul-12	16.45	220 KV Bus Section II & III outage at Mudshingi.
220KV	Mudshingi - Peth	16-Jul-12	09.05	16-Jul-12	16.55	220KV bus section-II and III outage at Mudsingi.
220KV	Mudshingi-Chikodi	16-Jul-12	09.05	16-Jul-12	14.39	220KV bus section-II and III outage at Mudsingi.
220KV	220/132KV,200 MVA T/F-II and III at Mudsingi	16-Jul-12	09.10	16-Jul-12	14.40	220KV bus section-II and III outage at Mudsingi.
220KV	Pedambe - Oni	16-Jul-12	07.00	16-Jul-12	16.07	Distance protection.
220KV	Mudshingi - Talandage - I	16-Jul-12	09.05	16-Jul-12	14.38	220 KV Bus Section II & III outage at Mudshingi.
220KV	Mudshingi-Talandage-II	16-Jul-12	09.05	16-Jul-12	14.37	220 KV Bus Section II & III outage at Mudshingi.
220KV	Mudshingi-Karad CKT IV	16-Jul-12	08.15	16-Jul-12	14.45	220 KV Bus Section II & III outage at Mudshingi.
220KV	Khaparkheda-Ambazari - I	16-Jul-12	22.31	17-Jul-12	02.32	Trip Ckt Faulty Indication Appeared
220KV	Vankuswadi - MIDC Satara- II	17-Jul-12	07.30	17-Jul-12	18.43	LILO work
220KV	Karad - Kiniwathar	17-Jul-12	03.45	17-Jul-12	04.02	Distance protection.
220KV	Vankushwadi - MIDC Satara - I	17-Jul-12	07.30	17-Jul-12	18.43	LILO work
220KV	Apta-HOC	17-Jul-12	09.51	17-Jul-12	12.48	Dismantalling of Aux.isolator
220KV	Pedambe-Mahad	17-Jul-12	10.10	17-Jul-12	17.58	Replacement of Wave Trap Jumper
220KV	Miraj - Kadegaon	17-Jul-12	10.31	17-Jul-12	17.58	Q.M.Work
220KV	Miraj -Vita	17-Jul-12	10.31	17-Jul-12	18.00	Main Bus Work at Miraj
220KV	Miraj -Ichalkarajni	17-Jul-12	10.31	17-Jul-12	18.16	Main Bus Work at Miraj
220KV	Miraj - Mhaisal	17-Jul-12	10.31	17-Jul-12	18.03	Main Bus Work at Miraj
220KV	220/132 KV 100 MVA ICT at Bhandara	17-Jul-12	10.45	18-Jul-12	16.33	Fixing of Differential and Backup Relay
220KV	220/110 KV 200 MVA T/F @ Ogalewadi	17-Jul-12	10.48	17-Jul-12	15.43	Q.M.Work
220KV	220/132 KV,200 MVA ICT-II at Chikhli	17-Jul-12	12.16	17-Jul-12	18.53	Measurement of Tan Delta of CT
220KV	Main Bus - I @ Ogalewadi	17-Jul-12	10.55	17-Jul-12	15.35	Q.M.work
220KV	Nasik-Navsari -II	17-Jul-12	09.40	17-Jul-12	18.41	Replacement of Faulty Disc Insulator
220KV	Pophali - Kandalgaon	17-Jul-12	12.20	17-Jul-12	18.45	R-ph Wave trap to line jumper opened.
220KV	Lote-Dasturi	17-Jul-12	12.20	17-Jul-12	12.55	Over Current
220KV	220/110 KV 200 MVA ICT - II @ Miraj	17-Jul-12	10.31	17-Jul-12	18.00	Main Bus Work at Miraj
220KV	220/110,200 MVA T/F-I at Miraj	17-Jul-12	10.31	17-Jul-12	18.00	Main Bus Work at Miraj
220KV	Khaparkheda-Ambazari - I	17-Jul-12	06.53	17-Jul-12	14.46	Trip Ckt faulty Indication receive(CKT is on TBC)
220KV	Parly - Harangool - I	17-Jul-12	10.05	17-Jul-12	14.55	Q.M.Work
220KV	Karad-Oglewadi-I	17-Jul-12	10.50	17-Jul-12	15.15	Q.M.Work
220KV	220/110 KV 100 MAV T/F - I @ Ogalewadi	17-Jul-12	10.49	17-Jul-12	18.10	Half Bus section-I outage
220KV	Nasik-Navsari-I	18-Jul-12	09.55	18-Jul-12	19.09	Replacement of Disc Insulator
220KV	Lamboti-Solapur-II	18-Jul-12	08.14	21-Jul-12	06.32	Replacement of Conductor
220KV	Karkumbh-Jeur	18-Jul-12	16.45	18-Jul-12	19.36	Hot Spot
220KV	220/22KV 50MVA T/F-I at Mulund	18-Jul-12	21.05	19-Jul-12	20.33	LV Side B Pole Breaker Burst
220KV	Main Bus -I at BBLSR	19-Jul-12	14.12		Continued.	Conductor replacement work.
220KV	Chinchwad - Parvati	19-Jul-12	09.10	19-Jul-12	14.56	Replacement of R phase CT.
220KV	Bhosari - Chakan	19-Jul-12	09.38	19-Jul-12	16.54	Conductor replacement work.
220KV	Kharghar-Nerul	19-Jul-12	11.39	19-Jul-12	17.31	D.C. leakage taken on TBC.
220KV	ONGC-JNPT	19-Jul-12	07.22	19-Jul-12	11.18	Distance Protection.
220KV	Murud - Girawli.	19-Jul-12	06.41	19-Jul-12	07.55	B Phase CT burst.
220KV	Murud-Tuljapur	19-Jul-12	06.41	19-Jul-12	08.22	Trip
220KV	Kalmeshwar-Kaparkheda	19-Jul-12	13.56	19-Jul-12	17.08	Quarterly maintenance work.
220KV	Paras - Akola - I	19-Jul-12	14.56	19-Jul-12	17.11	To Attending of hot spot.
220KV	Hingoli-Parbhani	19-Jul-12	10.40	19-Jul-12	13.13	Finding earth leakage.
220KV	220/132 KV 200 MVA ICT - II @ Parbhani	19-Jul-12	23.18	19-Jul-12	15.03	PRV operated.

220KV	Hingoli-Pusad	19-Jul-12	13.20	19-Jul-12	16.19	Attending hot spot measurement of Tan delta of CT.
220KV	220/33KV 50MVA T/F-II at Murud	19-Jul-12	06.41	19-Jul-12	07.55	Tripped 50 MVA T/F-I HV side B Ph. CT Burst.
220KV	220/33 KV 50 MVA T/F - I @ Murud	19-Jul-12	06.41	19-Jul-12	17.56	HV side B Phase CT Burst.
220KV	Kalwa-Airoli-Knowledge park	20-Jul-12	06.32	20-Jul-12	14.51	Creak side bus outage.
220KV	220 KV Interconnector Alongwith 220KV Cr	20-Jul-12	06.38	20-Jul-12	14.39	Replacement of damaged R ph. main bus jumper creak side bus.
220KV	Inter Connector @ Kalwa	20-Jul-12	06.35	20-Jul-12	14.47	Creak side bus outage.
220KV	220/100KV 200MVA ICT-I at Kalwa	20-Jul-12	06.27	20-Jul-12	15.07	Creak side bus outage.
220KV	220/100KV 200MVA ICT-II at Kalwa	20-Jul-12	06.28	20-Jul-12	15.13	Creak side bus outage.
220KV	220/22 KV 50 MVA T/F - I @ Kalwa	20-Jul-12	06.25	20-Jul-12	15.25	Creak side bus outage.
220KV	Kamba - Kolshet	20-Jul-12	08.45	20-Jul-12	18.38	Shifting of 1 conductor of highway crossing span from gantry to loc.no 13
220KV	Newkoyna -Lote-Parsuram	20-Jul-12	10.05	20-Jul-12	15.13	Maint.work.
220KV	220/110 KV 200 MVA ICT - I @ Kolhapur	20-Jul-12	10.30	20-Jul-12	12.36	Q.M.Work.
220KV	SPCL - IPCL	20-Jul-12	10.35	20-Jul-12	13.58	To attend hot spot.
220KV	Malegaon - Satana - II	20-Jul-12	14.20	20-Jul-12	16.27	Tan delta testing of C.T.
220KV	Malegaon - Satana - I	20-Jul-12	16.30	20-Jul-12	19.14	Tan delta testing of C.T.
220KV	Aurangabad-Padegaon CKT-II	20-Jul-12	10.46	20-Jul-12	16.48	Tand delta measurement and maint,Ckt.on TBC
220KV	Magarpatta - Sirum	21-Jul-12	19.18		Continued.	To free TBC of Magarpatta.
220KV	220/132 KV 200 MVA ICT - III @ Bale	21-Jul-12	14.50	21-Jul-12	18.02	Bus Bar protection pannel work.
220KV	Ghodbandar - Bhoisor (MSETCL)	21-Jul-12	11.08	21-Jul-12	13.48	Repl.of faulty insulator string.
220KV	220/132 KV,200 MVA ICT-I at Ahamadnaga	21-Jul-12	10.00	21-Jul-12	16.44	CT tan delta measurement work.
220KV	220/132 KV 200 MVA ICT - I @ Babaleshwa	21-Jul-12	09.50	21-Jul-12	13.02	Q.M.Work.
220KV	Magarpatta - Sirum	21-Jul-12	09.32	21-Jul-12	17.55	Half yearly maint.work.(Taken on TBC.)
220KV	Kurkumb-Bhigwan	21-Jul-12	09.20	21-Jul-12	20.15	Repl.of faulty disc insulator.
220KV	Main Bus & Line at Fiat	21-Jul-12	10.30	21-Jul-12	17.49	Testing and commissioning of remote scada.
220KV	Kaparkheda-Kalmeshwar	21-Jul-12	12.02	21-Jul-12	17.31	A/R scheme commissioning work.
220KV	220/66 KV 150 MVA ICT- I @ Gadchandur	21-Jul-12	10.50	21-Jul-12	15.34	Repl.of CT and Q.M.Work.
220KV	Tarapur - Borivali	22-Jul-12	08.50	22-Jul-12	13.11	R.M.Work
220KV	Mulund - Bhandup (GIS)	22-Jul-12	10.27	22-Jul-12	12.50	Repl.of defective jumper.
220KV	Pusad - Nanded	22-Jul-12	17.55		Continued.	Y-Ph CT cable burnt,H/T from Pusad end.
220KV	Kalmeshwar-Nippon	22-Jul-12	20.56	22-Jul-12	23.21	Dist.Protection.(Ckt charged on TBC).
132KV	Niwali-Ujni	16-Jul-12	04.31	16-Jul-12	05.07	Distance protection.
132KV	Jalna-Badnapur	16-Jul-12	11.55	16-Jul-12	20.25	B ph.CT burst at Badnapur .
132KV	Ujani-Umarga	17-Jul-12	05.41	17-Jul-12	16.00	Distance Protection
132KV	Girwali - Latur MIDC	17-Jul-12	05.39	17-Jul-12	06.00	Distance Protection
132KV	Chinchwad-Chakan	19-Jul-12	10.15	19-Jul-12	13.38	Tree cutting.
132KV	Padegaon-Pishor	20-Jul-12	08.00	20-Jul-12	18.20	Stringing work of conductor.
132KV	Bhusawal-Sawda	22-Jul-12	19.42		Continued.	Dist.Protection operated,Z-I,R-Ph.
132KV	132/7 KV,31.5 MVA Station T/F - II at Bhusa	22-Jul-12	19.43	22-Jul-12	21.38	Diff.protection.
132KV	Parli-Talegaon	22-Jul-12	20.10	22-Jul-12	20.20	Dist.Protection operated,Z-I,Y-Ph.
100KV	Kalwa-Washi	18-Jul-12	20.49	18-Jul-12	21.09	Tripped at Kalwa
100KV	Std.Alkali - washi	18-Jul-12	20.49	18-Jul-12	21.09	Distance Protection
100KV	Kalwa-Standard	18-Jul-12	20.49	18-Jul-12	21.09	Tripped at Standard
100KV	Kandalgaon-Roha-I	19-Jul-12	17.27	19-Jul-12	17.51	Distance Protection.