

LINE OUTAGES FOR THE WEEK

FROM 18-Oct-10 TO 24-Oct-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Akola - Aurangabad- II	3-Oct-10	17.38	22-Oct-10	14.43	Over Voltage.
400KV	Bhusawal- Aurangabad	15-Oct-10	10.06	18-Oct-10	13.29	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	15-Oct-10	23.16	21-Oct-10	15.21	Over Voltage.
400KV	Kolhapur - Mapusa - II	15-Oct-10	22.42	23-Oct-10	11.25	Over voltage.
400KV	Chandrapur - Parli - I	17-Oct-10	10.22	18-Oct-10	04.52	CVT oil leakage B-Ph at Parli end.
400KV	Babaleshwar - Dhule - I	17-Oct-10	22.08	18-Oct-10	06.53	Over Volatge.
400KV	Lonikand- Koyna Stage IV	17-Oct-10	22.47	18-Oct-10	07.27	Over Voltage.
400KV	Karad-Lamboti	17-Oct-10	23.24	18-Oct-10	08.05	Over Voltage.
400KV	Karad - Kolhapur - I	18-Oct-10	00.14	18-Oct-10	07.29	Over Voltage.
400KV	Bhusawal- Aurangabad	18-Oct-10	16.40	24-Oct-10	11.57	Over Voltage.
400KV	Karad-Lamboti	18-Oct-10	23.23	19-Oct-10	07.26	Over Voltage.
400KV	Lonikand- Koyna Stage IV	18-Oct-10	23.38	19-Oct-10	12.24	Over Voltage.
400KV	Koradi-Bhilai	18-Oct-10	10.16	18-Oct-10	14.50	Main breaker compressor air leakage problem.
400KV	Padgha - Kharghar	19-Oct-10	09.44	19-Oct-10	19.21	Jumper replacement
400KV	Main Bus - I @ Kharghar	19-Oct-10	09.48	19-Oct-10	19.55	Wave trap jumper replacement.
400KV	440/220 KV 315 MVA ICT @ Bhusawal II	19-Oct-10	15.06	19-Oct-10	15.34	NDR protection operated.
400KV	400/220 KV 600 MVA ICT- I @ Kalwa	19-Oct-10	16.15		Continued.	Fire in 200 MVA ICT.
400KV	Karad-Lamboti	20-Oct-10	00.22	20-Oct-10	14.10	Over Voltage.
400KV	Lonikand- Koyna Stage IV	20-Oct-10	00.22	20-Oct-10	08.51	Over Voltage.
400KV	Parli - Lamboti	20-Oct-10	14.36	20-Oct-10	14.58	For Planned Outage.
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	20-Oct-10	14.36	20-Oct-10	14.58	While Taking Outage on Parly-Lamboti.
400KV	400/220 KV 105 MVA Spare ICT Unit @ Bhusawal	20-Oct-10	16.04	20-Oct-10	22.14	H V Side L A Burst.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	21-Oct-10	10.09	21-Oct-10	16.48	Hot Spot Attending.
400KV	Dabhol - NewKoyna - II	21-Oct-10	15.21	21-Oct-10	15.58	OUTAGE.
400KV	Dhule-Sar'Sarovar - II	21-Oct-10	18.11	22-Oct-10	10.48	Over Voltage.
400KV	Akola - Aurangabad - I	22-Oct-10	14.43		Continued.	Changeover.
400KV	Dhule-Sar'Sarovar - I	22-Oct-10	10.49		Continued.	To attend the work of E/W refixing in clamp.
400KV	400/220 KV,105 MVA Spare ICT @ Dhule	22-Oct-10	09.35	22-Oct-10	16.15	SFRA and Tan delta measurement.
400KV	Lonikand- Koyna Stage IV	23-Oct-10	00.30	23-Oct-10	09.57	Over Voltage.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	23-Oct-10	03.59	23-Oct-10	06.42	Attending Red Hot.
400KV	400/220KV 315MVA ICT- I @ Chandrapur	23-Oct-10	08.21	23-Oct-10	17.24	CB testing and Bay maintenance.
400KV	Karad - Lonikand	23-Oct-10	13.48	23-Oct-10	17.13	Reactor testing work.
400KV	Kolhapur - Mapusa - I	23-Oct-10	22.12	24-Oct-10	08.38	Over Voltage.
400KV	Main breaker of New Koyna-Karad-I Ckt.	24-Oct-10	00.05		Continued.	Main breaker problem.Line on TBC.
400KV	Lonikand- Koyna Stage IV	24-Oct-10	00.27	24-Oct-10	08.31	Over Voltage.

400KV	400/220KV,500 MVA ICT-III At A'bad.	24-Oct-10	11.30	24-Oct-10	12.11	Load taken on New ICT(New commissioned ICT.)
400KV	Kolhapur - Mapusa - II	24-Oct-10	22.28		Continued.	Over Voltage.
220KV	Bableshtar-Nasik-I	13-Oct-10	09.50	20-Oct-10	15.00	Replacement of Old main bus I&II Isolator
220KV	Chinchwad - Hinjewadi	14-Oct-10	10.08	19-Oct-10	17.50	Line on TBC Bkr O/H Work.
220KV	Pirangut-Hinjewadi	17-Oct-10	19.42	18-Oct-10	00.41	Distance Protection under B/D.
220KV	Raymond-Washala	18-Oct-10	16.23	18-Oct-10	16.48	Distance Protection.
220KV	Reymond-OCR Nasik	18-Oct-10	16.23	18-Oct-10	16.28	Distance protection.
220KV	Bhosari-C'enka	18-Oct-10	18.12	18-Oct-10	19.12	Distance protection.
220KV	C' Enka - Khadki	18-Oct-10	18.12	18-Oct-10	19.22	Distance protection.
220KV	Kandalgaon-Pophali-I	18-Oct-10	20.55	18-Oct-10	21.45	Distance protection.
220KV	NewKoyna - Pawas	18-Oct-10	21.16	19-Oct-10	11.20	Distance protection.R Ph.D caping.
220KV	Phinolex-Kharepatan	18-Oct-10	21.23	19-Oct-10	12.12	R-E B/U prot.operated.R Ph.D caping.
220KV	New Koyna- Finolex	18-Oct-10	21.16	19-Oct-10	11.22	Distance protection.
220KV	Pedambe-Kharepatan	18-Oct-10	22.14	18-Oct-10	23.07	Trip,while charging 220KV Kharepatan-Finolex line.
220KV	220/132KV,200MVA ICT-III At Nanded.	18-Oct-10	11.37	18-Oct-10	15.45	Attend oil leakage of conservator tank.
220KV	Karad-M'peth	19-Oct-10	10.00	20-Oct-10	20.45	Breaker O/H work at Malharpeth .
220KV	Karad - Miraj	19-Oct-10	10.50	19-Oct-10	15.05	Removal of jumper.
220KV	220/33 KV 50 MVA T/F II @ Vita	19-Oct-10	11.00	19-Oct-10	14.50	R.M.work.
220KV	Padgha-Kamba	19-Oct-10	16.03	19-Oct-10	16.15	Distance protection.
220KV	Wada-Kolshet	19-Oct-10	16.35	19-Oct-10	17.30	Distance protection.
220KV	Nasik - Airoli - Knowledge Park	19-Oct-10	18.37	19-Oct-10	19.06	Distance protection.
220KV	Borivali-Tata Borivali 4	19-Oct-10	16.41		Continued.	To control ICT Kalwa loading.
220KV	Kalwa-Ghatghar	19-Oct-10	18.37	19-Oct-10	19.22	Distance protection.
220KV	220KV Mulund Tie Breaker.	19-Oct-10	09.42	19-Oct-10	17.05	Made on due to ICT Kalwa loading control.
220KV	Lamboti-Bale-I	20-Oct-10	14.36	20-Oct-10	15.02	Due to Tripping of Lamboti 500 MVA ICT-I.
220KV	Lamboti-Bale-II	20-Oct-10	15.02	20-Oct-10	15.02	Due to Tripping of Lamboti ICT - I.
220KV	Ghatghar-Jindal	20-Oct-10	18.22	20-Oct-10	18.57	Distenace Protection.
220KV	Nasik - Ghatghar	20-Oct-10	18.53	20-Oct-10	19.04	Distenace Protection
220KV	Nasik - Ghatghar	20-Oct-10	19.11	20-Oct-10	20.33	Distenace Protection.
220KV	Lamboti-Bale-I	20-Oct-10	10.55	20-Oct-10	14.24	Q.M.
220KV	Bus Coupler @ Varsoa	20-Oct-10	09.25	20-Oct-10	15.05	Annual Bay Maint.
220KV	Nasik-Navsari-I	20-Oct-10	11.00	20-Oct-10	18.17	For Load Relief.
220KV	Nasik - Navasari - II	20-Oct-10	12.56	20-Oct-10	19.20	For Load Relief.
220KV	MUDSHINGI-CHIKODI	20-Oct-10	13.35	20-Oct-10	15.58	Q.M.
220KV	Kalmeshwar-Ambazari	20-Oct-10	08.08	20-Oct-10	17.27	Laying of Earthwire @ Loc. 5 to 20.
220KV	220/132 KV 200 MVA ICT- II @ Kalmeshwar	20-Oct-10	09.31		Continued.	Oil Filtration Work.(4 Day's)
220KV	Pirangut - Kandalgaon	21-Oct-10	06.30	21-Oct-10	18.34	Replacement of Earthwire.
220KV	Lonikand-Khadki	21-Oct-10	07.13	21-Oct-10	08.22	Attending Hot Spot on C T B pH.
220KV	Chinchwad - Parvati	21-Oct-10	07.15		Continued.	Const. of Tower Work.
220KV	Bhosari-Telco	21-Oct-10	08.39		Continued.	Replacement of Conductor.

220KV	Phursungi - Parvati	21-Oct-10	08.03	22-Oct-10	05.57	Const.of Tower Work.
220KV	Nagothane-Mahad	21-Oct-10	09.33	21-Oct-10	17.33	Bay Maint.Work.
220KV	Jejuri - Baramati	21-Oct-10	09.30	21-Oct-10	17.48	Quarterly Maint.Work.
220KV	Kiniwathar - Karad	21-Oct-10	10.41	21-Oct-10	18.13	Commissining of New C B @ Karad.
220KV	220/22 KV 50 MVA T/F - I @ Kalwa	21-Oct-10	06.40	21-Oct-10	11.21	One O.G. Cable Faulty,Isolated.
220KV	Badnera - Deoli (PGCIL)	21-Oct-10	10.07	21-Oct-10	19.36	Jumpering Work.
220KV	Padgha - Boisar (PGCIL)	21-Oct-10	13.24		Continued.	Hand Tripped (To Transfer Load to PGCIL)
220KV	Kalmeshwar-Ambazari	21-Oct-10	08.57	21-Oct-10	17.36	Laying of Earthwire on Double Ckt Tower Bet.Loc.5 to 20.
220KV	Bhandara-Kanhan ckt-I	21-Oct-10	09.58	21-Oct-10	15.00	Replacement of Air Pressure Switch.
220KV	220/7 KV 35 MVA Station T/F - I @ Parly	21-Oct-10	10.20		Continued.	Replacement of Aux.& Bus Side Isolator.
220KV	Wardha - Yawatmal	21-Oct-10	17.11	21-Oct-10	19.19	To Replace L A.
220KV	Kalmeshwar-Kaparkheda	21-Oct-10	14.34	21-Oct-10	15.19	Distance Protection R Ph. E/F.
220KV	Khaparkheda-Kawlewada-I	21-Oct-10	16.05	21-Oct-10	16.21	Distance Protection B Ph. E/F.
220KV	Parli-Usmanabad	22-Oct-10	01.04	22-Oct-10	02.10	Distance Protection Zone - I.
220KV	Chinchwad-Urse	22-Oct-10	01.55	22-Oct-10	03.45	Distance Protection Operated Z-I Y Ph E/F.
220KV	Raymond-Washala	22-Oct-10	08.30	22-Oct-10	17.08	Insulator replacement work.
220KV	Nagothane-MSL	22-Oct-10	09.54	22-Oct-10	16.49	Relay testing and bay maint.
220KV	Padgha-Jambhul-I	22-Oct-10	09.00	22-Oct-10	17.08	Bay maintenance work.
220KV	Kolhapur-Karad-IV	22-Oct-10	10.10	22-Oct-10	13.40	CB dismaitling work.
220KV	Wada-Kolshet	22-Oct-10	10.00	22-Oct-10	20.55	For faulty distance relay replacement work.
220KV	New Koyna- Finolex	22-Oct-10	12.42	22-Oct-10	13.23	Dist.protection.
220KV	Kalwa - Ghatghar	22-Oct-10	22.06	23-Oct-10	03.10	Kalwa end.
220KV	Kalmeshwar - Pandurna	22-Oct-10	12.24	22-Oct-10	13.12	Dist.protection,B-Ph.
220KV	220/132KV 100MVA ICT at Butibori	22-Oct-10	10.24	22-Oct-10	16.24	Bay maint.work
220KV	Kanhan - Bhandara - II	22-Oct-10	11.33	22-Oct-10	13.00	Replacement of auto reclose pressure switch.
220KV	220/66KV 50 MVA ICT- II @ Wardha	22-Oct-10	09.39	22-Oct-10	12.10	Attending oil leakage.
220KV	Apta-Nagothane	23-Oct-10	08.45	23-Oct-10	18.41	Insulator replacement work.
220KV	220/132 KV 150 MVA ICT - I @ NSK.	23-Oct-10	09.18	23-Oct-10	17.01	Bay maintenance.
220KV	220/132 KV 150 MVA ICT- II @ Nasik	23-Oct-10	09.05	23-Oct-10	17.00	Bay maintenance.
220KV	220/100 KV,100 MVA ICT-I @ Tambati	23-Oct-10	10.30	23-Oct-10	15.27	OLTC servicing work.
220KV	Chinchwad-Bhosari	23-Oct-10	11.48	23-Oct-10	14.32	Maintenance work.
220KV	Bhugaon-Wardha	23-Oct-10	22.30		Continued.	To control Wardha-Warora line loading.
220KV	Kalwa - Ghatghar	24-Oct-10	00.55	24-Oct-10	05.08	To reduce load on ICT at Kalwa
220KV	Nasik - Airoli - Knowledge Park	24-Oct-10	06.59	24-Oct-10	08.18	Attending hot spot in R ph.wave trap.
220KV	Kandalgaon - Lonand	24-Oct-10	13.50	24-Oct-10	14.10	Distance protection.
220KV	Pedambe-Tambati	24-Oct-10	18.15	24-Oct-10	18.55	Distance protection B Ph.
132KV	Bhusawal - Pachora	18-Oct-10	14.29	18-Oct-10	18.50	To attend hot spot on phase line isolator.
132KV	Bhandara - Madgi - II	19-Oct-10	03.27	19-Oct-10	03.38	Distance protection.
132KV	Chalisgaon - Kannad	19-Oct-10	16.10	19-Oct-10	16.20	FTR operated.
132KV	132 KV Bus @ Arvi	20-Oct-10	10.55	20-Oct-10	15.40	Earthwire Stringing Work.

132KV	132 KV Bus P T - I @ Pardi	20-Oct-10	11.50	20-Oct-10	12.15	Replacement of 132 KV Bus PT-I Under LES
132KV	132 KV Bus P T - II @ Pardi	20-Oct-10	13.00		Continued.	Replacement of Bus PT-II Under LES.
132KV	Yawal-chopda	20-Oct-10	12.00	20-Oct-10	16.25	Attenuating The Leakage For SF6 Breaker.
132KV	Giravali-Latur	21-Oct-10	06.29	21-Oct-10	06.58	Distance Protection Operated.
132KV	Nanded - Tamsa	21-Oct-10	10.46	21-Oct-10	10.58	Backup Protection Operated.
132KV	Kanhan - Mansar.	21-Oct-10	16.03	21-Oct-10	16.19	Backup Protection Operated.
132KV	Bhandara - Madgi -I	21-Oct-10	16.50	21-Oct-10	19.27	Distance Protection Operated Z-I B Ph E/F.
132KV	Bhandara - Madgi - II	21-Oct-10	16.50	21-Oct-10	17.36	Distance Protection Operated Z-I A/R L/O.
132KV	Akot - Anjangaon	21-Oct-10	19.30	21-Oct-10	19.58	Distance Protection Operated Z-I R Ph E/F.
132KV	Dhule - Dhule - I	22-Oct-10	02.05	22-Oct-10	02.29	Backup Over Current Protection Operated R Ph.
132KV	Bhandara-Ambhora	22-Oct-10	06.12	22-Oct-10	06.22	Dist.Protection operated,Z-I.
132KV	Bhandara - Madgi -I	22-Oct-10	19.48	22-Oct-10	20.06	Dist.Protection operated,Z-I.
132KV	Bhandara - Madgi - II	22-Oct-10	19.48	22-Oct-10	20.05	Ckt.tripped at Bhandara end only.
132KV	Giravali-Gangakhed	22-Oct-10	23.11		Continued.	Dist.Protection operated,Z-I.
132KV	Main Bus at Nasik	23-Oct-10	09.40	23-Oct-10	17.00	Bay shifting work of new 200 MVA ICT.
132KV	132 KV Bus at Dondaicha	23-Oct-10	11.25	23-Oct-10	14.20	BKR erection and commissioning for 132 KV Nandurbar line.
132KV	Mankapur - Uppalwadi	23-Oct-10	09.15	23-Oct-10	17.12	Replacement of WT and CC under LES.
132KV	Sawda-Raver	23-Oct-10	08.30	23-Oct-10	17.55	Replacement of BKR.
132KV	Kalmeshwar-Katol	23-Oct-10	04.16	23-Oct-10	04.37	Dist.Protection.
132KV	Nanded - Umri	24-Oct-10	20.55	24-Oct-10	21.05	Distance protection.
100KV	K'gaon-Roha-II	18-Oct-10	21.05	19-Oct-10	09.51	Distance protection. Under break down.
100KV	Kandalgaon-Roha-I	18-Oct-10	21.05	18-Oct-10	22.10	Distance protection.
100KV	Kalwa-Washi	22-Oct-10	06.35	22-Oct-10	17.35	Maintenance work.
100KV	Kalwa-Standard	22-Oct-10	07.44	22-Oct-10	18.24	Maintenance work.
100KV	Kalwa-Kalyan	23-Oct-10	18.42	23-Oct-10	18.50	Without indication.
100KV	Kalwa-Washi	23-Oct-10	18.42	23-Oct-10	18.56	Without indication.