

LINE OUTAGES FOR THE WEEK

FROM 17-Oct-11 TO 23-Oct-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	400/220KV,500 MVA ICT-III at Nagothane.	29-Sep-11	15.20	22-Oct-11	18:53	NDR Trip.
400KV	Karad - Kolhapur - I	8-Oct-11	17.22	19-Oct-11	09.00	To control Over Voltage.
400KV	Parli-Solapur (PGCIL) Ckt.II	9-Oct-11	20.49	19-Oct-11	10.26	Over Voltage.
400KV	Karad - Solapur (PGCIL)	16-Oct-11	07.26	17-Oct-11	15.17	Over Voltage
400KV	Akola - Wardha - I	16-Oct-11	22.10	19-Oct-11	10.59	Over Voltage
400KV	Kolhapur - Mapusa - II	16-Oct-11	22.38	17-Oct-11	09.28	Over Voltage
400KV	Bhusawal- Aurangabad	16-Oct-11	21.09	17-Oct-11	06.30	Over Voltage
400KV	Dhule-Sar'Sarovar - I	17-Oct-11	00.10	17-Oct-11	10.20	Over Voltage
400KV	Karad - Solapur (PGCIL)	17-Oct-11	20.14	19-Oct-11	09.15	Over Voltage
400KV	Padgha-Bhoisor (PGCIL)	17-Oct-11	19.47	17-Oct-11	20.04	Oil Leakage in 50MVAR Line Reactor at Padgha
400KV	Kolhapur - Mapusa - I	17-Oct-11	16.34	18-Oct-11	09.47	Over Voltage
400KV	Parly(PG) - Wardha (PG) - I	17-Oct-11	15.44	17-Oct-11	15.45	Newly Line Charged
400KV	400/220 KV 315 MVA ICT @ Khadka	17-Oct-11	07.47	17-Oct-11	17.04	Main Breaker Prob.(ICT is on TBC)
400KV	Chandrapur - Parli - II	17-Oct-11	09.22	17-Oct-11	14.46	To attend Hot Spot(Ckt is on TBC)
400KV	400KV TBC at Dhule	17-Oct-11	11.20	17-Oct-11	12.35	CT and Tand delta measurement
400KV	Parli (PGCIL)-Bhadravati-II	17-Oct-11	20.10	19-Oct-11	13.26	Over Voltage
400KV	50 MVAR Reactor of 400 KV Padgha-Bhoisor	17-Oct-11	19.47		Continued.	Oil Leakage at Padgha Reactor
400KV	Dhule - S'Sarovar- II	18-Oct-11	00.43	18-Oct-11	10.55	Over Voltage
400KV	New Koyna - Jaigad - II	18-Oct-11	11.23	18-Oct-11	16.05	Metering Work.
400KV	Bhusawal- Aurangabad	18-Oct-11	20.15	19-Oct-11	05.19	Over Voltage.
400KV	Kolhapur - Mapusa - II	18-Oct-11	23.11	19-Oct-11	11.12	Over Voltage.
400KV	Dabhol - NewKoyna - II	19-Oct-11	10.06	19-Oct-11	15.22	Sparking @ Isolator.
400KV	New Koyna-Karad-II	19-Oct-11	11.08	19-Oct-11	12.11	Taken on Own Bkr @ New Koyna End.
400KV	Dabhol - New Koyna - I	19-Oct-11	16.24	19-Oct-11	21.15	Taken on TBC,Sparking in Isolator.
400KV	Parli-Parli (PGCIL) I	19-Oct-11	21.40		Continued.	Over Voltage.
400KV	Main Bus-II at Chakan	19-Oct-11	08.38	19-Oct-11	18.30	Red Hot.
400KV	Newkoyna - Jaigad - I	19-Oct-11	09.21	19-Oct-11	15.39	For Hooking up Existing Lene Metering to Four Feeder Summation
400KV	Parli - Solapur	19-Oct-11	10.45	19-Oct-11	18.26	Replacement of B Ph.Line CVT.
400KV	400/220 KV 315 MVA ICT-II @ Nagothane.	19-Oct-11	10.45		Continued.	H V Side Taken on TBC.
400KV	400/11.5KV 90 MVA STN T/F III @ 400KV C	19-Oct-11	09.12	21-Oct-11	12.14	Replacement of R,Y & B Ph.CTs.
400KV	Karad - Kolhapur - II	19-Oct-11	09:06	23-Oct-11	11:20	Over Voltage.
400KV	Solapur PG - Parly PG - I	19-Oct-11	21:30	23-Oct-11	12:27	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	20-Oct-11	02.31	20-Oct-11	09.15	Over Voltage.
400KV	Bhusawal- Aurangabad	20-Oct-11	00.30	20-Oct-11	06.13	Over Voltage.
400KV	Kolhapur - Mapusa - I	20-Oct-11	01.16	20-Oct-11	09.24	Over Voltage.
400KV	Chakan-Talegaon(PG)	20-Oct-11	09.16	20-Oct-11	09.36	H/T due to isolator problem.
400KV	Lonikand- Koyna Stage IV	20-Oct-11	07.10	20-Oct-11	17.55	Fitment of New Jumper.
400KV	400/220 KV 315 MVA ICT- II @ Chakan	20-Oct-11	08.25	20-Oct-11	16.54	Q.M.Work
400KV	Main Bus - I @ Chakan	20-Oct-11	09.42	20-Oct-11	16.34	To attend hot spot.
400KV	TBC at 400KV Lonikand.	20-Oct-11	15.59	20-Oct-11	17.14	Errection of Bus post insulator.
400KV	Dabhol-Nagothane - II	20-Oct-11	09.45	20-Oct-11	15.47	To attend hot spot.
400KV	Solapur-Solapur(PGCIL)	20-Oct-11	12.23	20-Oct-11	17.46	Insulator replacement work.
400KV	Akola - Aurangabad- II	20-Oct-11	16.36	20-Oct-11	20.03	To attend C.B. problem.
400KV	Bhusawal- Aurangabad	20-Oct-11	23.01	21-Oct-11	05.50	Over Voltage.
400KV	Bhusawal- Aurangabad	21-Oct-11	21:27	22-Oct-11	09:14	H/T for O/V.
400KV	Kolhapur - Mapusa - I	21-Oct-11	04.23	21-Oct-11	12:04	Over Voltage.
400KV	400/220KV 500MVA ICT-III at Bableshtar	21-Oct-11	01.00	21-Oct-11	03.49	For taking of TBC trial.
400KV	Kolhapur - Mapusa - II	21-Oct-11	22:54	22-Oct-11	09:50	H/T for O/V.

400KV	Bhusawal- Aurangabad	21-Oct-11	08:08	21-Oct-11	09:18	H/T for O/V.
400KV	Bableshwar-Aurangabad	21-Oct-11	08:08	21-Oct-11	08:52	Tripped due to O/V.
400KV	400/220KV 315 MVA ICT- II @ Padgha	21-Oct-11	06:25	21-Oct-11	18:11	Oil filtration work.
400KV	400/220KV 315MVA ICT- I @ Kharghar	21-Oct-11	09:00	21-Oct-11	18:55	Isolator aligments skm work.
400KV	400/220 KV 315 MVA ICT - I @ Aurangaba	21-Oct-11	12:07	21-Oct-11	15:58	Taken on TBC, To attend C B air leakages.
400KV	Karad - Solapur (PGCIL)	21-Oct-11	07:39	22-Oct-11	14:00	H/T for O/V.
400KV	Dabhol-Nagothane-II	21-Oct-11	14:08	21-Oct-11	18:23	Tripped on D/P.
400KV	Koradi - Bhusawal	21-Oct-11	10:25	21-Oct-11	19:10	Annual Maint. work.
400KV	Dhule-Sar'Sarovar - II	21-Oct-11	04.12	22-Oct-11	09:43	Over Voltage.
400KV	Karad - Solapur (PGCIL)	22-Oct-11	17:05		Continued.	Bus-I Bus bar protection operated due to Bursting of 400 KV Solapur
400KV	Karad - Kolhapur - I	22-Oct-11	17:05	22-Oct-11	19:04	Bus bar protection operated.
400KV	Karad-New Koyna II	22-Oct-11	17:05	22-Oct-11	19:35	Bus bar protection operated.
400KV	Karad - Lonikand	22-Oct-11	17:05	22-Oct-11	19:12	Bus bar protection operated.
400KV	400/220KV,315MVA ICT-I at Karad	22-Oct-11	17:05	22-Oct-11	18:50	Bus bar protection operated.
400KV	400/220 KV 315MVA ICT-II @ Karad	22-Oct-11	17:05	22-Oct-11	18:41	Bus bar protection operated.
400KV	400/220KV 315MVA ICT-III at Karad.	22-Oct-11	17:05	22-Oct-11	17:40	Bus bar protection operated.
400KV	400 KV Bus Coupler at Karad.	22-Oct-11	17:05	22-Oct-11	18:34	Bus bar protection operated.
400KV	400/220KV 315MVA ICT-II @ BBLSR	22-Oct-11	08:42	22-Oct-11	21:05	Retrofitting of realy attending oil leakage.
400KV	Dabhol - New Koyna - I	22-Oct-11	09:30	22-Oct-11	16:31	Replacement of flashover insulator.
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	22-Oct-11	17:05	22-Oct-11	19:01	Due to Bus Fault at Karad.
400KV	400/220KV,315 MVA ICT-I at Kolhapur.	22-Oct-11	17:05	22-Oct-11	19:01	Due to Bus fault at Karad.
400KV	Kolhapur - Mapusa - I	22-Oct-11	17:05	23-Oct-11	02:59	Due to Bus fault at Karad.
400KV	400/220KV 105 MVA Spare ICT at Parly II	22-Oct-11	13:50		Continued.	To remove trip coil assembaly for Bus Coupler.
400KV	Bhusawal- Aurangabad	22-Oct-11	22:38	23-Oct-11	08:49	Over Voltage.
400KV	Dhule-S'Sarovar I	22-Oct-11	09:46	23-Oct-11	14:20	Attend work at Loc.No 233 as earth wire slipped from qufter pin.
400KV	Kolhapur - Mapusa - II	23-Oct-11	03:02	23-Oct-11	11:42	Due to Heavy sparking at B-ph pentagraph isolator.
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	23-Oct-11	03:03	23-Oct-11	11:24	Due to Heavy sparking at B-ph pentagraph isolator.
400KV	Bus Coupler @ 400 KV Kolhapur	23-Oct-11	03:05		Continued.	Due to Heavy sparking at B-ph pentagraph isolator.
400KV	Main Bus - I @ Kolhapur	23-Oct-11	10:47		Continued.	R-ph Isolator work on 400 KV Bus Coupler.
400KV	Karad-Jaigad II	23-Oct-11	07:32	23-Oct-11	18:47	Over voltage.
400KV	New Koyna-Karad-II	23-Oct-11	13:54		Continued.	R-ph LA Burst at New Koyna.
400KV	New Koyna - Karad - I	23-Oct-11	14:44	23-Oct-11	14:55	Distance Protection.
400KV	Kolhapur - Mapusa - I	23-Oct-11	11:57		Continued.	Over Voltage.
400KV	Parli (PGCIL)-Bhadravati-II	23-Oct-11	21:57		Continued.	Over Voltage.
400KV	Karad - Solapur (PGCIL)	23-Oct-11	11:30		Continued.	Damper Vibration work.
400KV	Dabhol - Nagothane - I	23-Oct-11	08:52	23-Oct-11	14:24	Replacement of Insulator Stringing.
400KV	Dabhol-Nagothane - II	23-Oct-11	15:33	23-Oct-11	18:02	Hot Spot attend.
220KV	Chandrapur-Sicom - I	11-Oct-11	18.56	20-Oct-11	10.41	To attend SF6 gas low alarm.
220KV	Nasik-Navsari-I	15-Oct-11	20.45	17-Oct-11	18.16	Distance protection.Declared faulty.
220KV	Pedambe-Mahad	16-Oct-11	16.37	17-Oct-11	11.40	Distance Protection
220KV	Aurangabad - Padegaon - II	16-Oct-11	18.58	17-Oct-11	04.09	R Phase Conductor Snapped
220KV	Badnera-Akola Ckt.I	16-Oct-11	20.07	17-Oct-11	18.34	Y Phase Insulator String Broken
220KV	Jambul - Pal	16-Oct-11	19.55	17-Oct-11	02.07	R Phase CC Burst
220KV	Karad-Pophali	17-Oct-11	04.07	17-Oct-11	12.00	Distance Protection
220KV	Nasik-Raymond	17-Oct-11	09.18	17-Oct-11	09.42	Line Isolator alignment
220KV	Talangade - Mumewadi	17-Oct-11	10.28	17-Oct-11	19.19	Erection of Line Tower of 220KV Hamidwada Co-Gen.
220KV	Talangde-Five star MIDC	17-Oct-11	10.57	17-Oct-11	15.29	Q.M.Work
220KV	Kalwa-Colourchem	17-Oct-11	11.32	17-Oct-11	14.24	To attend Red Hot(Taken on TBC)
220KV	Pedambe-Newkoyna	17-Oct-11	15.35	17-Oct-11	16.54	Relay testing work

220KV	Kalwa - Salshet - III	17-Oct-11	11.05	17-Oct-11	11.21	Distance Protection
220KV	Kandalgaon - ONGC	17-Oct-11	17.15	17-Oct-11	17.24	Distance Protection
220KV	Phinolex-Kharepatan	17-Oct-11	18.19	17-Oct-11	18.39	Distance Protection
220KV	220/132 KV100 MVA ICT @ Bhugaon.	17-Oct-11	11.59	17-Oct-11	14.09	Over Current Earth Fault
220KV	220/132KV 100MVA ICT @ Bhugaon	17-Oct-11	17.25	17-Oct-11	18.45	Over Current Earth Fault
220KV	220/110 KV 200 MVA ICT - I @ Kolhapur	17-Oct-11	10.25	17-Oct-11	20.10	Q.M.Work
220KV	220/132 KV 200 MVA ICT- I @ Jalna	17-Oct-11	13.32	17-Oct-11	14.40	R phase attending Oil Leakage of CT
220KV	220/33KV 125MVA T/F- V at Versova	17-Oct-11	23.29	18-Oct-11	01.20	Emergency outage
220KV	220/132 KV 200 MVA ICT- I @ Bale	18-Oct-11	10.00	18-Oct-11	12.56	Attending Hot Spot to 132KV Isolator.
220KV	Karad - Vita - I	18-Oct-11	09.47	18-Oct-11	13.01	Q.M.Work & Crimping Work.
220KV	Uran - Kharghar	18-Oct-11	10.06	18-Oct-11	17.34	Hot Spot Attending Work.
220KV	Pedambe - Pophali - II	18-Oct-11	12.53	18-Oct-11	17.07	Bus Bar Protection Operated.
220KV	Pedambe - Karad	18-Oct-11	12.53	18-Oct-11	14.40	Bus Bar Protection Operated.
220KV	Pedambe - Tambati	18-Oct-11	12.53	18-Oct-11	14.11	Bus Bar Protection Operated.
220KV	Pedambe-Newkoyna	18-Oct-11	12.53	18-Oct-11	14.38	Tripped @ Newkoyna End Due to Bus Bar Operated @ Pedambe.
220KV	Karad-Vita-II	18-Oct-11	14.19	18-Oct-11	18.22	Q.M.Work.
220KV	Pedambe-Mahad	18-Oct-11	17.14	18-Oct-11	18.12	Distance Protection.
220KV	Pedambe - Tambati	18-Oct-11	17.14	18-Oct-11	18.40	Distance Protection.
220KV	Pedambe-Newkoyna	18-Oct-11	17.18	18-Oct-11	18.10	Distance Protection Due to Heavy Rains @ Lighting.
220KV	Lamboti - Pandharpur	18-Oct-11	19.19	19-Oct-11	00.43	Distance Protection R Ph. C C Burst.
220KV	Dondaicha - Jamde - I	18-Oct-11	17.12		Continued.	Towers Damaged.
220KV	Dondaicha - Jamde - II.	18-Oct-11	17.12		Continued.	Towers Damaged.
220KV	Dondaicha - Walve	18-Oct-11	17.18		Continued.	Towers Damaged.
220KV	Pedambe - Pophali - II	18-Oct-11	18.25	19-Oct-11	02.40	Conductor Snapped @ Pophali End.
220KV	Padgha-Temghar I	18-Oct-11	18.46	23-Oct-11	06:32	To Control Padgha ICT Loading.
220KV	Padgha - Temghar - II	18-Oct-11	18.48	23-Oct-11	06:35	To Control Padgha ICT Loading.
220KV	Pedambe - Oni	18-Oct-11	12.53	19-Oct-11	13.20	B Ph Insulator Bus & Jumper Opened.
220KV	Bus Section - II @ Pedambe	18-Oct-11	12.53	18-Oct-11	14.05	Bus Bar Protection Operated.
220KV	Oni - Kharepatan	18-Oct-11	12.53	18-Oct-11	13.10	Bus Bar Protection Operated.
220KV	220 KV Bus Bar @ New Koyna	18-Oct-11	12.53	18-Oct-11	13.18	Bus Bar Protection Operated @ Pedambe.
220KV	Valve-Jamde	18-Oct-11	17.18		Continued.	H/T due to Tower collapsed at Loc.N,40.44,45,46.
220KV	Lonikand-Ranjangaon	19-Oct-11	05.04	19-Oct-11	05.38	Distance Protection.
220KV	Boiser PGCIL-Boiser II	19-Oct-11	07.26		Continued.	Taken on TBC Hot Spot.
220KV	Mudshingi - Chikodi	19-Oct-11	17.33	19-Oct-11	18.09	Distance Protection.
220KV	Mudshingi - Chikodi	19-Oct-11	12.40	19-Oct-11	13.10	Distance Protection.
220KV	220/100KV 200MVA ICT-I at Kalwa	19-Oct-11	07.20	19-Oct-11	09.50	Hot Spot.
220KV	Karad-Pophali	19-Oct-11	08.32	19-Oct-11	09.10	Replacement of MICOM Display Card.
220KV	Pophali - Kandalgaon	19-Oct-11	09.20	19-Oct-11	10.35	Replacement of MICOM Display Card.
220KV	Bale-Osmanbad	19-Oct-11	09.17	19-Oct-11	14.38	Jumper Replacement Work.
220KV	220/100KV 200 MVA ICT- II @ Padgha	19-Oct-11	09.26	19-Oct-11	17.47	SFRA Test.
220KV	Padgha-Jambhul-I	19-Oct-11	11.38	19-Oct-11	16.39	Hot Spot.
220KV	New Koyna-Pophali	19-Oct-11	13.31	19-Oct-11	14.32	Conductor Replacement.
220KV	Vita - Pandharpur	19-Oct-11	12.23	19-Oct-11	17.03	Replacement of R Ph. Insulator.
220KV	Pawas-Kharepatan	19-Oct-11	16.00	19-Oct-11	18.52	Replacement of Insulator.
220KV	Butibori-Abhijeet ckt.	19-Oct-11	10.28	19-Oct-11	17.33	Quarterly Maintenance Work.
220KV	Kalmeshwar - Pandurna	19-Oct-11	09.26	22-Oct-11	19:30	Erection of Tower for LILO.
220KV	Main Bus @ Usmanabad	19-Oct-11	09.18	19-Oct-11	14.38	To Open Jumper of Solapur Bay.
220KV	220/66 KV 50 MVA ICT-I @ Warora	19-Oct-11	10.08	19-Oct-11	10.21	Attending Hot Spot.
220KV	Badnera-Akola-II	19-Oct-11	11.07	19-Oct-11	15.30	To Control Wardha-Deoli Flow.

220KV	Badnera - Akola - I	19-Oct-11	11.10	19-Oct-11	11.28	To Control Wardha-Deoli Flow.
220KV	220/132 KV 100 MVA ICT @ Gadchiroli	19-Oct-11	09.12	19-Oct-11	12.15	Quarterly Maintainance Work of ICT.
220KV	Lonikand - Bhosari	20-Oct-11	08.45	20-Oct-11	18.07	Replacement of faulty display card of dist.relay.
220KV	220/110,200 MVA T/F-I at Miraj	20-Oct-11	11.00	20-Oct-11	13.55	For providing support insulator.
220KV	Hinjawadi-I - Hinjawadi-II	20-Oct-11	10.05	20-Oct-11	16.10	Q.M.Work
220KV	Bhigwan-Baramati agro	20-Oct-11	09.40	20-Oct-11	13.15	Q.M.Work
220KV	Bus Coupler @ Jejuri	20-Oct-11	09.39	20-Oct-11	19.21	Tan delta C.B. testing and Maint.work.
220KV	220/100 KV 200 MVA ICT- I @ Kolshet	20-Oct-11	11.18	20-Oct-11	18.12	Tan delta measurement work.
220KV	Phursungi-Magarpatta	20-Oct-11	09.09	20-Oct-11	15.43	Q.M.Work
220KV	220/100 KV 200 MVA ICT-II @ Apta	20-Oct-11	09.41	20-Oct-11	17.05	Testing and Maint.work.
220KV	Karad-Pophali-II	20-Oct-11	14.56	21-Oct-11	01.56	Distance protection.
220KV	Mudshingi-Chikodi	20-Oct-11	16.12	20-Oct-11	22.47	Distance protection.
220KV	Purti - Bhugaon	20-Oct-11	10.46	20-Oct-11	16.56	Tightening of loose jumper pad clamp nut bolts.
220KV	BOISER - PGCIL-II	21-Oct-11	07:44	21-Oct-11	13:13	To attend Hot Spot on CT and Wave Trap.
220KV	Pophali - Bus Section - I	21-Oct-11	08:37	21-Oct-11	19:10	Isolator alignment work.
220KV	Pedambe - Mahad	21-Oct-11	09:37	21-Oct-11	10:10	Repl. of Micom relay card.
220KV	A'nagar-Pal	21-Oct-11	09.20	21-Oct-11	19.05	R.M.Work
220KV	Arrey-Goregoan(Rel).	21-Oct-11	09.30	21-Oct-11	12.38	Annual Maint. work.
220KV	Dhule - Malegaon	21-Oct-11	09.44	21-Oct-11	16.12	Replacement of insulator spring.
220KV	Padgha - Temghar - II	21-Oct-11	11.10	21-Oct-11	19.28	R.M.Work
220KV	Kandalgaon - Pophali	21-Oct-11	07.35	21-Oct-11	18.34	Maint. work at Koyna bus section.
220KV	Kandalgaon - Sonalloy	21-Oct-11	15.32	21-Oct-11	16.16	Distance protection R ph. to earth.
220KV	Lamboti - Pandharpur	21-Oct-11	16.34	21-Oct-11	20.02	LA replacement.
220KV	Badnera - Rly TSS - II	21-Oct-11	10.32	21-Oct-11	14.29	Maintenance of isolator.
220KV	220/132 KV 200 MVA ICT - II @ Nanded	21-Oct-11	13.00	21-Oct-11	17.58	Replacement of diff. relay.
220KV	220/132 KV 200 MVA ICT - I @ Parbhani	21-Oct-11	12.12	21-Oct-11	14.55	Replacement of PD relay.
220KV	Khaperkheda - Wardha.	21-Oct-11	11.46	22-Oct-11	09:51	To control Koradi ICT loading.
220KV	Abhijeet-Wardha-I	21-Oct-11	18.01	22-Oct-11	19:57	To control Koradi ICT loading.
220KV	220 KV Bus Coupler @ Karad.	22-Oct-11	17:05	22-Oct-11	18:40	Bus bar protection operated.
220KV	Karad - Karad -I	22-Oct-11	17:05	22-Oct-11	18:04	Bus bar protection operated.
220KV	Karad - Karad - II	22-Oct-11	17:05	22-Oct-11	19:17	Bus bar protection operated.
220KV	Karad - Vita - I	22-Oct-11	17:05	22-Oct-11	18:38	Bus bar protection operated.
220KV	Karad-Vita-II	22-Oct-11	17:05	22-Oct-11	18:52	Bus bar protection operated.
220KV	Karad - Miraj	22-Oct-11	17:05	22-Oct-11	18:36	Bus bar protection operated.
220KV	Karad-M'peth	22-Oct-11	17:05	22-Oct-11	18:39	Bus bar protection operated.
220KV	Karad - Sadawaghapur - II	22-Oct-11	17:05	22-Oct-11	18:26	Bus bar protection operated.
220KV	Karad-Pophali	22-Oct-11	17:05	22-Oct-11	19:09	Bus bar protection operated.
220KV	Karad-Pedambe	22-Oct-11	17:05	22-Oct-11	19:13	Bus bar protection operated.
220KV	Kolhapur - Karad - I	22-Oct-11	17:05	22-Oct-11	18:58	Bus bar protection operated.
220KV	Karad-Kolhapur - II	22-Oct-11	17:05	22-Oct-11	18:46	Bus bar protection operated.
220KV	Karad - Kini-wathar - III	22-Oct-11	17:05	22-Oct-11	18:55	Bus bar protection operated.
220KV	Karad-.Kolhapur-III	22-Oct-11	17:05	22-Oct-11	18:44	Bus bar protection operated.
220KV	220/33 KV,25 MVA TRF. at Pedambe.	22-Oct-11	17:05	22-Oct-11	17:35	Assymetrical load and due to occurrence at Karad.
220KV	Pophali - KDPH	22-Oct-11	17:05	22-Oct-11	18:20	Assymetrical load and due to occurrence at Karad.
220KV	Pedambe - Pophali - II	22-Oct-11	17:05	22-Oct-11	18:55	Assymetrical load and due to occurrence at Karad.
220KV	Pophali - Kandalgaon	22-Oct-11	17:05	22-Oct-11	19:17	Assymetrical load and due to occurrence at Karad.
220KV	Pophali-New Koyna	22-Oct-11	17:05	22-Oct-11	17:32	Assymetrical load and due to occurrence at Karad.
220KV	Pedambe-Newkoyna	22-Oct-11	17:05	22-Oct-11	17:32	Assymetrical load and due to occurrence at Karad.
220KV	Pedambe-Kharepatan	22-Oct-11	17:05	22-Oct-11	17:58	Assymetrical load and due to occurrence at Karad.

220KV	Pedambe - Mahad	22-Oct-11	17:05	22-Oct-11	18:00	Assymetrical load and due to occurrence at Karad.
220KV	220/110KV,50 MVA T/F-I At Pedambe	22-Oct-11	17:05	22-Oct-11	18:08	Assymetrical load and due to occurrence at Karad.
220KV	220/110KV,50 MVA T/F-II At Pedambe	22-Oct-11	17:05	22-Oct-11	18:09	Assymetrical load and due to occurrence at Karad.
220KV	Pedambe - Tambati	22-Oct-11	17:05	22-Oct-11	18:48	Assymetrical load and due to occurrence at Karad.
220KV	Mudsingi-Karad-I	22-Oct-11	18:12	22-Oct-11	18:58	Due to tripping of ICT-3 on overload at Karad.
220KV	Karad Mudsingi-II	22-Oct-11	18:12	22-Oct-11	18:46	Due to tripping of ICT-3 on overload at Karad.
220KV	Karad - Mudshingi - III	22-Oct-11	17:58	22-Oct-11	22:56	Due to tripping of ICT-3 on overload at Karad.
220KV	Karad-Mudsingi-IV	22-Oct-11	18:12	22-Oct-11	18:44	Due to tripping of ICT-3 on overload at Karad.
220KV	Mudshingi - Talandage - I	22-Oct-11	18:12	22-Oct-11	19:15	Due to tripping of ICT-3 on overload at Karad.
220KV	Mudshing - Talandage - II	22-Oct-11	18:12	22-Oct-11	19:00	Due to tripping of ICT-3 on overload at Karad.
220KV	Mudsinghi - Mumewadi - I	22-Oct-11	18:12	22-Oct-11	19:04	Due to tripping of ICT-3 on overload at Karad.
220KV	Pirangut - Hinjewadi - II	22-Oct-11	10:00	22-Oct-11	15:55	Q.M. Work.
220KV	220/132,100 MVA ICT - I @ A'Nagar	22-Oct-11	09:42	22-Oct-11	17:50	Q.M. Work.
220KV	Pedambe - Tambati	22-Oct-11	14:20	22-Oct-11	18:47	R-phase C T conductor replacement work.
220KV	Lamboti - Pandharpur	22-Oct-11	13:41	22-Oct-11	13:59	Dist. Protection.
220KV	Vita - Lamboti	22-Oct-11	13:57	22-Oct-11	14:09	Overload.
220KV	Lote - Dasturi	22-Oct-11	16:15	22-Oct-11	18:40	R-ph coupling capacitor burst.
220KV	Vita - Lamboti	22-Oct-11	17:05	22-Oct-11	17:34	Bus bar protection operated.
220KV	Jeur-Kurkumbh	22-Oct-11	17:05	22-Oct-11	17:49	Bus bar protection operated.
220KV	Kalwa-Colourchem	23-Oct-11	07:00	23-Oct-11	20:30	R-ph stub bus conductor replacement.
220KV	Dahanu - Ghodbandar - I	23-Oct-11	08:44	23-Oct-11	15:11	Annual maintenance work.
220KV	Main Bus-II at 220 KV Kalwa.	23-Oct-11	08:47	23-Oct-11	20:23	R-ph Bus conductor replacement.
220KV	220/100 KV 200 MVA ICT II at Trombay	23-Oct-11	09:57	23-Oct-11	16:33	Attending oil leakages.
220KV	Wadkhal - Ndil - 2	23-Oct-11	10:45		Continued.	Replacement of new CTPT metering.
220KV	Bhoisor-Bhoisor(PGCIL)-I	23-Oct-11	07:44	23-Oct-11	12:00	Hot spot attending work.
220KV	Tillari-Amona-II	23-Oct-11	16:30	24-Oct-11	03:22	Distance Protection.
132KV	132 / 7 KV 31.5 MVA Station T/F - I @ Bhus	15-Oct-11	16:18	22-Oct-11	19:24	Oil filtration and Bus and Auxilary isolator replacement work.
132KV	Bhugaon - Deoli	17-Oct-11	17:25	17-Oct-11	18:45	Tripped
132KV	Boiser - Palghar - I	18-Oct-11	07:23	18-Oct-11	19:05	Control Relay Panel Testing Work.
132KV	Parbhani-Jintur	19-Oct-11	15:12	19-Oct-11	15:37	Distance Protection Operated Z-II Y-B Ph
132KV	Eldari - Jintur	19-Oct-11	15:20		Continued.	B Phase Pole of C B Flashover.
132KV	Kannad - Kagzipura	21-Oct-11	10:17	21-Oct-11	13:16	Attending red hot spot.
132KV	Main Bus section-II at Washim	21-Oct-11	14:31	21-Oct-11	16:54	Construction work of new bay.
132KV	Girawali-Parli	21-Oct-11	14:28	21-Oct-11	15:59	To attend hot spot on R ph.line isolator.
132KV	Girwali - Kej	21-Oct-11	05:48	21-Oct-11	06:02	To control Parli-II ICT over loading.
132KV	Supa - Shirur	23-Oct-11	09:05		Continued.	Tower errection work.
132KV	Kanhan - Pench - I	23-Oct-11	10:11	23-Oct-11	15:22	Conductor tighting.
132KV	Girawali-Gangakhed	23-Oct-11	14:29	23-Oct-11	14:45	Distance Protection Operated Zone-1 Y-ph to earth.
110KV	Pedambe - Arawali	22-Oct-11	17:05	22-Oct-11	18:19	Assymetrical load and due to occurrence at Karad.
110KV	Borivali-Borivali Tata-II	23-Oct-11	07:18	23-Oct-11	19:37	To facilitate stringing of conductor at 220 KV Bo-Bo 5 line.
100KV	Kandalgaon-Roha-I	18-Oct-11	09:10	18-Oct-11	15:18	Replacement of Isolator @ Roha End.